



Application Type  
Facility Type  
Major / Minor

Renewal  
Municipal  
Major

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**


Application No. **PA0234079**  
APS ID **1079708**  
Authorization ID **1424803**

**Applicant and Facility Information**

Applicant Name	<b>Tiadaghton Valley Municipal Authority (TVMA)</b>	Facility Name	<b>Tiadaghton Valley Municipal Authority WWTP</b>
Applicant Address	290 Rice Road	Facility Address	290 Rice Road
Applicant Contact	Jersey Shore, PA 17740-8817	Facility Contact	Jersey Shore, PA 17740-8817
Applicant Phone	Shawn Lorson	Facility Phone	Shawn Lorson
Client ID	(570) 398-0104	Site ID	(570) 398-0104
Ch 94 Load Status	288264	Municipality	749166
Connection Status	Not Overloaded	County	Nippenose Township
Date Application Received	January 25, 2023	EPA Waived?	Lycoming
Date Application Accepted	February 3, 2023	If No, Reason	No
Purpose of Application	Major Facility, Significant CB Discharge		
	Application for a renewal of an NPDES permit for discharge of treated Sewage.		

**Summary of Review**

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		 Jonathan P. Peterman / Project Manager	June 26, 2025
X		 Nicholas W. Hartranft, P.E. / Environmental Engineer Manager	June 26, 2025

**Discharge, Receiving Waters and Water Supply Information**

Outfall No.	001	Design Flow (MGD)	1.05
Latitude	41° 11' 58.65"	Longitude	-77° 14' 20.26"
Quad Name		Quad Code	
Wastewater Description:	Sewage Effluent		
Receiving Waters	West Branch Susquehanna River	Stream Code	18668
NHD Com ID	66917281	RMI	55.5
Drainage Area	5230 mi <sup>2</sup>	Yield (cfs/mi <sup>2</sup> )	0.01
Q <sub>7-10</sub> Flow (cfs)	279	Q <sub>7-10</sub> Basis	USGS Stream Gauge 01551500
Elevation (ft)	530	Slope (ft/ft)	n/a
Watershed No.	10-A	Chapter 93 Class.	WWF-MF
Existing Use	WWF-MF	Existing Use Qualifier	n/a
Exceptions to Use	None	Exceptions to Criteria	None
Assessment Status	Impaired		
Cause(s) of Impairment	Metals, pH		
Source(s) of Impairment	Acid Mine Drainage		
TMDL Status	Issued 7/2/2009	Name	West Branch Susquehanna River Watershed TMDL
Nearest Downstream Public Water Supply Intake	West Branch of Susquehanna	PA American Water White Deer	
PWS Waters	River	Flow at Intake (cfs)	682
PWS RMI	10.5	Distance from Outfall (mi)	50

Changes Since Last Permit Issuance: The updated Q<sub>7-10</sub> data was obtained from the updated stream gage information obtained from *Stuckey, M.H., and Roland, M.A., 2011, Selected Streamflow Statistics for Streamgage Locations In and Near Pennsylvania*. A comparative analysis was previously conducted using the associated stream gage (01515000) which is located downstream of the discharge location in Williamsport. Q<sub>7-10</sub> calculations are attached in Appendix A. As previously described in the 11/17/2011 fact sheet, the river is divided by a large island at the discharge point. Therefore, the above Q<sub>7,10</sub> was calculated at 50% of the Q<sub>7,10</sub> of the entire river. The reach length used for modeling purposes is from the discharge point to the confluence of the river below the island, which is approximately 0.5 miles.

Other Comments: None.

### Anti-Backsliding

In accordance with 40 CFR 122.44(l)(1) and (2), this permit does not contain effluent limitations, standards, or conditions that are less stringent than the previous permit.

### Sludge Use and Disposal Description and Location(s)

Approximately 102 dry tons are sent to the Wayne Twp. Landfill annually. There is currently a WQM permit for new sludge drying beds.

### Hauled-In Wastes

The application indicates that the facility receives hauled-in waste from residential septic haulers. The annual average volume is approximately 2,624,763 gallons. A Part-C condition will be placed in the draft permit.

### TMDL Impairment

The Department's Geographic Information System (GIS) shows that the West Branch Susquehanna River is impaired and a TMDL does exist for the stream segment. High levels of metals caused these impairments (iron, manganese, aluminum) as well as pH. All impairments resulted from acid mine drainage. The TMDL addresses the three primary metals associated with acid mine drainage (iron, manganese, aluminum). There is currently no industrial waste being discharged into the treatment plant and this discharge is not expected to contribute to the level of metals in the stream. Given the regulations contained in 40 CFR §122.44(d)(1)(ii)&(iii), it can be determined that the type of effluent from this facility has no "Reasonable potential to cause, or contributes to an in-stream excursion above the allowable ambient concentration of a State numeric criteria within a State water quality standard for an individual pollutant." However, monitoring requirements for metals (iron, manganese and aluminum) were previously placed in the permit because point sources in the segment where the TMDL does not assign any wasteload allocations are not authorized to discharge these metals of concern. The result from the monitoring that was conducted over the previous permit cycles demonstrates that the facility is not contributing to this impairment and no further monitoring is required. The result indicated that the 90<sup>th</sup> percentile discharge concentrations for these parameters are below water quality criteria. Additionally, the highest discharge concentration from the past 5 years of eDMR data was input into the TMS model and the model did not require monitoring or effluent limits. Therefore, the monitoring requirements will be removed until WLA are assigned to the whole watershed or the data indicates that the facility is contributing to the impairment. The monitoring results for these metals are attached in the Appendix E.

### Chesapeake Bay Requirements

In 2010, the EPA established the Chesapeake Bay Total Maximum Daily Load (TMDL). The Chesapeake Bay TMDL sets limits on the amount of nutrients and sediment that can enter the Bay and its tidal rivers to meet water quality goals. In order to address the TMDL requirements, Pennsylvania developed a Chesapeake Watershed Implementation Plan (WIP) – Phase I. Since the publication of Pennsylvania's Phase I Chesapeake WIP in January 2011 and the Chesapeake Bay TMDL, several activities have occurred that necessitated the development of the Phase II WIP. Initially, a phased approach was utilized which imposed TN and TP cap loads in reissued permits for significant sewage dischargers. Accordingly, TVMA's renewed permit, issued 3/16/2012, included these TN and TP cap loads. In accordance with the Phase II WIP, the offsets were previously removed from the cap load and recognized in a footnote included in Part A of the permit. Per the April 6, 2015 revisions to the Chesapeake Bay Watershed Implementation Plan (WIP), Phase II, the monitoring frequencies for the Nitrogen series and Total Phosphorus were increased from 1/week to 2/week. Additionally, the Chesapeake Bay language at Part C I of the permit has been revised to reflect the revised WIP Phase III.

The limitations and monitoring requirements specified below are proposed for the draft permit, to comply with Pennsylvania's Chesapeake Bay Tributary Strategy:

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Monthly	Annual	Monthly	Monthly Average	Maximum	Instant. Maximum		
Ammonia--N	Report	Report	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Kjeldahl--N	Report	XXX	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Nitrate-Nitrite as N	Report	XXX	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Total Nitrogen	Report	Report	XXX	Report	XXX	XXX	1/month	Calculation
Total Phosphorus	Report	Report	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Net Total Nitrogen	Report	19,178	XXX	XXX	XXX	XXX	1/month	Calculation
Net Total Phosphorus	Report	2,557	XXX	XXX	XXX	XXX	1/month	Calculation

\*TN = 1.05 MGD x 6.0 mg/l x 8.34 x 365 days/yr = 19,178 lb/yr

\*\*TP = 1.05 MGD x 0.8 mg/l x 8.34 x 365 days/yr = 2,557 lb/yr

In addition to the above cap loads, the Department did approve nitrogen offsets of 5,000 lbs per year in a 9/14/2015 letter correspondence. The offsets were granted after verification of 200 EDUs that were built prior to 2003. As mentioned above, these offsets will be accounted for in a Chesapeake Bay footnote in Part A of the permit.

Treatment Facility Summary				
WQM Permit No.	Issuance Date	Comments		
4111404 A-2	Pending	Sludge Drying bed upgrades.		
4111404 A-1	10/31/2016	Railroad Street Pump Stations improvements.		
4111404	3/16/2012	New plant construction.		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary With Phosphorus Reduction	Sequencing Batch Reactor	Ultraviolet	1.05
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
1.5	4301	Not Overloaded	None	Landfill

**Treatment Facility Name:** Tiadaghton Valley Municipal Authority WWTP

**Tributary Sewer System Information:** All sewer systems are 100% separated. The Tiadaghton Valley Municipal Authority Wastewater Treatment Plant serves The following areas:

Municipality Served	Flow Contribution %
Jersey Shore Borough	86
Porter Township	8
Nippenose Township	6
<b>Total</b>	<b>100</b>

The discharge flow rates for the previous year (2022), in MGD, are as follows:

Existing Annual Average	Maximum Monthly Average	Month of Highest Flow
0.697	1.03	February 2022

**Treatment System Components (See Appendix E for Plant Process Flow Diagram):**

- The plant consists of a comminutor, mechanically cleaned influent screen, manual bar screen, vortex grit system, anaerobic tanks (3), anoxic/sludge return tanks (3), sequencing batch reactor tanks (3), a post equalization tank, and UV disinfection.

Compliance Sampling Location: Discharge from the UV tank.

Changes Since Last Permit Issuance: None.

**Industrial Users**

The application indicates that there are no industrial users that discharge to this facility.

**Whole Effluent Toxicity (WET)**

For Outfall 001,  **Acute**  **Chronic** WET Testing was completed:

- For the permit renewal application (4 tests).
- Quarterly throughout the permit term.
- Quarterly throughout the permit term and a TIE/TRE was conducted.
- Other:

The dilution series used for the tests was: 100%, 60%, 30%, 2%, and 1%. See section below for TIWC. See Appendix F for WETT Spreadsheet.

**Summary of Four Most Recent Test Results**

Refer to the four most recent DEP WET Analysis Spreadsheets are attached in Appendix E. All results indicate a passing result.

TST Data Analysis

Test Date	Ceriodaphnia Results (Pass/Fail)		Pimephales Results (Pass/Fail)	
	Survival	Reproduction	Survival	Growth
Sept. 2019	Pass	Pass	Pass	Pass
June 2020	Pass	Pass	Pass	Pass
June 2021	Pass	Pass	Pass	Pass
May 2022	Pass	Pass	Pass	Pass

\* A "passing" result is that in which the replicate data for the TIWC is not statistically significant from the control condition. This is exhibited when the calculated t value ("T-Test Result") is greater than the critical t value. A "failing" result is exhibited when the calculated t value ("T-Test Result") is less than the critical t value.

Is there reasonable potential for an excursion above water quality standards based on the results of these tests? (NOTE – In general, reasonable potential is determined anytime there is at least one test failure in the previous four tests).

**YES**  **NO**

**Comments:** No reasonable potential can be assumed.

**Evaluation of Test Type, IWC and Dilution Series for Renewed Permit**

Acute Partial Mix Factor (PMFa): **0.082**

Chronic Partial Mix Factor (PMFc): **0.574**

**1. Determine IWC – Acute (IWCA):**

$$(Q_d \times 1.547) / ((Q_{7-10} \times PMFa) + (Q_d \times 1.547))$$

$$[(1.05 \text{ MGD} \times 1.547) / ((279 \text{ cfs} \times 0.051) + (1.05 \text{ MGD} \times 1.547))] \times 100 = **6.75\%**$$

Is IWCA < 1%?  **YES**  **NO** (YES - Acute Tests Required OR NO - Chronic Tests Required)

If the discharge is to the tidal portion of the Delaware River, indicate how the type of test was determined:

**No.**

**Type of Test for Permit Renewal: Chronic**

**2a. Determine Target IWCA (If Acute Tests Required)**

$$TIWCA = IWCA / 0.3 = N/A\%$$

**2b. Determine Target IWCC (If Chronic Tests Required)**

$(Q_d \times 1.547) / (Q_{7-10} \times PMFc) + (Q_d \times 1.547)$

$[(1.05 \text{ MGD} \times 1.547) / ((279 \text{ cfs} \times 0.574) + (1.05 \text{ MGD} \times 1.547))] \times 100 = 0.42\%$

### 3. Determine Dilution Series

(NOTE – check Attachment C of WET SOP for dilution series based on TIWCa or TIWCc, whichever applies).

Dilution Series = 100%, 60%, 30%, 2%, and 1%.

### WET Limits

Has reasonable potential been determined?  YES  NO

Will WET limits be established in the permit?  YES  NO

If WET limits will be established, identify the species and the limit values for the permit (TU).

N/A.

If WET limits will not be established, but reasonable potential was determined, indicate the rationale for not establishing WET limits:

N/A.

### Part C of the permit will contain following requirements for this major sewage facility:

1. Part C Condition 114 "Whole Effluent Toxicity (WET)"

Existing Effluent Limitations and Monitoring Requirements

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Daily Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Metered
pH (S.U.)	XXX	XXX	6.0	XXX	9.0 Daily Max	XXX	1/day	Grab
Dissolved Oxygen	XXX	XXX	Report	XXX	XXX	XXX	1/day	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5)	218	350	XXX	25	40	50	2/week	24-Hr Composite
Biochemical Oxygen Demand (BOD5) Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Total Suspended Solids	262	394	XXX	30	45	60	2/week	24-Hr Composite
Total Suspended Solids Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/week	Grab
Aluminum, Total	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/quarter	24-Hr Composite
Copper, Total	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/quarter	24-Hr Composite
Iron, Total	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/quarter	24-Hr Composite
Manganese, Total	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/quarter	24-Hr Composite
Zinc, Total	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/quarter	24-Hr Composite
Ultraviolet light intensity (uW/cm <sup>2</sup> )	XXX	XXX	Report	XXX	XXX	XXX	1/day	Metered

The existing effluent limits for Outfall 001 were based on a design flow of 1.05 MGD.

### Development of Effluent Limitations

Outfall No. 001  
 Latitude 41° 12' 8.00"  
 Wastewater Description: Sewage Effluent

Design Flow (MGD) 1.05  
 Longitude -77° 13' 44.00"

#### Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

#### Water Quality-Based Limitations

To establish whether or not water-quality based effluent limitations (WQBELs) are required, the Department models in-stream conditions. In order to determine limitations for CBOD<sub>5</sub>, ammonia-N and dissolved oxygen, the Department utilizes the WQM 7.0 v1.0b model and in order to determine limitations for toxics, the Department utilizes the Toxics Management Spreadsheet.

**WQM 7.0 for Windows, Version 1.0b, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen**  
 The model was run using the latest information on Q7-10 stream flow, background water quality, average annual design flow, and other discharge characteristics. The existing technology based effluent limit for CBOD<sub>5</sub> (25 mg/l) and NH<sub>3</sub>-N (25 mg/l) were used as inputs for the modeling. The DO minimum daily average criterion from §93.7 (5 mg/L for WWF) was used for the in-stream objective for the model. The summary of the output is as follows:

Parameter	Effluent Limit		
	30 Day Average	Maximum	Minimum
CBOD5	25	N/A	N/A
Ammonia-N	25	50	N/A
Dissolved Oxygen	N/A	N/A	3

The model does not recommend water-quality based effluent limitations with regards to CBOD<sub>5</sub>, Ammonia-N, and dissolved oxygen. Refer to Appendix B for the WQM 7.0 inputs and results. Based on the model output, the existing limitations are appropriate and will be maintained.

#### **Toxics Management Spreadsheet (TMS)**

This model is a single discharge wasteload allocation program for toxics that uses a mass-balance water quality analysis to determine recommended water quality-based effluent limits. The model incorporates consideration for mixing, first-order decay and other factors to computes a Wasteload Allocation (WLA) for each applicable criterion. Finally, the model determines a maximum water quality-based effluent limitation (WQBEL) for each parameter and outputs the more stringent of the WQBEL or the input concentration. The output of which is the recommends average monthly and maximum daily effluent limitations.

Sampling for pollutant groups was submitted with the application. This sampling information and the receiving stream information was entered into the Toxics Management Spreadsheet. The modeling results indicated that there are no parameters that were candidates for monitoring or limitations. Also, the highest discharge concentration from the past 5 years of eDMR data for copper and zinc were input into the TMS model and the model did not require monitoring or effluent limits. Therefore, the monitoring requirements will be removed. Refer to Appendix C for TMS inputs and results.

### Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst the abovementioned technology, water quality, and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001) and/or BPJ.

#### Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Daily Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Metered
pH (S.U.)	XXX	XXX	6.0	XXX	9.0 Daily Max	XXX	1/day	Grab
Dissolved Oxygen	XXX	XXX	Report	XXX	XXX	XXX	1/day	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5)	218	350	XXX	25	40	50	2/week	24-Hr Composite
Biochemical Oxygen Demand (BOD5) Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Total Suspended Solids	262	394	XXX	30	45	60	2/week	24-Hr Composite
Total Suspended Solids Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/week	Grab
Ultraviolet light intensity (uW/cm <sup>2</sup> )	XXX	XXX	Report	XXX	XXX	XXX	1/day	Metered
E. Coli	XXX	XXX	XXX	XXX	XXX	Report	1/month	Grab
PFOA (ng/L)	XXX	XXX	XXX	XXX	Report	XXX	1/quarter	Grab
PFOS (ng/L)	XXX	XXX	XXX	XXX	Report	XXX	1/quarter	Grab

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Daily Minimum	Average Monthly	Weekly Average	Instant. Maximum		
PFBS (ng/L)	XXX	XXX	XXX	XXX	Report	XXX	1/quarter	Grab
HFPO-DA (ng/L)	XXX	XXX	XXX	XXX	Report	XXX	1/quarter	Grab

\*The proposed effluent limits for Outfall 001 were based on a design flow of 1.05 MGD.

### **General Information**

All of the limits proposed above are consistent with other permits issued for major wastewater treatment plants in the region. The associated mass-based limits (lbs/day) for all parameters were based on the formula: design flow (average annual) (MGD) x concentration limit (mg/L) at design flow x conversion factor (8.34). All effluent limits were then rounded down in accordance with the rounding rules established in the *Technical Guidance for the Development and Specification of Effluent Limitations* (362-0400-001), Chapter 5 - Specifying Effluent Limitations in NPDES Permits.

### **Flow**

Reporting of the average monthly and daily maximum flow is consistent with monitoring requirements for other treatment plants of this size.

### **Carbonaceous Biochemical Oxygen Demand (CBOD<sub>5</sub>)**

The results of the WQM 7.0 model show that the previously applied secondary treatment standards (25 PA Code §92a.47 (a) (1&2)) for CBOD<sub>5</sub> are protective of water quality and will remain.

### **Total Suspended Solids (TSS)**

The previously applied technology based secondary treatment standards (25 PA Code §92a.47 (a) (1&2)) for TSS will remain as well.

### **pH**

CFR Title 40 §133.102(c) and 25 PA Code §95.2(1) provide the basis of effluent limitations for pH. The existing limits will remain.

### **Fecal Coliforms**

The existing fecal coliform limits with I-max limits were updated from the previous Chapter 92 code to correspond with what is specified in the updated 25 PA Code § 92a.47 (a)(4)&(5).

### **U.V. Intensity (uW/cm<sup>2</sup>)**

The facility a meter for this monitoring and the daily sample type (Meter) is appropriate. The output of the existing meter has been verified to report ultraviolet light intensity.

### **Dissolved Oxygen (DO)**

Given results of the WQM 7.0 model, a discharge of effluent from this facility with a DO concentration of 3 mg/l would not result in an exceedance of water quality requirements for this stream. It is anticipated, based on similar technology, that the DO concentration in the effluent would be greater than 3.0 mg/l. Therefore, based on BPJ, only monitoring will be required for this facility. This will also provide historical data to establish baseline DO levels in the effluent for future reviews.

### **E. Coli**

25 PA Code § 92a.61 provide the basis of monitoring requirements for E. Coli. Monthly monitoring will be required going forward.

### **Influent BOD<sub>5</sub> and TSS**

The Department requires the reporting of raw sewage influent monitoring for BOD<sub>5</sub> and TSS in all POTW permits. This provides the Department with the ability to monitor the percent removal of each parameter as stipulated in section 2 of the Part A conditions and maintain records of the BOD<sub>5</sub> loading as required by 25 Pa. Code Chapter 94. The monitoring frequencies and sample types are identical to the effluent sampling.

**Per- and Polyfluoroalkyl Substances (PFAS)**

Scientific studies have shown that exposure to some Per- and Polyfluoroalkyl Substances (PFAS) in the environment is linked to harmful health effects in humans and animals. As part of DEP's initiative to collect more data pertaining to PFAS, quarterly monitoring for PFAS-related compounds PFOA, PFOS, HFPO-DA, and PFBS has been proposed. This screening was not conducted during the application process. (This updated application requirement was introduced after the application was submitted.) The following footnote will be included in part A of the permit: "The permittee may discontinue monitoring for PFOA, PFOS, HFPO-DA, and PFBS if the results in 4 consecutive monitoring periods indicate non-detect results at or below Quantitation Limits of 4.0 ng/L for PFOA, 3.7 ng/L for PFOS, 3.5 ng/L for PFBS and 6.4 ng/L for HFPO-DA. When monitoring is discontinued, permittees must enter a No Discharge Indicator (NODI) Code of "GG" on DMRs."

**Compliance History**

**Summary of Inspections** –The last inspection was conducted by the Department on 4/22/25. The inspection did not reveal any issues and the facility was operating normally.

**WMS Query Summary** -A WMS Query was run at *Reports - Violations & Enforcements – Open Violations for Client Report* to determine whether there are any unresolved violations associated with the client that will affect issuance of the permit (per CSL Section 609). This query revealed that there were no unresolved violations.

Compliance History

DMR Data for Outfall 001 (from March 1, 2024 to February 28, 2025)

Parameter	FEB-25	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24	APR-24	MAR-24
Flow (MGD) Average Monthly	0.549	0.491	0.606	0.523	0.545	0.511	0.722	0.535	0.510	0.695	0.929	0.736
Flow (MGD) Daily Maximum	1.408	0.570	1.434	0.786	0.807	0.732	2.53	1.201	0.845	1.293	3.379	1.412
pH (S.U.) Daily Minimum	6.59	6.66	6.63	6.62	6.71	6.6	6.6	6.57	6.65	6.71	6.78	6.66
pH (S.U.) Daily Maximum	6.89	6.80	6.81	6.86	7.01	6.86	6.85	6.86	6.98	6.95	7.10	6.93
DO (mg/L) Daily Minimum	1.73	1.84	1.65	1.71	1.08	1.65	1.65	1.67	1.18	1.37	1.62	1.63
CBOD5 (lbs/day) Average Monthly	19	10	16	< 10	< 11	< 13	< 15	< 14.0	20	24	27	< 15
CBOD5 (lbs/day) Weekly Average	34	13	19	14	15	< 21	20	23.0	33	63	70	< 19
CBOD5 (mg/L) Average Monthly	4.0	2.0	3.0	< 2.0	< 2.0	< 3.0	< 3.0	< 3.0	5.0	4.0	3.0	< 3.0
CBOD5 (mg/L) Weekly Average	8.0	3.0	4.0	3.0	3.0	< 5.0	4.0	4.0	7.0	7.0	5.0	< 3.0
BOD5 (lbs/day) Raw Sewage Influent   Average Monthly	1646	1252	1227	1678	1339	1377	1178	1288	1863	2446	2067	1927
BOD5 (lbs/day) Raw Sewage Influent   Daily Maximum	3642	2356	3061	3658	2285	3179	2573	3275	2990	7406	2939	5170
BOD5 (mg/L) Raw Sewage Influent   Average Monthly	362.0	283.0	209	363	280	325	199	272.0	411	387	315	325
TSS (lbs/day) Average Monthly	< 53	47	85	70	59	47	61	50	61.0	< 68	103	< 45
TSS (lbs/day) Raw Sewage Influent   Average Monthly	1484	1549	1711	1879	2401	1604	1653	1222	1477	1704	2665	2958

## NPDES Permit Fact Sheet

## Tiadaghton Valley Municipal Authority WWTP

## NPDES Permit No. PA0234079

TSS (lbs/day) Raw Sewage Influent   Daily Maximum	2923	4667	4147	3381	9697	3175	3149	2477	3166	4041	5038	11734
TSS (lbs/day) Weekly Average	66	60	107	95	86	60	89	73	96.0	165	278	57
TSS (mg/L) Average Monthly	< 13	11.0	16	17	< 13	11	11	10.0	14	< 10	12	< 8.0
TSS (mg/L) Raw Sewage Influent   Average Monthly	325	347	271	408	498	376	286	256	331	292	385	488
TSS (mg/L) Weekly Average	15	15.0	18	26	18	13	13	15.0	22	19	19	10.0
Fecal Coliform (No./100 ml) Geometric Mean	< 2.0	< 1.0	< 5.0	13.0	< 3.0	< 3.0	< 2.0	< 2.0	< 2.0	< 2.0	< 3.0	< 1.0
Fecal Coliform (No./100 ml) Instantaneous Maximum	16.0	2.0	71.2	35.5	32.3	10.9	6.3	19.5	6.3	9.7	182.9	2.0
UV Intensity (mW/cm <sup>2</sup> ) Daily Minimum	0.192	0.272	0.119	0.274	0.190	0.271	0.307	0.288	0.318	0.312	0.118	0.260
Nitrate-Nitrite (mg/L) Average Monthly	5.356	5.056	3.88	3.616	3.126	4.231	4.24	3.33	2.231	1.777	3.34	3.151
Nitrate-Nitrite (lbs) Total Monthly	614.3	665.2	632.3	483.7	437.7	531.8	691.2	551.9	291.5	284.3	514.7	473.4
Total Nitrogen (mg/L) Average Monthly	7.239	6.815	6.16	5.48	5.03	5.631	5.81	5.11	5.291	4.328	5.18	5.506
Total Nitrogen (lbs) Effluent Net   Total Monthly	835.7	891.5	1103.1	722.0	712.8	706.4	990.8	846.9	689.6	817.0	798.2	919.7
Total Nitrogen (lbs) Total Monthly	835.7	891.5	1103.1	722.0	712.8	706.4	990.8	846.9	689.6	817.0	798.2	919.7
Total Nitrogen (lbs) Effluent Net   Total Annual							12456					
Total Nitrogen (lbs) Total Annual							11870					
Ammonia (mg/L) Average Monthly	< 0.33	< 0.32	< 0.65	< 0.12	< 0.14	< 0.17	< 0.43	0.11	1.07	< 0.87	0.49	< 0.97
Ammonia (lbs) Total Monthly	< 40.2	< 41.2	< 185.8	< 15.1	< 21.0	< 21.3	< 97.4	18.2	137.4	< 214.1	75.5	< 200.1
Ammonia (lbs) Total Annual							< 2195					

## NPDES Permit Fact Sheet

## Tiadaghton Valley Municipal Authority WWTP

## NPDES Permit No. PA0234079

TKN (mg/L) Average Monthly	1.88	1.76	2.28	1.87	1.90	1.40	1.567	1.78	3.06	2.551	1.84	2.355
TKN (lbs) Total Monthly	221.4	226.4	470.8	238.3	275.1	174.6	299.5	295.0	398.1	532.6	283.5	446.3
Total Phosphorus (mg/L) Average Monthly	1.686	0.97	0.63	1.126	1.196	0.539	0.449	1.12	2.728	2.28	3.99	0.655
Total Phosphorus (lbs) Effluent Net   Total Monthly	197.9	122.5	106.9	149.2	5.03	68.5	81.4	185.6	351.6	391.7	614.8	102.8
Total Phosphorus (lbs) Total Monthly	197.9	122.5	106.9	149.2	170.3	68.5	81.4	185.6	351.6	391.7	614.8	102.8
Total Phosphorus (lbs) Effluent Net   Total Annual						2541						
Total Phosphorus (lbs) Total Annual						2541						
Total Aluminum (mg/L) Daily Maximum			0.22			0.66			0.14			0.13
Total Copper (mg/L) Daily Maximum			0.0059			0.009			0.0057			< 0.005
Total Iron (mg/L) Daily Maximum			0.075			0.14			0.12			0.068
Total Manganese (mg/L) Daily Maximum			0.075			0.11			0.052			0.047
Total Zinc (mg/L) Daily Maximum			0.042			0.058			0.050			0.03

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment B)
<input checked="" type="checkbox"/>	Toxics Management Spreadsheet (see Attachment C)
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input checked="" type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input checked="" type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [REDACTED]
<input type="checkbox"/>	Other: [REDACTED]

# **APPENDIX A**

## **Q<sub>7-10</sub> ANALYSIS AND STREAM DATA**

## StreamStats Report

Region ID: PA

Workspace ID: PA20250625115901468000

Clicked Point (Latitude, Longitude): 41.19458, -77.24337

Time: 2025-06-25 07:59:36 -0400



[Collapse All](#)

### Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
CARBON	Percentage of area of carbonate rock	5.02	percent
DRNAREA	Area that drains to a point on a stream	5230	square miles
ELEV	Mean Basin Elevation	1649	feet
FOREST	Percentage of area covered by forest	85.7697	percent
GLACIATED	Percentage of basin area that was historically covered by glaciers	10.4325	percent
PRECIP	Mean Annual Precipitation	41	inches
ROCKDEP	Depth to rock	4.6	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	1.71	miles per square mile



Prepared in cooperation with the Pennsylvania Department of Environmental Protection

## Selected Streamflow Statistics for Streamgage Locations in and near Pennsylvania



Open-File Report 2011-1070

U.S. Department of the Interior  
U.S. Geological Survey

Table 1 13

**Table 1.** List of U.S. Geological Survey streamgage locations in and near Pennsylvania with updated streamflow statistics.—Continued  
[Latitude and Longitude in decimal degrees; mi<sup>2</sup>, square miles]

Streamgage number	Streamgage name	Latitude	Longitude	Drainage area (mi <sup>2</sup> )	Regulated <sup>1</sup>
01541303	West Branch Susquehanna River at Hyde, Pa.	41.005	-78.457	474	Y
01541308	Bradley Run near Ashville, Pa.	40.509	-78.584	6.77	N
01541500	Clearfield Creek at Dimeling, Pa.	40.972	-78.406	371	Y
01542000	Moshannon Creek at Osceola Mills, Pa.	40.850	-78.268	68.8	N
01542500	WB Susquehanna River at Karthaus, Pa.	41.118	-78.109	1,462	Y
01542810	Waldy Run near Emporium, Pa.	41.579	-78.293	5.24	N
01543000	Driftwood Branch Sinnemahoning Creek at Sterling Run, Pa.	41.413	-78.197	272	N
01543500	Sinnemahoning Creek at Sinnemahoning, Pa.	41.317	-78.103	685	N
01544000	First Fork Sinnemahoning Creek near Sinnemahoning, Pa.	41.402	-78.024	245	Y
01544500	Kettle Creek at Cross Fork, Pa.	41.476	-77.826	136	N
01545000	Kettle Creek near Westport, Pa.	41.320	-77.874	233	Y
01545500	West Branch Susquehanna River at Renovo, Pa.	41.325	-77.751	2,975	Y
01545600	Young Womans Creek near Renovo, Pa.	41.390	-77.691	46.2	N
01546000	North Bald Eagle Creek at Milesburg, Pa.	40.942	-77.794	119	N
01546400	Spring Creek at Houserville, Pa.	40.834	-77.828	58.5	N
01546500	Spring Creek near Axemann, Pa.	40.890	-77.794	87.2	N
01547100	Spring Creek at Milesburg, Pa.	40.932	-77.786	142	N
01547200	Bald Eagle Creek below Spring Creek at Milesburg, Pa.	40.943	-77.786	265	N
01547500	Bald Eagle Creek at Blanchard, Pa.	41.052	-77.604	339	Y
01547700	Marsh Creek at Blanchard, Pa.	41.060	-77.606	44.1	N
01547800	South Fork Beech Creek near Snow Shoe, Pa.	41.024	-77.904	12.2	N
01547950	Beech Creek at Monument, Pa.	41.112	-77.702	152	N
01548005	Bald Eagle Creek near Beech Creek Station, Pa.	41.081	-77.549	562	Y
01548500	Pine Creek at Cedar Run, Pa.	41.522	-77.447	604	N
01549000	Pine Creek near Waterville, Pa.	41.313	-77.379	750	N
01549500	Blockhouse Creek near English Center, Pa.	41.474	-77.231	37.7	N
01549700	Pine Creek below Little Pine Creek near Waterville, Pa.	41.274	-77.324	944	Y
01550000	Lycoming Creek near Trout Run, Pa.	41.418	-77.033	173	N
01551500	WB Susquehanna River at Williamsport, Pa.	41.236	-76.997	5,682	Y
01552000	Loyalsock Creek at Loyalsockville, Pa.	41.325	-76.912	435	N
01552500	Muncy Creek near Sonestown, Pa.	41.357	-76.535	23.8	N
01553130	Sand Spring Run near White Deer, Pa.	41.059	-77.077	4.93	N
01553500	West Branch Susquehanna River at Lewisburg, Pa.	40.968	-76.876	6,847	Y
01553700	Chillisquaque Creek at Washingtonville, Pa.	41.062	-76.680	51.3	N
01554000	Susquehanna River at Sunbury, Pa.	40.835	-76.827	18,300	Y
01554500	Shamokin Creek near Shamokin, Pa.	40.810	-76.584	54.2	N
01555000	Penns Creek at Penns Creek, Pa.	40.867	-77.048	301	N
01555500	East Mahantango Creek near Dalmatia, Pa.	40.611	-76.912	162	N
01556000	Frankstown Branch Juniata River at Williamsburg, Pa.	40.463	-78.200	291	N
01557500	Bald Eagle Creek at Tyrone, Pa.	40.684	-78.234	44.1	N
01558000	Little Juniata River at Spruce Creek, Pa.	40.613	-78.141	220	N
01559000	Juniata River at Huntingdon, Pa.	40.485	-78.019	816	LF
01559500	Standing Stone Creek near Huntingdon, Pa.	40.524	-77.971	128	N
01559700	Sulphur Springs Creek near Manns Choice, Pa.	39.978	-78.619	5.28	N
01560000	Dunning Creek at Belden, Pa.	40.072	-78.493	172	N

## 26 Selected Streamflow Statistics for Streamgage Locations in and near Pennsylvania

Table 2. Selected low-flow statistics for streamgage locations in and near Pennsylvania.—Continued

[ft<sup>3</sup>/s; cubic feet per second; —, statistic not computed; <, less than]

Streamgage number	Period of record used in analysis <sup>1</sup>	Number of years used in analysis	1-day, 10-year (ft <sup>3</sup> /s)	7-day, 10-year (ft <sup>3</sup> /s)	7-day, 2-year (ft <sup>3</sup> /s)	30-day, 10-year (ft <sup>3</sup> /s)	30-day, 2-year (ft <sup>3</sup> /s)	90-day, 10-year (ft <sup>3</sup> /s)
01546000	1912–1934	17	1.8	2.2	6.8	3.7	12.1	11.2
01546400	1986–2008	23	13.5	14.0	19.6	15.4	22.3	18.7
01546500	1942–2008	67	26.8	29.0	41.3	31.2	44.2	33.7
01547100	1969–2008	40	102	105	128	111	133	117
01547200	1957–2008	52	99.4	101	132	106	142	115
01547500	<sup>2</sup> 1971–2008	38	28.2	109	151	131	172	153
01547500	<sup>3</sup> 1956–1969	14	90.0	94.9	123	98.1	131	105
01547700	1957–2008	52	.5	.6	2.7	1.1	3.9	2.2
01547800	1971–1981	11	1.6	1.8	2.4	2.1	2.9	3.5
01547950	1970–2008	39	12.1	13.6	28.2	17.3	36.4	23.8
01548005	<sup>2</sup> 1971–2000	25	142	151	206	178	241	223
01548005	<sup>3</sup> 1912–1969	58	105	114	147	125	165	140
01548500	1920–2008	89	21.2	24.2	50.1	33.6	68.6	49.3
01549000	1910–1920	11	26.0	32.9	78.0	46.4	106	89.8
01549500	1942–2008	67	.6	.8	2.5	1.4	3.9	2.6
01549700	1959–2008	50	33.3	37.2	83.8	51.2	117	78.4
01550000	1915–2008	94	6.6	7.6	16.8	11.2	24.6	18.6
01551500	<sup>2</sup> 1963–2008	46	520	578	1,020	678	1,330	919
01551500	<sup>3</sup> 1901–1961	61	400	439	742	523	943	752
01552000	1927–2008	80	20.5	22.2	49.5	29.2	69.8	49.6
01552500	1942–2008	67	.9	1.2	3.1	1.7	4.4	3.3
01553130	1969–1981	13	1.0	1.1	1.5	1.3	1.8	1.7
01553500	<sup>2</sup> 1968–2008	41	760	838	1,440	1,000	1,850	1,470
01553500	<sup>3</sup> 1941–1966	26	562	619	880	690	1,090	881
01553700	1981–2008	28	9.1	10.9	15.0	12.6	17.1	15.2
01554000	<sup>2</sup> 1981–2008	28	1,830	1,990	3,270	2,320	4,210	3,160
01554000	<sup>3</sup> 1939–1979	41	1,560	1,630	2,870	1,880	3,620	2,570
01554500	1941–1993	53	16.2	22.0	31.2	25.9	35.7	31.4
01555000	1931–2008	78	33.5	37.6	58.8	43.4	69.6	54.6
01555500	1931–2008	78	4.9	6.5	18.0	9.4	24.3	16.6
01556000	1918–2008	91	43.3	47.8	66.0	55.1	75.0	63.7
01557500	1946–2008	63	2.8	3.2	6.3	4.2	8.1	5.8
01558000	1940–2008	69	56.3	59.0	79.8	65.7	86.2	73.7
01559000	1943–2008	66	104	177	249	198	279	227
01559500	1931–1958	28	9.3	10.5	15.0	12.4	17.8	15.8
01559700	1963–1978	16	.1	.1	.2	.1	.3	.2
01560000	1941–2008	68	8.5	9.4	15.6	12.0	20.2	16.2
01561000	1932–1958	27	.4	.5	1.6	.8	2.5	1.7
01562000	1913–2008	96	64.1	67.1	106	77.4	122	94.5
01562500	1931–1957	27	1.1	1.6	3.8	2.3	5.4	3.7
01563200	<sup>2</sup> 1974–2008	35	—	—	—	112	266	129
01563200	<sup>3</sup> 1948–1972	25	10.3	28.2	86.1	64.5	113	95.5
01563500	<sup>2</sup> 1974–2008	35	384	415	519	441	580	493
01563500	<sup>3</sup> 1939–1972	34	153	242	343	278	399	333
01564500	1940–2008	69	3.6	4.2	10.0	6.2	14.4	10.6

# **APPENDIX B**

## **WQM 7.0 MODEL INPUT/OUTPUT**

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
10D	18668	WEST BRANCH SUSQUEHANNA RI	55.500	530.00	5230.00	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD	Rch Width	Rch Depth	Tributary Temp	pH	Stream Temp	pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.100	0.00	279.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
TVMA	PA0234079	1.0500	1.0500	1.0500	0.000	25.00	7.00
Parameter Data							
Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)		
CBOD5		25.00	2.00	0.00	1.50		
Dissolved Oxygen		3.00	8.24	0.00	0.00		
NH3-N		25.00	0.00	0.00	0.70		

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation	Drainage Area	Slope	PWS Withdrawal	Apply FC
				(ft)	(sq mi)	(ft/ft)	(mgd)	
10D	18668	WEST BRANCH SUSQUEHANNA RI	55.000	525.00	5235.00	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	pH	Stream Temp	pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.100	0.00	557.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00
Parameter Data							
Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)		
CBOD5		25.00	2.00	0.00	1.50		
Dissolved Oxygen		3.00	8.24	0.00	0.00		
NH3-N		25.00	0.00	0.00	0.70		

**WQM 7.0 Hydrodynamic Outputs**

RMI	Stream Flow (cfs)	PWS With (cfs)	SWP Basin		Stream Code		Stream Name					
			10D	18668	WEST BRANCH SUSQUEHANNA RIVER							
Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH			
<b>Q7-10 Flow</b>												
55.500	279.00	0.00	279.00	1.6243	0.00189	1.227	309.19	252.03	0.74	0.041	20.03	7.00
<b>Q1-10 Flow</b>												
55.500	262.26	0.00	262.26	1.6243	0.00189	NA	NA	NA	0.71	0.043	20.03	7.00
<b>Q30-10 Flow</b>												
55.500	326.43	0.00	326.43	1.6243	0.00189	NA	NA	NA	0.81	0.038	20.02	7.00

## WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.94	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.17	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

**WQM 7.0 Wasteload Allocations**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
10D	18668	WEST BRANCH SUSQUEHANNA RIVER					
<b>NH3-N Acute Allocations</b>							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
55.500	TVMA	16.72	50	16.72	50	0	0
<b>NH3-N Chronic Allocations</b>							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
55.500	TVMA	1.88	25	1.88	25	0	0
<b>Dissolved Oxygen Allocations</b>							
RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>	
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)
55.50	TVMA	25	25	25	25	3	3
						0	0

## WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
10D	18668	WEST BRANCH SUSQUEHANNA RIVER		
<u>RMI</u> 55.500	<u>Total Discharge Flow (mgd)</u> 1.050	<u>Analysis Temperature (°C)</u> 20.029	<u>Analysis pH</u> 7.000	
<u>Reach Width (ft)</u> 309.187	<u>Reach Depth (ft)</u> 1.227	<u>Reach WDRatio</u> 252.032	<u>Reach Velocity (fps)</u> 0.740	
<u>Reach CBOD5 (mg/L)</u> 2.13	<u>Reach Kc (1/days)</u> 0.099	<u>Reach NH3-N (mg/L)</u> 0.14	<u>Reach Kn (1/days)</u> 0.702	
<u>Reach DO (mg/L)</u> 8.213	<u>Reach Kr (1/days)</u> 6.541	<u>Kr Equation</u> Tsivoglou	<u>Reach DO Goal (mg/L)</u> 5	
<u>Reach Travel Time (days)</u> 0.041	<b>Subreach Results</b>			
	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.004	2.13	0.14	8.23
	0.008	2.13	0.14	8.24
	0.012	2.13	0.14	8.24
	0.017	2.13	0.14	8.24
	0.021	2.13	0.14	8.24
	0.025	2.13	0.14	8.24
	0.029	2.13	0.14	8.24
	0.033	2.13	0.14	8.24
	0.037	2.13	0.14	8.24
	0.041	2.12	0.14	8.24

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
10D	18668	WEST BRANCH SUSQUEHANNA RIVER					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
55.500	TVMA	PA0234079	1.050	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			3

# **APPENDIX C**

## **TOXICS MANAGEMENT SPREADSHEET**



## Discharge Information

Instructions **Discharge** Stream

Facility: **TVMA** NPDES Permit No.: **PA0234079** Outfall No.: **001**

Evaluation Type: **Major Sewage / Industrial Waste** Wastewater Description: **Sewage Effluent**

Discharge Characteristics								
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)			Complete Mix Times (min)		
			AFC	CFC	THH	CRL	Q <sub>7-10</sub>	Q <sub>h</sub>
1.05	100	7						

		Units	Max Discharge Conc	0 if left blank		0.5 if left blank		0 if left blank		1 if left blank		
Discharge Pollutant				Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteri a Mod	Chem Transl
Group 1	Total Dissolved Solids (PWS)	mg/L	469									
	Chloride (PWS)	mg/L	185									
	Bromide	mg/L	0.093									
	Sulfate (PWS)	mg/L	37.7									
	Fluoride (PWS)	mg/L										
Group 2	Total Aluminum	µg/L	660									
	Total Antimony	µg/L	0.38									
	Total Arsenic	µg/L	0.63									
	Total Barium	µg/L	24.4									
	Total Beryllium	µg/L	< 0.29									
	Total Boron	µg/L	140									
	Total Cadmium	µg/L	0.13									
	Total Chromium (III)	µg/L	< 1.3									
	Hexavalent Chromium	µg/L	< 2									
	Total Cobalt	µg/L	< 2.5									
	Total Copper	µg/L	16									
	Free Cyanide	µg/L	1.55									
	Total Cyanide	µg/L	0.014									
	Dissolved Iron	µg/L	< 34.6									
	Total Iron	µg/L	230									
	Total Lead	µg/L	0.52									
	Total Manganese	µg/L	110									
	Total Mercury	µg/L	< 0.16									
	Total Nickel	µg/L	2.6									
	Total Phenols (Phenolics) (PWS)	µg/L	0.027									
	Total Selenium	µg/L	< 0.84									
	Total Silver	µg/L	< 0.53									
	Total Thallium	µg/L	< 0.081									
	Total Zinc	µg/L	63									
	Total Molybdenum	µg/L	< 4.7									
Group 3	Acrolein	µg/L	< 4									
	Acrylamide	µg/L										
	Acrylonitrile	µg/L	< 1.4									
	Benzene	µg/L	< 0.41									
	Bromoform	µg/L	< 1.5									

Group 3	Carbon Tetrachloride	µg/L	<	0.52						
	Chlorobenzene	µg/L	<	0.42						
	Chlorodibromomethane	µg/L								
	Chloroethane	µg/L	<	0.75						
	2-Chloroethyl Vinyl Ether	µg/L	<	0.34						
	Chloroform	µg/L		1.6						
	Dichlorobromomethane	µg/L	<	0.42						
	1,1-Dichloroethane	µg/L	<	0.26						
	1,2-Dichloroethane	µg/L	<	0.35						
	1,1-Dichloroethylene	µg/L	<	0.28						
	1,2-Dichloropropane	µg/L	<	0.3						
	1,3-Dichloropropylene	µg/L	<	0.66						
	1,4-Dioxane	µg/L	<	1.9						
	Ethylbenzene	µg/L	<	0.31						
	Methyl Bromide	µg/L								
	Methyl Chloride	µg/L								
	Methylene Chloride	µg/L	<	0.75						
	1,1,2,2-Tetrachloroethane	µg/L	<	0.24						
	Tetrachloroethylene	µg/L	<	0.3						
	Toluene	µg/L	<	0.24						
Group 4	1,2-trans-Dichloroethylene	µg/L	<	0.33						
	1,1,1-Trichloroethane	µg/L	<	0.43						
	1,1,2-Trichloroethane	µg/L	<	0.46						
	Trichloroethylene	µg/L	<	0.33						
	Vinyl Chloride	µg/L	<	0.28						
	2-Chlorophenol	µg/L	<							
	2,4-Dichlorophenol	µg/L	<	0.74						
	2,4-Dimethylphenol	µg/L	<	0.79						
	4,6-Dinitro-o-Cresol	µg/L	<	2.1						
	2,4-Dinitrophenol	µg/L	<	2.9						
Group 5	2-Nitrophenol	µg/L	<	0.82						
	4-Nitrophenol	µg/L	<	0.43						
	p-Chloro-m-Cresol	µg/L	<	1.1						
	Pentachlorophenol	µg/L	<	1.9						
	Phenol	µg/L	<	0.31						
	2,4,6-Trichlorophenol	µg/L	<	0.28						
	Acenaphthene	µg/L	<	0.73						
	Acenaphthylene	µg/L	<	0.77						
	Anthracene	µg/L	<	0.8						
	Benzidine	µg/L	<	5.4						





## Stream / Surface Water Information

TVMA, NPDES Permit No. PA0234079, Outfall 001

Instructions **Discharge** Stream

Receiving Surface Water Name: **West Branch Susquehanna River**

No. Reaches to Model: **1**

Statewide Criteria

Great Lakes Criteria

ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi <sup>2</sup> )*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	018668	55.5	530	5230			Yes
End of Reach 1	018668	55	525	5235			Yes

**Q<sub>7-10</sub>**

Location	RMI	LFY (cfs/mi <sup>2</sup> )*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	55.5	0.1								100	7				
End of Reach 1	55	0.1													

**Q<sub>h</sub>**

Location	RMI	LFY (cfs/mi <sup>2</sup> )*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	55.5														
End of Reach 1	55														

## NPDES Permit Fact Sheet

NPDES Permit No. PA0234079

Diethyl Phthalate	0	0		0	N/A	N/A	N/A
Dimethyl Phthalate	0	0		0	N/A	N/A	N/A
Di-n-Butyl Phthalate	0	0		0	N/A	N/A	N/A
2,4-Dinitrotoluene	0	0		0	0.05	0.05	33.6
2,6-Dinitrotoluene	0	0		0	0.05	0.05	33.6
1,2-Diphenylhydrazine	0	0		0	0.03	0.03	20.2
Fluoranthene	0	0		0	N/A	N/A	N/A
Fluorene	0	0		0	N/A	N/A	N/A
Hexachlorobenzene	0	0		0	0.00008	0.00008	0.054
Hexachlorobutadiene	0	0		0	0.01	0.01	6.72
Hexachlorocyclopentadiene	0	0		0	N/A	N/A	N/A
Hexachloroethane	0	0		0	0.1	0.1	67.2
Indeno(1,2,3-cd)Pyrene	0	0		0	0.001	0.001	0.67
Isophorone	0	0		0	N/A	N/A	N/A
Naphthalene	0	0		0	N/A	N/A	N/A
Nitrobenzene	0	0		0	N/A	N/A	N/A
n-Nitrosodimethylamine	0	0		0	0.0007	0.0007	0.47
n-Nitrosodi-n-Propylamine	0	0		0	0.005	0.005	3.36
n-Nitrosodiphenylamine	0	0		0	3.3	3.3	2,217
Phenanthrene	0	0		0	N/A	N/A	N/A
Pyrene	0	0		0	N/A	N/A	N/A
1,2,4-Trichlorobenzene	0	0		0	N/A	N/A	N/A

### Recommended WQBELs & Monitoring Requirements

No. Samples/Month: 4

**Other Pollutants without Limits or Monitoring**

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., < Target QL).

## Model Results

6/25/2025

Page 14

Pollutants	Governing WQBEL	Units	Comments
Total Dissolved Solids (PWS)	N/A	N/A	PWS Not Applicable
Chloride (PWS)	N/A	N/A	PWS Not Applicable
Bromide	N/A	N/A	No WQS
Sulfate (PWS)	N/A	N/A	PWS Not Applicable
Total Aluminum	9,732	µg/L	Discharge Conc ≤ 10% WQBEL
Total Antimony	752	µg/L	Discharge Conc ≤ 10% WQBEL
Total Arsenic	1,343	µg/L	Discharge Conc ≤ 10% WQBEL
Total Barium	272,497	µg/L	Discharge Conc ≤ 10% WQBEL
Total Beryllium	N/A	N/A	No WQS
Total Boron	105,106	µg/L	Discharge Conc ≤ 10% WQBEL
Total Cadmium	27.7	µg/L	Discharge Conc ≤ 10% WQBEL
Total Chromium (III)	11,577	µg/L	Discharge Conc < TQL
Hexavalent Chromium	211	µg/L	Discharge Conc ≤ 10% WQBEL
Total Cobalt	1,233	µg/L	Discharge Conc ≤ 10% WQBEL
Total Copper	182	µg/L	Discharge Conc ≤ 10% WQBEL
Free Cyanide	285	µg/L	Discharge Conc ≤ 25% WQBEL
Total Cyanide	N/A	N/A	No WQS
Dissolved Iron	40,299	µg/L	Discharge Conc ≤ 10% WQBEL
Total Iron	484,462	µg/L	Discharge Conc ≤ 10% WQBEL
Total Lead	427	µg/L	Discharge Conc ≤ 10% WQBEL
Total Manganese	134,331	µg/L	Discharge Conc ≤ 10% WQBEL
Total Mercury	6.72	µg/L	Discharge Conc < TQL
Total Nickel	6,088	µg/L	Discharge Conc ≤ 10% WQBEL
Total Phenols (Phenolics) (PWS)		µg/L	PWS Not Applicable
Total Selenium	670	µg/L	Discharge Conc < TQL
Total Silver	49.1	µg/L	Discharge Conc ≤ 10% WQBEL
Total Thallium	32.2	µg/L	Discharge Conc < TQL
Total Zinc	1,555	µg/L	Discharge Conc ≤ 10% WQBEL
Total Molybdenum	N/A	N/A	No WQS
Acrolein	38.9	µg/L	Discharge Conc ≤ 25% WQBEL
Acrylonitrile	40.3	µg/L	Discharge Conc < TQL
Benzene	390	µg/L	Discharge Conc < TQL
Bromoform	4,702	µg/L	Discharge Conc ≤ 25% WQBEL
Carbon Tetrachloride	269	µg/L	Discharge Conc ≤ 25% WQBEL
Chlorobenzene	13,433	µg/L	Discharge Conc < TQL
Chloroethane	N/A	N/A	No WQS
2-Chloroethyl Vinyl Ether	233,569	µg/L	Discharge Conc < TQL
Chloroform	766	µg/L	Discharge Conc ≤ 25% WQBEL
Dichlorobromomethane	638	µg/L	Discharge Conc < TQL
1,1-Dichloroethane	N/A	N/A	No WQS
1,2-Dichloroethane	6,650	µg/L	Discharge Conc < TQL
1,1-Dichloroethylene	4,433	µg/L	Discharge Conc < TQL

1,2-Dichloropropane	605	µg/L	Discharge Conc < TQL
1,3-Dichloropropylene	181	µg/L	Discharge Conc ≤ 25% WQBEL
1,4-Dioxane	N/A	µg/L	No WQS
Ethylbenzene	9,135	µg/L	Discharge Conc < TQL
Methylene Chloride	13,434	µg/L	Discharge Conc ≤ 25% WQBEL
1,1,2,2-Tetrachloroethane	134	µg/L	Discharge Conc < TQL
Tetrachloroethylene	6,717	µg/L	Discharge Conc < TQL
Toluene	7,657	µg/L	Discharge Conc < TQL
1,2-trans-Dichloroethylene	13,433	µg/L	Discharge Conc < TQL
1,1,1-Trichloroethane	38,928	µg/L	Discharge Conc < TQL
1,1,2-Trichloroethane	369	µg/L	Discharge Conc < TQL
Trichloroethylene	403	µg/L	Discharge Conc < TQL
Vinyl Chloride	13.4	µg/L	Discharge Conc < TQL
2,4-Dichlorophenol	1,343	µg/L	Discharge Conc < TQL
2,4-Dimethylphenol	8,564	µg/L	Discharge Conc < TQL
4,6-Dinitro-o-Cresol	269	µg/L	Discharge Conc < TQL
2,4-Dinitrophenol	1,343	µg/L	Discharge Conc < TQL
2-Nitrophenol	103,808	µg/L	Discharge Conc < TQL
4-Nitrophenol	29,845	µg/L	Discharge Conc < TQL
p-Chloro-m-Cresol	2,076	µg/L	Discharge Conc < TQL
Pentachlorophenol	20.2	µg/L	Discharge Conc < TQL
Phenol	537,325	µg/L	Discharge Conc < TQL
2,4,6-Trichlorophenol	1,008	µg/L	Discharge Conc < TQL
Acenaphthene	1,077	µg/L	Discharge Conc < TQL
Acenaphthylene	N/A	N/A	No WQS
Anthracene	40,299	µg/L	Discharge Conc < TQL
Benzidine	0.067	µg/L	Discharge Conc < TQL
Benzo(a)Anthracene	0.67	µg/L	Discharge Conc < TQL
Benzo(a)Pyrene	0.067	µg/L	Discharge Conc < TQL
3,4-Benzo[fluoranthene	0.67	µg/L	Discharge Conc < TQL
Benzo(ghi)Perylene	N/A	N/A	No WQS
Benzo(k)Fluoranthene	6.72	µg/L	Discharge Conc < TQL
Bis(2-Chloroethoxy)Methane	N/A	N/A	No WQS
Bis(2-Chloroethyl)Ether	20.2	µg/L	Discharge Conc < TQL
Bis(2-Chloroisopropyl)Ether	26,866	µg/L	Discharge Conc < TQL
Bis(2-Ethylhexyl)Phthalate	215	µg/L	Discharge Conc < TQL
4-Bromophenyl Phenyl Ether	3,504	µg/L	Discharge Conc < TQL
Butyl Benzyl Phthalate	13.4	µg/L	Discharge Conc < TQL
2-Chloronaphthalene	107,465	µg/L	Discharge Conc < TQL
4-Chlorophenyl Phenyl Ether	N/A	N/A	No WQS
Chrysene	80.6	µg/L	Discharge Conc < TQL
Dibenz(a,h)Anthracene	0.067	µg/L	Discharge Conc < TQL
1,2-Dichlorobenzene	10,640	µg/L	Discharge Conc ≤ 25% WQBEL
1,3-Dichlorobenzene	940	µg/L	Discharge Conc ≤ 25% WQBEL
1,4-Dichlorobenzene	9,473	µg/L	Discharge Conc ≤ 25% WQBEL


**NPDES Permit Fact Sheet**  
**Tiadaghton Valley Municipal Authority WWTP**

**NPDES Permit No. PA0234079**

3,3-Dichlorobenzidine	33.6	µg/L	Discharge Conc < TQL
Diethyl Phthalate	51,904	µg/L	Discharge Conc < TQL
Dimethyl Phthalate	32,440	µg/L	Discharge Conc < TQL
Di-n-Butyl Phthalate	1,427	µg/L	Discharge Conc < TQL
2,4-Dinitrotoluene	33.6	µg/L	Discharge Conc < TQL
2,6-Dinitrotoluene	33.6	µg/L	Discharge Conc < TQL
Di-n-Octyl Phthalate	N/A	N/A	No WQS
1,2-Diphenylhydrazine	20.2	µg/L	Discharge Conc < TQL
Fluoranthene	2,595	µg/L	Discharge Conc < TQL
Fluorene	6,717	µg/L	Discharge Conc < TQL
Hexachlorobenzene	0.054	µg/L	Discharge Conc < TQL
Hexachlorobutadiene	6.72	µg/L	Discharge Conc ≤ 25% WQBEL
Hexachlorocyclopentadiene	64.9	µg/L	Discharge Conc < TQL
Hexachloroethane	67.2	µg/L	Discharge Conc < TQL
Indeno(1,2,3-cd)Pyrene	0.67	µg/L	Discharge Conc < TQL
Isophorone	4,567	µg/L	Discharge Conc < TQL
Naphthalene	1,817	µg/L	Discharge Conc ≤ 25% WQBEL
Nitrobenzene	1,343	µg/L	Discharge Conc < TQL
n-Nitrosodimethylamine	0.47	µg/L	Discharge Conc < TQL
n-Nitrosodi-n-Propylamine	3.36	µg/L	Discharge Conc < TQL
n-Nitrosodiphenylamine	2,217	µg/L	Discharge Conc < TQL
Phenanthrene	64.9	µg/L	Discharge Conc < TQL
Pyrene	2,687	µg/L	Discharge Conc < TQL
1,2,4-Trichlorobenzene	9.4	µg/L	Discharge Conc ≤ 25% WQBEL

# **APPENDIX D**

## **FACILITY MAP AND SCHEMATIC**




U.S.G.S 7.5 MINUTE SERIES  
LINDEN STATION QUADRANGLE  
CONTOUR INTERVAL 20 FT  
N.G.V.D. 1929

### PROJECT LOCATION MAP




### TIADAGHTON VALLEY MUNICIPAL AUTHORITY WASTEWATER TREATMENT PLANT NIPPENOSE TOWNSHIP, LYCOMING COUNTY, PA

2,500 1,250 0 2,500 5,000 7,500  
Feet



PROCESS SCHEMATIC LIQUID STREAM  
N.T.S.



PROCESS SCHEMATIC SOLIDS STREAM  
N.T.S.

NOTE:  
1. PROCESS DIAGRAM IS BASED ON  
LARSON DESIGN GROUPS PAGE  
W101 OF THE ISSUED FOR  
CONSTRUCTION DRAWINGS, REV. 2  
ADDENDUM 2.

# **APPENDIX E**

## **WETT INFO**

**WET Summary and Evaluation**

**Facility Name**  
**Permit No.**  
**Design Flow (MGD)**  
**Q<sub>7-10</sub> Flow (cfs)**  
**PMF<sub>a</sub>**  
**PMF<sub>c</sub>**

Tiadaghton Valley Municipal Authority WWTP
PA00234079

<b>Species</b>	<b>Endpoint</b>	<b>Test Results (Pass/Fail)</b>			
		<b>Test Date</b>	<b>Test Date</b>	<b>Test Date</b>	<b>Test Date</b>
Ceriodaphnia	Survival	9/17/19	PASS		

<b>Species</b>	<b>Endpoint</b>	<b>Test Results (Pass/Fail)</b>			
		<b>Test Date</b>	<b>Test Date</b>	<b>Test Date</b>	<b>Test Date</b>
Ceriodaphnia	Reproduction	9/17/19	PASS		

<b>Species</b>	<b>Endpoint</b>	<b>Test Results (Pass/Fail)</b>			
		<b>Test Date</b>	<b>Test Date</b>	<b>Test Date</b>	<b>Test Date</b>
Pimephales	Survival	9/17/18	PASS		

<b>Species</b>	<b>Endpoint</b>	<b>Test Results (Pass/Fail)</b>			
		<b>Test Date</b>	<b>Test Date</b>	<b>Test Date</b>	<b>Test Date</b>
Pimephales	Growth	9/17/18	PASS		

**Reasonable Potential?** NO

**Permit Recommendations**

**Test Type**  
 TIWC  
**Dilution Series** , , , , % Effluent  
**Permit Limit**  
**Permit Limit Species**

## DEP Whole Effluent Toxicity (WET) Analysis Spreadsheet

Type of Test	Chronic
Species Tested	Ceriodaphnia
Endpoint	Survival
TIWC (decimal)	0.1
No. Per Replicate	1
TST b value	0.75
TST alpha value	0.2

Facility Name
Tiadaghton Valley Municipal
Authority WWTP

Permit No.
PA00234079

Replicate No.	Test Completion Date	
	Control	TIWC
1	1	1
2	1	1
3	1	1
4	1	1
5	1	1
6	1	1
7	1	1
8	1	1
9	1	1
10	1	1
11		
12		
13		
14		
15		

Mean	1.000	1.000
Std Dev.	0.000	0.000
# Replicates	10	10

Replicate No.	Test Completion Date	
	Control	TIWC
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		

Mean	0.000	0.000
Std Dev.		
# Replicates		

T-Test Result  
Deg. of Freedom  
Critical T Value  
Pass or Fail

PASS
------

T-Test Result  
Deg. of Freedom  
Critical T Value  
Pass or Fail

Replicate No.	Test Completion Date	
	Control	TIWC
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		

Mean	0.000	0.000
Std Dev.		
# Replicates		

T-Test Result  
Deg. of Freedom  
Critical T Value  
Pass or Fail

Replicate No.	Test Completion Date	
	Control	TIWC
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		

Mean		
Std Dev.		
# Replicates		

T-Test Result  
Deg. of Freedom  
Critical T Value  
Pass or Fail

## DEP Whole Effluent Toxicity (WET) Analysis Spreadsheet

Type of Test  
Species Tested  
Endpoint  
TIWC (decimal)  
No. Per Replicate  
TST b value  
TST alpha value

Chronic
Ceriodaphnia
Survival
0.1
1
0.75
0.2

Facility Name
Tiadaghton Valley Municipal Authority WWTP
Permit No.
PA00234079

Replicate No.	Test Completion Date	
	Control	TIWC
1	1	1
2	1	1
3	1	1
4	1	1
5	1	1
6	1	1
7	1	1
8	1	1
9	1	1
10	1	1
11		
12		
13		
14		
15		

Mean 1.000 1.000  
Std Dev. 0.000 0.000  
# Replicates 10 10

T-Test Result  
Deg. of Freedom  
Critical T Value  
Pass or Fail **PASS**

Replicate No.	Test Completion Date	
	Control	TIWC
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		

Mean 0.000 0.000  
Std Dev.  
# Replicates

T-Test Result  
Deg. of Freedom  
Critical T Value  
Pass or Fail

Replicate No.	Test Completion Date	
	Control	TIWC
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		

Mean 0.000 0.000  
Std Dev.  
# Replicates

T-Test Result  
Deg. of Freedom  
Critical T Value  
Pass or Fail

Replicate No.	Test Completion Date	
	Control	TIWC
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		

Mean  
Std Dev.  
# Replicates

T-Test Result  
Deg. of Freedom  
Critical T Value  
Pass or Fail

DEP Whole Effluent Toxicity (WET) Analysis Spreadsheet

Type of Test	Chronic
Species Tested	Pimephales
Endpoint	Survival
TIWC (decimal)	0.1
No. Per Replicate	10
TST b value	0.75
TST alpha value	0.25

Facility Name
Tiadaghton Valley Municipal Authority WWTP
Permit No.
PA00234079

Replicate No.	Test Completion Date	
	Control	TIWC
1	9	10
2	10	10
3	9	9
4	9	9
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		

Mean 9.250 9.500  
Std Dev. 0.500 0.577  
# Replicates 4 4

T-Test Result 6.4742  
Deg. of Freedom 5  
Critical T Value 0.7267  
Pass or Fail **PASS**

Replicate No.	Test Completion Date	
	Control	TIWC
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		

Mean 0.000 0.000  
Std Dev.  
# Replicates

T-Test Result  
Deg. of Freedom  
Critical T Value  
Pass or Fail

Replicate No.	Test Completion Date	
	Control	TIWC
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		

Mean 0.000 0.000  
Std Dev.  
# Replicates

T-Test Result  
Deg. of Freedom  
Critical T Value  
Pass or Fail

Replicate No.	Test Completion Date	
	Control	TIWC
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		

Mean  
Std Dev.  
# Replicates

T-Test Result  
Deg. of Freedom  
Critical T Value  
Pass or Fail

## DEP Whole Effluent Toxicity (WET) Analysis Spreadsheet

Type of Test	Chronic
Species Tested	Pimephales
Endpoint	Growth
TIWC (decimal)	0.1
No. Per Replicate	4
TST b value	0.75
TST alpha value	0.25

Facility Name
Tiadaghton Valley Municipal
Authority WWTP
Permit No.
PA00234079

Replicate No.	Test Completion Date	
	Control	TIWC
1	0.605	0.617
2	0.701	0.585
3	0.717	0.516
4	0.645	0.68
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		

Mean 0.667 0.600  
 Std Dev. 0.052 0.068  
 # Replicates 4 4

T-Test Result 2.5305  
 Deg. of Freedom 5  
 Critical T Value 0.7267  
 Pass or Fail 

Replicate No.	Test Completion Date	
	Control	TIWC
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		

Mean 0.000 0.000  
 Std Dev.  
 # Replicates

T-Test Result  
 Deg. of Freedom  
 Critical T Value  
 Pass or Fail

Replicate No.	Test Completion Date	
	Control	TIWC
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		

Mean 0.000 0.000  
 Std Dev.  
 # Replicates

T-Test Result  
 Deg. of Freedom  
 Critical T Value  
 Pass or Fail

Replicate No.	Test Completion Date	
	Control	TIWC
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		

Mean  
 Std Dev.  
 # Replicates

T-Test Result  
 Deg. of Freedom  
 Critical T Value  
 Pass or Fail

**WET Summary and Evaluation**

Facility Name  
Permit No.  
Design Flow (MGD)  
Q<sub>7-10</sub> Flow (cfs)  
PMF<sub>a</sub>  
PMF<sub>c</sub>

Tiadaghton Valley Municipal Authority WWTP
PA00234079

Species	Endpoint	Test Results (Pass/Fail)			
		Test Date	Test Date	Test Date	Test Date
Ceriodaphnia	Survival	PASS			

Species	Endpoint	Test Results (Pass/Fail)			
		Test Date	Test Date	Test Date	Test Date
Ceriodaphnia	Reproduction	PASS			

Species	Endpoint	Test Results (Pass/Fail)			
		Test Date	Test Date	Test Date	Test Date
Pimephales	Survival	PASS			

Species	Endpoint	Test Results (Pass/Fail)			
		Test Date	Test Date	Test Date	Test Date
Pimephales	Growth	PASS			

Reasonable Potential? NO

**Permit Recommendations**

Test Type  
TIWC  
Dilution Series , , , , % Effluent  
Permit Limit  
Permit Limit Species

DEP Whole Effluent Toxicity (WET) Analysis Spreadsheet					
<b>Type of Test</b> Chronic <b>Species Tested</b> Ceriodaphnia <b>Endpoint</b> Survival <b>TIWC (decimal)</b> 0.01 <b>No. Per Replicate</b> 1 <b>TST b value</b> 0.75 <b>TST alpha value</b> 0.2			<b>Facility Name</b> Tiadaghton Valley Municipal Authority WWTP  <b>Permit No.</b> PA00234079		
<b>Test Completion Date</b> Replicate No. Control TIWC 1 1 1 2 1 1 3 1 1 4 1 1 5 1 1 6 1 1 7 1 1 8 1 1 9 1 1 10 1 1 11 12 13 14 15			<b>Test Completion Date</b> Replicate No. Control TIWC 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15		
Mean 1.000 1.000 Std Dev. 0.000 0.000 # Replicates 10 10			Mean 0.000 0.000 Std Dev. # Replicates		
T-Test Result Deg. of Freedom Critical T Value Pass or Fail <b>PASS</b>			T-Test Result Deg. of Freedom Critical T Value Pass or Fail		
<b>Test Completion Date</b> Replicate No. Control TIWC 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15			<b>Test Completion Date</b> Replicate No. Control TIWC 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15		
Mean 0.000 0.000 Std Dev. # Replicates			Mean Std Dev. # Replicates		
T-Test Result Deg. of Freedom Critical T Value Pass or Fail			T-Test Result Deg. of Freedom Critical T Value Pass or Fail		

DEP Whole Effluent Toxicity (WET) Analysis Spreadsheet					
Type of Test	Chronic		Facility Name		
Species Tested	Ceriodaphnia		Tiadaghton Valley Municipal		
Endpoint	Reproduction		Authority WWTP		
TIWC (decimal)	0.01		Permit No.		
No. Per Replicate	1		PA00234079		
TST b value	0.75				
TST alpha value	0.2				
Test Completion Date					
Replicate No.	6/17/2020		Replicate No.	Test Completion Date	
1	Control	TIWC	1		
2	22	25	2		
3	14	23	3		
4	19	17	4		
5	26	28	5		
6	25	24	6		
7	17	26	7		
8	27	25	8		
9	23	27	9		
10	22	23	10		
11	26	25	11		
12			12		
13			13		
14			14		
15			15		
Mean	22.100	24.300	Mean	0.000	0.000
Std Dev.	4.280	3.020	Std Dev.		
# Replicates	10	10	# Replicates		
T-Test Result	5.5422		T-Test Result		
Deg. of Freedom	17		Deg. of Freedom		
Critical T Value	0.8633		Critical T Value		
Pass or Fail	PASS		Pass or Fail		
Test Completion Date					
Replicate No.	6/17/2020		Replicate No.	Test Completion Date	
1	Control	TIWC	1		
2			2		
3			3		
4			4		
5			5		
6			6		
7			7		
8			8		
9			9		
10			10		
11			11		
12			12		
13			13		
14			14		
15			15		
Mean	0.000	0.000	Mean	0.000	0.000
Std Dev.			Std Dev.		
# Replicates			# Replicates		
T-Test Result			T-Test Result		
Deg. of Freedom			Deg. of Freedom		
Critical T Value			Critical T Value		
Pass or Fail			Pass or Fail		

DEP Whole Effluent Toxicity (WET) Analysis Spreadsheet					
Type of Test	Chronic		Facility Name		
Species Tested	Pimephales		Tiadaghton Valley Municipal		
Endpoint	Survival		Authority WWTP		
TIWC (decimal)	0.01		Permit No.		
No. Per Replicate	10		PA00234079		
TST b value	0.75				
TST alpha value	0.25				
Test Completion Date					
Replicate	6/18/2020		Replicate	Test Completion Date	
No.	Control	TIWC	No.	Control	TIWC
1	10	7	1		
2	9	10	2		
3	10	10	3		
4	9	10	4		
5			5		
6			6		
7			7		
8			8		
9			9		
10			10		
11			11		
12			12		
13			13		
14			14		
15			15		
Mean	9.500	9.250	Mean	0.000	0.000
Std Dev.	0.577	1.500	Std Dev.		
# Replicates	4	4	# Replicates		
T-Test Result	2.7836		T-Test Result		
Deg. of Freedom	4		Deg. of Freedom		
Critical T Value	0.7407		Critical T Value		
Pass or Fail	PASS		Pass or Fail		
Test Completion Date					
Replicate	6/18/2020		Replicate	Test Completion Date	
No.	Control	TIWC	No.	Control	TIWC
1			1		
2			2		
3			3		
4			4		
5			5		
6			6		
7			7		
8			8		
9			9		
10			10		
11			11		
12			12		
13			13		
14			14		
15			15		
Mean	0.000	0.000	Mean		
Std Dev.			Std Dev.		
# Replicates			# Replicates		
T-Test Result			T-Test Result		
Deg. of Freedom			Deg. of Freedom		
Critical T Value			Critical T Value		
Pass or Fail			Pass or Fail		

DEP Whole Effluent Toxicity (WET) Analysis Spreadsheet					
Type of Test		Chronic		Facility Name	
Species Tested		Pimephales		Tiadaghton Valley Municipal	
Endpoint		Growth		Authority WWTP	
TIWC (decimal)		0.01		Permit No.	
No. Per Replicate		10		PA00234079	
TST b value		0.75			
TST alpha value		0.25			
Test Completion Date					
Replicate No.	6/18/2020		Replicate No.	Test Completion Date	
	Control	TIWC		Control	TIWC
1	5.35	4.64	1		
2	5.94	6.16	2		
3	4.48	4.46	3		
4	5.29	4.36	4		
5			5		
6			6		
7			7		
8			8		
9			9		
10			10		
11			11		
12			12		
13			13		
14			14		
15			15		
Mean	5.265	4.905	Mean	0.000	0.000
Std Dev.	0.600	0.845	Std Dev.		
# Replicates	4	4	# Replicates		
T-Test Result	1.9984		T-Test Result		
Deg. of Freedom	5		Deg. of Freedom		
Critical T Value	0.7267		Critical T Value		
Pass or Fail	PASS		Pass or Fail		
Test Completion Date					
Replicate No.	6/18/2020		Replicate No.	Test Completion Date	
	Control	TIWC		Control	TIWC
1			1		
2			2		
3			3		
4			4		
5			5		
6			6		
7			7		
8			8		
9			9		
10			10		
11			11		
12			12		
13			13		
14			14		
15			15		
Mean	0.000	0.000	Mean		
Std Dev.			Std Dev.		
# Replicates			# Replicates		
T-Test Result			T-Test Result		
Deg. of Freedom			Deg. of Freedom		
Critical T Value			Critical T Value		
Pass or Fail			Pass or Fail		

**WET Summary and Evaluation**

Facility Name	Tiadaghton Valley Municipal Authority WWTP
Permit No.	PA00234079
Design Flow (MGD)	
Q <sub>7-10</sub> Flow (cfs)	
PMF <sub>a</sub>	
PMF <sub>c</sub>	

Species	Endpoint	Test Results (Pass/Fail)			
		Test Date	Test Date	Test Date	Test Date
		6/21/21			
Ceriodaphnia	Survival	PASS			

Species	Endpoint	Test Results (Pass/Fail)			
		Test Date	Test Date	Test Date	Test Date
		6/21/21			
Ceriodaphnia	Reproduction	PASS			

Species	Endpoint	Test Results (Pass/Fail)			
		Test Date	Test Date	Test Date	Test Date
		6/22/21			
Pimephales	Survival	PASS			

Species	Endpoint	Test Results (Pass/Fail)			
		Test Date	Test Date	Test Date	Test Date
		6/22/21			
Pimephales	Growth	PASS			

Reasonable Potential? NO

**Permit Recommendations**

Test Type

TIWC % Effluent

Dilution Series , , , , % Effluent

Permit Limit

Permit Limit Species

## DEP Whole Effluent Toxicity (WET) Analysis Spreadsheet

Type of Test	Chronic
Species Tested	Ceriodaphnia
Endpoint	Survival
TIWC (decimal)	0.01
No. Per Replicate	1
TST b value	0.75
TST alpha value	0.2

Facility Name
Tiadaghton Valley Municipal
Authority WWTP
Permit No.
PA0234079

Replicate No.	Test Completion Date	
	Control	TIWC
1	1	1
2	1	1
3	1	1
4	1	1
5	1	1
6	1	1
7	1	1
8	1	1
9	1	1
10	1	1
11		
12		
13		
14		
15		

Mean 1.000 1.000  
 Std Dev. 0.000 0.000  
 # Replicates 10 10

Replicate No.	Test Completion Date	
	Control	TIWC
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		

Mean 0.000 0.000  
 Std Dev.  
 # Replicates

T-Test Result  
 Deg. of Freedom  
 Critical T Value  
 Pass or Fail **PASS**

T-Test Result  
 Deg. of Freedom  
 Critical T Value  
 Pass or Fail

Replicate No.	Test Completion Date	
	Control	TIWC
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		

Mean 0.000 0.000  
 Std Dev.  
 # Replicates

Replicate No.	Test Completion Date	
	Control	TIWC
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		

Mean  
 Std Dev.  
 # Replicates

T-Test Result  
 Deg. of Freedom  
 Critical T Value  
 Pass or Fail

T-Test Result  
 Deg. of Freedom  
 Critical T Value  
 Pass or Fail

DEP Whole Effluent Toxicity (WET) Analysis Spreadsheet

Type of Test	Chronic
Species Tested	Ceriodaphnia
Endpoint	Reproduction
TIWC (decimal)	0.01
No. Per Replicate	1
TST b value	0.75
TST alpha value	0.2

Facility Name

Tiadaghton Valley Municipal Authority WWTP

Permit No.

PA00234079

Test Completion Date

Replicate No.	6/21/2021	
	Control	TIWC
1	21	42
2	40	40
3	40	38
4	19	36
5	40	49
6	48	42
7	40	40
8	44	44
9	40	43
10	46	39
11		
12		
13		
14		
15		

Mean 37.800 41.300

Std Dev. 9.830 3.622

# Replicates 10 10

Test Completion Date

Replicate No.		
	Control	TIWC
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		

Mean 0.000 0.000

Std Dev.

# Replicates

T-Test Result 4.9855

Deg. of Freedom 17

Critical T Value 0.8633

Pass or Fail PASS

T-Test Result

Deg. of Freedom

Critical T Value

Pass or Fail

Test Completion Date

Replicate No.		
	Control	TIWC
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		

Mean 0.000 0.000

Std Dev.

# Replicates

Test Completion Date

Replicate No.		
	Control	TIWC
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		

Mean

Std Dev.

# Replicates

T-Test Result

Deg. of Freedom

Critical T Value

Pass or Fail

T-Test Result

Deg. of Freedom

Critical T Value

Pass or Fail

## DEP Whole Effluent Toxicity (WET) Analysis Spreadsheet

Type of Test Chronic  
 Species Tested Pimephales  
 Endpoint Survival  
 TIWC (decimal) 0.01  
 No. Per Replicate 10  
 TST b value 0.75  
 TST alpha value 0.25

## Facility Name

Tiadaghton Valley Municipal Authority WWTP

## Permit No.

PA00234079

## Test Completion Date

Replicate No.	6/22/2021	
	Control	TIWC
1	10	10
2	9	10
3	10	10
4	10	10
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		

Mean 9.750 10.000

Std Dev. 0.500 0.000

# Replicates 4 4

T-Test Result 12.5523

Deg. of Freedom 3

Critical T Value 0.7649

Pass or Fail PASS

## Test Completion Date

Replicate No.		
	Control	TIWC
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		

Mean 0.000 0.000

Std Dev.

# Replicates

T-Test Result

Deg. of Freedom

Critical T Value

Pass or Fail

## Test Completion Date

Replicate No.		
	Control	TIWC
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		

Mean 0.000 0.000

Std Dev.

# Replicates

## Test Completion Date

Replicate No.		
	Control	TIWC
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		

Mean

Std Dev.

# Replicates

T-Test Result

Deg. of Freedom

Critical T Value

Pass or Fail

T-Test Result

Deg. of Freedom

Critical T Value

Pass or Fail

## DEP Whole Effluent Toxicity (WET) Analysis Spreadsheet

Type of Test      Chronic  
 Species Tested    Pimephales  
 Endpoint           Growth  
 TIWC (decimal)   0.01  
 No. Per Replicate 10  
 TST b value       0.75  
 TST alpha value   0.25

Facility Name  
 Tiadaghton Valley Municipal  
 Authority WWTP

Permit No.  
 PA00234079

Test Completion Date  
 Replicate      6/22/2021

Replicate No.	Control	TIWC
1	0.391	0.473
2	0.46	0.423
3	0.384	0.42
4	0.532	0.457
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		

Mean            0.442            0.443  
 Std Dev.       0.069            0.026  
 # Replicates   4                4

Test Completion Date  
 Replicate      6/22/2021

Replicate No.	Control	TIWC
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		

Mean            0.000            0.000  
 Std Dev.       0.000            0.000  
 # Replicates   0                0

T-Test Result    3.8549  
 Deg. of Freedom   5  
 Critical T Value   0.7267  
 Pass or Fail      PASS

T-Test Result  
 Deg. of Freedom  
 Critical T Value  
 Pass or Fail

Test Completion Date  
 Replicate      6/22/2021

Replicate No.	Control	TIWC
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		

Mean            0.000            0.000  
 Std Dev.       0.000            0.000  
 # Replicates   0                0

Test Completion Date  
 Replicate      6/22/2021

Replicate No.	Control	TIWC
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		

Mean            0.000            0.000  
 Std Dev.       0.000            0.000  
 # Replicates   0                0

T-Test Result  
 Deg. of Freedom  
 Critical T Value  
 Pass or Fail

T-Test Result  
 Deg. of Freedom  
 Critical T Value  
 Pass or Fail

**WET Summary and Evaluation**

Facility Name	Tiadaghton Valley Municipal Authority
Permit No.	PA0234079
Design Flow (MGD)	
Q <sub>7-10</sub> Flow (cfs)	
PMF <sub>a</sub>	
PMF <sub>c</sub>	

Species	Endpoint	Test Results (Pass/Fail)			
		Test Date	Test Date	Test Date	Test Date
Pimephales	Survival	PASS			

Species	Endpoint	Test Results (Pass/Fail)			
		Test Date	Test Date	Test Date	Test Date
Pimephales	Growth	PASS			

Species	Endpoint	Test Results (Pass/Fail)			
		Test Date	Test Date	Test Date	Test Date
Ceriodaphnia	Survival	PASS			

Species	Endpoint	Test Results (Pass/Fail)			
		Test Date	Test Date	Test Date	Test Date
Ceriodaphnia	Reproduction	PASS			

Reasonable Potential? NO

**Permit Recommendations**

Test Type

TIWC % Effluent

Dilution Series , , , , % Effluent

Permit Limit

Permit Limit Species

NPDES Permit Fact Sheet  
Tiadaghton Valley Municipal Authority WWTP

NPDES Permit No. PA0234079

DEP Whole Effluent Toxicity (WET) Analysis Spreadsheet

Type of Test Chronic  
Species Tested Pimephales  
Endpoint Survival  
TIWC (decimal) 1  
No. Per Replicate 10  
TST b value 0.75  
TST alpha value 0.25

Facility Name  
Tiadaghton Valley Municipal Authority  
Permit No.  
PA0234079

Replicate No.	Test Completion Date	
	Control	TIWC
1	8	8
2	9	7
3	9	9
4	8	7
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		

Mean 8.500  
Std Dev. 0.577  
# Replicates 4

Replicate No.	Test Completion Date	
	Control	TIWC
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		

Mean 0.000  
Std Dev.  
# Replicates

T-Test Result 2.9342  
Deg. of Freedom 4  
Critical T Value 0.7407  
Pass or Fail **PASS**

T-Test Result  
Deg. of Freedom  
Critical T Value  
Pass or Fail

Replicate No.	Test Completion Date	
	Control	TIWC
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		

Mean 0.000  
Std Dev.  
# Replicates

Replicate No.	Test Completion Date	
	Control	TIWC
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		

Mean 0.000  
Std Dev.  
# Replicates

T-Test Result  
Deg. of Freedom  
Critical T Value  
Pass or Fail

T-Test Result  
Deg. of Freedom  
Critical T Value  
Pass or Fail

## DEP Whole Effluent Toxicity (WET) Analysis Spreadsheet

Type of Test	Chronic
Species Tested	Pimephales
Endpoint	Growth
TIWC (decimal)	1
No. Per Replicate	10
TST b value	0.75
TST alpha value	0.25

Facility Name
Tiadaghton Valley Municipal
Authority
Permit No.
PA0234079

Replicate No.	Test Completion Date	
	Control	TIWC
1	0.504	0.544
2	0.541	0.47
3	0.588	0.476
4	0.393	0.457
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		

Mean 0.507 0.487  
 Std Dev. 0.083 0.039  
 # Replicates 4 4

Replicate No.	Test Completion Date	
	Control	TIWC
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		

Mean 0.000 0.000  
 Std Dev.  
 # Replicates

T-Test Result 2.9075  
 Deg. of Freedom 5  
 Critical T Value 0.7267  
 Pass or Fail **PASS**

T-Test Result  
 Deg. of Freedom  
 Critical T Value  
 Pass or Fail

Replicate No.	Test Completion Date	
	Control	TIWC
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		

Mean 0.000 0.000  
 Std Dev.  
 # Replicates

Replicate No.	Test Completion Date	
	Control	TIWC
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		

T-Test Result  
 Deg. of Freedom  
 Critical T Value  
 Pass or Fail

T-Test Result  
 Deg. of Freedom  
 Critical T Value  
 Pass or Fail

# **APPENDIX F**

## eDMR DATA (METALS)

## NPDES Permit Fact Sheet

# Tiadaghton Valley Municipal Authority WWTP

NPDES Permit No. PA0234079