

Application Type Renewal  
Wastewater Type Sewage  
Facility Type SRSTP

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SFTF/SRSTP**

Application No. PA0238431  
APS ID 1071024  
Authorization ID 1409849

**Applicant, Facility and Project Information**



Applicant Name	<u>Charles A Betts</u>	Facility Name	<u>Charles A Betts SRSTP</u>
Applicant Address	<u>1800 Weiler Road</u> <u>Warren, PA 16365-8514</u>	Facility Address	<u>1800 Weiler Road</u> <u>Warren, PA 16365</u>
Applicant Contact	<u>Charles Betts</u>	Facility Contact	<u>Charles Betts</u>
Applicant Phone	<u>(814) 726-3638</u>	Facility Phone	<u>(814) 726-3638</u>
Applicant E Mail	<u>chadb@bettsind.com</u>	Facility E Mail	<u></u>
Client ID	<u>146493</u>	Site ID	<u>535835</u>
Municipality	<u>Conewango Township</u>	County	<u>Warren</u>
SIC Code	<u>8800</u>	SIC Code	<u>4952</u>
SIC Description	<u>Private Households</u>	SIC Description	<u>Trans. &amp; Utilities - Sewerage Systems</u>
Date Application Received	<u>September 9, 2022</u>	WQM Required	<u>Present permit is adequate</u>
Date Application Accepted	<u>September 21, 2022</u>	WQM App. No.	<u></u>
Project Description	<u>NPDES renewal</u>		

**Summary of Review**

No violations on file. Septage pumped on July 7, 2022 and May 7, 2020.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
		<i>William H. Mentzer</i> William H. Mentzer, P.E. Environmental Engineering Specialist	September 21, 2022
		Vacant Environmental Engineer Manager	Okay to Draft JCD 9/26/2022



Discharge and Stream Data – 2 - Receiving Waters and PWS

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.0004</u>
Latitude DP	<u>41° 51' 57.20"</u>	Longitude DP	<u>-79° 12' 43.90"</u>
Latitude NHD	<u>41° 51' 56.55"</u>	Longitude NHD	<u>-79° 12' 59.06"</u>
Quad Name	<u>Warren</u>	Quad Code	<u>0412</u>
Wastewater Description: <u>Treated single residence domestic wastes</u>			
Receiving Waters	<u>Unnamed tributary to Morse Run</u>	Stream Code	<u>unknown</u>
NHD Com ID	<u>112374555</u>	RMI	<u>0.23</u>
Drainage Area	<u>102.5 acres 0.16 square mile</u>	Yield (cfs/mi <sup>2</sup> )	<u>0</u>
Q <sub>7-10</sub> Flow (cfs)	<u>0</u>	Q <sub>7-10</sub> Basis	<u>Dry stream</u>
Elevation (ft)	<u>1560.00</u>	Slope (ft/ft)	<u></u>
Watershed No.	<u>16-B</u>	Chapter 93 Class.	<u>HQ-CWF</u>
Existing Use	<u>statewide</u>	Existing Use Qualifier	<u>none</u>
Exceptions to Use	<u>none</u>	Exceptions to Criteria	<u>none</u>
Comments	<u>Drainage swale discharge to Morse Run RMI 2.12 and 1.07 mile above an unnamed stream.</u>		
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u></u>		
Source(s) of Impairment	<u></u>		
TMDL Status	<u></u>	Name	<u></u>
Background/Ambient Data		Data Source	
pH (SU)	<u></u>		<u></u>
Temperature (°F)	<u></u>		<u></u>
Hardness (mg/L)	<u></u>		<u></u>
Other:	<u></u>		<u></u>
Nearest Downstream Public Water Supply Intake	<u>Aqua Pa Emlenton</u>		
PWS Waters	<u>Allegheny River</u>	Flow at Intake (cfs)	<u></u>
PWS RMI	<u>90.57</u>	Distance from Outfall (mi)	<u>72</u>

Changes Since Last Permit Issuance: None

Other Comments: Because of the HQ stream classification water supply criteria are evaluated at the discharge.

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Annual Average	Maximum	Instant. Maximum		
Flow (GPD)	Report Annl Avg	XXX	XXX	XXX	XXX	XXX	1/year	Estimate
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/month	Grab
TRC	XXX	XXX	XXX	0.5 Avg Mo	XXX	1.6	1/month	Grab
BOD5	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
TSS	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
Fecal Coliform (No./100 ml)	XXX	XXX	XXX	200	XXX	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001 after disinfection