

Application Type Renewal
Facility Type Non-Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0238571
APS ID 1000399
Authorization ID 1285568

Applicant and Facility Information

Applicant Name	<u>Jones Estates Pinehurst Manor PA, LLC</u>	Facility Name	<u>Pinehurst Manor MHP</u>
Applicant Address	<u>PO Box 14466</u> <u>Durham, NC 27709</u>	Facility Address	<u>112 Jan Drive</u> <u>Butler, PA 16001</u>
Applicant Contact	<u>Kellen Buss, Director of Site Infrastructure</u>	Facility Contact	<u>David Bocci, Operator</u>
Applicant Phone	<u>(419) 357-9091</u>	Facility Phone	<u>(724) 712-3219</u>
Client ID	<u>366008</u>	Site ID	<u>451618</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Center Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Butler County</u>
Date Application Received	<u>August 9, 2019</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>August 28, 2019</u>	If No, Reason	<u>-</u>

Renewal of an NPDES Permit for an existing discharge of treated sanitary wastewater. Ownership is being transferred from Rhett Walls to the Jones Estates Pinehurst Manor PA, LLC.

Purpose of Application This application was published in the PA Bulletin under the previous owner on June 12, 2021. The 30-day comment period ended on July 13, 2021.

Summary of Review

Act 14 - Proof of Notification was submitted and received.

A Part II Water Quality Management permit is not required at this time.

The Permittee should be able to continue to meet the limits of this permit, which will continue to protect the uses of the receiving stream.

I. OTHER REQUIREMENTS:

- A. Stormwater into sewers
- B. Right of way
- C. Solids handling
- D. Public sewerage availability
- E. Little or no assimilative capacity or dilution

SPECIAL CONDITIONS:

- II. Solids Management

There are no open violations in efacts for Client ID 366008 as of 12/13/2021.

Approve	Deny	Signatures	Date
X		Stephen A. McCauley Stephen A. McCauley, E.I.T. / Environmental Engineering Specialist	12/8/2021
X		Justin C. Dickey Justin C. Dickey, P.E. / Environmental Engineer Manager	12/14/2021

Discharge, Receiving Waters and Water Supply Information

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.014</u>
Latitude	<u>40° 56' 48.10"</u>	Longitude	<u>-79° 56' 58.29"</u>
Quad Name	<u>-</u>	Quad Code	<u>-</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Unnamed Tributary to the Stony Run (WWF)</u>	Stream Code	<u>N/A</u>
NHD Com ID	<u>126221009</u>	RMI	<u>N/A</u>
Drainage Area	<u>0.06</u>	Yield (cfs/mi ²)	<u>0.047 (Buffalo Cr. 1976-1996)</u>
Q ₇₋₁₀ Flow (cfs)	<u>0.0028</u>	Q ₇₋₁₀ Basis	<u>calculated</u>
Elevation (ft)	<u>1260</u>	Slope (ft/ft)	<u>0.02228</u>
Watershed No.	<u>20-C</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u>-</u>	Existing Use Qualifier	<u>-</u>
Exceptions to Use	<u>-</u>	Exceptions to Criteria	<u>-</u>
Assessment Status	<u>Impaired*</u>		
Cause(s) of Impairment	<u>Metals</u>		
Source(s) of Impairment	<u>Acid Mine Drainage</u>		
TMDL Status	<u>Pending</u>	Name	<u>-</u>
Background/Ambient Data		Data Source	
pH (SU)	<u>-</u>		<u>-</u>
Temperature (°F)	<u>-</u>		<u>-</u>
Hardness (mg/L)	<u>-</u>		<u>-</u>
Other:	<u>-</u>		<u>-</u>
Nearest Downstream Public Water Supply Intake	<u>Beaver Falls Municipal Authority</u>		
PWS Waters	<u>Beaver River</u>	Flow at Intake (cfs)	<u>561</u>
PWS RMI	<u>3.5</u>	Distance from Outfall (mi)	<u>49.0</u>

* - This facility is not expected to discharge Aluminum, Iron, and Manganese in any significant quantities. However, per the previous renewal, which was based on the SOP, monitoring for Aluminum, Iron, and Manganese will be retained.

Sludge use and disposal description and location(s): Sludge is not used, it is disposed of at a certified landfill.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Narrative: This Fact Sheet details the determination of draft NPDES permit limits for an existing discharge of 0.014 MGD of treated sewage from an existing non-municipal STP serving a MHP in Center Township, Butler County.

Permitted treatment consists of: A 9,760 gallon aerated equalization tank with dual grinder pumps, two 11,387 gallon Sequential Batch Reactor (SBR) tanks in parallel, a 4,880 aerated sludge thickening/holding tank, a 4,880 gallon aerated effluent pump tank, and ultraviolet (UV) light disinfection.

1. Streamflow:

The yieldrate for the receiving stream at Outfall 001 was calculated from the nearest gage station details:

Buffalo Creek at Freeport, PA (1976-1996):	Q ₇₋₁₀ :	<u>6.37</u>	cfs	(from StreamStats)
<u>(USGS Gage 03049000)</u>	Drainage Area:	<u>137</u>	sq. mi.	(from StreamStats)
	Yieldrate:	<u>0.047</u>	cfsm	calculated
<u>Unnamed Tributary to the</u>	Yieldrate:	<u>0.047</u>	cfsm	(calculated above)
<u>Stoney Run at Outfall 001:</u>	Drainage Area:	<u>0.06</u>	sq. mi.	(from StreamStats)
	Q ₇₋₁₀ :	<u>0.0028</u>	cfs	calculated

2. Wasteflow: Outfall 001

Maximum discharge: 0.014 MGD = 0.021 cfs

Runoff flow period: 24 hours Basis: STP with flow equalization

There is less than 3 parts stream flow (Q7-10) to 1 part effluent (design flow) at the discharge point. However, since this is an existing discharge, the more stringent treatment requirements cannot be achieved, and the receiving stream is not impaired by the discharge, the treatment requirements in document number 391-2000-014, titled, "Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers", dated April 12, 2008, will not be implemented in this NPDES Permit.

3. Parameters:

The following parameters were evaluated: pH, Total Suspended Solids, Fecal Coliform, Phosphorus, NH₃-N, CBOD₅, Dissolved Oxygen, and Total Residual Chlorine. NH₃-N, CBOD₅, and Dissolved Oxygen were evaluated using WQM 7.0 at the discharge point.

NO₂-NO₃, Fluoride, Phenolics, Sulfates, and Chlorides can be evaluated using PentoxSD at the nearest downstream potable water supply (PWS). Since there is significant dilution available, no modeling was performed for this facility.

a. pH

Between 6.0 and 9.0 at all times

Basis: Application of Chapter 93.7 technology-based limits. The measurement frequency was increased from 1/week to 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001).

b. Total Suspended Solids

Limits are 30 mg/l as a monthly average and 60 as a daily maximum.

Basis: Application of Chapter 92a47 technology-based limits

c. Fecal Coliform

05/01 - 09/30: 200/100ml (monthly average geometric mean)
1,000/100ml (instantaneous maximum)

10/01 - 04/30: 2,000/100ml (monthly average geometric mean)
10,000/100ml (instantaneous maximum)

Basis: Application of Chapter 92a47 technology-based limits.

d. E. Coli

Monitoring was added for E. Coli at a frequency of 1/year.

Basis: Application of Chapter 92a.61 as recommended by the SOP for flows between 0.002 MGD and 0.05 MGD.

e. Phosphorus

Limit not necessary

Basis: N/A

Limit necessary due to:

- Discharge to a lake, pond, or impoundment
- Discharge to a stream
- Discharge to a dry stream

Basis: The previous Phosphorus limit of 2.0 mg/l will be retained based on Chapter 96.5 due to the discharge flowing downstream to the Connoquenessing Creek, which is impaired for nutrients.

f. Total Nitrogen

Limit not necessary

Basis: The previous monitoring for Total Nitrogen will be retained in accordance with the SOP, based on Chapter 92a.61.

Limit necessary due to:

- Discharge to a lake, pond, or impoundment
- Discharge to a stream
- Discharge to a dry stream

Basis: N/A

g. NO₂-NO₃, Fluoride, Phenolics, Sulfates, and Chlorides

Nearest Downstream potable water supply (PWS): Beaver Falls Municipal Authority

Distance downstream from the point of discharge: 49.0 miles (approximate)

- No limits necessary
- Limits needed

Basis: Significant dilution available.

h. Ammonia-Nitrogen (NH₃-N)

Median discharge pH to be used: 6.5 Standard Units (S.U.)

Basis: Average pH value from DMR summary

Discharge temperature: 25°C (default value used in the absence of data)

Median stream pH to be used: 7.0 Standard Units (S.U.)

Basis: Default value used in the absence of data

Stream Temperature: 25°C (default value used for WWF modeling)

Background NH₃-N concentration: 0.1 mg/l

Basis: Default value used in the absence of data

calculated summer NH₃-N limits: 2.0 mg/l (monthly average)

4.0 mg/l (instantaneous maximum)

calculated winter NH₃-N limits: 6.0 mg/l (monthly average)

12.0 mg/l (instantaneous maximum)

Result: WQ modeling resulted in the calculated summer limits above (see Attachment 1), which are more restrictive than in the previous NPDES Permit. The winter limits are calculated as three times the summer limits. However, since the previous NH₃-N limits of 1.5 mg/l monthly average (summer) and 4.5 mg/l monthly average (winter) are attainable, they will be retained with this renewal.

i. CBOD₅

Median discharge pH to be used: 6.5 Standard Units (S.U.)

Basis: Average pH value from DMR summary

Discharge temperature: 25°C (default value used in the absence of data)

Median stream pH to be used: 7.0 Standard Units (S.U.)

Basis: Default value used in the absence of data

Stream Temperature: 25°C (default value used for WWF modeling)

Background CBOD₅ concentration: 2.0 mg/l

Basis: Default value used in the absence of data

calculated summer CBOD₅ limits: 25.0 mg/l (monthly average)

50.0 mg/l (instantaneous maximum)

calculated winter CBOD₅ limits: 25.0 mg/l (monthly average)

50.0 mg/l (instantaneous maximum)

Result: WQ modeling resulted in the calculated summer limits above (see Attachment 1), which are the same as the previous NPDES Permit. The winter limits are calculated as three times the summer limits, but since the technology-based limits are more protective, they will be used. Since the summer limits and the winter limits are the same, the limits for CBOD₅ will be set year-round as in the previous NPDES Permit.

j. Dissolved Oxygen (DO)

4.0 mg/l - minimum desired in effluent to protect all aquatic life.

5.0 mg/l - desired in effluent for CWF, WWF, or TSF.

6.0 mg/l - minimum required due to discharge going to a drainage swale or ditch.

8.0 mg/l - required due to discharge going to a naturally reproducing salmonid stream

Compliance History

DMR Data for Outfall 001 (from November 1, 2020 to October 31, 2021)

Parameter	OCT-21	SEP-21	AUG-21	JUL-21	JUN-21	MAY-21	APR-21	MAR-21	FEB-21	JAN-21	DEC-20	NOV-20
Flow (MGD) Average Monthly	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002
Flow (MGD) Daily Maximum	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.003	0.003	0.003	0.003	0.003
pH (S.U.) Minimum	6.5	6.5	6.0	6.5	6.5	6.0	6.5	6.5	6.5	6.0	6.0	6.0
pH (S.U.) Maximum	7.0	7.0	7.0	7.0	7.5	7.0	7.5	7.0	7.0	7.5	7.5	7.0
DO (mg/L) Minimum	5.4	5.5	5.8	5.6	5.6	5.7	5.7	6.0	5.7	5.5	6.3	5.5
CBOD5 (mg/L) Average Monthly	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.7	3.3	3.0
TSS (mg/L) Average Monthly	3.0	5.0	3.0	3.0	3.0	4.5	3.0	3.0	7.5	8.5	5.0	5.5
Fecal Coliform (CFU/100 ml) Geometric Mean	135	33	113	2	11	10	2	3	19	257	1253	43
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	262	102	388	2	19	16	4	4	34	326	2420	613
UV Intensity (µw/cm ²) Average Monthly	4200	4200	4200	4200	4200	4200	4200	4200	4200	4200	4200	4200
Total Nitrogen (mg/L) Average Monthly	49.1	4.0	41.9	31.2	48.0	40.7	41.9	35.4	47.4	45.6	27.9	40.9
Ammonia (mg/L) Average Monthly	0.2	0.4	0.3	0.5	0.7	0.2	0.3	0.2	0.4	0.3	0.3	0.2
Total Phosphorus (mg/L) Average Monthly	2.2	2.0	1.0	0.9	1.5	1.7	2.2	1.9	1.0	2.1	2.4	2.0
Total Aluminum (mg/L) Average Monthly											0.70	
Total Iron (mg/L) Average Monthly											0.07	
Total Manganese (mg/L) Average Monthly											0.02	

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0 Inst Min	XXX	XXX	XXX	1/day	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	30.0	XXX	60	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
UV Intensity (µw/cm ²)	XXX	XXX	XXX	Report	XXX	XXX	1/day	Measured
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Ammonia-Nitrogen Nov 1 - Apr 30	XXX	XXX	XXX	4.5	XXX	9	2/month	8-Hr Composite
Ammonia-Nitrogen May 1 - Oct 31	XXX	XXX	XXX	1.5	XXX	3	2/month	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	2.0	XXX	4	2/month	8-Hr Composite
Total Aluminum	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	8-Hr Composite

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Total Iron	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	8-Hr Composite
Total Manganese	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	8-Hr Composite

Compliance Sampling Location: at Outfall 001, after Ultraviolet (UV) light disinfection.

Flow, UV intensity, and Total Nitrogen are monitor only based on Chapter 92a.61. The limits for pH are technology-based on Chapter 93.7. The limits for CBOD₅, Total Suspended Solids, Dissolved Oxygen, and Fecal Coliform are technology based on Chapter 92a.47. The limits for Ammonia-Nitrogen are water quality-based on Chapter 93.7. The Total Phosphorus limit is technology-based on Chapter 96.5. Monitoring for E. Coli, Total Aluminum, Total Iron, and Total Manganese is based on Chapter 92a.61.

Attachment 1

WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>				
20C		35275	STONY RUN				
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
0.680	Pinehurst Manor	PA0238571	0.014	CBOD5	25		
				NH3-N	2.06	4.12	
				Dissolved Oxygen			5

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>	
20C	35275	STONY RUN	
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>
0.680	0.014	25.000	6.536
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>
1.434	0.309	4.647	0.055
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>
22.35	1.466	1.82	1.029
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>
5.374	30.922	Owens	5
<u>Reach Travel Time (days)</u>	Subreach Results		
0.751	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>
			<u>D.O. (mg/L)</u>
	0.075	19.46	1.69
	0.150	16.94	1.56
	0.225	14.75	1.45
	0.301	12.84	1.34
	0.376	11.18	1.24
	0.451	9.73	1.15
	0.526	8.47	1.06
	0.601	7.37	0.98
	0.676	6.42	0.91
	0.751	5.59	0.84

WQM 7.0 Wasteload Allocations

SWP Basin Stream Code Stream Name
20C 35275 STONY RUN

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.680	Pinehurst Manor	8.32	9.01	8.32	9.01	1	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.680	Pinehurst Manor	1.75	2.06	1.75	2.06	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
0.68	Pinehurst Manor	25	25	2.06	2.06	5	5	0	0

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
20C		35275				STONY RUN						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow												
0.680	0.00	0.00	0.00	.0217	0.02228	.309	1.43	4.65	0.06	0.751	25.00	6.54
Q1-10 Flow												
0.680	0.00	0.00	0.00	.0217	0.02228	NA	NA	NA	0.05	0.769	25.00	6.52
Q30-10 Flow												
0.680	0.00	0.00	0.00	.0217	0.02228	NA	NA	NA	0.06	0.734	25.00	6.55

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20C	35275	STONY RUN	0.680	1260.00	0.06	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.047	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	25.00	7.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Pinehurst Manor	PA0238571	0.0140	0.0000	0.0000	0.000	25.00	6.50

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20C	35275	STONY RUN	0.000	1180.00	0.28	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.047	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	25.00	7.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	0.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70