

Application Type

Renewal

Facility Type

Non-Municipal

Major / Minor

Minor

Application No.

PA0238601

APS ID

1103788

Authorization ID

1467346

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

**Applicant and Facility Information**

Applicant Name	<u>Sutton MHP Inc.</u>	Facility Name	<u>Sutton MHP</u>
Applicant Address	<u>129 Elgie Drive</u>	Facility Address	<u>Mcgregor Road</u>
	<u>Butler, PA 16001-9691</u>		<u>Butler, PA 16001</u>
Applicant Contact	<u>Kevin Kniess</u>	Facility Contact	<u>Kevin Kniess</u>
Applicant Phone	<u>(724) 290-7363</u>	Facility Phone	<u>(724) 290-7363</u>
Client ID	<u>159050</u>	Site ID	<u>537156</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Clay Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Butler</u>
Date Application Received	<u>December 21, 2023</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>December 21, 2023</u>	If No, Reason	
Purpose of Application	<u>NPDES Permit Renewal.</u>		

**Summary of Review**

Sutton MHP Inc. has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of its NPDES permit. The permit was June 20, 2019 and became effective on July 1, 2019. The permit expired on June 30, 2024 but the terms and conditions have been extended since that time.

Based on the review, it is recommended that the permit be drafted.

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		<i>Jinsu Kim</i> Jinsu Kim / Environmental Engineering Specialist	September 22, 2025
X		Adam Olesnanik Adam Olesnanik, P.E. / Environmental Engineer Manager	September 24, 2025

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	.0125
Latitude	40° 59' 38.08"	Longitude	-79° 56' 31.68"
Quad Name	Mt Chestnut	Quad Code	1106
Wastewater Description: Sewage Effluent			
Receiving Waters	Unnamed Tributary to Glade Run	Stream Code	
NHD Com ID	126221141	RMI	0.2200
Drainage Area	0.07	Yield (cfs/mi <sup>2</sup> )	0
Q <sub>7-10</sub> Flow (cfs)	0	Q <sub>7-10</sub> Basis	Dry stream
Elevation (ft)	1316.03	Slope (ft/ft)	
Watershed No.	20-C	Chapter 93 Class.	CWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Impaired		
Cause(s) of Impairment	METALS, SILTATION		
Source(s) of Impairment	ACID MINE DRAINAGE, ACID MINE DRAINAGE		
TMDL Status	Name		
Nearest Downstream Public Water Supply Intake	PA American Water		
PWS Waters	Connoquenessing Creek	Flow at Intake (cfs)	
PWS RMI		Distance from Outfall (mi)	40

Comments: The discharge is to a dry stream and the watershed is impaired for metals and siltation as a result of acid mine drainage. The fact sheet developed for the last permit renewal shows the nearest downstream public water supply intake is PA American Water located on Connoquenessing Creek approximately 40 miles from the discharge. Given the nature and distance, the discharge is not expected to impact the water supply.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Sutton MHP				
<b>WQM Permit No.</b>	<b>Issuance Date</b>			
1002402	06/10/2002			
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary With Ammonia Reduction	Extended Aeration	Chlorine With Dechlorination	0.012563
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.012563	28.5	Not Overloaded	Aerobic Digestion	

The facility is utilizing an extended aeration activated sludge treatment process consisting of comminutor with equalization tank, extended aeration treatment units (2), final clarifier, chlorine contact tank and outfall structure. Chlorine tablets are used for disinfection and dechlorination tablets are used for dechlorination.

Compliance History	
<b>Summary of DMRs:</b>	A summary of past 12-month DMR data is presented on the next page.
<b>Summary of Inspections:</b>	11/17/2021: DEP conducted a routine inspection; no significant violations were identified at the time of inspection.
<b>Other Comments:</b>	Since the last permit reissuance, the facility had a number of permit violations particularly associated with effluent violations. These violations are shown on page 5 of this fact sheet.  DEP's database shows there is no open violation associated with this facility or permittee.

Effluent Data

DMR Data for Outfall 001 (from August 1, 2024 to July 31, 2025)

Parameter	JUL-25	JUN-25	MAY-25	APR-25	MAR-25	FEB-25	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24
Flow (MGD) Average Monthly	0.006	0.0054	0.0049	0.0049	0.0069	0.0065	0.0078	0.0058	0.0052	0.0049	0.0043	0.0041
Flow (MGD) Daily Maximum	0.0074	0.0069	0.006	0.0064	0.0118	0.0096	0.0121	0.0086	0.0081	0.0061	0.0054	0.005
pH (S.U.) Instantaneous Minimum	7.3	7.4	7.0	6.9	6.9	7.0	6.8	6.5	6.5	6.5	6.6	7.1
pH (S.U.) Instantaneous Maximum	7.6	8.6	7.6	7.6	7.5	7.9	7.5	7.7	7.6	7.4	7.4	7.5
DO (mg/L) Daily Minimum	4.06	4.07	4.08	4.9	4.75	6.64	6.59	5.72	4.5	4.61	4.8	4.08
TRC (mg/L) Average Monthly	0.3	0.3	0.4	0.4	0.3	0.3	0.3	0.3	0.2	0.3	0.3	0.3
CBOD5 (mg/L) Average Monthly	< 3.0	12.0	< 3.0	4.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0
TSS (mg/L) Average Monthly	< 3.0	14.0	< 3.0	6.0	13.0	12.0	19.0	25.0	< 3.0	3.0	< 4.0	< 3.0
Fecal Coliform (No./100 ml) Geometric Mean	< 3	< 26	< 4	< 1	1	3	11	11	4	10	11	< 3
Total Nitrogen (mg/L) Average Quarterly		7.75			21.6			51.3			22.8	
Ammonia (mg/L) Average Monthly	1.4	6.0	5.0	2.0	< 0.1	0.22	< 0.2	0.23	0.12	< 0.1	0.09	0.13
Total Phosphorus (mg/L) Average Quarterly		1.75			2.43			3.36			3.17	

Compliance History

Date	Description	Parameters	Results	Limits	Units	SBC
9/9/2019	Violation of permit condition	Dissolved Oxygen	3.99	4 mg/L	Daily Minimum	
5/9/2020	Violation of permit condition	Ammonia-Nitrogen	13	9 mg/L	Average Monthly	
6/5/2020	Violation of permit condition	Ammonia-Nitrogen	7	3 mg/L	Average Monthly	
6/5/2020	Violation of permit condition	Total Suspended Solids	49	30 mg/L	Average Monthly	
7/10/2020	Violation of permit condition	Ammonia-Nitrogen	10	3 mg/L	Average Monthly	
7/10/2020	Violation of permit condition	Total Residual Chlorine (TRC)	0.5	0.4 mg/L	Average Monthly	
8/7/2020	Violation of permit condition	pH	5.8	6 S.U.	Instantaneous Minimum	
8/7/2020	Violation of permit condition	Total Residual Chlorine (TRC)	0.5	0.4 mg/L	Average Monthly	
9/10/2020	Violation of permit condition	Dissolved Oxygen	3.58	4 mg/L	Daily Minimum	
9/10/2020	Violation of permit condition	Total Suspended Solids	<49.0	30 mg/L	Average Monthly	
12/2/2020	Violation of permit condition	Total Suspended Solids	35	30 mg/L	Average Monthly	
3/10/2021	Violation of permit condition	Total Suspended Solids	38	30 mg/L	Average Monthly	
10/7/2021	Violation of permit condition	Fecal Coliform	366	200 No./100 ml	Geometric Mean	
3/16/2022	Violation of permit condition	Carbonaceous Biochemical Oxygen Demand (CBOD5)	35	25 mg/L	Average Monthly	
6/10/2023	Violation of permit condition	Total Suspended Solids	43	30 mg/L	Average Monthly	
6/6/2025	Violation of permit condition	Ammonia-Nitrogen	5	3 mg/L	Average Monthly	
7/8/2025	Violation of permit condition	Ammonia-Nitrogen	6	3 mg/L	Average Monthly	

**Existing Effluent Limits and Monitoring Requirements**

A table below summarizes effluent limits and monitoring requirements specified in the current permit:

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	9.0	XXX	4/week	Grab
Dissolved Oxygen	XXX	XXX	4.0	XXX	XXX	XXX	4/week	Grab
Total Residual Chlorine (TRC)	XXX	XXX	XXX	0.4	XXX	0.9	4/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5)	XXX	XXX	XXX	25.0	XXX	50	2/month	8-Hr Composite
Total Suspended Solids	XXX	XXX	XXX	30.0	XXX	60	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Total Nitrogen	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	8-Hr Composite
Ammonia-Nitrogen Nov 1 - Apr 30	XXX	XXX	XXX	9.0	XXX	18	2/month	8-Hr Composite
Ammonia-Nitrogen May 1 - Oct 31	XXX	XXX	XXX	3.0	XXX	6	2/month	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	8-Hr Composite

<b>Development of Effluent Limitations</b>				
<b>Outfall No.</b>	001	<b>Design Flow (MGD)</b>	.0125	
<b>Latitude</b>	40° 59' 36.00"	<b>Longitude</b>	-79° 56' 4.00"	
<b>Wastewater Description:</b>	Sewage Effluent			

### **Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

<b>Pollutant</b>	<b>Limit (mg/l)</b>	<b>SBC</b>	<b>Federal Regulation</b>	<b>State Regulation</b>
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

### **Water Quality-Based Limitations**

#### *CBOD5, NH3-N and Dissolved Oxygen (DO)*

WQM 7.0 version 1.0b is a water quality model designed to assist DEP to determine appropriate permit requirements for CBOD5, NH3-N and DO. DEP's technical guidance no. 391-2000-007 describes the technical methods contained in the model for conducting wasteload allocation analyses and for determining recommended limits for point source discharges. Due to the very low-flow conditions expected in the receiving stream, the entire watershed of this receiving stream has been evaluated (Glade Run Watershed). The model output indicated that all existing effluent limits are still protective of water quality. No change is therefore recommended.

#### *Total Residual Chlorine*

Since chlorine is used, DEP's TRC\_CALC spreadsheet has been utilized; and the spreadsheet output shows that the existing effluent limit is still protective of water quality. No change is therefore recommended.

#### *Toxics*

This is a minor sewage facility receiving domestic wastewater only and the current application does not require sampling of toxic pollutants (or heavy metals) for those facilities with design flows less than 0.1 MGD. Therefore, no reasonable potential analysis for toxic pollutants has been performed for this permit renewal.

### **Best Professional Judgment (BPJ) Limitations**

#### *Dissolved Oxygen*

A minimum of 4.0 mg/L for DO is an existing effluent limit and will remain unchanged in the permit to ensure that the facility continues to protect all aquatic life. This approach is consistent with DEP's SOP no. BPNPSM-PMT-033.

### **Additional Considerations**

#### *Flow Monitoring*

The requirement to monitor the volume of effluent will remain in the draft permit per 40 CFR § 122.44(i)(1)(ii).

*E. Coli Monitoring Requirement*

DEP's SOP no. BPNPSM-PMT-033 recommends a quarterly routine monitoring of E. Coli for all sewage facilities that have design flow less than 0.1 MGD but greater than 0.05 MGD. A quarterly monitoring for E. Coli will therefore be included in the permit.

*Total Nitrogen & Total Phosphorus*

A continuation of nutrient monitoring is recommended. This approach is consistent with DEP's SOP no. BPNPSM-PMT-033. Since the facility has performed nutrient monitoring previously and the stream segment where the discharge is located is not impaired for nutrients, a quarterly sampling of nutrients is still acceptable.

*Monitoring Frequency and Sample Type*

The monitoring frequency for pH, DO and TRC has changed from 4/week to 1/day. It is unclear how the existing frequency of 4/week was developed but 1/day monitoring requirement for pH, DO and TRC has been consistently implemented on sewage facilities over 0.002 MGD throughout the state. This daily monitoring requirement is also consistent with DEP's technical guidance no. 362-0400-001.

*Mass Loading Limitations*

All effluent mass loading limits will be based on the formula: design flow x concentration limit x conversion factor of 8.34.

*Antidegradation Requirements*

All effluent limitations and monitoring requirements have been developed to ensure that existing instream water uses and the level of water quality necessary to protect the existing uses are maintained and protected.

*Class A Wild Trout Fishery*

No Class A Wild Trout Fisheries are also impacted by this discharge.

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)					
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum	Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	4.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.4	XXX	0.9	1/day	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	30.0	XXX	60	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX Geo Mean	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX Geo Mean	200 Geo Mean	XXX	1000	2/month	Grab
Total Nitrogen	XXX	XXX	XXX Report Avg Qrtly	Report Avg Qrtly	XXX	XXX	1/quarter	8-Hr Composite
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	9.0	XXX	18	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	XXX	XXX	XXX	3.0	XXX	6	2/month	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX Report Avg Qrtly	Report Avg Qrtly	XXX	XXX	1/quarter	8-Hr Composite
E. Coli (No. / 100 mL)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab

Tools and References Used to Develop Permit	
<input type="checkbox"/>	WQM for Windows Model (see Attachment [REDACTED])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [REDACTED]
<input type="checkbox"/>	Other: [REDACTED]


## StreamStats Report

Region ID: PA

Workspace ID: PA20250922172140365000

Clicked Point (Latitude, Longitude): 40.99407, -79.94230

Time: 2025-09-22 13:22:02 -0400



[Collapse All](#)

### ► Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	0.49	square miles
ELEV	Mean Basin Elevation	1364	feet

### ► Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 4]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	0.49	square miles	2.26	1400
ELEV	Mean Basin Elevation	1364	feet	1050	2580

Low-Flow Statistics Disclaimers [Low Flow Region 4]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 4]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.0139	ft <sup>3</sup> /s
30 Day 2 Year Low Flow	0.0279	ft <sup>3</sup> /s
7 Day 10 Year Low Flow	0.00366	ft <sup>3</sup> /s
30 Day 10 Year Low Flow	0.00838	ft <sup>3</sup> /s
90 Day 10 Year Low Flow	0.0183	ft <sup>3</sup> /s

*Low-Flow Statistics Citations*

**Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p.**  
(<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.29.2

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1


## StreamStats Report

Region ID: PA

Workspace ID: PA20250922172546364000

Clicked Point (Latitude, Longitude): 41.01517, -79.98098

Time: 2025-09-22 13:26:12 -0400



[Collapse All](#)

### ► Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	5.36	square miles
ELEV	Mean Basin Elevation	1341	feet

### ► Low-Flow Statistics

#### Low-Flow Statistics Parameters [Low Flow Region 4]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	5.36	square miles	2.26	1400
ELEV	Mean Basin Elevation	1341	feet	1050	2580

#### Low-Flow Statistics Flow Report [Low Flow Region 4]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR<sup>2</sup>: Pseudo R Squared (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	0.209	ft <sup>3</sup> /s	43	43
30 Day 2 Year Low Flow	0.375	ft <sup>3</sup> /s	38	38
7 Day 10 Year Low Flow	0.0693	ft <sup>3</sup> /s	66	66
30 Day 10 Year Low Flow	0.132	ft <sup>3</sup> /s	54	54
90 Day 10 Year Low Flow	0.256	ft <sup>3</sup> /s	41	41

*Low-Flow Statistics Citations*

**Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)**

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.29.2

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20C	34443	GLADE RUN			4.900	1200.00	0.49	0.00000	0.00	<input checked="" type="checkbox"/>
<b>Stream Data</b>										
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream pH
Q7-10	0.100	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00
Q1-10		0.00	0.00	0.000	0.000					
Q30-10		0.00	0.00	0.000	0.000					
<b>Discharge Data</b>										
	Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH		
	Sutton MHP Inc.	PA0238601	0.0125	0.0125	0.0125	0.000	25.00	7.00		
<b>Parameter Data</b>										
	Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)					
	CBOD5	25.00	2.00	0.00	1.50					
	Dissolved Oxygen	5.00	8.24	0.00	0.00					
	NH3-N	3.00	0.00	0.00	0.70					

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20C	34443	GLADE RUN			1.900	1182.00	5.36	0.00000	0.00	<input checked="" type="checkbox"/>
<b>Stream Data</b>										
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio (ft)	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream pH (°C)
Q7-10	0.100	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00
Q1-10		0.00	0.00	0.000	0.000					
Q30-10		0.00	0.00	0.000	0.000					
<b>Discharge Data</b>										
	Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor		Disc Temp (°C)	Disc pH	
			0.0000	0.0000	0.0000	0.000		25.00	7.00	
<b>Parameter Data</b>										
	Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)				
	CBOD5		25.00	2.00	0.00	1.50				
	Dissolved Oxygen		3.00	8.24	0.00	0.00				
	NH3-N		25.00	0.00	0.00	0.70				

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>			<u>Stream Code</u>			<u>Stream Name</u>							
20C			34443			GLADE RUN							
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH	
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)		
<b>Q7-10 Flow</b>													
4.900	0.05	0.00	0.05	.0193	0.00114	.354	3.99	11.28	0.05	3.790	21.41	7.00	
<b>Q1-10 Flow</b>													
4.900	0.03	0.00	0.03	.0193	0.00114	NA	NA	NA	0.04	4.480	21.91	7.00	
<b>Q30-10 Flow</b>													
4.900	0.07	0.00	0.07	.0193	0.00114	NA	NA	NA	0.06	3.333	21.12	7.00	

## WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

### WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>					
20C	34443	GLADE RUN							
<b>NH3-N Acute Allocations</b>									
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction		
4.900	Sutton MHP Inc.	14.31	6	14.31	6	0	0		
<b>NH3-N Chronic Allocations</b>									
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction		
4.900	Sutton MHP Inc.	1.76	3	1.76	3	0	0		
<b>Dissolved Oxygen Allocations</b>									
RMI	Discharge Name	CBOD5 Baseline (mg/L)	CBOD5 Multiple (mg/L)	NH3-N Baseline (mg/L)	NH3-N Multiple (mg/L)	Dissolved Oxygen Baseline (mg/L)	Dissolved Oxygen Multiple (mg/L)	Critical Reach	Percent Reduction
4.90	Sutton MHP Inc.	25	25	3	3	5	5	0	0

**WQM 7.0 D.O.Simulation**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
20C	34443	GLADE RUN		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
4.900	0.012	21.415	7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
3.992	0.354	11.282	0.048	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
8.51	0.358	0.85	0.781	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
7.325	20.152	Owens	5	
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>			
3.790	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.379	7.36	0.63	8.03
	0.758	6.37	0.47	8.03
	1.137	5.51	0.35	8.03
	1.516	4.77	0.26	8.03
	1.895	4.13	0.19	8.03
	2.274	3.57	0.14	8.03
	2.653	3.09	0.11	8.03
	3.032	2.67	0.08	8.03
	3.411	2.31	0.06	8.03
	3.790	2.00	0.04	8.03

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
20C	34443	GLADE RUN					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Efl. Limit 30-day Ave. (mg/L)	Efl. Limit Maximum (mg/L)	Efl. Limit Minimum (mg/L)
4.900	Sutton MHP Inc.	PA0238601	0.013	CBOD5	25		
				NH3-N	3	6	
				Dissolved Oxygen			5

TRC\_CALC

1A	B	C	D	E	F	G	
2	<b>TRC EVALUATION</b> Enter Facility Name in E3						
3	Input appropriate values in B4:B8 and E4:E7						
4	0.049 = Q stream (cfs)						
5	0.0125 = Q discharge (MGD)						
6	30 = no. samples						
7	0.3 = Chlorine Demand of Stream						
8	0 = Chlorine Demand of Discharge						
9	0.4 = BAT/BPJ Value						
	= % Factor of Safety (FOS)						
10	Source	Reference	AFC Calculations	Reference	CFC Calculations		
11	TRC	1.3.2.iii	WLA_afc = 0.827	1.3.2.iii	WLA_cfc = 0.799		
12	PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581		
13	PENTOXSD TRG	5.1b	LTA_afc = 0.308	5.1d	LTA_cfc = 0.465		
14							
15	Source	Effluent Limit Calculations					
16	PENTOXSD TRG	5.1f	AML MULT = 1.231				
17	PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.379				
18			INST MAX LIMIT (mg/l) = 1.241				
	WLA_afc	$(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))...$ ...+ Xd + (AFC_Yc*Qs*Xs/Qd)*(1-FOS/100)					
	LTAMULT_afc	$EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)$					
	LTA_afc	wla_afc*LTAMULT_afc					
	WLA_cfc	$(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))...$ ...+ Xd + (CFC_Yc*Qs*Xs/Qd)*(1-FOS/100)					
	LTAMULT_cfc	$EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)$					
	LTA_cfc	wla_cfc*LTAMULT_cfc					
	AML MULT	$EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))$					
	AVG MON LIMIT	$MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)$					
	INST MAX LIMIT	$1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)$					