

Application Type Renewal  
Facility Type Non-Municipal  
Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0238724  
APS ID 1095903  
Authorization ID 1452694

**Applicant and Facility Information**

Applicant Name	<u>Gary Freligh</u>	Facility Name	<u>Frelighs Whispering Pines MHP</u>
Applicant Address	<u>900 Sirak Drive</u> <u>Fairview, PA 16415-1410</u>	Facility Address	<u>9921 Ridge Road</u> <u>Girard, PA 16417</u>
Applicant Contact	<u>Gary Freligh</u>	Facility Contact	<u>Gary Freligh</u>
Applicant Phone	<u>(814) 440-3167</u>	Facility Phone	<u></u>
Applicant Email	<u>money_when_yousleep@yahoo.com</u>		<u></u>
Client ID	<u>160779</u>	Site ID	<u>547275</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Girard Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Erie</u>
Date Application Received	<u>August 21, 2023</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>March 20, 2025</u>	If No, Reason	<u></u>
Purpose of Application	<u>Renewal of a NPDES Permit for an Existing Discharge of 0.01 MGD</u>		

**Summary of Review**

This is a renewal Sewage Individual NPDES Permit for an Existing Design Flow of 0.01 MGD from a non-municipal minor sewage facility.

There are no proposed changes to effluent limitations as part of this permit renewal.

Act 14 – Proof of Notification was submitted and received.

This facility is currently using eDMR system.

SPECIAL CONDITIONS: NONE

The EPA waiver is in effect.

There are NO open violations in WMS for the subject Client ID (160779) as of March 24, 2025.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Aeshah Shameseldin Aeshah Shameseldin / Project Manager	March 24, 2025
X		Adam Olesnanik Adam Olesnanik, P.E. / Environmental Engineer Manager	April 7, 2025

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	.01
Latitude	41° 59' 42.00"	Longitude	-80° 19' 45.00"
Quad Name	Albion	Quad Code	41080H3
Wastewater Description: Sewage Effluent			
Receiving Waters	UNT to Elk Creek (WWF, MF)	Stream Code	62491
NHD Com ID	123919817	RMI	Confluence with Elk Creek is at RMI 3.7
Drainage Area	0.00015 (Dry), 92.9 (Perennial)	Yield (cfs/mi²)	0.001 (Dry Stream), 0.045 (Perennial)
Q <sub>7-10</sub> Flow (cfs)	0 (Dry), 4.18 (Perennial)	Q <sub>7-10</sub> Basis	Calculated
Elevation (ft)	676	Slope (ft/ft)	---
Watershed No.	15-A	Chapter 93 Class.	WWF, MF
Existing Use	----	Existing Use Qualifier	---
Exceptions to Use	---	Exceptions to Criteria	---
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment	---		
Source(s) of Impairment	---		
TMDL Status	---	Name	---
Background/Ambient Data	Data Source		
pH (SU)	7.0	Default	
Temperature (°F)	77	Default	
Hardness (mg/L)	100	Default	
Other:			
Nearest Downstream Public Water Supply Intake	PA – Canadian International Boundary in Lake Erie		
PWS Waters	Lake Erie	Flow at Intake (cfs)	---
PWS RMI	---	Distance from Outfall (mi)	---

Changes Since Last Permit Issuance: None.

Other Comments: None.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Freligh'S Whispering Pines MHP				
<b>WQM Permit No.</b>	<b>Issuance Date</b>			
2502428	February 13, 2003			
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage	Tertiary	Extended Aeration with Solids Removal	Chlorine With Dechlorination	0.01
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
0.01	20	Not Overloaded	Holding Tank	Other WWTP

Changes Since Last Permit Issuance: None.

Other Comments: Treatment facilities permitted under WQM Permit # 2502428 consist of: A comminutor with bypass bar screen, Alum feed for phosphorus control, a 10,400-gallon extended aeration tank, a 1,626 gallon settling tank, a 2,500 gallon aerated sludge holding tank, a 1,500 gallon dosing tank, two 528 square foot (22' x 24') surface sand filters, tablet chlorine disinfection with a 936 gallon contact tank, sodium sulfite tablet dechlorination with a 500 gallon contact tank.

Compliance History

DMR Data for Outfall 001 (from February 1, 2024 to January 31, 2025)

Parameter	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24	APR-24	MAR-24	FEB-24
Flow (MGD) Average Monthly	2029	2489	2190	1847	1836	1836	2018	1897	1915	1944	1666	1959
pH (S.U.) Instantaneous Minimum	7.7	7.6	7.6	7.6	7.6	7.5	8.0	7.3	7.6	7.0	7.9	7.6
pH (S.U.) Instantaneous Maximum	8.1	8.0	8.1	8.0	8.6	8.6	8.9	8.4	7.78	7.9	8.2	8.1
DO (mg/L) Daily Minimum	6.0	6.0	6.0	6.2	6.2	6.0	6.0	6.0	6.2	6.0	6.0	6.25
TRC (mg/L) Average Monthly	0.08	0.09	0.08	0.08	0.08	0.06	0.04	0.04	0.09	0.08	0.08	0.11
TRC (mg/L) Instantaneous Maximum	0.12	0.12	0.12	0.12	0.11	0.12	0.08	0.08	0.14	0.14	0.11	0.14
CBOD5 (mg/L) Average Monthly	< 2.00	< 2.00	< 2.00	< 2.00	< 2.00	< 2.00	< 2.00	< 2.00	< 2.00	< 2.00	< 2.00	3.795
TSS (mg/L) Average Monthly	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0
Fecal Coliform (No./100 ml) Geometric Mean	< 1	1	2.23	1	1	1	7.16	1	3.47	1	1	1
Fecal Coliform (No./100 ml) Instantaneous Maximum	1	1	1	1	1	1	7.16	1	12	1	1	1
Total Nitrogen (mg/L) Average Monthly	1.84	4.81	4.85	3.79	4.95	3.81	2.05	4.13	1.81	0.819	1.16	0.737
Ammonia (mg/L) Average Monthly	< 0.150	0.115	< 0.100	< 0.100	< 0.100	< 0.100	< 0.400	< 0.100	< 0.100	< 0.400	< 0.400	< 0.400
Total Phosphorus (mg/L) Average Monthly	< 0.150	< 0.100	< 0.300	< 0.100	0.1065	< 0.10	< 0.10	< 0.107	0.10	< 0.10	< 0.10	< 0.10

**Development of Effluent Limitations**

Outfall No. 001  
Latitude 41° 59' 42.00"  
Wastewater Description: Sewage Effluent

Design Flow (MGD) .01  
Longitude -80° 19' 45.00"

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
E. Coli	Report (No./100 ml)	IMAX	-	§ 92a.61

Comments: Monitoring for E. Coli is placed in the permit in accordance with the Department's SOP entitled "Establishing Effluent Limitations for Individual Sewage Permits."

**Water Quality-Based Limitations**

CBOD<sub>5</sub>, Ammonia, and DO are evaluated using WQM 7.0 (Attachment 1 and 2). TRC is evaluated using the Department's TRC evaluation spreadsheet (Attachment 3).

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
Dissolved Oxygen	4.0	Daily Min.	WQM 7.0
CBOD <sub>5</sub>	25	Average Monthly	WQM 7.0
	50	IMAX	
Ammonia Nitrogen (May 1 – Oct 31)	12.72	Average Monthly	WQM 7.0
	25.44	IMAX	
TRC	0.5	Average Monthly	TRC Evaluation Spreadsheet

Comments: WQM modeling didn't calculate more stringent average monthly Ammonia Nitrogen limit at perennial conditions. Current monitoring requirements are attainable and will be retained.

The TRC evaluation spreadsheet didn't calculate more stringent average monthly TRC limit at perennial conditions using the plant design flow, the limits established in previous permits are attainable and will be retained.

The previous technology-based minimum Dissolved Oxygen limit of 6.0 mg/l was retained, as this is the minimum required for discharge into a drainage swale or ditch.

**Best Professional Judgment (BPJ) Limitations**

Comments: Monitoring for total nitrogen, total phosphorus and raw sewage influent monitoring for CBOD<sub>5</sub> and TSS are placed in the permit in accordance with the Department's SOP entitled "Establishing Effluent Limitations for Individual Sewage Permits."

**Anti-Backsliding**

N/A

**Proposed Effluent Limitations and Monitoring Requirements**


The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	6.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.27	XXX	0.63	1/day	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	30.0	XXX	60	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	1/month	8-Hr Composite
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	6.0	XXX	12	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	XXX	XXX	XXX	2.0	XXX	4	2/month	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	1.0	XXX	XXX	2/month	8-Hr Composite

Compliance Sampling Location: Outfall 001, after disinfection.

Outfall Location - eMap with Aerial Imagery





Dry Reach - Drainage Area Location – StreamStats with Aerial Imagery


StreamStats Report

Region ID: PA

Workspace ID: PA20250320193949422000

Clicked Point (Latitude, Longitude): 41.99520, -80.32896

Time: 2025-03-20 15:40:18 -0400



+ Collapse All

> Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	0.000154	square miles

Perennial Reach - Drainage Area Location – StreamStats with Aerial Imagery

StreamStats Report

Region ID:

Workspace ID:

Clicked Point (Latitude, Longitude):


Time:

PA

PA20250320131359733000

41.99738, -80.33583

2025-03-20 09:14:29 -0400




+ Collapse All

> Basin Characteristics


Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	92.9	square miles



A two-step model was used. The first step was for a dry stream evaluation. The DO simulation end-of-reach data was then used to evaluate the second step perennial stream reach. The second step evaluated perennial stream conditions.







**Attachment 1**

**Dry Reach Modeling**

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>				
15		62491	ELK CREEK				
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
0.460	Frelighs Whispe	PA0238724	0.010	CBOD5	25		
				NH3-N	12.72	25.44	
				Dissolved Oxygen			4

### WQM 7.0 Modeling Specifications

Parameters	D.O.	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	2		

### WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
15	62491	ELK CREEK		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
0.460	0.010	20.000	7.800	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
0.138	0.712	0.194	0.158	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
25.00	1.500	12.72	0.700	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
4.000	11.810	Owens	2	
<u>Reach Travel Time (days)</u>				
0.174				
	<u>Subreach</u>	<u>Results</u>		
	<u>TravTime</u>	<u>CBOD5</u>	<u>NH3-N</u>	<u>D.O.</u>
	(days)	(mg/L)	(mg/L)	(mg/L)
	0.017	24.35	12.57	3.45
	0.035	23.73	12.42	3.03
	0.052	23.11	12.26	2.72
	0.070	22.52	12.12	2.49
	0.087	21.93	11.97	2.34
	0.105	21.37	11.82	2.24
	0.122	20.82	11.68	2.19
	0.140	20.28	11.54	2.17
	0.157	19.76	11.40	2.19
	0.174	19.25	11.26	2.22



### Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
15	62491	ELK CREEK	0.460	676.00	0.00	0.00000	0.00	<input checked="" type="checkbox"/>

#### Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.001	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.80	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

#### Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Frelighs Whispe	PA0238724	0.0100	0.0000	0.0000	0.000	20.00	7.80

#### Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	0.00	0.00	1.50
Dissolved Oxygen	4.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70



### Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
15	62491	ELK CREEK	0.010	631.00	0.17	0.00000	0.00	<input checked="" type="checkbox"/>

#### Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)						Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.001	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.80	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

#### Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	0.00	7.00

#### Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

## WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
15	62491	ELK CREEK

### Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
0.46	Frelighs Whispe	25	25	12.72	12.72	4	4	0	0

### WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>								
15		62491		ELK CREEK								
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
<b>Q7-10 Flow</b>												
0.460	0.00	0.00	0.00	.0155	0.01894	.712	.14	.19	0.16	0.174	20.00	7.80
<b>Q1-10 Flow</b>												
0.460	0.00	0.00	0.00	.0155	0.01894	NA	NA	NA	0.00	0.000	0.00	0.00
<b>Q30-10 Flow</b>												
0.460	0.00	0.00	0.00	.0155	0.01894	NA	NA	NA	0.00	0.000	0.00	0.00

### Perennial Reach Modeling

For CBOD5, Ammonia Nitrogen and DO, the resulting limits are the same as the inputs from the dry stream model therefore dry stream inputs are sufficient.

### WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>				
15		62491	ELK CREEK				
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
3.700	Frelighs Whispe	PA0238724	0.010	CBOD5	19.25		
				NH3-N	11.26	22.52	
				Dissolved Oxygen			2.22

### WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

## WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
15	62491	ELK CREEK		
<hr/>				
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
3.700	0.010	24.982	7.001	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
35.577	0.697	51.059	0.169	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
2.06	0.031	0.14	1.027	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
7.520	6.987	Tsivoglou	5	
<u>Reach Travel Time (days)</u>	<u>Subreach Results</u>			
0.602	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.060	2.06	0.13	7.54
	0.120	2.05	0.12	7.54
	0.181	2.05	0.12	7.54
	0.241	2.04	0.11	7.54
	0.301	2.04	0.10	7.54
	0.361	2.03	0.10	7.54
	0.422	2.03	0.10	7.54
	0.482	2.02	0.10	7.54
	0.542	2.02	0.10	7.54
	0.602	2.02	0.10	7.54

### Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
15	62491	ELK CREEK	3.700	623.00	93.00	0.00000	0.00	<input checked="" type="checkbox"/>

### Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)						Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.045	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

### Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Frelighs Whispe	PA0238724	0.0100	0.0000	0.0000	0.000	20.00	7.80

### Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	19.25	2.00	0.00	1.50
Dissolved Oxygen	2.22	7.54	0.00	0.00
NH3-N	11.26	0.10	0.00	0.70

### Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
15	62491	ELK CREEK	2.030	589.00	94.20	0.00000	0.00	<input checked="" type="checkbox"/>

#### Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	pH	Stream Temp (°C)	pH
	(cfsm)	(cfs)	(cfs)									
Q7-10	0.045	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

#### Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

#### Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70



## WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
15		62491				ELK CREEK						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
<b>Q7-10 Flow</b>												
3.700	4.18	0.00	4.18	.0155	0.00386	.697	35.58	51.06	0.17	0.602	24.98	7.00
<b>Q1-10 Flow</b>												
3.700	2.68	0.00	2.68	.0155	0.00386	NA	NA	NA	0.13	0.772	24.97	7.00
<b>Q30-10 Flow</b>												
3.700	5.69	0.00	5.69	.0155	0.00386	NA	NA	NA	0.20	0.507	24.99	7.00

## WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
15	62491	ELK CREEK

### NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
	3.700 Frelighs Whispe	11.08	22.52	11.08	22.52	0	0

### NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
	3.700 Frelighs Whispe	1.37	11.26	1.37	11.26	0	0

### Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
	3.70 Frelighs Whispe	19.25	19.25	11.26	11.26	2.22	2.22	0	0

Flow at End of Dry Reach / Start of Perennial Conditions was used for TRC Evaluation.

TRC EVALUATION					
Input appropriate values in A3:A9 and D3:D9					
4.18	= Q stream (cfs)	0.5	= CV Daily		
0.01	= Q discharge (MGD)	0.5	= CV Hourly		
30	= no. samples	1	= AFC_Partial Mix Factor		
0.3	= Chlorine Demand of Stream	1	= CFC_Partial Mix Factor		
0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)		
0.5	= BAT/BPJ Value	720	= CFC_Criteria Compliance Time (min)		
0	= % Factor of Safety (FOS)	0	= Decay Coefficient (K)		
Source	Reference	AFC Calculations		Reference	CFC Calculations
TRC	1.3.2.iii	WLA afc = 86.213		1.3.2.iii	WLA cfc = 84.043
PENTOXSD TRG	5.1a	LTAMULT afc = 0.373		5.1c	LTAMULT cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 32.125		5.1d	LTA_cfc = 48.859
Source	Effluent Limit Calculations				
PENTOXSD TRG	5.1f	AML MULT = 1.231			
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500		BAT/BPJ	
		INST MAX LIMIT (mg/l) = 1.635			
WLA afc	$(.019/e(-k*AFC\_tc)) + [(AFC\_Yc*Qs*.019/Qd*e(-k*AFC\_tc))... \\ ...+ Xd + (AFC\_Yc*Qs*Xs/Qd)]*(1-FOS/100)$				
LTAMULT afc	$EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)$				
LTA_afc	wla_afc*LTAMULT_afc				
WLA_cfc	$(.011/e(-k*CFC\_tc) + [(CFC\_Yc*Qs*.011/Qd*e(-k*CFC\_tc))... \\ ...+ Xd + (CFC\_Yc*Qs*Xs/Qd)]*(1-FOS/100)$				
LTAMULT_cfc	$EXP((0.5*LN(cvd^2/no\_samples+1))-2.326*LN(cvd^2/no\_samples+1)^0.5)$				
LTA_cfc	wla_cfc*LTAMULT_cfc				
AML MULT	$EXP(2.326*LN((cvd^2/no\_samples+1)^0.5)-0.5*LN(cvd^2/no\_samples+1))$				
AVG MON LIMIT	MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)				
INST MAX LIMIT	1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)				

