

Application Type  
Facility Type  
Major / Minor

Renewal  
Municipal  
Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. **PA0238945**  
APS ID **1101659**  
Authorization ID **1463198**

**Applicant and Facility Information**

Applicant Name	<u>Pulaski Township Municipal Authority</u>	Facility Name	<u>Pulaski Township STP</u>
Applicant Address	<u>1172 State Route 208</u>	Facility Address	<u>278 N Street Extension</u>
Applicant Contact	<u>Pulaski, PA 16143</u>	Facility Contact	<u>Pulaski, PA 16143</u>
Applicant Phone	<u>(724) 964-8891</u>	Facility Phone	<u>(724) 964-8891</u>
Client ID	<u>202480</u>	Site ID	<u>604733</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Pulaski Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Lawrence</u>
Date Application Received	<u>November 6, 2023</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted		If No, Reason	
Purpose of Application	<u>NPDES Renewal.</u>		

**Summary of Review**

An application was submitted for an NPDES permit renewal for an existing minor sewage facility discharge. The Pulaski Township STP consists of a pump station, shredder with manual bypass bar screen, two sequencing batch reactor (SBR) tanks, aerobic sludge digester, chlorine contact tank, and de-chlorination. Sludge is dewatered at the new Bedford STP.

Changes to the permit: E. Coli monitoring has been added to the permit. The monitoring frequency for pH, DO, and TRC has been increased from 3/week to 1/day.

There are no open violations for the Applicant.

Sludge use and disposal description and locations: Disposed off-site

**Public Participation**

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Benjamin R. Lockwood Benjamin R. Lockwood / Environmental Engineering Specialist	April 24, 2025
X		Adam Olesnanik Adam Olesnanik, P.E. / Environmental Engineer Manager	April 24, 2025

**Discharge, Receiving Waters and Water Supply Information**

Outfall No.	001	Design Flow (MGD)	.044
Latitude	41° 6' 56"	Longitude	80° 26' 12"
Quad Name		Quad Code	
Wastewater Description:	Sewage Effluent		
Receiving Waters	Shenango River (WWF)	Stream Code	35482
NHD Com ID	130025571	RMI	15.8
Drainage Area	742 mi <sup>2</sup>	Yield (cfs/mi <sup>2</sup> )	0.037
Q <sub>7-10</sub> Flow (cfs)	27.1	Q <sub>7-10</sub> Basis	USGS PA StreamStats
Elevation (ft)	1094	Slope (ft/ft)	
Watershed No.	20-A	Chapter 93 Class.	WWF
Existing Use	N/A	Existing Use Qualifier	N/A
Exceptions to Use	N/A	Exceptions to Criteria	N/A
Assessment Status	Impaired		
Cause(s) of Impairment	Metals, Polychlorinated Biphenyls (PCBs)		
Source(s) of Impairment	Source Unknown, Source Unknown		
TMDL Status	Final	Name	Shenango River
Nearest Downstream Public Water Supply Intake	PA American Water Company – New Castle		
PWS Waters	Shenango River	Flow at Intake (cfs)	
PWS RMI		Distance from Outfall (mi)	11.0

Changes Since Last Permit Issuance: None

Other Comments: None

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Pulaski Township STP				
<b>WQM Permit No.</b>	<b>Issuance Date</b>			
3702407	3/21/2003			
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary With Ammonia Reduction	Sequencing Batch Reactor	Chlorine With Dechlorination	0.044
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.044	58	Not Overloaded	Aerobic Digestion	Landfill

Changes Since Last Permit Issuance: None

<b>Compliance History</b>	
<b>Summary of DMRs:</b>	There were no violations in the past year DMR data.
<b>Summary of Inspections:</b>	<p>7/19/2019: A routine inspection was conducted. All treatment units were operational and the plant appeared to be well maintained.</p> <p>9/4/2019: A follow up inspection was conducted to observe Outfall 001. A path was cleared to the Outfall, no issues were noted.</p> <p>1/10/2024: A routine inspection was conducted. A walkthrough of the plant was performed and no issues were noted.</p>

Other Comments: There are currently no open violations for this Applicant

Compliance History

DMR Data for Outfall 001 (from March 1, 2024 to February 28, 2025)

Parameter	FEB-25	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24	APR-24	MAR-24
Flow (MGD) Average Monthly	0.011	0.010	0.011	0.009	0.008	0.007	0.006	0.009	0.013	0.016	0.028	0.019
Flow (MGD) Weekly Average	0.012	0.012	0.013	0.011	0.009	0.009	0.007	0.011	0.015	0.017	0.039	0.023
pH (S.U.) Daily Minimum	7.1	7.2	7.2	7.1	7.0	7.0	7.1	7.0	7.1	7.0	6.7	7.1
pH (S.U.) Daily Maximum	7.4	7.4	7.9	7.5	7.7	7.4	7.4	7.6	7.5	7.7	8.0	7.4
DO (mg/L) Daily Minimum	9.3	8.2	7.4	7.7	7.6	7.6	7.6	7.3	8.4	7.9	6.0	8.1
TRC (mg/L) Average Monthly	0.4	0.3	0.3	0.3	0.4	0.4	0.3	0.3	0.3	0.4	0.5	0.5
TRC (mg/L) Instantaneous Maximum	0.7	0.6	0.4	0.4	0.5	0.5	0.5	0.4	0.7	0.7	0.7	0.8
CBOD5 (lbs/day) Average Monthly	0.5	0.4	0.6	0.4	0.5	0.5	0.6	0.8	1.1	1.6	1.9	1.2
CBOD5 (lbs/day) Weekly Average	0.6	0.4	0.8	0.5	0.5	0.8	1.0	0.8	1.3	1.7	1.9	1.6
CBOD5 (mg/L) Average Monthly	5.0	5.0	5.4	5.5	6.2	8.3	10.7	12.7	8.6	10.8	9.2	7.5
CBOD5 (mg/L) Weekly Average	5.9	5.4	7.2	5.9	7.7	11.8	17.4	15.4	12.0	11.2	10.1	9.8
BOD5 (lbs/day) Raw Sewage Influent   Average Monthly	10	10	11	10	8	9	7	8	14	12	14	16
BOD5 (mg/L) Raw Sewage Influent   Average Monthly	123	122	118	136	103	144	126	127	100	83	71	98
TSS (lbs/day) Average Monthly	< 0.6	< 0.4	< 0.5	< 0.4	< 0.9	< 0.3	< 0.3	< 0.3	< 0.7	1.1	< 1.1	< 1.0
TSS (lbs/day) Raw Sewage Influent   Average Monthly	5	5	5	4	3	5	3	3	6	6	6	9

NPDES Permit Fact Sheet  
Pulaski Township STP

NPDES Permit No. PA0238945

TSS (lbs/day) Weekly Average	0.7	< 0.5	< 0.6	< 0.5	1.4	0.3	< 0.3	0.4	< 0.9	1.3	1.2	1.1
TSS (mg/L) Average Monthly	< 6.0	< 5.0	< 5.0	< 5.0	< 10.0	< 5.0	< 5.0	< 5.0	< 5.0	7.5	< 5.5	7.5
TSS (mg/L) Raw Sewage Influent   Average Monthly	61	64	56	63	45	88	50	47	38	44	31	53
TSS (mg/L) Weekly Average	7.0	< 5.0	5.0	< 5.0	15.0	5.0	< 5.0	5.0	< 5.0	9.0	6.0	9.8
Fecal Coliform (No./100 ml) Geometric Mean	3	< 84	102	291	1027	20	7	59	164	17	4	110
Fecal Coliform (No./100 ml) Instantaneous Maximum	7	1414	523	352	2738	31	26	173	548	51	13	2420
Total Nitrogen (mg/L) Average Quarterly			9.86			12.7			7.18			7.09
Ammonia (lbs/day) Average Monthly	0.1	0.1	0.1	0.1	0.1	< 0.1	< 0.1	< 0.1	0.1	0.2	< 0.6	0.4
Ammonia (mg/L) Average Monthly	1.1	0.60	0.3	0.1	0.2	< 0.1	< 0.3	< 0.4	0.1	1.3	< 2.9	2.2
Total Phosphorus (mg/L) Average Quarterly			3.16			5.1			0.94			3.2

**Development of Effluent Limitations**

Outfall No. 001  
Latitude 41° 6' 56.00"  
Wastewater Description: Sewage Effluent

Design Flow (MGD) .044  
Longitude -80° 26' 12.00"

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: E. Coli monitoring has been added per Chapter 92 requirements.

**Water Quality-Based Limitations**

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
NH3-N	25	Avg. Mo.	WQM 7.0
CBOD <sub>5</sub>	25	Avg. Mo.	WQM 7.0

Comments: The existing NH<sub>3</sub>-N and CBOD<sub>5</sub> limits of 25 mg/l are the same as the WQM Model output, and will remain in the permit. DEP's Toxics Management Spreadsheet was used to evaluate toxic parameters. The spreadsheet did not recommend any monitoring/limits for toxic parameters. The TRC Spreadsheet was used to evaluate total residual chlorine. The output recommend an average monthly limit of 0.5 mg/l and an IMAX of 1.6 mg/l, the same as the existing permit limit. The output for these models is attached below.

**Additional Considerations**

This facility is a POTW, therefore, the requirement to sample raw sewage BOD and TSS has been incorporated into the permit.

Total Nitrogen and Total Phosphorus will be monitored 1/quarter per the Departments' SOP.

The monitoring frequency for pH, DO, and TRC has been increased from 3/week to 1/day. This is consistent with the previous permit renewal, which allowed the frequency to remain at 3/week with the understanding that it would be increased to 1/day during the next permit renewal.

A Dissolved Oxygen minimum limitation of 4.0 mg/L will be implemented based on the standard in 25 PA Code Chapter 93 and best professional judgment.

**Anti-Backsliding**

Pursuant to 40 CFR § 122.44(l)(1), all proposed permit requirements addressed in this fact sheet are at least as stringent as the requirements implemented in the existing NPDES permit.

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	4.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	9.1	14.6	XXX	25.0	40.0	50	2/month	8-Hr Composite
BOD5 Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
TSS	11.0	16.5	XXX	30.0	45.0	60	2/month	8-Hr Composite
TSS Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Total Nitrogen	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	8-Hr Composite
Ammonia	9.1	XXX	XXX	25.0	XXX	50	2/month	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	8-Hr Composite

Compliance Sampling Location: Outfall 001, after chlorination/de-chlorination


## Pulaski Township Municipal Authority PA0238945 Outfall 001

**Region ID:** PA

**Workspace ID:** PA20250418105603031000

**Clicked Point (Latitude, Longitude):** 41.11551, -80.43698

**Time:** 2025-04-18 06:56:40 -0400



+ [Collapse All](#)

### ➤ Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	742	square miles
ELEV	Mean Basin Elevation	1094	feet

➤ Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 4]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	742	square miles	2.26	1400
ELEV	Mean Basin Elevation	1094	feet	1050	2580

Low-Flow Statistics Flow Report [Low Flow Region 4]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR<sup>2</sup>: Pseudo R Squared (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	48.4	ft <sup>3</sup> /s	43	43
30 Day 2 Year Low Flow	68.2	ft <sup>3</sup> /s	38	38
7 Day 10 Year Low Flow	27.1	ft <sup>3</sup> /s	66	66
30 Day 10 Year Low Flow	34.9	ft <sup>3</sup> /s	54	54
90 Day 10 Year Low Flow	50.7	ft <sup>3</sup> /s	41	41

*Low-Flow Statistics Citations*

**Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)**

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.


## Pulaski Township Municipal Authority PA0238945 RMI = 13.8

**Region ID:** PA

**Workspace ID:** PA20250418110107108000

**Clicked Point (Latitude, Longitude):** 41.09658, -80.41981

**Time:** 2025-04-18 07:01:43 -0400



+ [Collapse All](#)

### ➤ Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	759	square miles
ELEV	Mean Basin Elevation	1092	feet

➤ Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 4]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	759	square miles	2.26	1400
ELEV	Mean Basin Elevation	1092	feet	1050	2580

Low-Flow Statistics Flow Report [Low Flow Region 4]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR<sup>2</sup>: Pseudo R Squared (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	49.6	ft <sup>3</sup> /s	43	43
30 Day 2 Year Low Flow	69.8	ft <sup>3</sup> /s	38	38
7 Day 10 Year Low Flow	27.8	ft <sup>3</sup> /s	66	66
30 Day 10 Year Low Flow	35.8	ft <sup>3</sup> /s	54	54
90 Day 10 Year Low Flow	51.9	ft <sup>3</sup> /s	41	41

*Low-Flow Statistics Citations*

**Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)**

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

TRC\_CALC

1A	B	C	D	E	F	G						
<b>2 TRC EVALUATION</b>												
3 Input appropriate values in B4:B8 and E4:E7												
4	27.1	= Q stream (cfs)		0.5	= CV Daily							
5	0.044	= Q discharge (MGD)		0.5	= CV Hourly							
6	30	= no. samples		1	= AFC_Partial Mix Factor							
7	0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor							
8	0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)							
9	0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)							
	0	= % Factor of Safety (FOS)			= Decay Coefficient (K)							
10	Source	Reference	AFC Calculations	Reference	CFC Calculations							
11	TRC	1.3.2.iii	WLA_afc = 127.023	1.3.2.iii	WLA_cfc = 123.830							
12	PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581							
13	PENTOXSD TRG	5.1b	LTA_afc = 47.332	5.1d	LTA_cfc = 71.989							
14												
15	Source	Effluent Limit Calculations										
16	PENTOXSD TRG	5.1f	AML MULT = 1.231									
17	PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500		BAT/BPJ							
18			INST MAX LIMIT (mg/l) = 1.635									
<p>WLA_afc      <math>(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))...\\ ...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)</math></p> <p>LTAMULT_afc    <math>EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)</math></p> <p>LTA_afc        <math>wla_afc*LTAMULT_afc</math></p> <p>WLA_cfc        <math>(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))...\\ ...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)</math></p> <p>LTAMULT_cfc    <math>EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)</math></p> <p>LTA_cfc        <math>wla_cfc*LTAMULT_cfc</math></p> <p>AML MULT        <math>EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))</math></p> <p>AVG MON LIMIT   <math>MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)</math></p> <p>INST MAX LIMIT   <math>1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)</math></p>												

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC																																	
20A		35482 SHENANGO RIVER			15.800	1094.00	742.00	0.00000	0.00	<input checked="" type="checkbox"/>																																	
<b>Stream Data</b>																																											
<b>Design Cond.</b>	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)																																	
<table> <tr> <td>Q7-10</td><td>0.100</td><td>0.00</td><td>27.10</td><td>0.000</td><td>0.000</td><td>0.0</td><td>0.00</td><td>0.00</td><td>20.00</td><td>7.00</td></tr> <tr> <td>Q1-10</td><td></td><td></td><td>0.00</td><td>0.000</td><td>0.000</td><td></td><td></td><td></td><td>0.00</td><td>0.00</td></tr> <tr> <td>Q30-10</td><td></td><td></td><td>0.00</td><td>0.000</td><td>0.000</td><td></td><td></td><td></td><td></td><td></td></tr> </table>											Q7-10	0.100	0.00	27.10	0.000	0.000	0.0	0.00	0.00	20.00	7.00	Q1-10			0.00	0.000	0.000				0.00	0.00	Q30-10			0.00	0.000	0.000					
Q7-10	0.100	0.00	27.10	0.000	0.000	0.0	0.00	0.00	20.00	7.00																																	
Q1-10			0.00	0.000	0.000				0.00	0.00																																	
Q30-10			0.00	0.000	0.000																																						
<b>Discharge Data</b>																																											
		Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH																																		
		Pulaski TWP	PA0238945	0.0440	0.0440	0.0440	0.000	25.00	7.00																																		
<b>Parameter Data</b>																																											
				Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)																																				
				CBOD5	25.00	2.00	0.00	1.50																																			
				Dissolved Oxygen	3.00	8.24	0.00	0.00																																			
				NH3-N	25.00	0.00	0.00	0.70																																			

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC																																	
20A	35482	SHENANGO RIVER			15.800	1094.00	742.00	0.00000	0.00	<input checked="" type="checkbox"/>																																	
<b>Stream Data</b>																																											
<b>Design Cond.</b>	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)																																	
<table> <tr> <td>Q7-10</td><td>0.100</td><td>0.00</td><td>27.10</td><td>0.000</td><td>0.000</td><td>0.0</td><td>0.00</td><td>0.00</td><td>20.00</td><td>7.00</td></tr> <tr> <td>Q1-10</td><td></td><td></td><td>0.00</td><td>0.000</td><td>0.000</td><td></td><td></td><td></td><td></td><td></td></tr> <tr> <td>Q30-10</td><td></td><td></td><td>0.00</td><td>0.000</td><td>0.000</td><td></td><td></td><td></td><td></td><td></td></tr> </table>											Q7-10	0.100	0.00	27.10	0.000	0.000	0.0	0.00	0.00	20.00	7.00	Q1-10			0.00	0.000	0.000						Q30-10			0.00	0.000	0.000					
Q7-10	0.100	0.00	27.10	0.000	0.000	0.0	0.00	0.00	20.00	7.00																																	
Q1-10			0.00	0.000	0.000																																						
Q30-10			0.00	0.000	0.000																																						
<b>Discharge Data</b>																																											
		Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH																																		
		Pulaski TWP	PA0238945	0.0440	0.0440	0.0440	0.000	25.00	7.00																																		
<b>Parameter Data</b>																																											
				Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)																																				
				CBOD5	25.00	2.00	0.00	1.50																																			
				Dissolved Oxygen	3.00	8.24	0.00	0.00																																			
				NH3-N	25.00	0.00	0.00	0.70																																			

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>			<u>Stream Code</u>			<u>Stream Name</u>							
20A			35482			SHENANGO RIVER							
RMI	Stream Flow	PWS Wth	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH	
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)		
<b>Q7-10 Flow</b>													
15.800	27.10	0.00	27.10	.0681 0.00019	1.068	107.68	100.85	0.24	0.517	20.01	7.00		
<b>Q1-10 Flow</b>													
15.800	17.34	0.00	17.34	.0681 0.00019	NA	NA	NA	0.18	0.664	20.02	7.00		
<b>Q30-10 Flow</b>													
15.800	36.86	0.00	36.86	.0681 0.00019	NA	NA	NA	0.28	0.436	20.01	7.00		

## WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

### WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>				
20A	35482	SHENANGO RIVER					
<b>NH3-N Acute Allocations</b>							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
15.800	Pulaski TWP	16.73	50	16.73	50	0	0
<b>NH3-N Chronic Allocations</b>							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
15.800	Pulaski TWP	1.89	25	1.89	25	0	0
<b>Dissolved Oxygen Allocations</b>							
RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>	
15.80	Pulaski TWP	25	25	25	25	3	3
						0	0

**WQM 7.0 D.O.Simulation**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>	
20A	35482	SHENANGO RIVER	
<u>RMI</u> 15.800	<u>Total Discharge Flow (mgd)</u> 0.044	<u>Analysis Temperature (°C)</u> 20.013	<u>Analysis pH</u> 7.000
<u>Reach Width (ft)</u> 107.681	<u>Reach Depth (ft)</u> 1.068	<u>Reach WDRatio</u> 100.854	<u>Reach Velocity (fps)</u> 0.236
<u>Reach CBOD5 (mg/L)</u> 2.06	<u>Reach Kc (1/days)</u> 0.032	<u>Reach NH3-N (mg/L)</u> 0.06	<u>Reach Kn (1/days)</u> 0.701
<u>Reach DO (mg/L)</u> 8.230	<u>Reach Kr (1/days)</u> 0.209	<u>Kr Equation</u> Tsivoglou	<u>Reach DO Goal (mg/L)</u> 5
<u>Reach Travel Time (days)</u> 0.517	<b>Subreach Results</b>		
	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)
		0.052	2.05
		0.103	2.05
		0.155	2.05
		0.207	2.04
		0.259	2.04
		0.310	2.04
		0.362	2.03
		0.414	2.03
		0.465	2.03
		0.517	2.02
			D.O. (mg/L)
			0.06
			8.22
			8.22
			8.22
			8.21
			8.21
			8.20
			8.20
			8.20
			8.20
			8.19

**WQM 7.0 Effluent Limits**

<b><u>SWP Basin</u></b>	<b><u>Stream Code</u></b>	<b><u>Stream Name</u></b>					
<b>20A</b>	<b>35482</b>	<b>SHENANGO RIVER</b>					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
15.800	Pulaski TWP	PA0238945	0.044	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			3



## Discharge Information

Instructions   Discharge   Stream

Facility: Pulaski Township Municipal Authority   NPDES Permit No.: PA0238945   Outfall No.: 001

Evaluation Type: Major Sewage / Industrial Waste   Wastewater Description: Sewage effluent

Discharge Characteristics						
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)			Complete Mix Times (min)
			AFC	CFC	THH	
0.044	100	7				

		Discharge Pollutant	Units	Max Discharge Conc	Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteria Mod	Chem Transl
Group 1	Total Dissolved Solids (PWS)	mg/L											
	Chloride (PWS)	mg/L											
	Bromide	mg/L											
	Sulfate (PWS)	mg/L											
	Fluoride (PWS)	mg/L											
Group 2	Total Aluminum	µg/L											
	Total Antimony	µg/L											
	Total Arsenic	µg/L											
	Total Barium	µg/L											
	Total Beryllium	µg/L											
	Total Boron	µg/L											
	Total Cadmium	µg/L											
	Total Chromium (III)	µg/L											
	Hexavalent Chromium	µg/L											
	Total Cobalt	µg/L											
	Total Copper	mg/L	0.005										
	Free Cyanide	µg/L											
	Total Cyanide	µg/L											
	Dissolved Iron	µg/L											
	Total Iron	µg/L											
	Total Lead	mg/L	0.0004										
	Total Manganese	µg/L											
	Total Mercury	µg/L											
	Total Nickel	µg/L											
	Total Phenols (Phenolics) (PWS)	µg/L											
	Total Selenium	µg/L											
	Total Silver	µg/L											
	Total Thallium	µg/L											
	Total Zinc	mg/L	0.03										
	Total Molybdenum	µg/L											
Group 3	Acrolein	µg/L	<										
	Acrylamide	µg/L	<										
	Acrylonitrile	µg/L	<										
	Benzene	µg/L	<										
	Bromoform	µg/L	<										







## Stream / Surface Water Information

Toxics Management Spreadsheet  
Version 1.4, May 2023

Pulaski Township Municipal Authority, NPDES Permit No. PA0238945, Outfall 001

Instructions   **Discharge**   Stream

Receiving Surface Water Name: **Shenango River**

No. Reaches to Model: 1

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi <sup>2</sup> )*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	035482	15.8	1094	742		Yes	
End of Reach 1	035482	13.8	1092	759			Yes

**Q<sub>7-10</sub>**

Location	RMI	LFY (cfs/mi <sup>2</sup> )*	Flow (cfs)	W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary	Stream
	Stream	Tributary							Hardness	pH
Point of Discharge	15.8	0.1	27.1						100	7
End of Reach 1	13.8	0.1	27.8						100	7

**Q<sub>h</sub>**

Location	RMI	LFY (cfs/mi <sup>2</sup> )*	Flow (cfs)	W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary	Stream
	Stream	Tributary							Hardness	pH
Point of Discharge	15.8									
End of Reach 1	13.8									



## Model Results

Pulaski Township Municipal Authority, NPDES Permit No. PA0238945, Outfall 001

<input type="button" value="Instructions"/>	<input checked="" type="button" value="Results"/>
<input type="button" value="RETURN TO INPUTS"/>	<input type="button" value="SAVE AS PDF"/>
<input type="button" value="PRINT"/>	<input checked="" type="radio"/> All <input type="radio"/> Inputs <input type="radio"/> Results <input type="radio"/> Limits

Hydrodynamics

Wasteload Allocations

AFC      CCT (min):       PMF:       Analysis Hardness (mg/l):       Analysis pH:

Pollutants	Stream Conc ( $\mu\text{g/L}$ )	Stream CV	Trib Conc ( $\mu\text{g/L}$ )	Fate Coef	WQC ( $\mu\text{g/L}$ )	WQ Obj ( $\mu\text{g/L}$ )	WLA ( $\mu\text{g/L}$ )	Comments
Total Copper	0	0	0	0	13.439	14.0	683	Chem Translator of 0.96 applied
Total Lead	0	0	0	0	64.581	81.6	3,983	Chem Translator of 0.791 applied
Total Zinc	0	0	0	0	117.180	120	5,844	Chem Translator of 0.978 applied

CFC	CCT (min):	720	PMF:	0.831	Analysis Hardness (mgf):	100	Analysis pH:	7.00
-----	------------	-----	------	-------	--------------------------	-----	--------------	------

PMF: 0.831

cCT (min): 720

CFC

Analysis pH:

Analysis Hardness (mg/l): 100

(mg/l):

PMF: 0.831

cCT (min): 720

CFC

Analysis pH:	N/A
Analysis Hardness (mol/L):	N/A

0831

CCT (min): 720

7



✓ Recommended WQBELs & Monitoring Requirements

No. Samples/Month:

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., < Target QL).