

Application Type Renewal
Facility Type Non-Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0239003
APS ID 1017725
Authorization ID 1316801

Applicant and Facility Information

Applicant Name	<u>H&H Property Investments, LLC</u>	Facility Name	<u>Perry Lake Estates MHP</u>
Applicant Address	<u>21 Winnow Drive</u> <u>Clayton, DE 19938</u>	Facility Address	<u>126 Holly Circle</u> <u>Harmony, PA 16037</u>
Applicant Contact	<u>Tessie Harrison</u>	Facility Contact	<u>Tessie Harrison</u>
Applicant Phone	<u>(267) 981-4783</u>	Facility Phone	<u>(267) 981-4783</u>
Client ID	<u>236252</u>	Site ID	<u>445365</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Lancaster Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Butler County</u>
Date Application Received	<u>May 22, 2020</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>June 10, 2020</u>	If No, Reason	<u>-</u>

Purpose of Application Renewal of an NPDES Permit for an existing discharge of treated sanitary wastewater. This is permit is being drafted for a second time due to compliance issues preventing final issuance. The first draft was noticed more than two years ago, so it is being redrafted to provide for public comment.

Summary of Review

Act 14 - Proof of Notification was submitted and received.
A Part II Water Quality Management permit is not required at this time.
The applicant should be able to continue to meet the limits of this permit, which will protect the uses of the receiving stream.

I. OTHER REQUIREMENTS:

- A. Stormwater into sewers
- B. Right of way
- C. Solids handling
- D. Public sewerage availability
- E. Effluent Chlorine Optimization and Minimization

SPECIAL CONDITIONS:

- II. Solids Management

There are 5 open violations in efacts associated with the subject Client ID (236252) as of 1/9/2024 (see Attachment 1). *The permittee will be notified of the open violations in the Draft Permit Cover Letter and given an opportunity to address the violations prior to final permit issuance. CWY 1/9/2024*

Approve	Deny	Signatures	Date
X		Stephen A. McCauley Stephen A. McCauley, E.I.T. / Environmental Engineering Specialist	1/9/2024
X		Chad W. Yurisc Chad W. Yurisc, P.E. / Environmental Engineer Manager	1/9/2024

Discharge, Receiving Waters and Water Supply Information

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.0046</u>
Latitude	<u>40° 52' 30.00"</u>	Longitude	<u>-80° 8' 40.00"</u>
Quad Name	<u>-</u>	Quad Code	<u>-</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Scholars Run (WWF)</u>	Stream Code	<u>34913</u>
NHD Com ID	<u>126216798</u>	RMI	<u>5.9</u>
Drainage Area	<u>0.35</u>	Yield (cfs/mi ²)	<u>0.047 (Buffalo Cr. 1976-1996)</u>
Q ₇₋₁₀ Flow (cfs)	<u>0.016</u>	Q ₇₋₁₀ Basis	<u>calculated</u>
Elevation (ft)	<u>1200</u>	Slope (ft/ft)	<u>0.01578</u>
Watershed No.	<u>20-C</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u>-</u>	Existing Use Qualifier	<u>-</u>
Exceptions to Use	<u>-</u>	Exceptions to Criteria	<u>-</u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u>-</u>		
Source(s) of Impairment	<u>-</u>		
TMDL Status	<u>-</u>	Name	<u>-</u>
Background/Ambient Data		Data Source	
pH (SU)	<u>-</u>		<u>-</u>
Temperature (°F)	<u>-</u>		<u>-</u>
Hardness (mg/L)	<u>-</u>		<u>-</u>
Other:	<u>-</u>		<u>-</u>
Nearest Downstream Public Water Supply Intake	<u>Beaver Falls Municipal Water Authority - Eastvale</u>		
PWS Waters	<u>Beaver River</u>	Flow at Intake (cfs)	<u>561</u>
PWS RMI	<u>3.5</u>	Distance from Outfall (mi)	<u>33.0</u>

Sludge use and disposal description and location(s): Sludge is hauled to the New Castle WWTP, where it is disposed of at an approved landfill.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the Pennsylvania Bulletin in accordance with 25 Pa. Code § 92a.82. Upon publication in the Pennsylvania Bulletin, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the Pennsylvania Bulletin at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Narrative: This Fact Sheet details the determination of draft NPDES permit limits for an existing discharge of 0.0046 MGD of treated sewage from a MHP in Lancaster Township, Butler County.

Treatment permitted under Water Quality Management Permit No. 1003404 consists of the following: A 1,700 gallon flow equalization tank, a Bio-Wheel rotating biological contactor package STP that provides aeration as well as 2,367 square feet of contact stabilization, an integral 1,064 gallon clarifier, chemical addition for ammonia and phosphorus control, chlorine tablet disinfection with a 376 gallon chlorine contact tank, and a 1,970 gallon aerated sludge holding tank.

1. Streamflow:

Buffalo Creek at Freeport, PA (1976-1996) - used for most Connoquenessing Creek discharges:

Q ₇₋₁₀ :	<u>137</u>	cfs	(USGS StreamStats)
Drainage Area:	<u>6.37</u>	sq. mi.	(USGS StreamStats)
Yieldrate:	<u>0.047</u>	cfs/m	calculated

Scholars Run at Outfall 001:

Yieldrate:	<u>0.047</u>	cfs/m	calculated above
Drainage Area:	<u>0.35</u>	sq. mi.	(USGS StreamStats)
Q ₇₋₁₀ :	<u>0.016</u>	cfs	calculated

% of stream allocated: 100% Basis: No nearby discharges

2. Wasteflow:

Maximum discharge: 0.0046 MGD = 0.0071 cfs

Runoff flow period: 24 hours Basis: Runoff flow with flow equalization

There is greater than 3 parts stream flow (Q7-10) to 1 part effluent (design flow). In accordance with the SOP, the treatment requirements in document number 391-2000-014, titled, "Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers", dated April 12, 2008, are not required to be evaluated for this facility.

Flow will be required to be monitored as authorized under Chapter 92a.61, and as recommended in the SOP.

3. Parameters:

The following parameters were evaluated: pH, Total Suspended Solids, Fecal Coliform, E. Coli, Total Phosphorus, Total Nitrogen, NH₃-N, CBOD₅, Dissolved Oxygen, and Disinfection.

a. pH

Between 6.0 and 9.0 at all times

Basis: Application of Chapter 93.7 technology-based limits.

The measurement frequency was previously set to 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001), which will be retained.

b. Total Suspended Solids

Limits are 30.0 mg/l as a monthly average and 60.0 as an instantaneous maximum.

Basis: Application of Chapter 92a47 technology-based limits.

c. Fecal Coliform

05/01 - 09/30: 200/100ml (monthly average geometric mean)
1,000/100ml (instantaneous maximum)

10/01 - 04/30: 2,000/100ml (monthly average geometric mean)
10,000/100ml (instantaneous maximum)

Basis: Application of Chapter 92a47 technology-based limits

d. E. Coli

Monitoring was added for E. Coli at a frequency of 1/year.

Basis: Application of Chapter 92a.61 as recommended by the SOP for flows greater than 0.002 MGD and less than 0.05 MGD.

e. Total Phosphorus

The previous limits based on Chapter 96.5 to protect the Connoquenessing Creek will be retained with this renewal.

f. Total Nitrogen

The previous monitoring for Total Nitrogen will be retained in accordance with the SOP, based on Chapter 92a.61.

g. Ammonia-Nitrogen (NH₃-N)

Median discharge pH to be used: 7.2 Standard Units (S.U.)

Basis: eDMR data

Discharge temperature: 25°C (default value used in the absence of data)

Median stream pH to be used: 7.0 Standard Units (S.U.)

Basis: default value used in the absence of data

Stream Temperature: 25°C (default value used for WWF modeling)

Background NH₃-N concentration: 0.1 mg/l

Basis: Default value.

Calculated NH₃-N Summer limits: 5.5 mg/l (monthly average)
11.0 mg/l (instantaneous maximum)

Calculated NH₃-N Winter limits: 16.5 mg/l (monthly average)
33.0 mg/l (instantaneous maximum)

Result: WQ modeling resulted in the summer limits above (see Attachment 2). The winter limits are calculated as three times the summer limits. Since the previous NH₃-N limits are more restrictive, and are being attained, they will be retained.

h. CBOD₅

Median discharge pH to be used: 7.2 Standard Units (S.U.)

Basis: eDMR data

Discharge temperature: 25°C (default value used in the absence of data)

Median stream pH to be used: 7.0 Standard Units (S.U.)

Basis: default value used in the absence of data

Stream Temperature: 25°C (default value used for WWF modeling)

Background CBOD₅ concentration: 2.0 mg/l

Basis: Default value

Calculated CBOD₅ limits: 25.0 mg/l (monthly average)

50.0 mg/l (instantaneous maximum)

Result: WQ modeling resulted in the limits above (see Attachment 2), which are the same as in the previous permit and will be retained.

i. Dissolved Oxygen (DO)

The Dissolved Oxygen minimum of 4.0 mg/l will be retained with this renewal. The technology-based minimum of 4.0 mg/l is recommended by the WQ Model (see Attachment 2) and the SOP based on Chapter 93.7, under the authority of Chapter 92a.61.

The measurement frequency was previously set to 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001), which will be retained.

j. Disinfection

Ultraviolet (UV) light monitoring

Total Residual Chlorine (TRC) limits: 0.3 mg/l (monthly average)
1.1 mg/l (instantaneous maximum)

Basis: The TRC limits above are water quality-based using the TRC Calc Spreadsheet (see Attachment 3), which are the same as the final limits in the previous permit and will be retained.

The measurement frequency was previously set to 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001), which will be retained.

4. **Reasonable Potential Analysis for Receiving Stream:**

A Reasonable Potential Analysis was not performed in accordance with State practices for Outfall 001 since no sampling other than sewage-related parameters was performed for this facility with the renewal application.

5. Reasonable Potential for Downstream Public Water Supply (PWS):

The Reasonable Potential Analysis performed above does not calculate limits for parameters that are based on PWS criteria (TDS, Chloride, Bromide, and Sulfate). However, since no data was provided, mass-balance calculations were not able to be performed.

Nearest Downstream potable water supply (PWS): Beaver Falls Municipal Water Authority - Eastvale
Distance downstream from the point of discharge: 33.0 miles (approximate)

Basis: No limits or monitoring are necessary as significant dilution is available.

6. Anti-Backsliding:

Since all the permit limits in this renewal are the same or more restrictive than the previous NPDES Permit, anti-backsliding is not applicable.

6. Attachment List:

- Attachment 1 - Open Violations by Client
- Attachment 2 - WQ Modeling Printouts
- Attachment 3 - TRC_Calc Spreadsheet

(The Attachments above can be found at the end of this document)

Compliance History

DMR Data for Outfall 001 (from December 1, 2022 to November 30, 2023)

Parameter	NOV-23	OCT-23	SEP-23	AUG-23	JUL-23	JUN-23	MAY-23	APR-23	MAR-23	FEB-23	JAN-23	DEC-22
Flow (MGD) Average Monthly	0.0016	0.00171	0.00164	0.00158	0.00169	0.00098	E	E	E	E	E	E
Flow (MGD) Daily Maximum	0.0028	0.00281	0.00258	0.0022	0.0051	0.0017	E	E	E	E	E	E
pH (S.U.) Minimum	7.4	7.59	6.99	7.27	6.74	6.69	6.02	6.21	E	E	E	E
pH (S.U.) Maximum	8.99	8.99	8.8	8.58	8.63	7.83	7.73	7.59	E	E	E	E
DO (mg/L) Minimum	4.91	4.54	4.01	4.88	1.16	0.88	0.9	1.58	E	E	E	E
TRC (mg/L) Average Monthly	0.08	< 0.06	0.07	< 0.06	0.08	0.09	0.08	0.59	E	E	E	E
TRC (mg/L) Instantaneous Maximum	0.25	0.24	0.38	0.72	0.23	0.22	0.22	1.52	E	E	E	E
CBOD5 (mg/L) Average Monthly	18.1	17.5	27.9	26	< 33.5	21.5	51.2	81.2	266.7	< 117.8	< 41.9	60.7
CBOD5 (mg/L) Instantaneous Maximum	32	23.3	66.2	60.1	118	53.1	132	155	551	303	63.6	70.5
TSS (mg/L) Average Monthly	757	56	67	63	15	129	183	179	72	199	20	23
TSS (mg/L) Instantaneous Maximum	1460	57	98	70	18	248	348	274	108	370	29	25
Fecal Coliform (CFU/100 ml) Geometric Mean	2420	68	312	> 85	< 7	69	< 1	> 2420	> 2420	> 2420	> 2420	> 2420
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	2420	82	649	> 2420	44	473	1	> 2420	> 2420	> 2420	> 2420	> 2420
Total Nitrogen (mg/L) Average Monthly	44.3	32	29.5	43.2	19.7	51.3	39.5	79.3	52	89.3	43.6	47.9
Ammonia (mg/L) Average Monthly	29.3	22.3	20.9	29.7	20.3	3.13	24.0	26.9	40.1	41.7	28.4	39.5
Ammonia (mg/L) Instantaneous Maximum	31.7	23.4	21.0	32.3	27.1	4.98	26.7	48.0	42.6	43.3	28.9	40.3
Total Phosphorus (mg/L) Average Monthly	9.8	5.57	5.44	5.09	2.63	5.65	5.8	9.14	9.55	8.22	7.34	6.65
Total Phosphorus (mg/L) Instantaneous Maximum	11.5	5.85	6.3	5.14	3.4	9.6	8.72	9.94	12.5	11.6	9.72	6.8

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0 Daily Max	XXX	1/day	Grab
DO	XXX	XXX	4.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.3	XXX	1.1	1/day	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50.0	2/month	Grab
TSS	XXX	XXX	XXX	30.0	XXX	60.0	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	1/month	Grab
Ammonia Nitrogen Nov 1 - Apr 30	XXX	XXX	XXX	10.5	XXX	21.0	2/month	Grab
Ammonia- Nitrogen May 1 - Oct 31	XXX	XXX	XXX	3.5	XXX	7.0	2/month	Grab
Total Phosphorus	XXX	XXX	XXX	2.0	XXX	4.0	2/month	Grab

Compliance Sampling Location: at Outfall 001, after disinfection.

Flow is monitor only based on Chapter 92a.61. The limits for pH and Dissolved Oxygen are technology-based on Chapter 93.7. The Total Residual Chlorine (TRC) limits are water quality-based on Chapter 93.7. The limits for CBOD₅, Total Suspended Solids, and Fecal Coliforms are technology-based on Chapter 92a.47. Monitoring for E. Coli and Total Nitrogen is based on Chapter 92a.61. The limits for Ammonia-Nitrogen are water quality-based on Chapter 93.7. The limits for Total Phosphorus are based on Chapter 96.5.

Attachment 1



**WATER MANAGEMENT SYSTEM
OPEN VIOLATIONS BY CLIENT**

Client ID: 236252

Client: All

Open Violations: 5

CLIENT ID	CLIENT	PF ID	FACILITY	PF KIND	PF STATUS	INSP PROGRAM
236252	H & H PROP INVESTMENTS LLC	470387	PERRY LAKE ESTATES	Community	Active	Safe Drinking Water
236252	H & H PROP INVESTMENTS LLC	631232	PERRY LAKE ESTATES MHP	Sewage Non-Publicly Owned (Non-Muni)	Active	WPC NPDES
236252	H & H PROP INVESTMENTS LLC	631232	PERRY LAKE ESTATES MHP	Sewage Non-Publicly Owned (Non-Muni)	Active	WPC NPDES
236252	H & H PROP INVESTMENTS LLC	631232	PERRY LAKE ESTATES MHP	Sewage Non-Publicly Owned (Non-Muni)	Active	WPC NPDES
236252	H & H PROP INVESTMENTS LLC	631232	PERRY LAKE ESTATES MHP	Sewage Non-Publicly Owned (Non-Muni)	Active	WPC NPDES

PROGRAM SPECIFIC ID	INSP ID	VIOLATION ID	INSPECTION CATEGORY	VIOLATION DATE	VIOLATION CODE	VIOLATION	PF INSPECTOR	INSP REGION
5100043	3561485	996808	PF	05/23/2023	C7	FAILURE TO COMPLY WITH A PERMIT CONDITION	MUHA,LARRY	NWRO
PA0239003	3331032	947164	PF	03/02/2022	CSL611A	CSL - Failure to comply with a DEP-issued enforcement order	SINGER,SEAN	NWRO
PA0239003	3390192	961404	PF	07/11/2022	CSL611A	CSL - Failure to comply with a DEP-issued enforcement order	SINGER,SEAN	NWRO
PA0239003	3437105	971446	PF	10/06/2022	CSL611A	CSL - Failure to comply with a DEP-issued enforcement order	SINGER,SEAN	NWRO
PA0239003	3533337	990529	PF	04/04/2023	CSL611A	CSL - Failure to comply with a DEP-issued enforcement order	SINGER,SEAN	NWRO

Attachment 2

WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
20C		34913		SCHOLARS RUN			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
5.900	Perry Lake	PA0239003	0.005	CBOD5	25		
				NH3-N	5.57	11.14	
				Dissolved Oxygen			4

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
20C	34913	SCHOLARS RUN		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
5.900	0.005	25.000	7.051	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
2.378	0.278	8.563	0.036	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
8.95	0.580	1.68	1.029	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
6.471	28.037	Owens	5	
<u>Reach Travel Time (days)</u>	Subreach Results			
2.054	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.205	7.70	1.36	7.54
	0.411	6.63	1.10	7.54
	0.616	5.71	0.89	7.54
	0.822	4.91	0.72	7.54
	1.027	4.23	0.59	7.54
	1.233	3.64	0.47	7.54
	1.438	3.13	0.38	7.54
	1.643	2.70	0.31	7.54
	1.849	2.32	0.25	7.54
	2.054	2.00	0.20	7.54

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20C	34913	SCHOLARS RUN	5.900	1200.00	0.35	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.047	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Perry Lake	PA0239003	0.0046	0.0000	0.0000	0.000	25.00	7.20

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	7.54	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20C	34913	SCHOLARS RUN	4.700	1100.00	1.20	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.047	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00
Parameter Data							
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
CBOD5	25.00	2.00	0.00	1.50			
Dissolved Oxygen	3.00	8.24	0.00	0.00			
NH3-N	25.00	0.00	0.00	0.70			

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
20C		34913				SCHOLARS RUN						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow												
5.900	0.02	0.00	0.02	.0071	0.01578	.278	2.38	8.56	0.04	2.054	25.00	7.05
Q1-10 Flow												
5.900	0.01	0.00	0.01	.0071	0.01578	NA	NA	NA	0.03	2.416	25.00	7.07
Q30-10 Flow												
5.900	0.02	0.00	0.02	.0071	0.01578	NA	NA	NA	0.04	1.812	25.00	7.04

WQM 7.0 Wasteload Allocations

SWP Basin **Stream Code** **Stream Name**
20C 34913 SCHOLARS RUN

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
	5.900 Perry Lake	10.38	25.75	10.38	25.75	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
	5.900 Perry Lake	1.35	5.57	1.35	5.57	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
	5.90 Perry Lake	25	25	5.57	5.57	4	4	0	0

Attachment 3

TRC EVALUATION				
Input appropriate values in A3:A9 and D3:D9				
0.016	= Q stream (cfs)	0.5	= CV Daily	
0.0048	= Q discharge (MGD)	0.5	= CV Hourly	
30	= no. samples	1	= AFC_Partial Mix Factor	
0.3	= Chlorine Demand of Stream	1	= CFC_Partial Mix Factor	
0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)	
0.5	= BAT/BPJ Value	720	= CFC_Criteria Compliance Time (min)	
0	= % Factor of Safety (FOS)	0	= Decay Coefficient (K)	
Source	Reference	AFC Calculations		Reference
TRC	1.3.2.iii	WLA_afc = 0.736		1.3.2.iii
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c
PENTOXSD TRG	5.1b	LTA_afc = 0.274		5.1d
		WLA_cfc = 0.710		
		LTAMULT_cfc = 0.581		
		LTA_cfc = 0.413		
Source	Effluent Limit Calculations			
PENTOXSD TRG	5.1f	AML_MULT = 1.231		
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.338		AFC
		INST MAX LIMIT (mg/l) = 1.104		
WLA_afc	$(.019/e^{-k \cdot AFC_tc}) + [(AFC_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC_tc}) \dots + Xd + (AFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$			
LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$			
LTA_afc	$wla_afc \cdot LTAMULT_afc$			
WLA_cfc	$(.011/e^{-k \cdot CFC_tc}) + [(CFC_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC_tc}) \dots + Xd + (CFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$			
LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no_samples + 1)) - 2.326 \cdot LN(cvd^2 / no_samples + 1)^{0.5})$			
LTA_cfc	$wla_cfc \cdot LTAMULT_cfc$			
AML_MULT	$EXP(2.326 \cdot LN((cvd^2 / no_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no_samples + 1))$			
AVG MON LIMIT	$MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) \cdot AML_MULT)$			
INST MAX LIMIT	$1.5 \cdot ((av_mon_limit / AML_MULT) / LTAMULT_afc)$			