

Application Type Renewal  
Facility Type Non-Municipal  
Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0239437  
APS ID 983438  
Authorization ID 1256275

**Applicant and Facility Information**

Applicant Name	<u>Human Service Center</u>	Facility Name	<u>Edgewood Group Home</u>
Applicant Address	<u>130 W North Street</u> <u>New Castle, PA 16101-3906</u>	Facility Address	<u>Human Services Ctr 130 W North Street</u> <u>New Castle, PA 16101</u>
Applicant Contact	<u>Michele Kelly-Thompson</u>	Facility Contact	<u></u>
Applicant Phone	<u>(724) 658-3578</u>	Facility Phone	<u></u>
Applicant E Mail	<u>mkthompson@humanservicescenter.net</u>	Facility E Mail	<u></u>
Client ID	<u>125</u>	Site ID	<u>615162</u>
Municipality	<u>Pulaski Township</u>	County	<u>Lawrence</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Connection Status	<u>No Limitations</u>
SIC Code	<u>8361</u>	SIC Code	<u>4952</u>
SIC Description	<u>Services - Residential Care</u>	SIC Description	<u>Trans. &amp; Utilities - Sewerage Systems</u>
Application Received	<u>December 24, 2018</u>	EPA Waived?	<u>Yes</u>
Application Accepted	<u>January 16, 2019</u>	If No, Reason	<u></u>
Application Purpose	<u>NPDES permit renewal</u>		

**Summary of Review**

The facility design flow is marginally above that for a small flow sewage treatment facility.

Poor effluent quality led to UV radiation disinfection failure and reactivation of the formerly permitted chlorine disinfection system. A Consent Order and Agreement (CO&A) is pending addressing the poor effluent quality and disinfection. Anticipated compliance is through a connection to a local publicly operated treatment works (POTW).

Proposed:

Reducing the ammonia monthly average from 6.0 to 5.0-mg/L and TRC monthly average from 0.9 to 0.5-mg/L. *(A 3-year compliance schedule will be provided for compliance with the new WQBEL for Ammonia-Nitrogen because the facility has demonstrated that they CANNOT consistently meet this limitation. NO compliance schedule is being provided for TRC since the facility has demonstrated that they CAN consistently meet this limitation).* JCD

Increasing the effluent minimum daily DO to 4.0mg/L and DO, pH and TRC monitoring frequency from weekly to daily.

UV radiation monitoring has been discontinued as not necessary.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		<i>William H. Mentzer</i> William H. Mentzer, P.E. Environmental Engineering Specialist	May 19, 2022
X		Justin C. Dickey Justin C. Dickey, P.E. Environmental Engineer Manager	July 1, 2022

**Discharge, Receiving Waters and Water Supply Information**

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.0022</u>
Latitude DP	<u>41° 6' 18.00"</u>	Longitude DP	<u>-80° 25' 6.00"</u>
Latitude NHD	<u>41° 6' 23.07"</u>	Longitude NHD	<u>-80° 25' 11.69"</u>
Quad Name	<u>Edinburg</u>	Quad Code	<u>1002</u>
Wastewater:	<u>Treated domestic wastes from a group home</u>		

Receiving Waters	<u>Unnamed Tributary to Shenango River</u>	Stream Code	<u>35883</u>
NHD Com ID	<u>130025424</u>	RMI	<u>0.88</u>
Drainage Area	<u>0.35</u>	Yield (cfs/mi <sup>2</sup> )	<u>0.021</u>
Q <sub>7-10</sub> Flow (cfs)	<u>0.007</u>	Q <sub>7-10</sub> Basis	<u>Shenango River at Sharon</u>
Elevation (ft)	<u>870.246</u>	Slope (ft/ft)	<u>0.00028</u>
Watershed No.	<u>20-A</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u>statewide</u>	Existing Use Qualifier	<u>none</u>
Exceptions to Use	<u>none</u>	Exceptions to Criteria	<u>none</u>

Assessment Status Attaining Use(s)

Cause(s) of Impairment \_\_\_\_\_

Source(s) of Impairment \_\_\_\_\_

TMDL Status \_\_\_\_\_ Name \_\_\_\_\_

Background/Ambient Data		Data Source	
pH (SU)	<u>7.0</u>	default	
Temperature (°C)	<u>25</u>	WWF default	
Hardness (mg/L)			
CBOD5	<u>1.0</u>	Default	
Ammonia	<u>0.1</u>	default	

Nearest Downstream Public Water Supply Intake	<u>Pennsylvania American Water – New Castle District</u>		
PWS Waters	<u>Shenango River</u>	Flow at Intake (cfs)	<u>118.24</u>
PWS RMI	<u>5.02</u>	Distance from Outfall (mi)	<u>9.67</u>

Changes Since Last Permit Issuance:  
none

Other Comments:  
Stream flow is minimum flow at Sharon less water intake plus accrued drainage times the yield.

**Treatment Facility Summary**

**Treatment Facility Name:** Edgewood Group Home

WQM Permit No.	Issuance Date
3704404	June 8, 2004

Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Activated Sludge	Ultraviolet	0.0022
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.0022	4.6	Not Overloaded	Aerobic Digestion	Other WWTP

Changes Since Last Permit Issuance: none

Other Comments:

This NPDES permit and related WQM permit replaced NPDES permit PA0210897 and WQM Permit 3793405. This NPDES permit moved the discharge 175-feet upstream while the WQM permit included UV disinfection.

Planning approval

Approval Date: 28 July 2003  
 Design Year 2004  
 Design Population \_\_\_\_\_

Planning Code: N6-02-294  
 Design year should be the ultimate need.  
 SFTF facilities

Approval Date: 16 October 2003  
 Design Year 2004  
 Design Population 20

Planning Code: N6-03-174  
 Design year should be the ultimate need.  
 Group home

**Design is for 20 disabled or elderly people with 16 people expected to reside on site.**

**PRETREATMENT/EQUALIZATION**

Both the Westfield Adult Housing and Edgewood Group Home wastes are collected at the pump station for equalization and conveyance to the sequencing batch reactor for treatment.

The duplex submersible grinder pump station/equalization tank is rated at 24 gpm (0.03456 MGD) with flow control valving. The pump station is included in the facility description as equalization.

**TREATMENT**

Treatment is a Wagner Fluid System continuous flow sequencing batch reactor with disinfection.

This is a proprietary single tank system with a bar screen and coarse bubble diffusers.

Air supply is 22 cfm at 4.5 psig

Discharge is to be pumped to disinfection and discharge. Specified pump rate is 183 gpm (0.26 MGD).

**DISINFECTION**

Disinfection is by ultraviolet light. Specified is two low pressure 40 w lamps at 32,000 μws at 254 nm.

Sunlight Model 200 with low pressure UV lamps operating at least at 32 to 40-mWs/cm<sup>2</sup> at λ254-nm. Specifications include an intensity meter.

Direct flow measurement with a meter is not provided. The SBR is decanted (pumped) to disinfection.

**Chlorination is installed and chlorine monitored.**

Compliance History

DMR Data for Outfall 001 (from December 1, 2017 to November 30, 2018)

Parameter	NOV-18	OCT-18	SEP-18	AUG-18	JUL-18	JUN-18	MAY-18	APR-18	MAR-18	FEB-18	JAN-18	DEC-17
Flow (MGD) Ave Monthly	0.0013	0.00125	0.00119	0.00104	0.00116	0.00109	0.00115	0.00117	0.00109	0.00116	0.00183	0.00146
pH (S.U.) Minimum	7.0	7.1	7.6	6.9	6.8	7.3	7.4	7.1	7.4	7.3	6.9	6.9
pH (S.U.) Maximum	7.7	7.7	7.8	7.7	7.5	8.1	8.1	8.0	7.8	7.5	7.6	8.1
DO (mg/L) Minimum	6.98	6.10	5.27	5.03	5.51	5.64	5.84	7.26	7.25	7.14	6.87	6.0
TRC (mg/L) Ave Monthly	<u>0.365</u>	0.234	0.235	0.14	0.214	0.21	0.22	0.2	0.23	0.183	0.20	0.28
CBOD5 (mg/L) Average Monthly	21	21.9	14.7	<b>26.1</b>	13.6	14.6	22	<b>49</b>	<b>26</b>	18.3	21	24
TSS (mg/L) Ave Monthly	27.5	57	30	< 11.5	<b>30.75</b>	25.2	14.5	9.4	27.5	<b>54</b>	23	32
Fecal Coliform (#/100 ml) Geometric Mean	65	500	< 3	< 3	< 4	< 128	< 14	< 1	38	< 2	< 86	< 2
Total Nitrogen (mg/L) Average Monthly	19.15	11.6	10.4	20.95	19	13.6	15.05	15.6	22.9	17.1	8.0	< 17.9
Ammonia (mg/L) Average Monthly	<b>9.46</b>	<b>5.06</b>	<b>3.44</b>	<b>12.9</b>	<b>7.7</b>	<b>4.99</b>	<b>4.765</b>	<b>4.2</b>	<b>5</b>	<b>5.61</b>	<b>6.17</b>	<b>6.21</b>
Total Phosphorus (mg/L) Ave Monthly	4.43	4.2	4.97	7.24	6.8	6.58	6.135	4.5	5.54	5.37	1.89	5.09

DMR Data for Outfall 001 (from February 1, 2019 to January 31, 2020)

Parameter	JAN-20	DEC-19	NOV-19	OCT-19	SEP-19	AUG-19	JUL-19	JUN-19	MAY-19	APR-19	MAR-19	FEB-19
Flow (MGD) Ave Monthly	0.00129	0.0011	0.00118	0.00104	0.00109	0.00084	0.00134	0.001439	0.00147	0.000923	0.00114	0.00107
pH (S.U.) Minimum	6.8	7.1	7.2	7.1	7.3	7.6	6.9	6.8	6.9	6.8	7.3	6.7
pH (S.U.) Maximum	7.3	7.7	7.8	7.9	8.1	7.8	7.4	7.4	7.5	7.8	7.9	7.5
DO (mg/L) Minimum	7.12	7.19	6.88	6.04	5.59	5.09	5.44	6.0	6.21	6.35	7.94	7.04
TRC (mg/L) Ave Monthly	<u>0.35</u>	<u>0.31</u>	0.26	0.27	<u>0.38</u>	<u>0.34</u>	0.21	0.155	0.24	0.20	0.27	0.24
CBOD5 (mg/L) Average Monthly	5.54	< 11.35	13.13	10.2	< 5.11	< 21.1	<b>26</b>	<b>70.4</b>	12	19.7	16.25	10.36
TSS (mg/L) Ave Monthly	11.05	<b>42.3</b>	<b>38.5</b>	19	7	21.5	<b>60.5</b>	29.8	< 5.9	17.9	14.75	< 6
Fecal Coliform (#/100 ml) Geometric Mean	< 77	<b>&lt; 8</b>	<b>28</b>	12	< 1	< 79	< 6	6	< 3	13	2	3
Total Nitrogen (mg/L) Average Monthly	15.1	14.30	18.5	15.61	8.456	10	15.15	< 38.35	10.83	14.1	18.1	22.4
Ammonia (mg/L) Average Monthly	0.66	2.18	<b>3.62</b>	<b>5.03</b>	2.985	<b>4.51</b>	<b>4.69</b>	<b>14.18</b>	<b>4.275</b>	<b>3.84</b>	<b>5.31</b>	2.95
Total Phosphorus (mg/L) Average Monthly	3.34	4.14	<b>5.37</b>	<b>6.50</b>	1.90	3.437	3.48	5.26	2.875	5.99	5.13	5.26

DMR Data for Outfall 001 (from April 1, 2021 to March 31, 2022)

Parameter	MAR-22	FEB-22	JAN-22	DEC-21	NOV-21	OCT-21	SEP-21	AUG-21	JUL-21	JUN-21	MAY-21	APR-21
Flow (MGD) Average Monthly	0.0041	0.004	0.004	0.0038	0.0012	0.0014	0.0018	0.00127	0.001263	0.00127	0.00119	0.0104
pH (S.U.) Minimum	7.5	7.1	6.9	7.1	6.8	7.4	6.7	7.4	6.7	7.3	7.1	7.6
pH (S.U.) Maximum	7.9	7.8	7.4	7.8	7.3	7.7	7.8	7.9	7.4	7.9	7.7	7.7
DO (mg/L) Minimum	6	7.4	8.6	6.6	9.1	5.16	6.8	4.17	5.38	5.42	6.2	5.83
TRC (mg/L) Average Monthly	0.206	0.45	0.18	0.3	0.33	0.25	0.32	0.18	0.24	0.36	0.25	0.24
CBOD5 (mg/L) Average Monthly	14.15	21.9	9.09	27	13.3	15.8	8.28	18.3	46	5.66	10.41	17.97
TSS (mg/L) Average Monthly	35	32	16.9	40	24.4	31.3	12.49	25.5	79.8	14.4	< 7.8	12.7
Fecal Coliform (CFU/100 ml) Geometric Mean	> 52	< 1	< 1	55	< 2	< 7	< 1	< 2	21	< 8	66	< 2
Total Nitrogen (mg/L) Average Monthly	27.6	18.2	413.4	19	433.8	< 43	25.5	< 39.3	41	15.16	11.41	18.66
Ammonia (mg/L) Average Monthly	3.9	2.98	4.1	5.96	23	34.0	13.81	8.93	19.62	9.0	1.98	3.06
Total Phosphorus (mg/L) Average Monthly	6.81	4.69	2.67	3.32	2.3	3.14	2.51	3.59	5.6	4.48	7.16	4.95

Compliance History

Effluent Violations for Outfall 001, from: January 1, 2018 to: November 30, 2018

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
CBOD5	03/31/18	Avg Mo	26	mg/L	25	mg/L
CBOD5	08/31/18	Avg Mo	26.1	mg/L	25	mg/L
CBOD5	04/30/18	Avg Mo	49	mg/L	25	mg/L
TSS	07/31/18	Avg Mo	30.75	mg/L	30	mg/L
TSS	10/31/18	Avg Mo	57	mg/L	30	mg/L
TSS	02/28/18	Avg Mo	54	mg/L	30	mg/L
Ammonia	07/31/18	Avg Mo	7.7	mg/L	6.0	mg/L
Ammonia	08/31/18	Avg Mo	12.9	mg/L	6.0	mg/L

Effluent Violations for Outfall 001, from: March 1, 2019 To: January 31, 2020

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
<b>CBOD5</b>	<b>07/31/19</b>	<b>Avg Mo</b>	<b>26</b>	<b>mg/L</b>	<b>25</b>	<b>mg/L</b>
CBOD5	06/30/19	Avg Mo	70.4	mg/L	25	mg/L
<b>TSS</b>	<b>11/30/19</b>	<b>Avg Mo</b>	<b>38.5</b>	<b>mg/L</b>	<b>30</b>	<b>mg/L</b>
<b>TSS</b>	<b>12/31/19</b>	<b>Avg Mo</b>	<b>42.3</b>	<b>mg/L</b>	<b>30</b>	<b>mg/L</b>
<b>TSS</b>	<b>07/31/19</b>	<b>Avg Mo</b>	<b>60.5</b>	<b>mg/L</b>	<b>30</b>	<b>mg/L</b>
<b>Ammonia</b>	<b>06/30/19</b>	<b>Avg Mo</b>	<b>14.18</b>	<b>mg/L</b>	<b>6.0</b>	<b>mg/L</b>

Effluent Violations for Outfall 001, from: May 1, 2021 To: March 31, 2022

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
CBOD5	12/31/21	Avg Mo	27	mg/L	25	mg/L
CBOD5	07/31/21	Avg Mo	46	mg/L	25	mg/L
TSS	12/31/21	Avg Mo	40	mg/L	30	mg/L
TSS	07/31/21	Avg Mo	79.8	mg/L	30	mg/L
TSS	10/31/21	Avg Mo	31.3	mg/L	30	mg/L
TSS	02/28/22	Avg Mo	32	mg/L	30	mg/L
TSS	03/31/22	Avg Mo	35	mg/L	30	mg/L
Fecal Coliform	03/31/22	Geo Mean	> 52	CFU/100 ml	2000	CFU/100 ml
Ammonia	06/30/21	Avg Mo	9.0	mg/L	6.0	mg/L
Ammonia	07/31/21	Avg Mo	19.62	mg/L	6.0	mg/L
Ammonia	10/31/21	Avg Mo	34.0	mg/L	6.0	mg/L
Ammonia	09/30/21	Avg Mo	13.81	mg/L	6.0	mg/L
Ammonia	08/31/21	Avg Mo	8.93	mg/L	6.0	mg/L
Ammonia	11/30/21	Avg Mo	23	mg/L	18	mg/L

Summary of Inspections: March 9, 2017. Joseph McIlvenny, certified operator; Angela Hensley, WQS. Recording and totalizing flow meter present

**NPDES Permit Fact Sheet  
Edgewood Group Home**

**NPDES Permit No. PA0239437**

Other Comments:

NOV issued January 11, 2019 for effluent violations  
0.394 dry tons sludge removed to the New Castle STP

	Influent		mean PPD	min	Effluent		#
	Month	year			mean MGD	mean	
Annual Average Hydraulic			0.00220				
Organic							4.6
Annual average		2018	0.00121				
		2017	0.00123				
		2015	0.00123				
PH				7.0		7.3	8
TRC				0.06	0.375	0.84	8
Coliform				< 1	< 1	< 1	2
CBOD5				19.1	20.1	21	2
TSS				< 5	< 9.25	13.5	2
Ammonia				< 0.5	< 2.05	3.59	2
N				10.3	16.1	21.9	2
P				3.98	4.49	5.0	2

Incomplete tabulation that is not verified through self-monitoring reports

**Development of Effluent Limitations**

<b>Outfall No.</b> <u>001</u>	<b>Design Flow (MGD)</b> <u>.0022</u>
<b>Latitude</b> <u>41° 6' 18.00"</u>	<b>Longitude</b> <u>-80° 25' 6.00"</u>
<b>Wastewater Description:</b> <u>Sewage Effluent</u>	

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
DO	4-mg/L	Daily minimum		

Comments:

A 4-mg/l daily minimum DO limit is recommended based on the self-monitoring reports.

**Water Quality-Based Limitations**

Previous modelling identified ammonia for water quality evaluation.

The following limitations were determined through water quality modeling (output files attached):

Parmenter		Drainage	pH	Limit (mg/l)			SBC	Model		
		Sq Mile	SU	Mg/L	Mg/L	Mg/L		Mg/L	Mg/L	Mg/L
ammonia	summer	0.4	7.04		6.0	12.0	NA		6.3	12.5
	winter		7.04		18.0	36.0				
DO				3.0				3.0		
ammonia	summer	0.4	7.04		6.0	12.0			6.04	12.08
	winter				18.0	36.0				
DO								4.0		
ammonia	summer	<b>0.35</b>	7.6		5.0	10.0			5.25	10.5
	winter				15.0	30.0				
DO				4.0				4.0		
ammonia	summer				5.0	10.0			5.31	10.62
	winter				15.0	30.0				
DO				4.0				4.0		



Comments:

Stream Stats has reduced the drainage area from 0.422 to 0.35-square miles. Current operation reports a higher effluent pH. Previous review used a 7.04-SU summer median pH. The current summer median pH is 7.6-SU. The higher effluent pH lowers the effluent ammonia limitations by 1.0-mg/L.

*A three-year compliance schedule will be provided for Ammonia-Nitrogen. However, it is anticipated that the facility will be connected to public sewer by November 2023.* JCD

**Best Professional Judgment (BPJ) Limitations**

Comments:

Based on the facility design flow phosphorus and nitrogen have been identified for potential regulation.

**Anti-Backsliding**

Nothing appropriate

1A	B	C	D	E	F	G	H	I	J	K	L	M
	<b>Discharger Site</b>		Human Services Center						Tuesday, March 3, 2020			
	<b>Municipality</b>		Edgewood Group Home				Revised		Thursday, May 19, 2022			
	<b>County</b>		Pulaski Township									
	<b>NPDES Permit</b>		Lawrence									
			PA0239437									
2	<b>TRC EVALUATION</b>											
3	Input appropriate values in B4:B8 and E4:E7											
4	0.0080		= Q stream (cfs)			0.5						= CV Daily
5	0.0022		= Q discharge (MGD)			0.5						= CV Hourly
6	30		= no. samples			1						= AFC_Partial Mix Factor
7	0.4		= Chlorine Demand of Stream			1						= CFC_Partial Mix Factor
8	0		= Chlorine Demand of Discharge			15						= AFC_Criteria Compliance Time (min)
9	1.4		= BAT/BPJ Value			720						= CFC_Criteria Compliance Time (min)
	1		= % Factor of Safety (FOS)									= Decay Coefficient (K)
10	Source	Reference	CFC Calculations				Reference	CFC Calculations				
11	TRC	1.3.2.iii			WLA_afc = 1		1.3.2.iii			WLA_cfc = 1.085		
12	PENTOXSD TRG	5.1a			LTAMULT_afc = 0.373		5.1c			LTAMULT_cfc = 0.581		
13	PENTOXSD TRG	5.1b			LTA_afc = 0		5.1d			LTA_cfc = 0.631		
14												
15	Source	Effluent Limit Calculations										
16	PENTOXSD TRG	5.1f			AML MULT = 1.231							
17	PENTOXSD TRG	5.1g			↓ LIMIT (mg/l) = 0.511				AFC			
18					↓ LIMIT (mg/l) = 1.670							
	WLA_afc	$(0.19/e^{-(k \cdot AFC\_tc)}) + [(AFC\_Yc \cdot Qs \cdot 0.19 / Qd) \cdot e^{-(k \cdot AFC\_tc)}] \dots$ $\dots + Xd + (AFC\_Yc \cdot Qs \cdot Xs / Qd) \cdot (1 - FOS / 100)$ $EXP[(0.5 \cdot LN((cvd^2 + 1)) - 2.326 \cdot LN((cvd^2 + 1)^{0.5}))]$ $wla\_afc = LTAMULT\_afc$										
	LTAMULT_afc											
	LTA_afc											
	WLA_cfc	$(0.11/e^{-(k \cdot CFC\_tc)}) + [(CFC\_Yc \cdot Qs \cdot 0.11 / Qd) \cdot e^{-(k \cdot CFC\_tc)}] \dots$ $\dots + Xd + (CFC\_Yc \cdot Qs \cdot Xs / Qd) \cdot (1 - FOS / 100)$ $EXP[(0.5 \cdot LN((cvd^2 / no\_samples + 1)) - 2.326 \cdot LN((cvd^2 / no\_samples + 1)^{0.5}))]$ $wla\_cfc = LTAMULT\_cfc$										
	LTAMULT_cfc											
	LTA_cfc											
	AML_MULT	EXP(2.326 * LN((cvd^2 / no_samples + 1)^0.5) - 0.5 * LN((cvd^2 / no_samples + 1))										
	AVG MON LIMIT	MIN(BAT, BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)										
	INST MAX LIMIT	1.5 * (avg_mon_limit * AML_MULT) / LTA_MULT_afc										
	$(0.011 / EXP\{-(k \cdot CFC\_tc / 1440)\}) + ((CFC\_Yc \cdot Qs \cdot 0.011) / (1.647 \cdot Qd)) \dots$ $\dots + EXP\{-(k \cdot CFC\_tc / 1440)\} + Xd + (CFC\_Yc \cdot Qs \cdot Xs / 1.647 \cdot Qd) \cdot (1 - FOS / 100)$											
	Stream	Chlorine Required	=	intermittent	Chlorine Demand	+	Chlorine Residual					
	Reach/Node	2		1	2							
	Flow	Conditions		perennial	unknown							
	Code			35883	35883							
	Function			Outfall	unknown							
	Samples			30	30							
	reach	outfall	RMI	0.87	0.87							
	Reach End		RMI	0	0							
	reach			4593.6	4593.6							
	drainage			sq miles	0.35	0.42						
	TRC	limitation	average	mg/L	0.327	0.151						
			maximum	mg/L	1.070	1.670						
	elevation		modelled	feet	870.246	870.246						
	elevation		modelled	feet	803.72	803.72						
	slope		modelled	foot/foot	0.014	0.014						
	low flow			cfs/sq mi	0.021	0.021						
	discharge			mgd	0.0022	0.0022						
	Runoff	Period		hours	24.000	24.000						
	Previously 1.4-mg/L technology requirement was evaluated using discharge and stream chlorine demand. A 0.9-g/L water-quality based limitation was then determined. The current review does not use a discharge chlorine demand and evaluates the 0.5-mg/L effluent default TRC value.											
	stream	flow	cfs	0.00748	0.00898							
	stream	flow	MGD	0.004837	0.005804							
	stream	flow	total	MGD	0.007037	0.008004						
	stream	chlorine	demand	mg/L	0.3	0.4						
	discharge	discharge	demand	mg/L								
	stream	Total Stream/Waste	ratio		3.2	3.6						
	A 0.3-mg/L water-quality based limit should not be necessary in the dry stream reach.											
	permitted	TRC	mean	BAT	0.5	0.5						
	permitted	TRC	maximum	WQ	1.2	1.2						

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
20A		35883		Trib 35883 to Shenango River			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
0.880	Edgewood	PA0239437	0.002	CBOD5	25		
				NH3-N	6.04	12.08	
				Dissolved Oxygen			4

**WQM 7.0 D.O. Simulation**

SWP Basin	Stream Code	Stream Name		
20A	35883	Trib 35883 to Shenango River		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
0.880	0.002	23.578	7.011	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
2.064	0.246	8.379	0.024	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
8.54	0.539	1.79	0.922	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
6.533	23.492	Owens	5	
<u>Reach Travel Time (days)</u>	<u>Subreach Results</u>			
2.286	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.229	7.39	1.45	7.54
	0.457	6.39	1.18	7.54
	0.686	5.53	0.95	7.54
	0.914	4.78	0.77	7.54
	1.143	4.13	0.62	7.54
	1.372	3.57	0.51	7.54
	1.600	3.09	0.41	7.54
	1.829	2.67	0.33	7.54
	2.058	2.31	0.27	7.54
	2.286	2.00	0.22	7.54

**WQM 7.0 Wasteload Allocations**

**SWP Basin**    **Stream Code**                      **Stream Name**  
 20A                      35883                      Trib 35883 to Shenango River

**NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.880	Edgewood	7.67	19.85	7.67	19.85	0	0

**NH3-N Chronic Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.880	Edgewood	1.44	6.04	1.44	6.04	0	0

**Dissolved Oxygen Allocations**

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
0.88	Edgewood	25	25	6.04	6.04	4	4	0	0

**WQM 7.0 Modeling Specifications**

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input checked="" type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input checked="" type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
20A		35883				Trib 35883 to Shenango River						
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
<b>Q7-10 Flow</b>												
0.880	0.01	0.00	0.01	.0034	0.01432	.246	2.06	8.38	0.02	2.286	23.58	7.01
<b>Q1-10 Flow</b>												
0.880	0.01	0.00	0.01	.0034	0.01432	NA	NA	NA	0.02	2.701	23.08	7.01
<b>Q30-10 Flow</b>												
0.880	0.01	0.00	0.01	.0034	0.01432	NA	NA	NA	0.03	2.011	23.87	7.01

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20A	35883	Trib 35883 to Shenango River	0.000	803.72	766.16	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	pH	Stream Temp (°C)	pH
Q7-10	0.021	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

  

Parameter Data				
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70



**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20A	35883 Trib	35883 to Shenango River	0.880	870.25	0.40	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.021	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Edgewood	PA0239437	0.0022	0.0022	0.0022	0.000	20.00	7.04

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	7.54	0.00	0.00
NH3-N	25.00	0.10	0.00	0.70

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Three Years from Permit Effective Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0 Daily Max	XXX	1/day	Grab
DO	XXX	XXX	4.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50	2/month	Grab
TSS	XXX	XXX	XXX	30.0	XXX	60	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	2/month	Grab
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	18.0	XXX	36	2/month	Grab
Ammonia May 1 - Oct 31	XXX	XXX	XXX	6.0	XXX	12	2/month	Grab
Total Phosphorus	XXX	XXX	XXX	Report	XXX	XXX	2/month	Grab

Compliance Sampling Location: Outfall 001 after disinfection

Other Comments: Due to the facility design flow daily DO, chlorine, and pH monitoring is recommended.

**Proposed Effluent Limitations and Monitoring Requirements (continued)**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Three Years from Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0 Daily Max	XXX	1/day	Grab
DO	XXX	XXX	4.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50	2/month	Grab
TSS	XXX	XXX	XXX	30.0	XXX	60	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	2/month	Grab
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	15.0	XXX	30	2/month	Grab
Ammonia May 1 - Oct 31	XXX	XXX	XXX	5.0	XXX	10	2/month	Grab
Total Phosphorus	XXX	XXX	XXX	Report	XXX	XXX	2/month	Grab

Compliance Sampling Location: Outfall 001 after disinfection

Other Comments: Due to the facility design flow daily DO, chlorine, and pH monitoring is recommended.