

Application Type Renewal  
Facility Type Municipal  
Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0239445  
APS ID 1000513  
Authorization ID 1285751

**Applicant and Facility Information**

Applicant Name	<u>Sugar Grove Area Sewer Authority</u>	Facility Name	<u>Sugar Grove Area STP</u>
Applicant Address	<u>195 Creek Road</u> <u>Sugar Grove, PA 16350-5803</u>	Facility Address	<u>Dobson Road</u> <u>Sugar Grove, PA 16350</u>
Applicant Contact	<u>Randal Brown</u>	Facility Contact	_____
Applicant Phone	<u>(814) 489-7809</u>	Facility Phone	_____
Applicant E Mail	<u>sugargrovetownship@yahoo.com</u>	Applicant E Mail	_____
Client ID	<u>216050</u>	Site ID	<u>627650</u>
Municipality	<u>Sugar Grove Borough</u>	County	<u>Warren</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Connection Status	<u>No Limitations</u>
Application Received	<u>August 13, 2019</u>	EPA Waived?	<u>Yes</u>
Application Accepted	<u>September 11, 2019</u>	If No, Reason	_____
Purpose of Application	<u>NPDES permit renewal</u>		



**Summary of Review**

No listed open violations.

Minor occasional non-recurring high values have been reported.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
		William H. Mentzer William H. Mentzer, P.E. Environmental Engineering Specialist	October 22, 2020
		Justin C. Dickey Justin C. Dickey, P.E. Environmental Engineer Manager	November 9, 2020

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.2</u>
Latitude NHD	<u>41° 59' 7.05"</u>	Longitude NHD	<u>-79° 19' 8.82"</u>
Latitude DP	<u>41° 59' 7.08"</u>	Longitude DP	<u>-79° 19' 8.870"</u>
Quad Name	<u>Sugar Grove</u>	Quad Code	<u>0311</u>
Wastewater Description: <u>Treated municipal sanitary sewer wastewater</u>			
Receiving Waters	<u>Stillwater Creek</u>	Stream Code	<u>56422</u>
NHD Com ID	<u>129447492</u>	RMI	<u>13.8600</u>
Drainage Area	<u>12.1</u>	Yield (cfs/mi <sup>2</sup> )	<u>0.11</u>
Q <sub>7-10</sub> Flow (cfs)	<u>1.27</u>	Q <sub>7-10</sub> Basis	<u>Brokenstraw Creek</u>
Elevation (ft)	<u>1590.36</u>	Slope (ft/ft)	<u>0.00218</u>
Watershed No.	<u>16-B</u>	Chapter 93 Class.	<u>CWF</u>
Existing Use	<u>statewide</u>	Existing Use Qualifier	<u>none</u>
Exceptions to Use	<u>none</u>	Exceptions to Criteria	<u>none</u>
Comments _____			
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>Siltation</u>		
Source(s) of Impairment	<u>Grazing Related Agriculture, Agriculture, Crop Related Agriculture</u>		
TMDL Status	<u>pending</u>	Name	_____
Background/Ambient Data		Data Source	
pH (SU)	_____		_____
Temperature (°F)	_____		_____
Hardness (mg/L)	_____		_____
Other:	_____		_____
Nearest Downstream Public Water Supply Intake	<u>State of New York</u>		
PWS Waters	<u>Stillwater Creek</u>	Flow at Intake (cfs)	<u>1.92</u>
PWS RMI	<u>12.28</u>	Distance from Outfall (mi)	<u>1.76</u>

Changes Since Last Permit Issuance: none

Other Comments: This discharge should not impact any downstream water use

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Sugar Grove Area STP				
<b>WQM Permit No.</b>		<b>Issuance Date</b>		
6208401		April 8, 2009		
6208401 A1		November 18, 2010		
6203418		October 22, 2008		
6203418 A1		July 18, 2005		
6203418		December 15, 2004		
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage	Secondary With Ammonia Reduction	Extended Aeration	Hypochlorite	0.2
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
0.2	316	Not Overloaded	Aerobic Digestion	Landfill

Changes Since Last Permit Issuance: none

Other Comments:

6203418 the application was dated 11/6/2004, revised on 6/28/2004, 8/18/2004, 9/28/2004, and 11/22/2004, and issued 12/15/2004 for 3 pump stations rated at 174, 225, and 450-gpm, 0.2-MGD hydraulic design, 0.2-MGD mean flow and 316-PPD organic load. Included was 6 and 8-inch sewers and 236-grinder pump units. Treatment proposed was: comminutor with bypass bar screen, 54 722-gallon aerated flow equalization tank, two 125,000 gallon aeration tanks, two 32,944-gallon secondary clarifiers, chlorination, 5,656-gallon chlorine contact tank, 1,480-gallon polishing clarifier, dechlorination, post-aeration, flow monitoring, two 46 455-gallon sludge holding tanks and three 2 480 square foot reed beds.

6203418 A1 the application was dated 4/11/05 and issued 7/18.2005 for Pump Station #1 with a 155-gpm design flow and #2 with a 450-gpm design flow. Included is 1500 feet 8 inch diameter and 10 inch diameter sewers and 150000 feet of low pressure sewers. Pump Stations 1 and 2 are replaced by new Pump Station #1 and a new Pump Station #2 has been added.

6203418 the application was dated August 25, 2008 and issued on October 22, 2009 as a revision not labelled as such. This is for a comminutor and bar screen by pass for odor control. Approved was a subsurface 30-ft long by 2-ft wide by 2.5-ft deep French drain system connected by a 4-inch diameter perforated pipe. This is an air pollution control proposal.

6208401 A1 the application was dated July 2010 and issued on November 18, 2010 for a pump station serving 8 EDU (24-gpm duplex). This is referred to a Phase III Pump Station #1.

6208401 for a SuGASA Phase III Wastewater Collection Project, application dated February 10, 2009, revised on March 18, 2009 and April 1, 2009, and issued on April 8, 2009. For a split low pressure collection system with 118 units to SuGASA and 19 units to Brokenstraw Valley (total 137 units).

WQG028304 issued on November 8. 2006 for sewers and pump station serving the Overlook. Design is for 30-grinder pump units (low pressure sewers)

WLMR 2013

Sugar Grove Borough and portion of Sugar Grove Township

Hydraulic Design 2.0 MGD Maximum 0.09 MGD in July

Organic Load 316-PPD Maximum 243-PPD in July

No future additions expected.

Changes:

Main line head of plant diverter removed

Seven certified operators retained.

Weekly influent manual composite sampling provided. This matches the effluent sampling and the proposed NPDES influent monitoring.

Effluent metering is provided.

The collection system is mostly low-pressure sewers.

Duplex Pump Stations with auxiliary power. Four installed with no design or actual flows provided. Maximum pump rates reported

1	P1 230-gpm	P2 234-gpm	155-gpm WQM 6203418 A1
2	P1 544-gpm	P2 540-gpm	450-gpm WQM 6203418 A1
3	P1 68-gpm	P2 66-gpm	450-gpm WQM 6203418
4	P1 23-gpm	P2 23-gpm	24-gpm WQM 6208401 A1

Flow metering is tank capacity and pumping based.

**Compliance History**

**DMR Data for Outfall 001 (from August 1, 2018 to July 31, 2019)**

Parameter	JUL-19	JUN-19	MAY-19	APR-19	MAR-19	FEB-19	JAN-19	DEC-18	NOV-18	OCT-18	SEP-18	AUG-18
Flow (MGD) Ave Mon	0.107	0.110	0.086	0.097	0.09	0.105	0.1	0.095	0.111	0.1	<b>0.086</b>	0.1
Flow (MGD) Daily Max	0.167	0.234	0.162	0.142	0.175	0.168	0.238	0.153	0.207	0.273	<b>0.206</b>	0.175
pH (S.U.) Minimum	6.3	6.4	6.4	6.7	6.9	7.2	6.9	7.1	7.2	7.1	<b>6.9</b>	6.8
pH (S.U.) Maximum	7.0	7.2	6.9	7.0	7.4	7.6	7.4	7.5	7.5	7.6	<b>7.3</b>	8.5
DO (mg/L) Minimum	6.8	5.0	6.7	8.9	9.3	9.1	8.7	8.7	6.1	6.0	<b>5.9</b>	5.9
TRC (mg/L) Ave Mon	0.12	0.13	0.16	0.16	0.07	0.13	0.13	0.14	0.15	0.15	<b>0.1</b>	0.15
CBOD5 (PPD) Ave Mo	< 3	8	< 3	< 3	3	5	< 4	< 3	< 4	< 2	<b>&lt; 3</b>	< 2
CBOD5 (PPD) Wk Ave	5	19	3	4	5	6	8	3	5	< 4	<b>&lt; 4</b>	< 2
CBOD5 (mg/L) Average Monthly	< 3.86	7.75	< 3.57	< 3.69	3.86	5.38	< 4.45	< 3.48	< 4.15	< 3	<b>&lt; 3.12</b>	< 3
CBOD5 (mg/L) Weekly Average	5.28	15.3	4.26	4.43	4.44	6.29	8.06	4.62	5.58	< 3	<b>3.46</b>	< 3
BOD5 (PPD) Influent Aver Monthly	149	149	117	131	126	136	101	139	113	114	<b>120</b>	133
BOD5 (mg/L) Influent Ave Monthly	171	166	154	161	162	163	113.2	177	135.4	150.3	<b>148</b>	183
TSS (PPD) Ave Mon	5	14	8	9	7	7	9	3	4	< 4	<b>19</b>	7
TSS (lbs/day) Influent Ave Monthly	110	114	96	73	78	93	78	60	61	83	<b>113</b>	107
TSS (PPD) Weekly Ave	6	24	14	10	12	10	21	4	5	9	<b>58</b>	10
TSS (mg/L) Average Monthly	5.3	14.5	10.8	10.7	7.9	8.4	11	4	5.2	< 5	<b>21.2</b>	9.1
TSS (mg/L) Influent Ave Monthly	128	124	132	88	99	116	89	75	72	82	<b>130</b>	148
TSS (mg/L) Weekly Average	5.3	19.2	12.8	13.6	11.6	11.2	29.6	5.2	6.8	7.6	<b>66</b>	13.6
Fecal Coliform (#/100 ml) Geomean	< 36	< 219	< 17	< 26	< 34	40	38	518	245	< 54	<b>&lt; 43</b>	< 10
Fecal Coliform (#/100 ml) Instant Maximum	315	4721	20	40	82	104	102	4028	7701	3873	<b>1780</b>	< 10
Total Nitrogen (mg/L) Average Monthly	48.02	33.52	44.52	35.49	34.74	31.45	30.32	33.32	29.51	32.91	<b>41.8</b>	36.97
Ammonia (lbs/day) Average Monthly	< 0.1	< 3.0	< 0.08	< 0.08	0.08	< 0.09	0.09	0.08	< 0.09	0.1	<b>0.08</b>	< 0.2
Ammonia (mg/L) Average Monthly	< 0.116	< 3.10	< 0.1	< 0.1	< 0.1	< 0.11	< 0.1	< 0.1	< 0.1	< 0.1	<b>&lt; 0.1</b>	< 0.228
TI Phosphorus (mg/L) Average Monthly	5.0	4.77	5.67	3.56	2.64	3.01	3.11	3.61	3.92	3.36	<b>3.89</b>	6.59

NPDES Permit Fact Sheet  
Sugar Grove Area STP

NPDES Permit No. PA0239445

Potential high flows in

DMR Data for Outfall 001 (from September 1, 2019 to August 31, 2020)

Parameter	AUG-20	JUL-20	JUN-20	MAY-20	APR-20	MAR-20	FEB-20	JAN-20	DEC-19	NOV-19	OCT-19	SEP-19
Flow (MGD) A Mon	0.111	0.124	0.122	0.140	0.109	0.124	0.104	0.110	0.072	0.063	0.083	0.087
Flow (MGD) D Max	0.143	0.157	0.164	0.99	0.179	0.232	0.179	196	0.177	0.218	0.13	0.123
pH (S.U.) Minimum	6.8	6.8	6.8	6.7	6.9	7.0	6.9	6.7	7.1	7.1	6.9	6.3
pH (S.U.) Maximum	7.5	7.8	7.6	7.1	7.4	7.7	7.6	7.6	7.4	7.4	7.5	7.1
DO (mg/L) Minimum	5.9	6.1	7.2	5.3	8.1	7.6	7.6	6.1	6.7	6.7	6.4	6.3
TRC (mg/L) A Monthly	0.2	0.31	0.23	0.47	0.2	0.15	0.17	0.16	0.11	0.11	0.12	0.12
CBOD5 (lbs/day) Average Monthly	< 4	< 4	< 8	5	6	7	6	< 3	< 5	2	< 3	3
CBOD5 (lbs/day) Weekly Average	4	7	18	7	9	12	11	< 4	10	3	3	4
CBOD5 (mg/L) Average Monthly	< 3.62	< 4.25	< 8.14	5.37	5.91	6.36	7.6	< 3.69	< 5.48	< 5.14	< 3.81	4.04
CBOD5 (mg/L) W Ave	4.16	5.74	17.2	6.32	6.92	8.51	11.1	5.28	10.1	7.8	4.34	5.09
BOD5 (ppd) Influent Average Monthly	225	176	226	176	186	211	130	152	138	99	129	149
BOD5 (mg/L) Influent Average Monthly	230	175	220	193	198	194	161.9	163	161	209	195	201
TSS (ppd) A Monthly	4	6	12	10	12	10	6	6	12	24	11	9
TSS (ppd) Influent Average Monthly	127	154	142	100	103	97	60	85	97	1528	66	129
TSS (ppd) W Average	5	7	16	14	24	28	9	9	18	76	17	14
TSS (mg/L) A Monthly	4	5.7	11.4	11.6	10.6	9.1	7.6	6.6	16.8	52	16.4	12.6
TSS (mg/L) Influent Average Monthly	129	154	139	107	102	92	73	92	129	3447	96	172
TSS (mg/L) W Ave	6	6.4	15.6	14	16	20	12.8	8.4	27.6	172	23.2	18
Fecal Coliform (#/100 ml) Geometric Mean	14	11	31	< 33	80	37	740	79	< 68	76	< 29	< 86
Fecal Coliform (#/100 ml) Instant Maximum	38.8	23.1	146.6	187	228	86	3256	201	6510	512	63	268
T Nitrogen (mg/L) Average Monthly	48.41	40.89	33.71	40.49	29.34	30.14	25.94	26.22	28	34.18	43.47	47.1
Ammonia (ppd) A Mon	< 0.1	< 2.0	< 2.0	< 0.09	< 0.1	< 0.1	< 0.5	2	< 0.2	0.05	< 0.07	< 0.2
Ammonia (mg/L) Average Monthly	< 0.1	< 1.4	< 1.4	< 0.1	< 0.111	< 0.1	< 0.49	0.603	< 0.215	< 0.1	< 0.1	< 0.255
T Phosphorus (mg/L) Average Monthly	5.83	5	5.0	4.57	4.93	3.77	4.39	3.71	4.41	3.63	5.49	4

**Compliance History**

**Effluent Violations for Outfall 001, from: September 1, 2018 To: July 31, 2019**

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
TSS	09/30/18	Wkly Avg	66	mg/L	45	mg/L
Fecal Coliform	06/30/19	Geo Mean	< 219	CFU/100 ml	200	CFU/100 ml
Fecal Coliform	09/30/18	IMAX	1780	CFU/100 ml	1000	CFU/100 ml
Fecal Coliform	06/30/19	IMAX	4721	CFU/100 ml	1000	CFU/100 ml

**Effluent Violations for Outfall 001, from: October 1, 2019 To: August 31, 2020**

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
TSS	11/30/19	Wkly Avg	76	lbs/day	75	lbs/day
TSS	11/30/19	Avg Mo	52	mg/L	30	mg/L
TSS	11/30/19	Wkly Avg	172	mg/L	45	mg/L

High maximum flows in November

**Development of Effluent Limitations**

Outfall No. 001 Design Flow (MGD) .2  
 Latitude 41° 59' 7.08" Longitude -79° 19' 8.76"  
 Wastewater Description: Sewage Effluent

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
DO	4.0	Daily Minimum		BPJ

Comments: None

**Water Quality-Based Limitations**

A Sewerage program based “Reasonable Potential Analysis” determined CBOD<sub>5</sub>, TSS ammonia, DO and pH candidates for limitations:

The following limitations were determined through water quality modeling (output files attached):

Parameter		Limit (mg/l)			SBC	Model	
ammonia	summer	5.0	6.5	13.0		6.11	12.22
DO		5.0			5.0		

Comments: Ammonia was rounded up to the nearest half milligram.

**Anti-Backsliding**

*There are no backsliding limitations being proposed.*



**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	41.0	65.0	XXX	25.0	40.0	50.0	1/week	8-Hr Composite
TSS	50.0	75.0	XXX	30.0	45.0	60.0	1/week	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	XXX	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Ammonia Nov 1 - Apr 30	32	XXX	XXX	19.5	XXX	39.0	1/week	8-Hr Composite
Ammonia May 1 - Oct 31	15.8	XXX	XXX	6.5	XXX	13.0	1/week	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report	XXX	XXX	1/week	8-Hr Composite

Compliance Sampling Location: Outfall 001 after disinfection

### Input Data WQM 7.0

		Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
		56422	STILLWATER CREEK	<b>13.860</b>	1590.36	12.10	0.00000	0.00	<input checked="" type="checkbox"/>

#### Stream Data

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Tributary pH	Stream Temp (°C)	Stream pH
	<b>Q7-10</b>	0.110	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.80	0.00
<b>Q1-10</b>		0.00	0.00	0.000	0.000							
<b>Q30-10</b>		0.00	0.00	0.000	0.000							

#### Discharge Data

Name	Permit Number	Existing Permitted Design			Reserve Factor	Disc Temp (°C)	Disc pH
		Disc Flow (mgd)	Disc Flow (mgd)	Disc Flow (mgd)			
Sugar Grove	PA0239445	0.2000	0.2000	0.2000	0.000	25.00	7.78

#### Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	8.24	0.00	0.00
NH3-N	25.00	0.10	0.00	0.70

### Input Data WQM 7.0

		Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
		56422	STILLWATER CREEK	<b>12.280</b>	1566.63	18.46	0.00000	0.00	<input checked="" type="checkbox"/>

#### Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
<b>Q7-10</b>	0.110	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.80	0.00	0.00
<b>Q1-10</b>		0.00	0.00	0.000	0.000							
<b>Q30-10</b>		0.00	0.00	0.000	0.000							

#### Discharge Data

Name	Permit Number	Existing Permitted Design			Reserve Factor	Disc Temp	Disc pH
		Disc Flow (mgd)	Disc Flow (mgd)	Disc Flow (mgd)		(°C)	
		0.0000	0.0000	0.0000	0.000	25.00	7.00

#### Parameter Data

Parameter Name	Disc Conc	Trib Conc	Stream Conc	Fate Coef
	(mg/L)	(mg/L)	(mg/L)	(1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

## WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
16B		56422				STILLWATER CREEK						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
<b>Q7-10 Flow</b>												
13.860	1.33	0.00	1.33	.3094	0.00284	.56	19.17	34.25	0.15	0.632	20.94	7.80
<b>Q1-10 Flow</b>												
13.860	0.85	0.00	0.85	.3094	0.00284	NA	NA	NA	0.13	0.767	21.33	7.79
<b>Q30-10 Flow</b>												
13.860	1.81	0.00	1.81	.3094	0.00284	NA	NA	NA	0.18	0.547	20.73	7.80

## WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	Uniform Treatme	Use Inputted W/D Ratio	<input checked="" type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input checked="" type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input type="checkbox"/>
D.O. Goal	5		

## WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
16B	56422	STILLWATER CREEK

### NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
13.860	Sugar Grove	NA	50	3.41	12.54	1	75

### NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
13.860	Sugar Grove	NA	25	.98	6.11	1	76

### Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5 Oxygen</u>		<u>NH3-N</u>		<u>Dissolved</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
13.86	Sugar Grove	25	25	6.11	6.11	4	4	0	0

## WQM 7.0 D.O. Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
16B	56422	STILLWATER CREEK		
<hr/>				
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>
13.860	0.200	20.943		7.796
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>
19.172	0.560	34.246		0.153
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>
6.34	0.955	1.23		0.753
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>
7.443	4.131	Tsivoglou		5
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>			
0.632	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.063	5.95	1.18	7.06
	0.126	5.59	1.12	6.81
	0.190	5.25	1.07	6.65
	0.253	4.93	1.02	6.57
	0.316	4.63	0.97	6.54
	0.379	4.34	0.93	6.55
	0.442	4.08	0.88	6.59
	0.505	3.83	0.84	6.65
	0.569	3.60	0.80	6.73
	0.632	3.38	0.77	6.81

## WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
16B		56422		STILLWATER CREEK			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
13.860	Sugar Grove	PA0239445	0.200	CBOD5	25		
				NH3-N	6.11	12.22	
				Dissolved Oxygen			5



1A	B	C	D	E	F	G	H	I	J	K	L	M	
	<b>Discharger Site Municipality County NPDES Permit</b>		Sugar Grove MA Sugar Grove STP Sugar Grove Borough Warren PA0239445							Revised	Wednesday, October 21, 2020 Tuesday, November 10, 2020		
2	<b>TRC EVALUATION</b>												
3	Input appropriate values in B4:B8 and E4:E7												
4	1.3310	= Q stream (cfs)								0.5	= CV Daily		
5	0.2000	= Q discharge (MGD)								0.5	= CV Hourly		
6	30	= no. samples								1	= AFC_Partial Mix Factor		
7	0.4	= Chlorine Demand of Stream								1	= CFC_Partial Mix Factor		
8	0	= Chlorine Demand of Discharge								15	= AFC_Criteria Compliance Time (min)		
9	0.5	= BAT/BPJ Value								720	= CFC_Criteria Compliance Time (min)		
	0	= % Factor of Safety (FOS)									=Decay Coefficient (K)		
10	Source	Reference AFC Calculations					Reference CFC Calculations						
11	TRC	1.3.2.iii	WLA_afc = 1.821					1.3.2.iii WLA_cfc = 1.779					
12	PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373					5.1c LTAMULT_cfc = 0.581					
13	PENTOXSD TRG	5.1b	LTA_afc = 0.679					5.1d LTA_cfc = 1.034					
14	Source	Effluent Limit Calculations											
16	PENTOXSD TRG	5.1f	AML_MULT = 1.231										
17	PENTOXSD TRG	5.1g	LIMIT (mg/l) = 0.500			BAT/BPJ							
18			X LIMIT (mg/l) = 1.635										
	WLA_afc	$(.019/e^{-k \cdot AFC\_tc}) + [(AFC\_Yc \cdot Qs \cdot .019/Qd) \cdot e^{-k \cdot AFC\_tc}] \dots$											
	LTAMULT_afc	$\dots + Xd + (AFC\_Yc \cdot Qs \cdot Xs/Qd) \cdot (1-FOS/100)$											
	LTA_afc	$EXP((0.5 \cdot LN(cvh^2+1)) - 2.326 \cdot LN(cvh^2+1)^{0.5})$											
	WLA_cfc	$(.011/e^{-k \cdot CFC\_tc}) + [(CFC\_Yc \cdot Qs \cdot .011/Qd) \cdot e^{-k \cdot CFC\_tc}] \dots$											
	LTAMULT_cfc	$\dots + Xd + (CFC\_Yc \cdot Qs \cdot Xs/Qd) \cdot (1-FOS/100)$											
	LTA_cfc	$EXP((0.5 \cdot LN(cvd^2/no\_samples+1)) - 2.326 \cdot LN(cvd^2/no\_samples+1)^{0.5})$											
	AML_MULT	$EXP(2.326 \cdot LN((cvd^2/no\_samples+1)^{0.5}) - 0.5 \cdot LN(cvd^2/no\_samples+1))$											
	AVG MON LIMIT	$MIN(BAT\_BPJ, MIN(LTA\_afc, LTA\_cfc) \cdot AML\_MULT)$											
	INST MAX LIMIT	$1.5 \cdot ((av\_mon\_limit/AML\_MULT)/LTAMULT\_afc)$											
	$(0.011/EXP(-K \cdot CFC\_tc/1440)) + ((CFC\_Yc \cdot Qs \cdot 0.011)/(1.547 \cdot Qd)) \dots$												
	$\dots \cdot EXP(-K \cdot CFC\_tc/1440)) + Xd + (CFC\_Yc \cdot Qs \cdot Xs/1.547 \cdot Qd) \cdot (1-FOS/100)$												
	Stream	Chlorine Required	=	perennial	Chlorine Demand	+	Chlorine Residual						
	Stream	Reach/Node	1	1									
	Stream	Flow Conditions		perennial									
	Stream	Code		56422									
	Stream	Function											
	Samples			30									
	reach	outfall	RMI	13.86									
	reach	Reach End	RMI	12.28									
	reach		feet	8342.4									
	drainage		sq miles	12.1									
	TRC	limitation	average	mg/L	0.500								
			maximum	mg/L	1.635								
	elevation		modelled	feet	1590.36								
	elevation		modelled	feet	1566.63								
	slope		modelled	foot/foot	0.003								
	low flow			cfs/sq mi	0.110								
	discharge			mgd	0.2000								
	Runoff	Period		hours	24.000								
	BAT is adequate												
	stream	flow	cfs	1.33100									
	stream	flow	MGD	0.860248									
	stream	flow	total	MGD	1.060248								
	stream	chlorine	demand	mg/L	0.4								
	discharge	discharge	demand	mg/L									
	stream	Total Stream/Waste	ratio	5.3									
	permitted	TRC	mean	BAT	0.5								
	permitted	TRC	maximum	BAT	1.6								
			AFC	WLA	PA0239445								

Model Set-Up									
		G	H	I	J	K	L	M	N
Reach	Number	1	2	3	4	6	6	7	8
Stream	Name	Stillwater							
Stream	Code	56422							
Stream	Function	Outfall							
Stream	Flow	Condition	perennial						
Stream	Reach	Start	miles	13.86					
Stream	Elevation	Start	feet	1590.36					
Stream	Reach	End				miles			12.28
Stream	Elevation	End				feet			1566.63
Stream	Discharge	Drainage			sq		miles		12.1
Stream	Basin	Yield				cfs			0.1100
Public Water	Supply	Name					New		York
Public Water	Supply	Downstream				miles			1.76
Public Water	Supply	Location	miles	12.28					
Stream Flow									
	References	Reserve	Drainage		low flow	yield	yield		period
		%	sq mi		cfs	cfs/sq mi	MGD		period
low flow	Stillwater		100		11	0.110	0.071095		
					18				1940-72
	yield					0.11	0.071095		
	yield	75				0.0275	0.017774		
Low Flow Estimate									
		Reserve	Drainage	Drainage	low flow	yield			
		%	Sq mile	Sq mile	cfs	cfs/sq mi	MGD		
		NA				0.11			
		NA				0.11			
	Total Area	NA	0	0	NA	0.11			
Adjusted Low Flow Estimate									
		Reserve	Drainage	Drainage	low flow	yield			
		%	Sq mile	Sq mile	cfs	cfs/sq mi	MGD		
		25							
		25							
	Total Area at main stem	25	0						

Parameter	June	May	April	March	February	January	December	November	October	September	August	July	median		average		tss/bod	
													annually	summer	annually	summer		
Flow (MGD)																		
Flow (MGD)																		
pH (S.U.)	6.4	6.4	6.7	6.9	7.2	6.9	7.1	7.2	7.1	6.9	6.8	6.3	7.05	6.95	7.08	7.13		
	2511886	2511886	5011872	7943282	15848932	7943282	12589254	15848932	12589254	7943282	6309573	1995262	11,294,627	8971641.17	26,253,046	60404751.21		
pH (S.U.)	7.2	6.9	7	7.4	7.6	7.4	7.5	7.5	7.6	7.3	8.5	7	7.05	6.95	7.42	7.78		
	15848932	7943282	10000000	25118864	39810717	25118864	31622777	31622777	39810717	19952623	316227766	10000000						
DO (mg/L)																		
TRC (mg/L)																		
TRC (mg/L)																		
CBOD5 (mg/L)													#NUM!	#NUM!	#DIV/0!		#NUM!	
TSS (mg/L)													#NUM!	#NUM!	#DIV/0!		#NUM!	
Fecal Coliform (#/100 ml)																		
Fecal Coliform (#/100 ml)																		
Total Nitrogen (mg/L)																		
Ammonia (mg/L)													#NUM!	#NUM!	#DIV/0!			
Total Phosphorus (mg/L)																		

Parameter	19-Jul	19-Jun	19-May	19-Apr	19-Mar	19-Feb	19-Jan	18-Dec	18-Nov	18-Oct	18-Sep	18-Aug
Flow (MGD) Ave Mon	0.107	0.11	0.086	0.097	0.09	0.105	0.1	0.095	0.111	0.1	<b>0.086</b>	0.1
Flow (MGD) Daily Max	0.167	0.234	0.162	0.142	0.175	0.168	0.238	0.153	0.207	0.273	<b>0.206</b>	0.175
pH (S.U.) Minimum	6.3	6.4	6.4	6.7	6.9	7.2	6.9	7.1	7.2	7.1	<b>6.9</b>	6.8
pH (S.U.) Maximum	7	7.2	6.9	7	7.4	7.6	7.4	7.5	7.5	7.6	<b>7.3</b>	8.5

Back Calculations							
Secondary Waters							
Parameter	Symbol	Equation					
Downstream Concentration	C <sub>0</sub>		3.45	3.45		3.45	3.45
Nitrogen decay factor	k <sub>n</sub>		0.70	0.70		0.70	0.70
Reach Travel Time	T <sub>t</sub>		0.33	0.33		0.33	0.33
exponential factor	e		2.72	2.72		2.72	2.72
Upstream Concentration 1	C <sub>t</sub>	$C_0 e^{(k_n T)}$	4.33	4.33		4.33	4.33
Upstream Concentration 2	C <sub>t</sub>	$C_0 e^{(k_n T)}$	4.33	4.33		4.33	4.33
Downstream check 1	C <sub>0</sub>	$C_t / e^{(k_n T)}$	3.45	3.45		3.45	3.45
Downstream check 2	C <sub>0</sub>	$C_t / e^{(k_n T)}$	3.45	3.45		3.45	3.45
Input data is from WQM 7 report; The default nitrogen decay factor is 0.7							
First Upstream Node							
Downstream Concentration	C <sub>0</sub>		4.33	4.33		4.33	4.33
Nitrogen decay factor	k <sub>n</sub>		0.70	0.70		0.70	0.70
Reach Travel Time	T <sub>t</sub>		0.00	0.00		0.00	0.00
exponential factor	e		2.72	2.72		2.72	2.72
Upstream Concentration 1	C <sub>t</sub>	$C_0 e^{(k_n T)}$	4.33	4.33		4.33	4.33
Upstream Concentration 2	C <sub>t</sub>	$C_0 e^{(k_n T)}$	4.33	4.33		4.33	4.33
Downstream check 1	C <sub>0</sub>	$C_t / e^{(k_n T)}$	4.33	4.33		4.33	4.33
Downstream check 2	C <sub>0</sub>	$C_t / e^{(k_n T)}$	4.33	4.33		4.33	4.33
Second Upstream Node							
Downstream Concentration	C <sub>0</sub>		4.33	4.33		4.33	4.33
Nitrogen decay factor	k <sub>n</sub>		0.70	0.70		0.70	0.70
Reach Travel Time	T <sub>t</sub>		0.00	0.00		0.00	0.00
exponential factor	e		2.72	2.72		2.72	2.72
Upstream Concentration 1	C <sub>t</sub>	$C_0 e^{(k_n T)}$	4.33	4.33		4.33	4.33
Upstream Concentration 2	C <sub>t</sub>	$C_0 e^{(k_n T)}$	4.33	4.33		4.33	4.33
Downstream check 1	C <sub>0</sub>	$C_t / e^{(k_n T)}$	4.33	4.33		4.33	4.33
Downstream check 2	C <sub>0</sub>	$C_t / e^{(k_n T)}$	4.33	4.33		4.33	4.33
Third Upstream Node							
Downstream Concentration	C <sub>0</sub>		4.33	4.33		4.33	4.33
Nitrogen decay factor	k <sub>n</sub>		0.00	0.00		0.00	0.00
Reach Travel Time	T <sub>t</sub>		0.00	0.00		0.00	0.00
exponential factor	e		2.72	2.72		2.72	2.72
Upstream Concentration 1	C <sub>t</sub>	$C_0 e^{(k_n T)}$	4.33	4.33		4.33	4.33
Upstream Concentration 2	C <sub>t</sub>	$C_0 e^{(k_n T)}$	4.33	4.33		4.33	4.33
Downstream check 1	C <sub>0</sub>	$C_t / e^{(k_n T)}$	4.33	4.33		4.33	4.33
Downstream check 2	C <sub>0</sub>	$C_t / e^{(k_n T)}$	4.33	4.33		4.33	4.33
Summary							
	ammonia	summer	4.0	8.5		4.0	8.5
		winter	12.0	25.0		12.0	25.0
	Multipliers	winter	3.0			3.0	
		maximum	2.0			2.0	

Ammonia Limitations							
	downstream	kn	travel time	e Factor	30 day average	1 day maximum	notes pH
				2.7182818	0.00	0.00	7.74
summer				2.7182818	0.00	0.00	7.74
winter	0	NA	NA	2.718282	0.00	0.00	
summer				2.718282	0.00	0.00	7.4
winter	0	NA	NA	2.718282	0.00	0.00	
summer				2.718282	0.00	0.00	6.82
winter	0	NA	NA	2.718282	0.00	0.00	
summer		0.7	0.33	2.7182818	0.00	0.00	7.74
winter	0	0.7	0.33	2.718282	0.00	0.00	
summer		0.7	0.33	2.718282	0.00	0.00	7.4
winter	0	0.7	0.33	2.718282	0.00	0.00	
summer		0.7	0.33	2.718282	0.00	0.00	6.82
winter	0	0.7	0.33	2.718282	0.00	0.00	