



Application Type

Renewal

Facility Type

Municipal

Major / Minor

Minor

Application No.

PA0239445

APS ID

1142334

Authorization ID

1535559

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

**Applicant and Facility Information**

Applicant Name	<b>Sugar Grove Area Sewer Authority Warren County</b>	Facility Name	<b>Sugar Grove Area STP</b>
Applicant Address	195 Creek Road Sugar Grove, PA 16350-5803	Facility Address	181 Dobson Road Sugar Grove, PA 16350
Applicant Contact	Melanie Eggleston	Facility Contact	
Applicant Phone	(814) 489-7809	Facility Phone	
Client ID	216050	Site ID	627650
Ch 94 Load Status	Not Overloaded	Municipality	Sugar Grove Borough
Connection Status	No Limitations	County	Warren
Date Application Received	July 28, 2025	EPA Waived?	Yes
Date Application Accepted		If No, Reason	
Purpose of Application	Renewal Application for a Minor Sewage Facility		

**Summary of Review**

The permittee is applying for reissuance of Individual Permit No. **PA0239445** which will expire on January 31, 2026. In the facility, the Influent flow first enters a 54,722-gallon aerated flow equalization tank. From there, it proceeds to two 125,000-gallon aeration basins, followed by two 32,944-gallon secondary clarifiers. Thereafter, the flow moves into a 5,656-gallon chlorine contact tank for disinfection, then into a 1,480-gallon polishing clarifier. Dechlorination and post-aeration are performed before final flow monitoring and discharge at the outfall.

Waste solids are directed to two 46,455-gallon sludge holding tanks and subsequently processed through three reed beds, each measuring 2,480 square feet

This is a discharge into a stream channel - Stillwater Creek

DMRs were submitted for the past five years.

Act 14 – Notifications were submitted and received.

There are no open violations in WMS for the subject Client ID (**216050**) as of 7/31/25.

Sludge use and disposal description and location(s): 152.35 dry tons of sewage sludge were disposed of at landfills.

**Public Participation**

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-

Approve	Deny	Signatures	Date
x		Adebayo Olude Adebayo Olude / Civil Engineer Trainee	July 31, 2025
X		Adam Olesnanik Adam Olesnanik, P.E. / Environmental Engineer Manager	August 15, 2025

### Summary of Review

day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	.2
Latitude	41° 59' 7.05"	Longitude	-79° 19' 8.82"
Quad Name	Sugar Grove	Quad Code	41079H3
Wastewater Description:	Sewage Effluent		
Receiving Waters	Stillwater Creek (CWF)	Stream Code	56422
NHD Com ID	129447492	RMI	13.8600
Drainage Area	12.2	Yield (cfs/mi <sup>2</sup> )	0.0674
Q <sub>7-10</sub> Flow (cfs)	0.823	Q <sub>7-10</sub> Basis	USGS StreamStats
Elevation (ft)	1362	Slope (ft/ft)	-
Watershed No.	16-B	Chapter 93 Class.	CWF
Existing Use		Existing Use Qualifier	
Exceptions to Use	-	Exceptions to Criteria	-
Assessment Status	Impaired		
Cause(s) of Impairment	SILTATION, SILTATION, SILTATION		
Source(s) of Impairment	AGRICULTURE, CROP PRODUCTION (CROP LAND OR DRY LAND), GRAZING IN RIPARIAN OR SHORELINE ZONES		
TMDL Status	Name _____		
Background/Ambient Data		Data Source	
pH (SU)	7	Default	
Temperature (°F)	20	Default - CWF	
Hardness (mg/L)	100	Default	
Other:	-	-	
Nearest Downstream Public Water Supply Intake	State of New York		
PWS Waters	Stillwater Creek	Flow at Intake (cfs)	-
PWS RMI	-	Distance from Outfall (mi)	1.78

Changes Since Last Permit Issuance: Elevation was revised using Google Earth. Drainage Area and Q<sub>7-10</sub> Flow were revised using USGS StreamStats.

Other Comments: The streamflow value used for the receiving stream is different from previous permit. According to USGS Stream Stats, the anticipated low-flow (Q<sub>7-10</sub>) for the stream is 0.823cfs, whereas the previous model assumed a low-flow of 1.27cfs. The basis for the earlier flow value is unclear, but this difference in streamflow inputs likely accounts for the change in modeled results under attachment 3 and 4.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Sugar Grove Area STP				
<b>WQM Permit No.</b>	<b>Issuance Date</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
6208401 A1	11/18/2010			
6208401	04/08/2009			
6203418 A1	07/18/2005			
6203418	12/15/2004			
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage	Secondary With Ammonia Reduction	Extended Aeration	Hypochlorite	0.2
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
0.2	316	Not Overloaded	Aerobic Digestion	Landfill

Changes Since Last Permit Issuance: WQM Permit No. 6203418 dated October 22, 2008, in previous permit is not found on WMS.

Other Comments: 6203418 was first issued on 12/15/2004 and later amended on 07/18/2005. WQ2PS for the same permit No. was issued on 04/08/2009. Lastly an amendment was executed on 11/18/2010 for WQ2TP.

WQG028304 issued on November 8. 2006 and WQG028303 was issued 11/07/2006.

Compliance History	
<b>Summary of DMRs:</b>	DMRs were submitted for the past five years.
<b>Summary of Inspections:</b>	There are no open violations in WMS for the subject Client ID ( <b>216050</b> ) as of 7/31/25.

Other Comments: None

Compliance History

DMR Data for Outfall 001 (from June 1, 2024 to May 31, 2025)

Parameter	MAY-25	APR-25	MAR-25	FEB-25	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24
Flow (MGD) Average Monthly	0.101	0.09	0.103	0.097	0.094	0.106	0.075	0.066	0.063	0.077	0.084	0.081
Flow (MGD) Daily Maximum	0.219	0.162	0.232	0.115	0.183	0.166	0.106	0.093	0.085	0.116	0.146	0.154
pH (S.U.) Instantaneous Minimum	6.2	6.2	6.4	6.6	6.7	6.4	6.4	6.1	6.0	6.1	5.8	6.1
pH (S.U.) Instantaneous Maximum	7.4	7.0	7.1	7.1	7.1	7.1	7.8	7.3	7.0	7.1	7.1	7.4
DO (mg/L) Daily Minimum	6.1	5.1	7.1	7.6	7.8	7.0	6.5	5.7	5.7	6.1	6.1	6.4
TRC (mg/L) Average Monthly	0.18	0.16	0.16	0.17	0.22	0.18	0.17	0.14	0.17	0.19	0.2	0.15
CBOD5 (lbs/day) Average Monthly	2.0	5.0	6.0	4.0	< 3.0	5.0	4.0	3.0	1.0	< 2.0	2.0	< 3.0
CBOD5 (lbs/day) Weekly Average	5.0	8.0	13.0	9.0	4.0	7.0	6.0	4.0	1.0	3.0	3.0	5.0
CBOD5 (mg/L) Average Monthly	< 2.8	6.15	5.75	3.82	< 3.18	4.62	5.6	5.12	2.66	3.09	< 2.68	< 3.99
CBOD5 (mg/L) Weekly Average	4.35	8.64	8.34	4.9	3.87	7.08	7.25	6.21	2.61	3.79	4.45	6.05
BOD5 (lbs/day) Raw Sewage Influent   Average Monthly	141	189	345	214	189	168	132.0	116	114	150	146	145
BOD5 (mg/L) Raw Sewage Influent   Average Monthly	183	215	347	193	195	171	210.0	204	248	213	190	205
TSS (lbs/day) Average Monthly	8.0	19.0	11.0	5.0	7.0	7.0	6.0	8.0	6.0	< 7.0	6.0	5.0
TSS (lbs/day) Raw Sewage Influent   Average Monthly	150	168	169	124	115	159	97.0	123	129	170	156	169.0

NPDES Permit Fact Sheet  
Sugar Grove Area STP

NPDES Permit No. PA0239445

TSS (lbs/day) Weekly Average	18.0	40.0	15.0	9.0	12.0	9.0	10.0	11.0	7.0	9.0	9.0	6.0
TSS (mg/L) Average Monthly	8.5	23.0	11.1	5.0	7.4	7.54	10.0	14.1	12.7	< 9.3	8.1	6.6
TSS (mg/L) Raw Sewage Influent   Average Monthly	202	195	178	114	118	162	160.0	218	278	239	200	237.0
TSS (mg/L) Weekly Average	15.0	49.5	14.5	6.0	11.5	10.0	12.0	19.5	14.5	< 3.79	15.5	8.5
Fecal Coliform (No./100 ml) Geometric Mean	27	15.0	21.0	20	39.0	47.0	11.0	42.0	82	93	25	18.0
Total Nitrogen (mg/L) Average Monthly	31.4	29.15	36.41	34.87	31.87	32.32	45.68	44.7	47.48	47.01	50.16	47.3
Ammonia (lbs/day) Average Monthly	< 0.08	< 0.1	0.2	< 0.1	< 0.1	< 0.2	< 0.06	0.07	< 0.08	< 2.1	< 0.3	< 0.07
Ammonia (mg/L) Average Monthly	< 0.1	< 0.1598	< 0.2	< 0.1	< 0.1	< 0.193	< 0.1	0.115	< 0.2	< 2.1	0.44	< 0.1034
Total Phosphorus (mg/L) Average Monthly	3.92	3.81	2.67	3.37	3.48	3.73	6.07	6.29	6.8	7.59	7.08	6.97

**Development of Effluent Limitations**

**Outfall No.** 001  
**Latitude** 41° 59' 7.08"  
**Wastewater Description:** Sewage Effluent

**Design Flow (MGD)** .2  
**Longitude** -79° 19' 8.76"

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
Total Nitrogen	Report	Average Monthly		92a.61
Total Phosphorus	Report	Average Monthly		92a.61
E. Coli	Report	IMAX		92a.61

Comments: The limits for pH are technology-based on Chapter 93.7. The limits for Total Suspended Solids, and Fecal Coliforms are technology-based on Chapter 92a.47. The limits for TRC are applicable under chapter 92a.48. Monitoring for E. Coli is placed in the permit in accordance with the Department's SOP entitled "Establishing Effluent Limitations for Individual Sewage Permits." With a design flow  $\geq 0.05$  and  $< 1$  MGD, a sample frequency of 1/quarter is being proposed.

**Water Quality-Based Limitations**

CBOD<sub>5</sub>, Ammonia, and Dissolved oxygen are evaluated using WQM 7.0 (Attachment 3). TRC is evaluated using the Department's TRC evaluation spreadsheet (Attachment 4).

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
CBOD <sub>5</sub>	25	Average Monthly	WQM 7.0
	50	IMAX	
NH3-N May 1 – Oct 31	8.0	Average Monthly	WQM 7.0
	16	IMAX	
NH3-N Nov 1 – Apr 30	24	Average Monthly	WQM 7.0
	48	IMAX	
Dissolved Oxygen	5.0	Daily minimum	WQM 7.0
TRC	0.4	Average Monthly	TRC Spreadsheet Model
	1.3	IMAX	

Comments: This discharge was evaluated using the WQM 7.0 model to determine appropriate effluent limitations for CBOD<sub>5</sub>, Ammonia-Nitrogen, and Dissolved Oxygen. The modeling results confirmed that the current CBOD<sub>5</sub> limitations remain appropriate, and existing Dissolved Oxygen limits are also adequate for the facility. The model calculated WQBELs for NH<sub>3</sub>-N that are less stringent than what is currently imposed in the previous permit. The default pH value of 7.0 S.U. was used in this most recent WQM 7.0 model run, instead of a site-specific pH value like what was done in the previous permit renewal. This may explain why different WQBELs were calculated in the previous permit. The previous NH<sub>3</sub>-N limits will be retained in this renewal.

The current limit for TRC (0.5 mg/L) is less stringent than what was calculated as part of this renewal (0.398 mg/L). Based on the existing discharge data, the permittee has demonstrated its ability to comply by meeting the proposed limit at least 75% of the time; therefore, no compliance schedule is established in the draft permit. This is in accordance with the Department's SOP entitled "New and Reissuance Sewage Individual NPDES Permit Applications."

**Best Professional Judgment (BPJ) Limitations**

Comments: None

**Anti-Backsliding**

The previous limits can be used pursuant to EPA's anti-backsliding regulation, 40 CFR 122.44(l). The previous permit limitations, monitoring requirements, and conditions will be retained. New or more stringent limitations are being proposed for E. Coli, and TRC.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day)		Concentrations (mg/L)				Minimum Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
Dissolved Oxygen	XXX	XXX	5.0 Daily Min	XXX	XXX	XXX	1/day	Grab
Total Residual Chlorine (TRC)	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
Influent BOD5	Report	XXX	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Influent Total Suspended Solids	Report	XXX	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Carbonaceous Biochemical Oxygen Demand (CBOD5)	41.0	65.0	XXX	25.0	40.0	50	1/week	8-Hr Composite
Total Suspended Solids	50.0	75.0	XXX	30.0	45.0	60	1/week	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	XXX	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Ammonia-Nitrogen Nov 1 - Apr 30	32	XXX	XXX	19.5	XXX	39	1/week	8-Hr Composite
Ammonia-Nitrogen May 1 - Oct 31	15.8	XXX	XXX	6.5	XXX	13	1/week	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report	XXX	XXX	1/week	8-Hr Composite

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**


Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.4	XXX	1.3	1/day	Grab
CBOD5	41.0	65.0	XXX	25.0	40.0	50	1/week	8-Hr Composite
BOD5 Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	1/week	8-Hr Composite
TSS Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	1/week	8-Hr Composite
TSS	50.0	75.0	XXX	30.0	45.0	60	1/week	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	XXX	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Ammonia Nov 1 - Apr 30	32	XXX	XXX	19.5	XXX	39	1/week	8-Hr Composite
Ammonia May 1 - Oct 31	15.8	XXX	XXX	6.5	XXX	13	1/week	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report	XXX	XXX	1/week	8-Hr Composite
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab

Compliance Sampling Location: Outfall 001 after disinfection


Other Comments:

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [REDACTED])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [REDACTED])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [REDACTED]
<input type="checkbox"/>	Other: [REDACTED]

Attachment 1  
eMAP – Receiving stream location and Designation



**Attachment 2**  
**Google Earth Aerial Site View**



Attachment 3  
WQM 7.0 Modeling Output files

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name		RMI	Elevation	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC		
16B	56422	STILLWATER CREEK		1.720	1373.00	12.00	0.00000	0.00	<input checked="" type="checkbox"/>		
Stream Data											
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream pH	
Q7-10	0.087	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	
Q1-10		0.00	0.00	0.000	0.000						
Q30-10		0.00	0.00	0.000	0.000						
Discharge Data											
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH				
StillwaterCreek	PA0239445	0.2000	0.2000	0.2000	0.000	25.00	7.00				
Parameter Data											
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)							
CBOD5	25.00	2.00	0.00	1.50							
Dissolved Oxygen	5.00	8.24	0.00	0.00							
NH3-N	25.00	0.00	0.00	0.70							

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name		RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC	
16B	56422	STILLWATER CREEK		1.316	1357.00	12.20	0.00000	0.00	<input checked="" type="checkbox"/>	
Stream Data										
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)
Q7-10	0.068	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00
Q1-10		0.00	0.00	0.000	0.000					
Q30-10		0.00	0.00	0.000	0.000					
Discharge Data										
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH			
		0.0000	0.0000	0.0000	0.000	25.00	7.00			
Parameter Data										
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)						
CBOD6	25.00	2.00	0.00	1.50						
Dissolved Oxygen	5.00	8.24	0.00	0.00						
NH3-N	25.00	0.00	0.00	0.70						

**WQM 7.0 Hydrodynamic Outputs**

SWP Basin		Stream Code		Stream Name								
16B	56422	STILLWATER CREEK										
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
(cfs)	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
<b>Q7-10 Flow</b>												
1.720	0.81	0.00	0.81	.3094 0.00750	.525	15.91	30.31	0.13	0.184	21.38	7.00	
<b>Q1-10 Flow</b>												
1.720	0.52	0.00	0.52	.3094 0.00750	NA	NA	NA	0.11	0.218	21.87	7.00	
<b>Q30-10 Flow</b>												
1.720	1.10	0.00	1.10	.3094 0.00750	NA	NA	NA	0.15	0.162	21.10	7.00	

**WQM 7.0 Modeling Specifications**

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

**WQM 7.0 Wasteload Allocations**

SWP Basin		Stream Code	Stream Name				
16B	56422	STILLWATER CREEK					
<b>NH3-N Acute Allocations</b>							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
1.720	StillwaterCreek	14.35	38.37	14.35	38.37	0	0
<b>NH3-N Chronic Allocations</b>							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
1.720	StillwaterCreek	1.76	8.01	1.76	8.01	0	0
<b>Dissolved Oxygen Allocations</b>							
RMI	Discharge Name	CBOD5 Baseline (mg/L)	CBOD5 Multiple (mg/L)	NH3-N Baseline (mg/L)	NH3-N Multiple (mg/L)	Dissolved Oxygen Baseline (mg/L)	Dissolved Oxygen Multiple (mg/L)
1.72	StillwaterCreek	25	25	8.01	8.01	5	5
						0	0

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
16B	56422	STILLWATER CREEK		
RML	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
1.720	0.200	21.383	7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
15.911	0.526	30.314	0.134	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
8.36	1.207	2.22	0.779	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
7.346	9.862	Tsivoglou	5	
<u>Reach Travel Time (days)</u>	<u>Subreach Results</u>			
0.184	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.018	8.17	2.18	7.21
	0.037	7.98	2.15	7.10
	0.055	7.79	2.12	7.02
	0.074	7.61	2.09	6.96
	0.092	7.43	2.06	6.92
	0.111	7.25	2.03	6.89
	0.129	7.08	2.00	6.88
	0.148	6.92	1.98	6.87
	0.166	6.76	1.95	6.87
	0.184	6.60	1.92	6.88

WQM 7.0 Effluent Limits

SWP Basin	Stream Code	Stream Name					
		16B	56422	STILLWATER CREEK			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
1.720	StillwaterCreek	PA0239445	0.200	CBOD5	25		
				NH3-N	8.01	16.02	
				Dissolved Oxygen			5

**Attachment 4**  
**TRC\_CALC Modeling Output files**

TRC\_CALC

<b>TRC EVALUATION</b>							
Input appropriate values in A3:A9 and D3:D9							
0.823	= Q stream (cfs)		0.5	= CV Daily			
0.2	= Q discharge (MGD)		0.5	= CV Hourly			
30	= no. samples		1	= AFC_Partial Mix Factor			
0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor			
0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)			
0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)			
0	= % Factor of Safety (FOS)			=Decay Coefficient (K)			
Source	Reference	AFC Calculations		Reference	CFC Calculations		
TRC	1.3.2.iii	WLA_afc = 0.868		1.3.2.iii	WLA_cfc = 0.838		
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581		
PENTOXSD TRG	5.1b	LTA_afc= 0.323		5.1d	LTA_cfc = 0.487		
Source							
Effluent Limit Calculations							
PENTOXSD TRG	5.1f		AML MULT = 1.231				
PENTOXSD TRG	5.1g		AVG MON LIMIT (mg/l) = 0.398		AFC		
			INST MAX LIMIT (mg/l) = 1.301				
WLA_afc		(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))... ...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)					
LTAMULT_afc		EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)					
LTA_afc		wla_afc*LTAMULT_afc					
WLA_cfc		(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))... ...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)					
LTAMULT_cfc		EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)					
LTA_cfc		wla_cfc*LTAMULT_cfc					
AML MULT		EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))					
AVG MON LIMIT		MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)					
INST MAX LIMIT		1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)					