

Application Type Renewal
Wastewater Type Sewage
Facility Type SRSTP

**NPDES PERMIT FACT SHEET
INDIVIDUAL SFTF/SRSTP**

Application No. PA0239658
APS ID 1052377
Authorization ID 1377443

Applicant, Facility and Project Information

Applicant Name	<u>Gregory Renninger</u>	Facility Name	<u>Gregory Renninger SRSTP</u>
Applicant Address	<u>138 Buena Vida Lane</u> <u>Shippenville, PA 16254</u>	Facility Address	<u>27 Gravel Lick Road</u> <u>Fisher, PA 16225</u>
Applicant Contact	<u>Gregory Renninger</u>	Facility Contact	<u>Gregory Renninger</u>
Applicant Phone	<u>(814) 229-9818</u>	Facility Phone	<u>(814) 229-9818</u>
Client ID	<u>366951</u>	Site ID	<u>648771</u>
SIC Code	<u>8800</u>	Municipality	<u>Millcreek Township</u>
SIC Description	<u>Private Households</u>	County	<u>Clarion County</u>
Date Application Received	<u>November 29, 2021</u>	WQM Required	<u>Yes</u>
Date Application Accepted	<u>November 30, 2021</u>	WQM App. No.	<u>1605403 will be transferred concurrently</u>

Project Description Renewal of an NPDES Permit for an existing Single Residence Sewage Treatment Plant. This application also transfers ownership from Matthew C. Culp to Gregory Renninger.

Summary of Review

Act 14 - Proof of Notification was submitted and received.

The applicant should be able to meet the limits of this permit, which will protect the uses of the receiving stream.

I. OTHER REQUIREMENTS:

- | | |
|----------------------------------------------------|---------------------------------|
| A. AMRs | F. Stormwater into sewers |
| B. DMRs | G. Right of way |
| C. Depth of Septage and Scum Measurement | H. Solids handling |
| D. Septic Tank Pumping | I. Public Sewerage Availability |
| E. Effluent Chlorine Optimization and Minimization | |

SPECIAL CONDITIONS: None.

Permitted treatment consists of: A 1,000 gallon dual compartment septic tank, a 500 gallon dose tank, a 313.5 square foot (WQM Permit no. 1605403) (14'-3" x 22'-0") recirculating subsurface sand filter (RSSF) and Ultraviolet (UV) light disinfection.

It is recommended that this NPDES Permit be renewed/transferred.

There are no open violations in efacts associated with the subject Client ID (366951) as of 1/26/2022.

Approve	Deny	Signatures	Date
X		Stephen A. McCauley Stephen A. McCauley, E.I.T. / Environmental Engineering Specialist	1/26/2022
X		Justin C. Dickey Justin C. Dickey, P.E. / Environmental Engineer Manager	1/28/2022

Discharge, Receiving Waters and Water Supply Information

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.0004</u>
Latitude	<u>41° 15' 59.70"</u>	Longitude	<u>79° 14' 34.08"</u>
Quad Name	<u>Cooksburg</u>	Quad Code	<u>0812</u>
Wastewater Description: <u>treated sanitary wastewater</u>			
Receiving Waters	<u>Unnamed Tributary to the Blyson Run (EV)</u>	Stream Code	<u>N/A</u>
NHD Com ID	<u>102669261</u>	RMI	<u>N/A</u>
Drainage Area	<u>-</u>	Yield (cfs/mi ²)	<u>-</u>
Q ₇₋₁₀ Flow (cfs)	<u>-</u>	Q ₇₋₁₀ Basis	<u>-</u>
Elevation (ft)	<u>-</u>	Slope (ft/ft)	<u>-</u>
Watershed No.	<u>17-B</u>	Chapter 93 Class.	<u>EV</u>
Existing Use	<u>-</u>	Existing Use Qualifier	<u>-</u>
Exceptions to Use	<u>-</u>	Exceptions to Criteria	<u>-</u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u>-</u>		
Source(s) of Impairment	<u>-</u>		
TMDL Status	<u>-</u>	Name	<u>-</u>
Background/Ambient Data		Data Source	
pH (SU)	<u>-</u>		<u>-</u>
Temperature (°F)	<u>-</u>		<u>-</u>
Hardness (mg/L)	<u>-</u>		<u>-</u>
Other:	<u>-</u>		<u>-</u>
Nearest Downstream Public Water Supply Intake	<u>Pennsylvania American Water Company - Clarion</u>		
PWS Waters	<u>Clarion River</u>	Flow at Intake (cfs)	<u>90.7</u>
PWS RMI	<u>33.3</u>	Distance from Outfall (mi)	<u>4.0</u>

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

This SFTF was designed in accordance with the SFTF Manual, but it does not qualify for the PAG-04 General Permit due to the receiving stream being designated as Exceptional Value (EV).

No modeling was performed for this NPDES Permit as septic tank/sand filter systems have been documented as being capable of meeting the proposed BOD₅ and TSS limits of 10 mg/l, which are less than the inputs of the WQ model.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Annual Average	Maximum	Instant. Maximum		
Flow (GPD)	Report Annl Avg	XXX	XXX	XXX	XXX	XXX	1/year	Estimate
pH (S.U.)	XXX	XXX	6.0	XXX	9.0	XXX	1/month	Grab
BOD5	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
TSS	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
Fecal Coliform (No./100 ml)	XXX	XXX	XXX	200	XXX	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001, after Ultraviolet (UV) light disinfection.

Flow is monitor only based on Chapter 92a.61. The limits for pH are technology-based on Chapter 93.7. The limits for BOD₅, Total Suspended Solids, and Fecal Coliform are technology-based on Chapter 92a.47.