

Application Type Renewal
Wastewater Type Sewage
Facility Type SRSTP

**NPDES PERMIT FACT SHEET
INDIVIDUAL SFTF/SRSTP**

Application No. PA0239691
APS ID 1034549
Authorization ID 1346976

Applicant, Facility and Project Information

Applicant Name	<u>Carl R Brugger</u>	Facility Name	<u>Carl R Brugger SRSTP</u>
Applicant Address	<u>6194 Cobblestone Drive</u> <u>Erie, PA 16509-7802</u>	Facility Address	<u>13478 Old Lake Road #66</u> <u>East Springfield, PA 16411</u>
Applicant Contact	<u>Carl Brugger</u>	Facility Contact	<u>Carl Brugger</u>
Applicant Phone	<u>(814) 460-0882</u>	Facility Phone	<u>(814) 460-0882</u>
Client ID	<u>328412</u>	Site ID	<u>655853</u>
SIC Code	<u>8800</u>	Municipality	<u>Springfield Township</u>
SIC Description	<u>Private Households</u>	County	<u>Erie</u>
Date Application Received	<u>March 9, 2021</u>	WQM Required	<u>No, already permitted</u>
Date Application Accepted	<u></u>	WQM App. No.	<u>2506402 T-2</u>
Project Description	<u>Renewal of an SRSTP NPDES permit.</u>		

Summary of Review

This application is for a renewal of an NPDES permit, for an existing discharge of treated sewage from a small flow treatment facility.

A 600-gallon and a dual-compartment, 1000-gallon septic tank (in series). The first compartment of the second tank will serve as septic treatment and include a Zabel effluent filter. The second compartment will serve as the pump chamber. The discharge from this second compartment will dose an Ecoflo peat filter. The peat filter effluent will gravity flow to a UV disinfection unit prior to discharging to an existing storm drain. The storm drain will carry the discharge approx. 400-ft. to the receiving stream.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Emily Voorhees Emily C. M. Voorhees / Civil Engineer	June 8, 2021
X		Justin C. Dickey Justin C. Dickey, P.E. / Environmental Engineer Manager	June 11, 2021

Discharge and Stream Data – 2 - Receiving Waters and PWS

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.0004</u>
Latitude	<u>41° 59' 41.65"</u>	Longitude	<u>-80° 27' 40.01"</u>
Quad Name	<u></u>	Quad Code	<u></u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Unnamed Stream to Lake Erie</u>	Stream Code	<u>---</u>
NHD Com ID	<u>123922038</u>	RMI	<u></u>
Drainage Area	<u>---</u>	Yield (cfs/mi ²)	<u>---</u>
Q ₇₋₁₀ Flow (cfs)	<u>---</u>	Q ₇₋₁₀ Basis	<u>---</u>
Elevation (ft)	<u></u>	Slope (ft/ft)	<u>---</u>
Watershed No.	<u>15-A</u>	Chapter 93 Class.	<u>CWF, MF</u>
Existing Use	<u></u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u>none</u>	Exceptions to Criteria	<u>---</u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u></u>		
Source(s) of Impairment	<u></u>		
TMDL Status	<u></u>	Name	<u></u>
Background/Ambient Data		Data Source	
pH (SU)	<u>---</u>		<u></u>
Temperature (°F)	<u>---</u>		<u></u>
Hardness (mg/L)	<u>---</u>		<u></u>
Other:	<u>---</u>		<u></u>
Nearest Downstream Public Water Supply Intake	<u>PA/Canadian international boundary</u>		
PWS Waters	<u>Lake Erie</u>	Flow at Intake (cfs)	<u>---</u>
PWS RMI	<u>---</u>	Distance from Outfall (mi)	<u>---</u>

Changes Since Last Permit Issuance:

Other Comments:

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Annual Average	Maximum	Instant. Maximum		
Flow (GPD)	Report Annl Avg	XXX	XXX	XXX	XXX	XXX	1/year	Estimate
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	Upon Request	Grab
BOD5	XXX	XXX	XXX	10.0	XXX	20	1/year	Grab
TSS	XXX	XXX	XXX	10.0	XXX	20	1/year	Grab
Fecal Coliform (No./100 ml)	XXX	XXX	XXX	200	XXX	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001, after UV disinfection.

Other Comments: Flow is monitor only based on Chapter 92a.61. The limits for BOD5, Total Suspended Solids, and Fecal Coliforms are technology- based on Chapter 92a.47.