

Application Type Renewal
Facility Type Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0239712
APS ID 892018
Authorization ID 1372302

Applicant and Facility Information

Applicant Name	<u>Bear Creek Watershed Authority</u>	Facility Name	<u>Bruin STP</u>
Applicant Address	<u>258 Argyle Street</u> <u>Petrolia, PA 16050</u>	Facility Address	<u>Bruin STP Parker Street</u> <u>Bruin, PA 16022</u>
Applicant Contact	<u>Thomas McElravy, Chairman</u>	Facility Contact	<u>Chris Dunmyre, Operator</u>
Applicant Phone	<u>(724) 756-4600</u>	Facility Phone	<u></u>
Applicant E Mail	<u>bearcreekwater@zoominternet.net</u>	Facility E Mail	<u></u>
Client ID	<u>62798</u>	Site ID	<u>724614</u>
Municipality	<u>Fairview Township</u>	Municipality	<u>Parker Township</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Connection Status	<u>No Limitations</u>
Applicant Name	<u>Bear Creek Watershed Authority</u>	County	<u>Butler</u>
Received	<u>October 12, 2021</u>	EPA Waived?	<u>Yes</u>
Accepted	<u>October 19, 2021</u>	If No, Reason	<u></u>

Purpose of Application NPDES renewal

Summary of Review

No current violations reported. The facility serves Parker Township with a 632-person population for 9% of the total population served and Bruin Borough with a 524-person population for 91% of the total population served with 100% separate sanitary sewers.

Sludge is sent to the Petrolia STP for final treatment and disposal.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		<i>William H. Mentzer</i> William H. Mentzer, P.E. Environmental Engineering Specialist	January 4, 2023
X		Justin C. Dickey Justin C. Dickey, P.E. Environmental Engineer Manager	January 11, 2023

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.0432
Latitude DP	41° 3' 50.77"	Longitude DP	-79° 43' 34.80"
Latitude NHD	41° 3' 50.72"	Longitude NHD	-79° 43' 34.47"
Quad Name	Parker	Quad Code	1008
Wastewater Description:	Municipal sanitary sewers		
Receiving Waters	Bear Creek	Stream Code	49116
NHD Com ID	123851477	RMI	3.87
Drainage Area	38.4	Yield (cfs/mi ²)	0.044*
Q ₇₋₁₀ Flow (cfs)	1.6	Q ₇₋₁₀ Basis	Stream Stats 4.0
Elevation (ft)	1010.65	Slope (ft/ft)	0.00912
Watershed No.	17-C	Chapter 93 Class.	CWF
Existing Use	statewide	Existing Use Qualifier	none
Exceptions to Use	none	Exceptions to Criteria	none
Comments	Node RMI 0.03 above tributary 49138. At the North Branch Drainage 62.0 sq mile Elevation 888.74 feet RMI 1.42. Mouth drainage 7730 sq mile Elevation 820.39 feet		
Assessment Status	Impaired		
Cause(s) of Impairment	unknown, nutrients, and siltation		
Source(s) of Impairment	municipal point source discharges, urban runoff/storm sewers and unknown other		
TMDL Status	Name		
Background/Ambient Data	Data Source		
pH (SU)	7.94	June 14 2017 Bear Creek below South Branch study	
Temperature (°C)	20	CWF default	
Hardness (mg/L)	100	Default	
Other:			
Nearest Downstream Public Water Supply Intake	Butler District Pennsylvania-American Water Company**		
PWS Waters	Allegheny River	Flow at Intake (cfs)	NA
PWS RMI	69.9	Distance from Outfall (mi)	16.2

Changes Since Last Permit Issuance: none

Other Comments:

*Previous evaluations used the Toms Run @ Cooksburg gage station data to develop a yield rate for this watershed (0.048 cfs/mi). Previous evaluations used the USGS Stream Stats Version 3T with 'Low Flow Statistics for PA Streams'. Beta Version 4 is now in place which uses Low-Flow, Base-Flow, and Mean-Flow Regression Equations for Pennsylvania Streams by Marla H. Stuckey to determine low flows.

**This is a supplemental water source that transfers water from the Allegheny River over to the Boydstown-Oneida & Thorn Run reservoirs in the headwaters of Connoquenessing Creek.

Treatment Facility Summary				
Treatment Facility Name: Bruin Borough Bear Creek Watershed Authority				
WQM Permit No.		Issuance Date		
1083402		25 August 1983		
1083402		1985		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Extended Aeration	Hypochlorite	0.0432
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.0432	120	Not Overloaded	Holding	Other

Changes Since Last Permit Issuance: none

Other Comments: The 1985 design load is 115-PPD. Biosolids treatment is provided at the Petrolia Borough STP

Last Reviewed WLMR is for 2017

Sanitary sewer service for 775 EDU.
 Annual average flow is 0.0432-MGD
 Mean Flow 0.018-MGD
 Maximum monthly Flow 0.029-MGD January 2017

Annual Average BOD5 Load 119.68-PPD
 Mean BOD5 25-PPD
 Maximum monthly BPD5 37-PPD July 2017

Pump Stations

- 1 Parker Street
- 2 Bruin Park
- 4 Hook City Road
- 3 Linamen Grinder

Compliance History

DMR Data for Outfall 001 (from September 1, 2020 to August 31, 2021)

Parameter	AUG-21	JUL-21	JUN-21	MAY-21	APR-21	MAR-21	FEB-21	JAN-21	DEC-20	NOV-20	OCT-20	SEP-20
Flow (MGD) Ave Mon	0.0446	0.0275	0.0217	0.0467	0.0314	0.0363	0.0330	0.0321	0.0369	0.0196	0.0281	0.0267
Flow (MGD) D Max	0.0498	0.0289	0.0321	0.1684	0.0343	0.0375	0.0351	0.0372	0.0373	0.0320	0.0977	0.0537
pH (S.U.) Minimum	7.54	7.48	7.48	7.44	7.49	7.42	7.41	7.39	7.38	7.29	7.25	7.39
pH (S.U.) Maximum	7.62	7.59	7.56	7.54	7.56	7.55	7.5	7.52	7.49	7.40	7.54	7.54
DO (mg/L) Daily Min	4.0	4.0	4.0	4.0	4.0	4.0	4.0	4.0	4.0	4.0	4.0	4.0
TRC (mg/L) Ave Mon	0.31	0.31	0.34	0.26	0.25	0.25	0.41	0.40	0.41	0.34	0.47	0.46
TRC (mg/L) Inst Max	0.62	0.50	0.55	0.60	0.56	0.38	1.19	0.66	0.69	0.6	1.04	0.90
CBOD5 (ppd) Ave Mon	2.3	0.7	0.9	3.1	2.6	1.73	1.5	1.10	1.9	1.03	0.96	1.22
CBOD5 (lbs/day) Weekly Average	3.6	0.8	1.7	3.8	3.1	2.03	2.2	2.23	2.8	1.07	1.31	1.31
CBOD5 (mg/L) Ave M	6.1	3.1	5.2	8.0	10.1	5.7	5.3	4.1	6.15	6.3	4.1	5.5
CBOD5 (mg/L) Wkly A	8.6	3.2	6.4	9.5	10.9	6.5	7.6	7.2	9.1	6.5	5.6	5.9
BOD5 (ppd) Influent Average Monthly	58.2	29.8	52.6	102.2	74.9	48.7	67	37.1	50.2	28.1	71.7	61.9
BOD5 (ppd) Influent Weekly Average	76.8	35.4	94.8	105.9	113.6	83.2	78.5	64.5	63.1	54.2	73.8	71.0
BOD5 (mg/L) Influent Average Monthly	56.5	130	290.5	262.5	286	161	242	138.7	163	171	306	278
BOD5 (mg/L) Influent Weekly Average	185	147	354.0	267	397	266	268	208.0	203	203	315	319
TSS (ppd) Ave Mon	1.7	0.6	0.6	2.1	1.8	0.41	1.3	0.37	1.0	2.0	1.36	0.45
TSS (ppd) Influent Average Monthly	31.2	21.3	21.7	69.3	63.9	29.5	38.5	31.6	42.7	29.6	89.9	0.45
TSS (ppd) Influent Weekly Average	39.0	27.0	48.2	95.3	74.4	46.9	46.3	48.4	52.3	42.7	112.0	0.45
TSS (ppd) Wkly Ave	3.7	0.9	1.5	2.7	2.4	0.47	1.9	0.87	1.2	2.4	2.24	0.45
TSS (mg/L) Ave Mon	4.5	2.6	3.5	5.4	6.85	1.35	4.6	1.4	3.25	12.0	5.8	2.0
TSS (mg/L) Influent Average Monthly	84.0	93.0	120.0	178	244	97.5	140	118	139	180	383	2.0
TSS (mg/L) Influent Weekly Average	94.0	112.0	180.0	240	260	150	158	156	168	260	478	2.0
TSS (mg/L) Wkly Ave	9.0	3.6	5.6	6.8	8.4	14.5	6.4	2.8	4.0	14.8	9.6	2.0
F Coliform (#/100 ml) Geometric Mean	170	141	120	64	515	353	1458	1329	253	721	407	88
T N (mg/L) Ave Mon	4.0	0.5	0.2	0.92	1.6	6.34	0.42	4.6	7.4	1.67	3.7	2.68
Amm (ppd) Ave Mon	1.2	0.24	0.1	0.02							0.44	1.58
Amm (mg/L) Ave Mon	3.2	1.03	0.7	0.1	0.7	4.2	0.4	0.65	4.0	1.09	1.87	7.11
T P (mg/L) Ave Mon	5.5	3.1	5.8	3.6	4.4	3.39	4.9	2.8	4.6	3.4	5.43	5.12

**NPDES Permit Fact Sheet
Bruin STP**

NPDES Permit No. PA0239712

	Month	Year	INFLUENT				EFFLUENT					
			Mean MGD	Mean PPD	Min	Mean	Max	#	Min	Mean	Max	#
Annual Average Design			0.0432									
Hydraulic Design			0.0432									
Annual Average Flow		2018	0.0270									
		2019	0.0280									
		2020	0.0290									
Highest Monthly Average	March		0.0390									
pH									7.1		7.78	1460
TRC										0.29	1.29	73
Fecal Coliform										381	1000	48
CBOD5										7.32	19.6	48
TSS										7.20	25.6	48
Amm										3.76	18.51	48
N										4.32	14.12	48
P										3.61	6.91	48

Chemicals used:

- Calcium Oxide (lime) for pH adjustment
- Calcium hypochlorite for disinfection

3.88 dry tons sludge was removed to the Dalton Processing Facility then to a landfill by Dalton Service Company after treatment at the Petrolia STP.

Development of Effluent Limitations

Outfall No. <u>001</u>	Design Flow (MGD) <u>.0432</u>
Latitude <u>41° 3' 50.77"</u>	Longitude <u>-79° 43' 34.80"</u>
Wastewater Description: <u>Sewage Effluent</u>	

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
DO	4.0	Daily Minimum		BPJ
E Coli	Report			BPJ

Comments: none

Water Quality-Based Limitations

A sewage based "Reasonable Potential Analysis" determined the following parameters were candidates for limitations: BOD₅, CBOD₅, TSS, ammonia-nitrogen, nitrogen, phosphorus, chlorine, UV light, DO and pH.

The following limitations were determined through water quality modeling (output files attached):

Parameter		Limit (mg/l)		SBC	Model		
CBOD ₅		25.0	50.0	NA	25.0	50.0	
Ammonia N	summer	13.0	26.0	NA	13.0	26.0	
Ammonia N	winter	Report	Report		39.0	78.0	
DO		4.0			4.0		

Comments:

As the assumed winter ammonia nitrogen effluent concentration is less than the winter limits no winter concentration limit is necessary and monitoring is recommended.

Best Professional Judgment (BPJ) Limitations

Comments: Applies to DO.

Anti-Backsliding

With ammonia compliance the existing requirements are continued.

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
17C	49141	SOUTH BRANCH BEAR CREEK	0.000	855.00	63.20	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.044	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
17C	49141	SOUTH BRANCH BEAR CREEK	4.110	1046.00	38.41	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.044	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Bruin	PA0239712	0.0432	0.0432	0.0432	0.000	25.00	7.50

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	8.24	0.00	0.00
NH3-N	25.00	0.10	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
17C	49141	SOUTH BRANCH BEAR CREEK	7.640	1158.00	8.80	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.044	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Petrolia	PA0094200	0.0411	0.0411	0.0411	0.000	25.00	7.20

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	8.24	0.00	0.00
NH3-N	25.00	0.10	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
17C	49141	SOUTH BRANCH BEAR CREEK	9.790	1195.00	4.54	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.044	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Karns City	PA0239739	0.0340	0.0340	0.0340	0.000	25.00	7.10

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	8.24	0.00	0.00
NH3-N	25.00	0.10	0.00	0.70

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
17C		49141				SOUTH BRANCH BEAR CREEK						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow												
9.790	0.20	0.00	0.20	.0526	0.00326	.417	9	21.59	0.07	1.954	21.04	7.02
7.640	0.39	0.00	0.39	.1162	0.00601	.465	12.03	25.9	0.09	2.396	21.15	7.03
4.110	1.69	0.00	1.69	.183	0.00880	.598	22.34	37.35	0.14	1.791	20.49	7.02
Q1-10 Flow												
9.790	0.13	0.00	0.13	.0526	0.00326	NA	NA	NA	0.06	2.358	21.46	7.03
7.640	0.25	0.00	0.25	.1162	0.00601	NA	NA	NA	0.08	2.874	21.60	7.04
4.110	1.08	0.00	1.08	.183	0.00880	NA	NA	NA	0.11	2.232	20.72	7.03
Q30-10 Flow												
9.790	0.27	0.00	0.27	.0526	0.00326	NA	NA	NA	0.08	1.698	20.81	7.01
7.640	0.53	0.00	0.53	.1162	0.00601	NA	NA	NA	0.10	2.090	20.90	7.02
4.110	2.30	0.00	2.30	.183	0.00880	NA	NA	NA	0.16	1.530	20.37	7.01

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	95.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

WQM 7.0 Wasteload Allocations

SWP Basin **Stream Code** **Stream Name**
17C 49141 SOUTH BRANCH BEAR CREEK

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
9.790	Karns City	14.5	49.51	14.5	49.51	0	0
7.640	Petrolia	14.94	50	14.13	50	0	0
4.110	Bruin	16.11	50	15.39	50	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
9.790	Karns City	1.78	10.46	1.78	9.66	2	8
7.640	Petrolia	1.81	15.97	1.76	14.75	2	8
4.110	Bruin	1.86	25	1.83	25	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
9.79	Karns City	25	25	9.66	9.66	4	4	0	0
7.64	Petrolia	25	25	14.75	14.75	4	4	0	0
4.11	Bruin	25	25	25	25	4	4	0	0

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>			
17C	49141	SOUTH BRANCH BEAR CREEK			
<hr/>					
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>	
9.790	0.034	21.042		7.019	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>	
9.002	0.417	21.587		0.067	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>	
6.79	0.596	2.09		0.758	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>	
7.359	18.384	Owens		5	
<u>Reach Travel Time (days)</u>					
1.954					
Subreach Results					
	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>	
	0.195	6.01	1.80	8.24	
	0.391	5.32	1.56	8.24	
	0.586	4.71	1.34	8.24	
	0.782	4.17	1.16	8.24	
	0.977	3.69	1.00	8.24	
	1.173	3.26	0.86	8.24	
	1.368	2.89	0.74	8.24	
	1.563	2.55	0.64	8.24	
	1.759	2.26	0.55	8.24	
	1.954	2.00	0.48	8.24	
<hr/>					
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>	
7.640	0.075	21.154		7.031	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>	
12.035	0.465	25.901		0.090	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>	
4.91	0.355	2.14		0.765	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>	
7.707	18.346	Owens		5	
<u>Reach Travel Time (days)</u>					
2.396					
Subreach Results					
	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>	
	0.240	4.48	1.78	8.24	
	0.479	4.10	1.48	8.24	
	0.719	3.75	1.23	8.24	
	0.959	3.43	1.03	8.24	
	1.198	3.13	0.85	8.24	
	1.438	2.86	0.71	8.24	
	1.678	2.62	0.59	8.24	
	1.917	2.39	0.49	8.24	
	2.157	2.19	0.41	8.24	
	2.396	2.00	0.34	8.24	
<hr/>					

WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
17C	49141	SOUTH BRANCH BEAR CREEK					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
9.790	Karns City	PA0239739	0.034	CBOD5	25		
				NH3-N	9.66	19.32	
				Dissolved Oxygen			4
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
7.640	Petrolia	PA0094200	0.041	CBOD5	25		
				NH3-N	14.75	29.5	
				Dissolved Oxygen			4
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
4.110	Bruin	PA0239712	0.043	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			4

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
17C	49141	SOUTH BRANCH BEAR CREEK		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
4.110	0.118	20.489	7.019	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
22.336	0.598	37.353	0.140	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
2.82	0.188	1.05	0.727	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
8.092	11.864	Tsivoglou	5	
<u>Reach Travel Time (days)</u>	Subreach Results			
1.791	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.179	2.73	0.92	8.24
	0.358	2.63	0.81	8.24
	0.537	2.54	0.71	8.24
	0.716	2.46	0.63	8.24
	0.896	2.38	0.55	8.24
	1.075	2.29	0.48	8.24
	1.254	2.22	0.42	8.24
	1.433	2.14	0.37	8.24
	1.612	2.07	0.33	8.24
	1.791	2.00	0.29	8.24

WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
17C	49141	SOUTH BRANCH BEAR CREEK					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
9.790	Karns City	PA0239739	0.034	CBOD5	25		
				NH3-N	9.66	19.32	
				Dissolved Oxygen			4
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
7.640	Petrolia	PA0094200	0.041	CBOD5	25		
				NH3-N	14.75	29.5	
				Dissolved Oxygen			4
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
4.110	Bruin	PA0239712	0.043	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			4

1A	B	C	D	E	F	G	H	I	J	K	L	M
	Discharger Site Municipality County NPDES Permit 0.5		Bruin Borough Bruin STP Bruin Borough Butler PA0239712					Revised	Wednesday, December 15, 2021 Thursday, December 29, 2022			
2	TRC EVALUATION											
3	Input appropriate values in B4:B8 and E4:E7											
4	0.1975	= Q stream (cfs)				0.5	= CV Daily					
5	0.0340	= Q discharge (MGD)				0.5	= CV Hourly					
6	30	= no. samples				1	= AFC_Partial Mix Factor					
7	0.4	= Chlorine Demand of Stream				1	= CFC_Partial Mix Factor					
8	0	= Chlorine Demand of Discharge				15	= AFC_Criteria Compliance Time (min)					
9	0	= BAT/BPJ Value				720	= CFC_Criteria Compliance Time (min)					
		= % Factor of Safety (FOS)					= Decay Coefficient (K)					
10	Source	Reference	AFC Calculations				Reference	CFC Calculations				
11	TRC	1.3.2.iii	WLA afc = 1.593				1.3.2.iii	WLA cfc = 1.555				
12	PENTOXSD TRG	5.1a	LTAMULT afc = 0.373				5.1c	LTAMULT cfc = 0.581				
13	PENTOXSD TRG	5.1b	LTA_afc = 0.593				5.1d	LTA_cfc = 0.904				
14	Source	Effluent Limit Calculations										
15	PENTOXSD TRG	5.1f	AML MULT = 1.231									
16	PENTOXSD TRG	5.1g	↓ LIMIT (mg/l) = 0.500				BAT/BPJ					
17			↓ LIMIT (mg/l) = 1.635									
18												
	WLA_afc	$(0.1975e^{-k \cdot AFC_tc}) + [(AFC_Yc \cdot Qs \cdot 0.019 / Qd) e^{-k \cdot AFC_tc}] \dots + Xd + (AFC_Yc \cdot Qs \cdot Xs / Qd) \cdot (1 - FOS / 100)$										
	LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$										
	LTA_afc	wla_afc / LTAMULT_afc										
	WLA_cfc	$(0.117e^{-k \cdot CFC_tc}) + [(CFC_Yc \cdot Qs \cdot 0.117 / Qd) e^{-k \cdot CFC_tc}] \dots + Xd + (CFC_Yc \cdot Qs \cdot Xs / Qd) \cdot (1 - FOS / 100)$										
	LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no_samples + 1)) - 2.326 \cdot LN(cvd^2 / no_samples + 1)^{0.5})$										
	LTA_cfc	wla_cfc / LTAMULT_cfc										
	AML_MULT	$EXP(2.326 \cdot LN((cvd^2 / no_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no_samples + 1))$										
	AVG MON LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)										
	INST MAX LIMIT	$1.5 \cdot ((av_mon_limit / AML_MULT) / LTA_afc)$										
	$(0.0117 \cdot EXP(-k \cdot CFC_tc / 1440)) + ((CFC_Yc \cdot Qs \cdot 0.0117) / (1.547 \cdot Qd)) \dots + EXP(-k \cdot CFC_tc / 1440) + Xd + (CFC_Yc \cdot Qs \cdot Xs / 1.547 \cdot Qd) \cdot (1 - FOS / 100)$											
	Stream	Chlorine Required	=	perennial	Chlorine Demand	+	Chlorine Residual					
	Stream	Reach/Node	1	1								
	Stream	Flow	Conditions	perennial								
	Stream	Code		49141								
	Stream	Function										
	Samples			30								
	reach	outfall	RMI	9.79								
	reach	Reach End	RMI	7.64								
	reach		feet	11352								
	drainage		sq miles	4.54								
	TRC	limitation	average	mg/L	0.500							
			maximum	mg/L	1.600							
	elevation		modelled	feet	1195							
	elevation		modelled	feet	1158							
	slope		modelled	foot/foot	0.003							
	low flow			cfs/sq mi	0.044							
	discharge			mgd	0.0340							
	Runoff	Period		hours	24.000							
	Multiple discharges											
	stream	flow		cfs	0.19755							
	stream	flow		MGD	0.127678							
	stream	flow	total	MGD	0.161678							
	stream	chlorine	demand	mg/L	0.4	0.3						
	discharge	discharge	demand	mg/L								
	stream	Total Stream/Waste	ratio		4.8							
	PaGIS map and NHD place the discharge at RMI 0.34. This is approximately 1000 feet above tributary 62717 and perennial stream conditions.											
	permitted	TRC	mean	BAT	0.5							
	permitted	TRC	maximum	BAT	1.6							

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average Report Daily Max	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	4.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	9.0	14.4	XXX	25.0	40.0	50.0	2/month	8-Hr Composite
BOD5 Raw Sewage Influent	Report	Report	XXX	Report	Report	XXX	2/month	8-Hr Composite
TSS Raw Sewage Influent	Report	Report	XXX	Report	Report	XXX	2/month	8-Hr Composite
TSS	10.8	16.2	XXX	30.0	45.0	60.0	2/month	8-Hr Composite
E Coli	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	XXX	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	XXX	2/month	Grab
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	3.2	XXX	XXX	13.0	XXX	26.0	2/month	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite

Compliance Sampling Location: Outfall 001 after disinfection