

Application Type Renewal  
Wastewater Type Sewage  
Facility Type SRSTP

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SFTF/SRSTP**

Application No. PA0240141  
APS ID 640740  
Authorization ID 1259805

**Applicant, Facility and Project Information**

Applicant Name	<u>Stephen Sherk</u>	Facility Name	<u>Stephen Sherk SFTF</u>
Applicant Address	<u>20 Yohe Road</u> <u>Bradford, PA 16701</u>	Facility Address	<u>20 Yohe Road</u> <u>Bradford, PA 16701</u>
Applicant Contact	<u>Stephen Sherk</u>	Facility Contact	<u>Stephen Sherk</u>
Applicant Phone	<u>(814) 362-3405</u>	Facility Phone	<u>(814) 362-3405</u>
Client ID	<u>262669</u>	Site ID	<u>680584</u>
SIC Code	<u>8800</u>	Municipality	<u>Corydon Township</u>
SIC Description	<u>Private Households</u>	County	<u>McKean County</u>
Date Application Received	<u>January 20, 2019</u>	WQM Required	<u>No</u>
Date Application Accepted	<u>January 29, 2019</u>	WQM App. No.	<u>-</u>
Project Description	<u>Single Residence Sewage Treatment Plant.</u>		

**Summary of Review**

Act 14 - Proof of Notification was submitted and received.

A Part II Water Quality Management permit is not required at this time.

The applicant should be able to meet the limits of this permit, which will continue to protect the uses of the receiving stream.

**I. OTHER REQUIREMENTS:**

- |  |                                 |
|--|---------------------------------|
| A. AMRs  | F. Stormwater into sewers       |
| B. DMRs  | G. Right of way                 |
| C. Depth of Septage and Scum Measurement           | H. Solids handling              |
| D. Septic Tank Pumping                             | I. Public Sewerage Availability |
| E. Effluent Chlorine Optimization and Minimization |                                 |

SPECIAL CONDITIONS: None.

Permitted treatment consists of: A 1,000 gallon dual compartment septic tank with an effluent filter, a 500 gallon dosing tank, a 680 square foot (20' x 34') subsurface sand filter, and Ultraviolet (UV) light disinfection.  
(WQM Permit #4208401)

There are no open violations in effects for Client ID 262669 as of 9/27/2019.

Approve	Deny	Signatures	Date
X		Stephen A. McCauley, E.I.T. / Environmental Engineering Specialist	
X		Justin C. Dickey, P.E. / Environmental Engineer Manager	

**Discharge, Receiving Waters and Water Supply Information**

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.0004</u>
Latitude	<u>41° 58' 41.00"</u>	Longitude	<u>78° 52' 25.00"</u>
Quad Name	<u>-</u>	Quad Code	<u>-</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Unnamed Tributary to the Willow Creek (HQ-CWF)</u>	Stream Code	<u>N/A</u>
NHD Com ID	<u>112366625</u>	RMI	<u>N/A</u>
Drainage Area	<u>-</u>	Yield (cfs/mi <sup>2</sup> )	<u>-</u>
Q <sub>7-10</sub> Flow (cfs)	<u>-</u>	Q <sub>7-10</sub> Basis	<u>-</u>
Elevation (ft)	<u>-</u>	Slope (ft/ft)	<u>-</u>
Watershed No.	<u>16-B</u>	Chapter 93 Class.	<u>High Quality Waters - Cold Water Fishes</u>
Existing Use	<u>-</u>	Existing Use Qualifier	<u>-</u>
Exceptions to Use	<u>-</u>	Exceptions to Criteria	<u>-</u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u>-</u>		
Source(s) of Impairment	<u>-</u>		
TMDL Status	<u>-</u>	Name	<u>-</u>
Background/Ambient Data		Data Source	
pH (SU)	<u>-</u>		<u>-</u>
Temperature (°F)	<u>-</u>		<u>-</u>
Hardness (mg/L)	<u>-</u>		<u>-</u>
Other:	<u>-</u>		<u>-</u>
Nearest Downstream Public Water Supply Intake	<u>Pennsylvania - New York State border</u>		
PWS Waters	<u>Allegheny River</u>	Flow at Intake (cfs)	<u>N/A</u>
PWS RMI	<u>N/A</u>	Distance from Outfall (mi)	<u>4.5</u>

The measurement frequency for pH was changed from 1/Year to 1/month to comply with the SOP and current Department policy due to the receiving stream being designated as High Quality.

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Annual Average	Maximum	Instant. Maximum		
Flow (MGD)	Report Annl Avg	XXX	XXX	XXX	XXX	XXX	1/year	Estimate
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/month	Grab
BOD5	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
TSS	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
Fecal Coliform (No./100 ml)	XXX	XXX	XXX	200	XXX	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001, after Ultraviolet (UV) light disinfection.

Flow is monitor only based on Chapter 92a.61. The limits for pH are technology-based on Chapter 93.7. The limits for BOD5, Total Suspended Solids, and Fecal Coliforms are technology-based on Chapter 92a.47.