

Application Type Renewal  
Wastewater Type Sewage  
Facility Type SRSTP

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SFTF/SRSTP**

Application No. PA0240214  
APS ID 808960  
Authorization ID 1264309

**Applicant, Facility and Project Information**

Applicant Name	<u>Wen-Li Wang</u>	Facility Name	<u>Wen-Li Wang SRSTP</u>
Applicant Address	<u>225 Oak Tree Court</u> <u>Erie, PA 16511</u>	Facility Address	<u>7671 East Lake Road</u> <u>Erie, PA 16511</u>
Applicant Contact	<u>Wen-Li Wang</u>	Facility Contact	<u>Wen-Li Wang</u>
Applicant Phone	<u>-</u>	Facility Phone	<u>-</u>
Client ID	<u>295750</u>	Site ID	<u>705778</u>
SIC Code	<u>8800</u>	Municipality	<u>Harborcreek Township</u>
SIC Description	<u>Private Households</u>	County	<u>Erie County</u>
Date Application Received	<u>March 4, 2019</u>	WQM Required	<u>No</u>
Date Application Accepted	<u>March 5, 2019</u>	WQM App. No.	<u>-</u>
Project Description	<u>Renewal of an NPDES Permit for an existing discharge of treated sanitary wastewater from an SRSTP.</u>		

**Summary of Review**

Act 14 - Proof of Notification was submitted and received.  
A Part II Water Quality Management permit is not required at this time.  
The applicant should be able to meet the limits of this permit, which will continue to protect the uses of the receiving stream.

**I. OTHER REQUIREMENTS:**

- |  |                                 |
|--|---------------------------------|
| A. AMRs  | F. Stormwater into sewers       |
| B. DMRs  | G. Right of way                 |
| C. Depth of Septage and Scum Measurement           | H. Solids handling              |
| D. Septic Tank Pumping                             | I. Public Sewerage Availability |
| E. Effluent Chlorine Optimization and Minimization |                                 |

SPECIAL CONDITIONS: None.

Permitted treatment consists of: A 1,000 gallon dual-compartment septic tank with an effluent filter, an Eco Flow STB 650 peat biofilter, Ultraviolet (UV) light disinfection, and a 235 gallon effluent pump tank.  
(WQM Permit no. 2508404)

There are no open violations in efacts for Client ID 295750 as of 10/11/2019.

Approve	Deny	Signatures	Date
X		Stephen A. McCauley, E.I.T. / Environmental Engineering Specialist	
X		Justin C. Dickey, P.E. / Environmental Engineer Manager	

**Discharge, Receiving Waters and Water Supply Information**

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.0004</u>
Latitude	<u>42° 11' 37.48"</u>	Longitude	<u>79° 56' 35.76"</u>
Quad Name	<u>-</u>	Quad Code	<u>-</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Eightmile Creek (CWF, MF)</u>	Stream Code	<u>N/A</u>
NHD Com ID	<u>123923654</u>	RMI	<u>N/A</u>
Drainage Area	<u>-</u>	Yield (cfs/mi <sup>2</sup> )	<u>-</u>
Q <sub>7-10</sub> Flow (cfs)	<u>-</u>	Q <sub>7-10</sub> Basis	<u>-</u>
Elevation (ft)	<u>-</u>	Slope (ft/ft)	<u>-</u>
Watershed No.	<u>15-A</u>	Chapter 93 Class.	<u>Cold Water Fishes, Migratory Fishes</u>
Existing Use	<u>-</u>	Existing Use Qualifier	<u>-</u>
Exceptions to Use	<u>-</u>	Exceptions to Criteria	<u>-</u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u>-</u>		
Source(s) of Impairment	<u>-</u>		
TMDL Status	<u>-</u>	Name	<u>-</u>
Background/Ambient Data		Data Source	
pH (SU)	<u>-</u>		<u>-</u>
Temperature (°F)	<u>-</u>		<u>-</u>
Hardness (mg/L)	<u>-</u>		<u>-</u>
Other:	<u>-</u>		<u>-</u>
Nearest Downstream Public Water Supply Intake	<u>Pennsylvania-Canada border</u>		
PWS Waters	<u>Lake Erie</u>	Flow at Intake (cfs)	<u>-</u>
PWS RMI	<u>-</u>	Distance from Outfall (mi)	<u>10+</u>

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

This SRSTP does not qualify for PAG-04 General NPDES Permit due to the use of a peat biofilter.

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Annual Average	Maximum	Instant. Maximum		
Flow (MGD)	Report Annl Avg	XXX	XXX	XXX	XXX	XXX	1/year	Estimate
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/year	Grab
BOD5	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
TSS	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
Fecal Coliform (No./100 ml)	XXX	XXX	XXX	200	XXX	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001, after Ultraviolet (UV) light disinfection.

Flow is monitor only based on Chapter 92a.61. The limits for pH are technology-based on Chapter 93.7. The limits for BOD5, Total Suspended Solids, and Fecal Coliforms are technology-based on Chapter 92a.47.