

Application Type Renewal
 Facility Type Non-Municipal
 Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0244074
 APS ID 1032004
 Authorization ID 1342633

Applicant and Facility Information

Applicant Name	<u>Aqua Pennsylvania Wastewater Inc.</u>	Facility Name	<u>Stony Creek Farms WWTF</u>
Applicant Address	<u>762 W Lancaster Avenue</u> <u>Bryn Mawr, PA 19010</u>	Facility Address	<u>233 Caspian Lane</u> <u>Eagleville, PA 19403</u>
Applicant Contact	<u>Todd Duerr</u>	Facility Contact	<u>Kyle Roberts</u>
Applicant Phone	<u>(610) 645-1122</u>	Facility Phone	<u>(610) 645-6384</u>
Client ID	<u>62614</u>	Site ID	<u>638277</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Worcester Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Montgomery</u>
Date Application Received	<u>January 28, 2021</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u></u>	If No, Reason	<u></u>
Purpose of Application	<u>Permit renewal</u>		

Summary of Review

The Permittee, Aqua Pennsylvania Wastewater Inc. has submitted application for renewal of a NPDES permit to discharge 45,000-gpd of treated sewage to Stony Creek from the Stony Creek Farms subdivision in Worcester Township, Montgomery County. The facility receives sewage from 209 age-restricted homes, a bed and breakfast, and clubhouse.

The original NPDES permit was issued in 2006 for a permitted flow of 42,863-gpm. The effluent limits for the permit were derived from a Preliminary Treatment Requirements letter issued to DeVal Soil & Environmental Consultants, Inc., on March 31, 2003. The Total Phosphorus limit was reduced from 1.0 mg/l to 0.5 mg/l as per meeting between FX Browne and DEP. The limits for CBOD₅, Ammonia Nitrogen, and Dissolved Oxygen were confirmed as protective of in-stream criteria, by computer modeling using WQM 7.0 for Windows. Based on a comment letter dated February 26, 2006, the numerical nitrite-nitrate numerical limit was removed from the permit, and monitoring and reporting requirement was included in the final permit.

Based on an April 25, 2007 planning approval letter, an additional connection of 2,030-gpd was approved for a total flow of 45,000-gpd. Since the original effluent limits were technology-based limits, the revised permit included the same concentration-based limits.

The sewage treatment plant is extended aeration plant consisting of equalization tank, six aeration tanks, two clarifiers, tertiary filters, UV disinfection, and sludge holding tank.

This is a minor NPDES permit renewal and there are no proposed changes to the treatment plant or influent sewage characteristics. Therefore, it is recommended to carry over the effluent limits from the existing permit. Minor changes are made to this permit renewal that includes the addition of influent monitoring for TSS & BOD₅, and effluent monitoring for E.

Approve	Deny	Signatures	Date
X		<i>Ketan Thaker</i> Ketan Thaker / Project Manager	11/15/2021
		Pravin C. Patel, P.E. / Environmental Engineer Manager	

Summary of Review

Coli which is consistent with SOP. The discharge is generally in compliance with effluent limits of the NPDES permit. The effluent limits for all other parameters are rolled over in this permit renewal.

The following is a summary of the original Water Quality Protection Report dated December 29, 2005.

Technology Based Effluent Limits

Overview - The wastewater treatment facility discharges to a small stream with a Q7-10 low-flow discharge of approximately 0.13-cfs. A preliminary treatment requirement letter was issued by the DEP on March 31, 2003 that lists technology based effluent limits for small stream discharges. CBOD₅ and TSS limits are consistent with the most stringent ABACT technology-based standard outlined in the Water Quality Antidegradation Implementation Guidance manual, and the "minimum treatment" requirement outlined in Implementation Guidance for Evaluating Wastewater Discharges to Drainage Ditches and Swales. Per discussion with Katie Ferry of FX Browne on 9/21/05, the PTR limit for phosphorus was reduced to 0.5 mg/l.

CBOD₅ - The PTR listed a CBOD₅ limit of 10 mg/l as a monthly average.

Total Suspended Solids (TSS) - The PTR listed a TSS limit of 10 mg/l as a monthly average.

NH₃-N - The PTR listed a seasonal NH₃-N limit of 1.5 mg/l (May 1 – Oct 31), and 3.0 mg/l (Nov 1 – Apr 30).

Nitrite + Nitrate as N - The PTR listed a 10 mg/l limit for Nitrate + Nitrite as N. This limit is consistent with the drinking water standard and 25 PA Code 93.7 for public water supplies. This was later removed in response to the February 26, 2006 comment letter.

Phosphorous - The PTR listed the phosphorus limit as 1.0 mg/l. Based on a meeting with FX Browne on 9/21/05, this limit was revised to 0.5 mg/l.

Dissolved Oxygen - The PTR listed a 6.0 mg/l minimum limit for dissolved oxygen.

Disinfection/ Total Residual Chlorine (TRC) - The PTR listed a fecal coliform limit of 50#/100ml as a geometric mean. Since a UV disinfection system was proposed, no residual chlorine is permitted in the discharge.

Water Based Effluent Limits

The technology-based effluent limits listed in the preliminary treatment requirement (PTR) letter were evaluated using the Department's WQM 7.0 for Windows computer model. The design stream (Q7-10) flow at the proposed point of discharge was based on the USGS website Low Flow Statistics for Pennsylvania Streams. The reference gage used was Skippack Creek near Collegetown (Gage # 01473120). The Q7-10 flow of 1.89-cfs for a drainage area of 53.7 mi² calculates to a low-flow yield of 0.035-cfs.

The model showed that ammonia limits are sensitive to both temperature and pH, because of the limited dilution afforded by the stream. Since the stream has limited dilution and because of the trout stocking designation, conservative values for temperature and pH were used in the model. For summer, stream temperature was 20° C (25 C° discharge) and pH was 8.0 S.U. For winter, temperature was 5° C and pH was 8.0 S.U. The model showed that the limits are protective of water quality criteria for both dissolved oxygen and ammonia.

The Department has not established numerical nutrient criterion. However, EPA published eco-region based guidelines and other studies suggest that nuisance algae can occur at levels below 0.1 mg/l phosphorus. The Department required a technology-based limit of 0.5 mg/l for total phosphorus. Assuming background phosphorus concentrations of 0.04 – 0.1 mg/l, the in-stream concentration of phosphorus at design condition was estimated as 0.20 – 0.24 mg/l. The Department will continue to monitor the stream to see if the stream and reserves the right to amend the permit in the future for more stringent limits.

Act 14 Notice to Worcester Township on January 13, 2021.

Act 14 Notice to Montgomery County on January 13, 2021.

Summary of Review

Sludge use and disposal description and location(s): Sludge is sent to DELCORA for treatment and disposal

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Discharge, Receiving Waters and Water Supply Information

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.045</u>
Latitude	<u>40° 9' 59.43"</u>	Longitude	<u>-75° 19' 19.81"</u>
Quad Name	_____	Quad Code	_____
Wastewater Description: <u>Sewage Effluent</u>			

Receiving Waters	<u>Stony Creek (TSF, MF)</u>	Stream Code	<u>00948</u>
NHD Com ID	<u>25979214</u>	RMI	<u>5.6000</u>
Drainage Area	<u>3.6</u>	Yield (cfs/mi ²)	<u>0.035</u>
Q ₇₋₁₀ Flow (cfs)	<u>0.13</u>	Q ₇₋₁₀ Basis	<u>2005 WQPR</u>
Elevation (ft)	<u>210</u>	Slope (ft/ft)	_____
Watershed No.	<u>3-F</u>	Chapter 93 Class.	<u>TSF, MF</u>
Existing Use	_____	Existing Use Qualifier	_____
Exceptions to Use	_____	Exceptions to Criteria	_____

Assessment Status	<u>Impaired</u>
Cause(s) of Impairment	<u>CAUSE UNKNOWN, FLOW REGIME MODIFICATION, FLOW REGIME MODIFICATION, FLOW REGIME MODIFICATION, SILTATION</u>
Source(s) of Impairment	<u>HABITAT MODIFICATION - OTHER THAN HYDROMODIFICATION, HIGHWAY/ROAD/BRIDGE RUNOFF (NON-CONSTRUCTION RELATED), HIGHWAY/ROAD/BRIDGE RUNOFF (NON-CONSTRUCTION RELATED), REMOVAL OF RIPARIAN VEGETATION, RURAL (RESIDENTIAL AREAS)</u>
TMDL Status	Name _____

Background/Ambient Data	Data Source
pH (SU)	_____
Temperature (°F)	_____
Hardness (mg/L)	_____
Other:	_____

Nearest Downstream Public Water Supply Intake _____	
PWS Waters _____	Flow at Intake (cfs) _____
PWS RMI _____	Distance from Outfall (mi) _____

Treatment Facility Summary				
Treatment Facility Name: Stony Creek Farms WWTF				
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Tertiary	Extended Aeration with Solids Removal	Ultraviolet	0.045
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.045	112	Not Overloaded	Dewatering	Landfill

Compliance History

DMR Data for Outfall 001 (from September 1, 2020 to August 31, 2021)

Parameter	AUG-21	JUL-21	JUN-21	MAY-21	APR-21	MAR-21	FEB-21	JAN-21	DEC-20	NOV-20	OCT-20	SEP-20
Flow (MGD) Average Monthly	0.01575	0.01997	0.0168	0.0180	0.0197	0.01836	0.0174	0.0181	0.0195	0.0179	0.01588	0.0155
pH (S.U.) Minimum	6.98	7.04	7.10	7.04	7.0	6.67	6.9	6.84	6.78	7.1	7.23	7.40
pH (S.U.) Maximum	8.15	8.13	7.88	7.73	7.8	7.62	7.55	7.55	7.86	7.98	8.09	7.97
DO (mg/L) Minimum	6.91	6.12	6.33	7.82	7.93	7.49	9.84	9.03	7.63	7.35	7.81	8.6
CBOD5 (lbs/day) Average Monthly	< 0.32	< 0.36	< 0.32	< 0.57	0.39	0.72	< 0.35	0.35	0.44	< 0.29	0.36	< 0.26
CBOD5 (mg/L) Average Monthly	< 2.2	< 2	< 2	< 4.4	2.8	3.7	< 2.5	2.35	2.7	< 2	2.68	< 2
TSS (lbs/day) Average Monthly	0.16	0.22	0.05	0.46	< 0.37	< 0.40	0.16	0.24	0.40	0.29	0.18	0.15
TSS (mg/L) Average Monthly	1.2	1.3	0.3	3.6	< 2.5	< 2	1.2	1.6	2.4	2.0	1.2	1.2
Fecal Coliform (CFU/100 ml) Geometric Mean	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	1	1	< 1
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	1	1	< 1
UV Transmittance (%) Minimum	59.9	62.8	85	69.1	82.6	79.4	81	81.0	80.7	86.2	81.3	80.5
Nitrate-Nitrite (lbs/day) Average Monthly	< 4.1	< 3.7	2.3	1.3	2.42	< 4.77	3.4	3.89	4.64	4.04	3.75	4.3
Nitrate-Nitrite (mg/L) Average Monthly	< 28.1	< 20.6	14.7	11.1	17.94	< 24.56	25.6	26.79	26.76	28.17	29.6	33.1
Total Nitrogen (lbs/day) Average Monthly	< 4.2	< 3.8	2.5	1.58	2.67	< 5.0	3.5	3.99	4.82	4.1	3.8	4.4
Total Nitrogen (mg/L) Average Monthly	< 28.8	< 21.2	15.5	12.99	19.71	25.73	26.2	27.42	27.83	28.8	30.2	33.7
Ammonia (lbs/day) Average Monthly	< 0.07	< 0.09	0.15	< 0.06	< 0.06	< 0.02	< 0.07	< 0.07	0.13	< 0.07	< 0.06	< 0.06

**NPDES Permit Fact Sheet
Stony Creek Farms WWTF**

NPDES Permit No. PA0244074

Ammonia (mg/L) Average Monthly	< 0.5	< 0.5	0.9	< 0.52	< 0.4	< 0.1	< 0.5	< 0.5	0.75	< 0.5	< 0.5	< 0.5
TKN (lbs/day) Average Monthly	0.10	< 0.11	< 0.13	0.25	0.25	0.23	< 0.08	< 0.09	0.18	< 0.09	< 0.08	< 0.08
TKN (mg/L) Average Monthly	0.71	< 0.63	< 0.81	< 1.91	1.78	1.17	< 0.63	< 0.63	1.06	< 0.63	< 0.63	< 0.63
Total Phosphorus (lbs/day) Average Monthly	0.06	0.03	0.03	0.03	0.04	0.06	0.03	0.03	0.04	0.03	0.02	0.04
Total Phosphorus (mg/L) Average Monthly	0.41	0.16	0.2	0.28	0.27	0.32	0.21	0.23	0.25	0.21	0.2	0.26

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Daily Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	Continuous	Metered
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	6.0 Inst Min	XXX	XXX	XXX	1/day	Grab
CBOD5	3.75	XXX	XXX	10	XXX	20	2/month	24-Hr Composite
BOD5 Raw Sewage Influent	XXX	XXX	XXX	Report	XXX	XXX	2/month	24-Hr Composite
TSS	3.75	XXX	XXX	10	XXX	20	2/month	24-Hr Composite
TSS Raw Sewage Influent	XXX	XXX	XXX	Report	XXX	XXX	2/month	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	50 Geo Mean	XXX	1000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	50 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
UV Transmittance (%)	XXX	XXX	Report	XXX	XXX	XXX	1/day	Measured
Nitrate-Nitrite	Report	XXX	XXX	Report	XXX	XXX	2/month	24-Hr Composite
Total Nitrogen	Report	XXX	XXX	Report	XXX	XXX	1/month	Calculation

Outfall001 , Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Daily Minimum	Average Monthly	Maximum	Instant. Maximum		
Ammonia Nov 1 - Apr 30	1.13	XXX	XXX	3.0	XXX	6	2/month	24-Hr Composite
Ammonia May 1 - Oct 31	0.56	XXX	XXX	1.5	XXX	3	2/month	24-Hr Composite
TKN	Report	XXX	XXX	Report	XXX	XXX	2/month	24-Hr Composite
Total Phosphorus	0.19	XXX	XXX	0.5	XXX	1	2/month	24-Hr Composite