

Application Type Amendment  
Facility Type Storm Water  
Major / Minor Minor

## NPDES PERMIT FACT SHEET

Application No. PA0244929 A-1  
APS ID 987379  
Authorization ID 1263180

### Applicant and Facility Information

Applicant Name	<u>Waste Management of PA Inc.</u>	Facility Name	<u>Waste Management of PA - Bordertown Road Facility</u>
Applicant Address	<u>1000 New Ford Mill Road</u> <u>Morrisville, PA 19067</u>	Facility Address	<u>1400 Bordertown Road</u> <u>Morrisville, PA 19067</u>
Applicant Contact	<u>Brian Bolvin</u>	Facility Contact	<u>Brian Bolvin</u>
Applicant Phone	<u>(215) 428-4384</u>	Facility Phone	<u>(215) 428-4384</u>
Client ID	<u>92382</u>	Site ID	<u>704882</u>
SIC Code	<u>4953</u>	Municipality	<u>Falls Township</u>
SIC Description	<u>Trans. &amp; Utilities - Refuse Systems</u>	County	<u>Bucks</u>
Date Application Received	<u>February 28, 2019</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u></u>	If No, Reason	<u></u>
Purpose of Application	<u>Department initiated Permit amendment to address permit appeal filed by applicant.</u>		

### Summary of Review

The permit amendment is initiated by the Department to address permit appeal filed by applicant with Environmental Hearing Board on January 22, 2018. The NPDES permit was issued on December 19, 2017. This permit amendment replaces other requirement no. VII "Seepage Management Plan" on page no.22 of NPDES permit with language under title "Control and Sampling Requirements for Leachate Impacted Stormwater Basins". Also, monitoring frequency for all the parameters with Benchmark Value is revised from monthly to quarterly as the effluent did not exceed benchmark parameters in last two years.

Approve	Return	Deny	Signatures	Date
			Ketan Thaker / Project Manager	
			Pravin C. Patel, P.E. / Environmental Engineer Manager	