

Application Type New
Facility Type Industrial
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL INDUSTRIAL WASTE (IW)
AND IW STORMWATER**

Application No. PA0245186
APS ID 1011920
Authorization ID 1306470

Applicant and Facility Information

Applicant Name	<u>Victory Brewing Co.</u>	Facility Name	<u>Victory Brewing Parkesburg Site</u>
Applicant Address	<u>420 Acorn Lane</u> <u>Downingtown, PA 19335</u>	Facility Address	<u>3127 Lower Valley Road</u> <u>Parkesburg, PA 19365</u>
Applicant Contact	<u>Ray Reiff</u>	Facility Contact	<u>Ray Reiff</u>
Applicant Phone	<u>(610) 514-7000</u>	Facility Phone	<u>(610) 514-7000</u>
Client ID	<u>304462</u>	Site ID	<u>770150</u>
SIC Code	<u>2082</u>	Municipality	<u>West Sadsbury Township</u>
SIC Description	<u>Manufacturing - Malt Beverages</u>	County	<u>Chester</u>
Date Application Received	<u>February 4, 2020</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>Not Applicable</u>	If No, Reason	<u></u>
Purpose of Application	<u>Non-contact cooling water and stormwater run-off into Valley Creek.</u>		

Summary of Review

Victory Brewing submitted an application for a NPDES permit to discharge non-contact cooling water (NCCW) and stormwater associated with industrial activity. Victory Brewing manufactures malt beverages. There are two (2) cooling towers called the Evapco and the Bac. The discharge is to the Valley Creek, a tributary to East Branch Octoraro Creek. This creek is located in the Susquehanna River Basin which is part of the larger Chesapeake Bay Basin.

The water used for NCCW comes from the public water supply (PWS) PA American Water. The facility sends process wastewater to the wastewater treatment plant in Coatesville, PA. This permit is for NCCW and SW only.

This facility uses three (3) chemical additives in the NCCW; all three chemical additives are on the DEP approved list.

- GCS6308 – Phosphonate based corrosion inhibitor
- GCS3907 – Stabilized Liquid Bromine – Oxidizing biological control
- GCS3215 – Isothiazolin - non-oxidizing biocide

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Harmonie Hawley, PhD, PE / Environmental Engineering Specialist /s/	5/7/2020
X		Pravin C. Patel, P.E. / Environmental Engineer Manager /s/	05/07/2020

Summary of Review

Maximum usage rates as reported in the permit application and subsequent correspondences:

Discharge Rates:

The Evapco Tower volume is 2,000 gallons with a holding time index of 12.4 hours. The average weekly blowdown for the Evapco Tower is about 5,000 gallons. These blowdowns occur as needed. The Evapco tower reportedly releases ~ 714 gpd or 0.50 gpm in daily bleed/blowdown discharges as needed under normal operation.

The BAC Tower volume is 900 gallons (contained in two towers of 450 gallons each) with a holding time of 5.6 hours. The average weekly blowdown for the BAC Tower is about 4,000 gallons per week. These blowdowns occur as needed. The BAC towers reportedly release ~ 571 gpd or 0.40 gpm in daily bleed/blowdown discharges as needed under normal operation.

The combined flow is 9,000 gallons per week or 0.001286 MGD.

Chemical Additives:

GCS6308 = 1.723 lbs. per week; 0.187 lbs. of product / 1000 gallons of blowdown – (40% active product)

BAC Tower = 0.75 lbs. of product per week. Evapco Tower = 0.973 lbs. of product per week.

GCS3907 = 1.695 lbs. per week.

BAC Tower = 0.525 lbs. of product per week, fed at 0.075 lbs. per application (7 applications per week). This is based on 900 gallons at 10 ppm of product. Evapco Tower = 1.17 lbs. of product per week, fed at 0.167 lbs. per application (7 applications per week). This is based on 2,000 gallons at 10 ppm of product.

GCS3215 = 4.35 lbs. per week.

BAC Tower = 1.35 lbs. per week, fed at 0.676 lbs. per application (2 applications per week). This is based on 900 gallons at 90 ppm of product.

Evapco Tower = 3 lbs. per week, fed at 1.5 lbs. per application (2 applications per week). This is based on 2,000 gallons at 90 ppm of product.

Annual Batch Discharge:

Evapco: According to Victory, the maximum “batch” discharge from the 2,000-gallon Evapco tower is 403 gallons during annual servicing. When discharged, it is released at a rate of 45 gallons per minute. This will therefore take approximately 9 minutes as currently configured; however, the discharge rate can be slowed.

BAC: According to Victory, the maximum “batch” discharge from the 900-gallon BAC tower system is 482 gallons (2x241 gallons). The two towers are connected and when the annual service is done, they discharge one at a time (as not to disrupt cooling of HVAC in the offices and Tap room spaces). When discharged, it is released at a rate of 45 gallons per minute. This will therefore take approximately 10 minutes.

Act 14 Notifications

Chester County received January 8, 2020

West Sadsbury Township received January 8, 2020

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.001286</u>
Latitude	<u>39° 57' 2.40"</u>	Longitude	<u>-75° 56' 3.83"</u>
Quad Name	<u>Parkeburg</u>	Quad Code	<u>1938</u>
Wastewater Description: <u>Noncontact Cooling Water (NCCW) blowdown discharge and Stormwater</u>			
Receiving Waters	<u>Valley Creek (TSF, MF)</u>	Stream Code	<u>07131</u>
NHD Com ID	<u>57464913</u>	RMI	<u>0.8500</u>
Drainage Area	<u>1.37 square miles</u>	Yield (cfs/mi ²)	<u>0.146</u>
Q ₇₋₁₀ Flow (cfs)	<u>0.2</u>	Q ₇₋₁₀ Basis	<u>Pennsylvania StreamStats</u>
Elevation (ft)	<u>508</u>	Slope (ft/ft)	<u>0.005</u>
Watershed No.	<u>7-K</u>	Chapter 93 Class.	<u>TSF, MF</u>
Existing Use	<u>Trout Stocking</u>	Existing Use Qualifier	<u>N/A</u>
Exceptions to Use	<u>None</u>	Exceptions to Criteria	<u>None</u>
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>Siltation</u>		
Source(s) of Impairment	<u>Agriculture</u>		
TMDL Status	<u>Tentative</u>	Name	<u>Octoraro Creek Watershed TMDL</u>
Background/Ambient Data		Data Source	
pH (SU)	<u>8.8</u>	Application analysis results	
Temperature (°F)	<u>77.7</u>	Application analysis results	
Nearest Downstream Public Water Supply Intake	<u>Not applicable – no intakes</u>		
PWS Waters	<u>N/A</u>	Flow at Intake (cfs)	<u>N/A</u>
PWS RMI	<u>N/A</u>	Distance from Outfall (mi)	<u>N/A</u>

Changes Since Last Permit Issuance: Not applicable – new permit

Other Comments: The TMDL for the Octoraro Creek Watershed is not finalized.

Treatment Facility Summary				
Treatment Facility Name: Not Applicable				
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Industrial	N/A	N/A	N/A	N/A
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
N/A	N/A	N/A	N/A	N/A

Changes Since Last Permit Issuance: Not applicable – new permit

Other Comments: This is NCCW and stormwater, thus there is no treatment facility.

Compliance History	
Summary of DMRs:	Not Applicable – new permit
Summary of Inspections:	In progress

Other Comments: None

Compliance History

Not applicable – new permit

Development of Effluent Limitations

Outfall No. 001 (IMP001) **Design Flow (MGD)** 0.001286
Latitude 39° 57' 7.89" **Longitude** -75° 56' 8.04"
Wastewater Description: Noncontact Cooling Water (NCCW)

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Parameter	Limit (mg/l)	SBC	Federal Regulation	State Regulation
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: The above industrial minimum technology standards were evaluated. As the source water is treated potable water, and the discharge is NCCW, it is assumed fecal coliform will not be an issue.

The intake water is PWS and is presumed to contain chlorine. As the facility adds a bromine based chemical additive, total residual halogens will be monitored in lieu of total residual chlorine (TRC), but the limits will be those of TRC per the standard.

Oil & grease (O&G) will be monitored as the concentration noted in the application less than 4.8 mg/l (quantitation limit 4.8). Standard practice is to monitor O&G if the concentration is between 4 mg/L and 8 mg/L (SOP and Chapter 95.2); as the detection limit is above 4 mg/l, O&G will be monitored.

Temperature was added as a parameter for this facility as it is cooling water discharge. The application sample was at 77.7 °F and was taken in the winter.

Total Dissolved Solids (TDS) sample results were 926 mg/l which indicates a potential for contamination (Chapter 95.10). While the concentration did not exceed 1,000 mg/l, the concentration of 926 mg/l is high enough to warrant the need for baseline monitoring.

This facility is in the Chesapeake Bay Watershed and the chemical additives contain phosphorus, thus total phosphorous monitoring was added to the permit. The sampling frequency is consistent with the Phase 3 WIP Supplement.

Monitoring frequency and sample type are consistent with Table 6-4 of the Permit Writer’s Manual (362-0400-001 10/1/97).

Water Quality-Based Limitations

A “Reasonable Potential Analysis” was not conducted as this is NCCW. The BOD₅ was well below 30 mg/l and the reported maximum ammonia-N concentration was <0.10 mg/l.

Best Professional Judgment (BPJ) Limitations

Comments: The BOD₅ (<4.1 mg/l) and Total Suspended Solids (TSS, 78 mg/l) are less than 100 mg/l, no monitoring is needed.

Anti-Backsliding

Not applicable

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (cfs) Internal Monitoring Point	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/month	Metered
pH (S.U.) Internal Monitoring Point	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/month	Grab
Total Residual Halogens Internal Monitoring Point	XXX	XXX	XXX	0.5	XXX	1.6	1/month	Grab
Temperature (°F) Internal Monitoring Point	XXX	XXX	XXX	XXX	XXX	110.0	1/month	I-S
Total Dissolved Solids Internal Monitoring Point	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/month	Grab
Oil and Grease Internal Monitoring Point	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/month	Grab
Total Phosphorus Internal Monitoring Point	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab

Compliance Sampling Location: IMP001

Other Comments: None.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
pH (S.U.)	XXX	XXX	XXX	XXX	Report	XXX	1/6 months	Grab
BOD5	XXX	XXX	XXX	XXX	Report	XXX	1/6 months	Grab
COD	XXX	XXX	XXX	XXX	Report	XXX	1/6 months	Grab
TSS	XXX	XXX	XXX	XXX	Report	XXX	1/6 months	Grab
Oil and Grease	XXX	XXX	XXX	XXX	Report	XXX	1/6 months	Grab
Nitrate-Nitrite	XXX	XXX	XXX	XXX	Report	XXX	1/6 months	Grab
Total Nitrogen	XXX	XXX	XXX	XXX	Report	XXX	1/6 months	Grab
Total Phosphorus	XXX	XXX	XXX	XXX	Report	XXX	1/6 months	Grab

Compliance Sampling Location: 001

Other Comments: These effluent limitations and monitoring requirements are for stormwater. These limits and monitoring requirements are consistent with stormwater sampling protocols for facilities of a similar industry (PAG03). Total Phosphorous and Total Nitrogen monitoring were added as the facility is located in the Chesapeake Bay Watershed.

Tools and References Used to Develop Permit	
<input type="checkbox"/>	WQM for Windows Model (see Attachment)
<input type="checkbox"/>	PENTOXSD for Windows Model (see Attachment)
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment)
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment)
<input type="checkbox"/>	Toxics Screening Analysis Spreadsheet (see Attachment)
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input checked="" type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP for Establishing Effluent Limitations for Individual Industrial Permits, BCW-PMT-032, Final November 9, 2012, Revised January 10, 2019, Version 1.5. SOP for New and Reissuance Industrial Waste and Industrial Stormwater Individual NPDES Permits, BPNPSM-PMT-001, Final November 9, 2012, Revised October 11, 2013, Version 1.5. SOP for Chemical Additives, BPNPSM-PMT-030, Final November 9, 2012, Revised January 13, 2015, Version 1.4. SOP for Whole Effluent Toxicity (WET), BPNPSM-PMT-031, Final November 9, 2012, Revised May 13, 2014, Version 1.4.
<input checked="" type="checkbox"/>	Other: DEP, Phase III Watershed Implementation Plan (WIP) Supplement. Policy and Procedure for NPDES Permitting of Discharges of Total Dissolved Solids (385-2100-002).