

Application Type

Renewal

Facility Type

Non-Municipal

Major / Minor

Minor

Application No.

PA0246484

APS ID

542007

Authorization ID

1498178

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Applicant and Facility Information

Applicant Name	AQUA PA Wastewater Inc.	Facility Name	Links At Gettysburg
Applicant Address	762 W Lancaster Avenue	Facility Address	601 Mason Dixon Road
	Bryn Mawr, PA 19010		Gettysburg, PA 17325-8642
Applicant Contact	Mike Fili	Facility Contact	Stephen Draus
Applicant Phone	(570) 648-5783	Facility Phone	(570) 648-5783
Client ID	62614	Site ID	615172
Ch 94 Load Status	Not Overloaded	Municipality	Mount Joy Township
Connection Status	No Limitations	County	Adams
Date Application Received	August 28, 2024	EPA Waived?	Yes
Date Application Accepted	September 4, 2024	If No, Reason	
Purpose of Application	NPDES permit renewal.		

Summary of Review

Entech Engineers, Inc., on behalf of AQUA PA Wastewater, Inc., has applied to the Pennsylvania Department of Environmental Protection (DEP) for issuance of the NPDES permit. The permit was issued on February 26, 2020, became effective on March 1, 2020, and expires on February 28, 2025. The NPDES PA0246484 A-1 minor amendment was issued on 4/8/2022 to correct a typographical error of the annual average design flow from 0.060 MGD to 0.11 MGD as per planning approval.

This facility receives 100% of its flow from Links at Gettysburg Golf Course Community. There are no industrial contributors. The average annual design flow and hydraulic design capacity is 0.11 MGD, and the organic loading capacity is 250 lbs BOD₅/day.

The original WQM Part II 0102404 was issued on October 31, 2002, #0102404 05-1 was amended on January 28, 2005 to change the ownership from the Links at Gettysburg Utility Company LLC to Little Washington Wastewater Company and to change the disinfection system from chlorine to ultraviolet, and #0102404 T-1 was amended on December 19, 2013 to change from Little Washington Wastewater Company, Inc. to AQUA PA Wastewater, Inc.

The WQM No. 0102404 A-2 amendment was issued on 11/3/2022 to expand existing wastewater treatment plant to increase hydraulic capacity and annual design flow from 0.060 MGD to 0.11 MGD as per planning approval.

Sludge use and disposal description and location(s): N/A because sludge hauling by Smith's Septic Service.

Changes from the previous permit: The E. Coli monitoring and report requirements will add to the proposed permit.

Based on the review outlined in this fact sheet, it is recommended that the permit be drafted. A public notice of the draft permit will be published in the *Pennsylvania Bulletin* for public comments for 30 days.

Approve	Deny	Signatures	Date
X		Hilaryle Hilary H. Le / Environmental Engineering Specialist	February 7, 2025
X		/s/ Daniel W. Martin, P.E. / Environmental Engineer Manager	February 14, 2025

Discharge, Receiving Waters and Water Supply Information

Outfall No.	001	Design Flow (MGD)	0.11
Latitude	39° 43' 24.40"	Longitude	-77° 13' 43.16"
Quad Name	Taneytown	Quad Code	
Wastewater Description:	Sewage Effluent		

Receiving Waters	Rock Creek (WWF)	Stream Code	59041
NHD Com ID	53321770	RMI	0.71 mile
Drainage Area	63.1 mi. ²	Yield (cfs/mi ²)	0.04
Q ₇₋₁₀ Flow (cfs)	2.45	Q ₇₋₁₀ Basis	USGS StreamStats
Elevation (ft)	370.73	Slope (ft/ft)	
Watershed No.	13-D	Chapter 93 Class.	WWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Impaired		
Cause(s) of Impairment	Nutrients		
Source(s) of Impairment	Agriculture, Municipal Point Source Discharges		
TMDL Status	Name		

Nearest Downstream Public Water Supply Intake	PA-MA State Border		
PWS Waters	Monocacy River	Flow at Intake (cfs)	
PWS RMI		Distance from Outfall (mi)	Approximate 0.72 mile

Changes Since Last Permit Issuance:

Drainage Area

The discharge is to Rock Creek at RMI 0.71 miles. A drainage area upstream of the discharge is estimated to be 63.1 mi.², according to USGS PA StreamStats available at <https://streamstats.usgs.gov/ss/>.

Streamflow

According to StreamStats, the discharge point on Rock Creek has a Q₇₋₁₀ of 2.45 cfs and a drainage area of 63.1 mi.², which results in a Q₇₋₁₀ low flow yield of 0.04 cfs/mi.². This information is used to obtain a chronic or 30-day (Q₃₀₋₁₀), and an acute or 1-day (Q₁₋₁₀) exposure stream flow for the discharge point as follows (Guidance No. 391-2000-023):

$$\begin{aligned} Q_{7-10} &= 2.45 \text{ cfs} \\ \text{Low Flow Yield} &= 2.45 \text{ cfs} / 63.1 \text{ mi.}^2 \approx 0.04 \text{ cfs/mi.}^2 \\ Q_{30-10} &= 1.36 * 2.45 \text{ cfs} \approx 3.3 \text{ cfs} \\ Q_{1-10} &= 0.64 * 2.45 \text{ cfs} \approx 1.56 \text{ cfs} \end{aligned}$$

Rock Creek

25 Pa Code § 93.9z classifies Rock Creek as warm water fishes and migratory fishes surface water. Based on the 2024 Integrated Water Quality Report, Rock Creek is impaired due to nutrients caused by agriculture and municipal point source (see Table 1). A TMDL does not currently exist for this stream segment.

2024 PA Integrated Water Quality Monitoring and Assessment Report Category 5 – Pollutants Requiring a TMDL			
Rock Creek (02070009)			
Aquatic Life (15114) – 20.94 miles			
Source	Cause	Date Listed	TMDL
Agriculture	Nutrients	2002	Medium
Municipal Point Source	Nutrients	2002	Medium

Table 1 Impaired for one or more designated used by any pollutant and requiring a TMDL

Links At Gettysburg**Public Water Supply**

The nearest downstream public water supply is the PA-MD State Border located on the Rock Creek, approximately 0.72 miles downstream of the discharge point. Based on the nature of discharge, the discharge is not expected to impact the public water supply standards.

Treatment Facility Summary				
Treatment Facility Name: Links At Gettysburg Golf Course				
WQM Permit No.	Issuance Date			
0102404	10/31/2002			
0102404 05-1	1/28/2005			
0102404 A-1	12/19/2013			
0102404 A-2	11/3/2022			
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Extended Aeration	Ultraviolet	0.11
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.11	250	Not Overloaded	Anaerobic Digestion	Other WWTP

Changes Since Last Permit Issuance:

Other Comments:

The facility process consist of:

Auger Monster Influent Screen / Aluminum Bar Screen (1) ⇒ EQ Tank (1) ⇒ Aeration Tanks (2) ⇒ Clarifiers (2) ⇒ Sludge Holding Tank (1) ⇒ new UV disinfection (1) ⇒ Discharge to Rock Creek

Chemical used:

The system incorporates chemical addition in the form of poly aluminum chloride (DEL PAC 2020) (for coagulation), and soda ash (for pH control).

Biosolids:

The total sewage sludge/biosolids production within the facility for the previous year was 8.632 dry tons.

Industrial/Commercial Users:

The permit application indicated there is no industrial/commercial contributor to the treatment plant.

Compliance History	
Summary of DMRs:	DMRs reported last 12 months are summarized in the next page.
Summary of Inspections:	1/4/2024: Mr. Hoy, DEP WQS, conducted a compliance evaluation inspection. The discharge was clear. The field test results indicated in permit limits. There were no violations indicate during inspection. DEP's recommendations: 1. Keeping physical copies of discharge monitoring reports, sample results, and supplemental reports on-site. 2. Clearing the leaves so the outfall is easily identified.
Other Comments:	There are currently no open violations associated with the permittee or the facility.

Other Comments: 

Compliance History

DMR Data for Outfall 001 (from January 1, 2024 to December 31, 2024)

Parameter	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24	APR-24	MAR-24	FEB-24	JAN-24
Flow (MGD) Average Monthly	0.0352	0.0232	0.0330	0.0390	0.0486	0.0411	0.0332	0.0491	0.0461	0.0491	0.0392	0.0531
Flow (MGD) Daily Maximum	0.1022	0.0402	0.1159	0.0891	0.1686	0.0926	0.0611	0.1324	0.1834	0.1324	0.0991	0.1420
pH (S.U.) Daily Minimum	7.96	7.96	7.92	7.89	8.07	8.0	8.13	7.77	7.97	7.77	7.35	7.93
pH (S.U.) Instantaneous Maximum	8.27	8.35	8.39	8.48	8.54	8.51	8.48	8.32	8.36	8.32	8.48	8.41
DO (mg/L) Daily Minimum	6.48	5.79	5.4	5.29	5.15	5.37	5.03	6.57	6.03	6.57	6.12	5.64
CBOD5 (mg/L) Average Monthly	9.86	< 2	< 2.97	< 2.5	8.91	8.85	5.58	4.2	3.09	4.2	3.74	6.88
CBOD5 (mg/L) Instantaneous Maximum	12.8	< 2	3.93	< 3	10.10	13.7	8.52	4.36	3.9	4.36	4.79	10.6
TSS (mg/L) Average Monthly	14.5	8.3	3	5	2.8	7.5	6	10.5	2.8	10.5	4.8	11.3
TSS (mg/L) Instantaneous Maximum	18	10.5	4.5	6	3	11	8.5	14	3	14	5	13.5
Fecal Coliform (No./100 ml) Geometric Mean	26.8	< 3.2	10.5	< 2.8	< 7.2	< 1	30.7	< 5.5	< 1	< 5.5	7	23.5
Fecal Coliform (No./100 ml) Instantaneous Maximum	45	10	22	8	52	< 1	111	30	< 1	30	9	24
UV Transmittance (%) Daily Minimum	79.7	72	71.3	72.5	70.4	73.1	75	74.8	73.5	74.8	69.6	72.1
Total Phosphorus (mg/L) Average Monthly	1.062	0.340	0.585	0.429	0.661	0.648	0.802	< 0.181	0.313	< 0.181	0.441	0.410
Total Phosphorus (mg/L) Instantaneous Maximum	1.45	0.0588	0.736	0.541	0.691	0.712	0.889	0.311	0.343	0.311	0.566	0.454

Existing Effluent Limitations and Monitoring Requirements

Outfall 001,

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Daily Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
D.O.	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
UV Transmittance (%)	XXX	XXX	Report	XXX	XXX	XXX	1/week	Measured
CBOD ₅	XXX	XXX	XXX	25	XXX	50	2/month	Grab
TSS	XXX	XXX	XXX	30	XXX	60	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Total Nitrogen	Report Annl Avg	Report Total Annual	XXX	Report Annl Avg	XXX	XXX	1/year	Calculation
Total Phosphorus	XXX	XXX	XXX	2.0	XXX	4.0	2/month	8-Hr Composite

Development of Effluent Limitations

Outfall No. 001
Latitude 39° 43' 24.40"
Wastewater Description: Sewage Effluent

Design Flow (MGD) .11
Longitude -77° 13' 43.16"

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: The Total Residual Chlorine is not applied to this facility. Because the facility utilizes UV for disinfection.

Water Quality-Based Limitations

Ammonia (NH₃-N):

NH₃-N calculations are based on the Department's Implementation Guidance of Section 93.7 Ammonia Criteria, dated 11/4/97 (ID No. 391-2000-013). The following data is necessary to determine the in-stream NH₃-N criteria used in the attached WQM 7.0 computer model of the stream:

- Discharge pH = 7.0 (Default)
- Discharge Temperature = 25°C (Default)
- Stream pH = 7.0 (Default)
- Stream Temperature = 20°C (Default)
- Background NH₃-N = 0 mg/L (Default)

Analysis Results WQM 7.0

Hydrodynamics		NH ₃ -N Allocations		D.O. Allocations		D.O. Simulation		Effluent Limitations			
RMI	Discharge Name	Permit Number Disc Flow (mgd)									
0.71	Links at Gettys	PA0246484 0.1100									
		Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)						
		CBOD ₅	25	50	5						
		NH ₃ -N	25	50	5						
		Dissolved Oxygen									
Record: 1 of 1 < Back Next > No Filter Search											
Print		< Back		Next >		Archive		Cancel			

The printout of the WQM 7.0 (ver. 1.1) output indicates that at a discharge of 0.11 MGD, limits (rounded according to the NPDES Technical Guidance 362-0400-001) of 25.0 mg/L NH₃-N as a monthly average and 50.0 mg/L NH₃-N instantaneous maximum are necessary to protect the aquatic life from toxicity effects.

Carbonaceous Biochemical Oxygen Demand (CBOD₅):

The attached computer printout of the WQM 7.0 stream model (ver. 1.1) indicates that a monthly average limit of 25.0 mg/L, or secondary treatment, is adequate to protect the water quality of the stream. This limit is consistent with the before upgrade permit. Therefore, the limits of 25.0 mg/L monthly average (AML), and 50.0 mg/L instantaneous maximum will remain in the amendment permit.

Total Suspended Solids (TSS):

The existing technology-based limits of 30.0 mg/L average monthly, and 60.0 mg/L instantaneous maximum will remain in the amendment permit based on the minimum level of effluent quality attainable by secondary treatment based on 25 Pa. Code § 92a.47.

Dissolved Oxygen (D.O.):

A minimum D.O. of 5.0 mg/L is required per 25 Pa. Code § 93.7. This is consistent with the previous permit and current Department criteria.

pH:

The effluent discharge pH should remain above 6.0 and below 9.0 standard units according to 25 Pa Code § 95.2(1).

Fecal Coliform:

The recent coliform guidance in 25 Pa. Code § 92a.47.(a)(4) requires a summer technology limit of 200/100 ml as a geometric mean and an instantaneous maximum not greater than 1,000/100 ml and 25 Pa Code § 92a.47.(a)(5) requires a winter limit of 2,000/100 ml as a geometric mean and an instantaneous maximum not greater than 10,000/100 ml.

E. Coli:

As recommended by DEP's SOP No. BCW-PMT-033, version 2.0 revised February 5, 2024, a routine monitoring for E. Coli will be included in the proposed permit under 25 Pa. Code § 92a.61. This requirement applies to all sewage dischargers greater than 0.002 MGD in their new and reissued permits. A monitoring frequency of 1/quarter will be included in the permit to be consistent with the recommendation from this SOP.

UV:

The UV system daily monitor and report the UV light transmittance (%) after update to replace chlorine disinfection to UV disinfection system will be in the amendment permit.

Toxic:

DEP's current permit renewal application for minor sewage facilities greater than 0.1 MGD requires sampling of Total Copper, Total Lead, and Total Zinc. The application reported non-detect sample results for Total Lead. Total Copper and Total Zinc were detected in effluent, but the reported levels are below the current water quality criteria. No reasonable potential analysis is needed for this permit term based on the review of these sample results.

Chesapeake Bay Strategy

The Department formulated a strategy to comply with the EPA and Chesapeake Bay Foundation requirements by reducing point source loadings of Total Nitrogen (TN) and Total Phosphorus (TP). Sewage discharges have been prioritized by Central Office based on their delivered TN loadings to the Bay. The highest priority (Phases 1, 2, and 3) dischargers will receive annual loading caps based on their design flow on August 29, 2005 and concentrations of 6 mg/L TN and 0.8 mg/L TP. These limits may be achieved through a combination of treatment technology, credits, or offsets. Phase 4 (0.2 -0.4 MGD) will be required to monitor and report TN and TP during permit renewal monthly and Phase 5 (below 0.2 MGD) will monitor during current permit renewal once a year. However, any facility in Phases 4 and 5 that undergoes expansion is subjected to cap load right away. This plant is classified as a phase 5, will be required to monitor and report TN once a year, and the 2.0 mg/L TP average monthly and 4.0 mg/L IMAX limits will remain in the proposed permit.

Additional Consideration

Flow Monitoring

The requirement to monitor the volume of effluent will remain in the draft permit per 40 CFR § 122.44(i)(1)(ii).

Links At Gettysburg**Monitoring Frequency and Sample Type**

The facility currently is required to collect daily effluent grab samples for DO, and pH; bi-monthly effluent grab samples of CBOD₅, and TSS; bi-monthly effluent grab samples of fecal coliform; weekly record UV light transmittance (%); bi-monthly effluent 8-hour composite samples of TP; and annual effluent calculate samples of TN. Based on the best professional judgement of the author, the existing monitoring frequencies are sufficient and necessary. Therefore, the renewal permit monitoring frequencies will remain the same as those specified in the existing permit.

Antidegradation (93.4)

The effluent limits for this discharge have been developed to ensure that existing in-stream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High-Quality Waters are impacted by this discharge. No Exceptional Value Waters are impacted by this discharge.

303d Listed Streams

This discharge is not located on a 303d listed stream segment.

Class A Wild Trout Fisheries

No Class A Wild Trout Fisheries are impacted by this discharge.

Anti-Backsliding

Unless stated otherwise in this fact sheet, all permit requirements proposed in this fact sheet are at least as stringent as existing permit requirements in accordance with 40 CFR §122.44(l)(1).

WQM 7.0



• Discharge pH	=	7.0	(Default)
• Discharge Temperature	=	25°C	(Default)
• Stream pH	=	7.0	(Default)
• Stream Temperature	=	20°C	(Default)
• Background NH ₃ -N	=	0 mg/L	(Default)

1. Outfall 001 on Rock Creek (59041)
 - a. Elevation: 370.73 ft
 - b. RMI: 0.71 miles to PA & MD boundaries
 - c. Drainage Area: 63.1 mi.²
 - d. Low Flow Yield: 0.04 cfs/mi.²
 - e. Discharge Flow: 0.11 MGD
2. Just before Rock Creek to PA-MD border
 - a. Elevation: 363.74 ft
 - b. RMI: 0.001 miles to PA & MD boundaries
 - c. Drainage Area: 63.5 mi.²
 - d. Low Flow Yield: 0.04 cfs/mi.²
 - e. Discharge Flow: 0.000 MGD

NPDES Permit Fact Sheet

Links At Gettysburg

NPDES Permit No. PA0246484



NPDES Permit Fact Sheet Links At Gettysburg

NPDES Permit No. PA0246484

USGS StreamStats

SELECT A STATE / REGION Pennsylvania

IDENTIFY A STUDY AREA Basin Delineated

SELECT SCENARIOS

BUILD A REPORT Report Built

Step 1: You can modify computed basin characteristics here, then select the types of reports you wish to generate. Then click the "Build Report" button

Show Basin Characteristics

Select available reports to display:

- ✓ Basin Characteristics Report
- ✓ Scenario Flow Reports

Open Report

POWERED BY WIM

USGS Home Contact USGS Search USGS Accessibility FOIA Privacy Policy & Notices

Zoom Level: 12 Map Scale: 1:144,000 Lat: 39.7679, Long: -77.0452

Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
CARBON	Percentage of area of carbonate rock	0	percent
DRNAREA	Area that drains to a point on a stream	63.5	square miles
PRECIP	Mean Annual Precipitation	41	inches
ROCKDEP	Depth to rock	4.4	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	2.44	miles per square mile

Low-Flow Statistics


Low-Flow Statistics Parameters [Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	63.5	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	41	inches	35	50.4
STRDEN	Stream Density	2.44	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	4.4	feet	3.32	5.65
CARBON	Percent Carbonate	0	percent	0	99

Low-Flow Statistics Flow Report [Low Flow Region 2]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	5.62	ft³/s	38	38
30 Day 2 Year Low Flow	7.65	ft³/s	33	33
7 Day 10 Year Low Flow	2.71	ft³/s	51	51
30 Day 10 Year Low Flow	3.67	ft³/s	46	46
90 Day 10 Year Low Flow	5.67	ft³/s	36	36



Analysis Results WQM 7.0

Hydrodynamics NH3-N Allocations D.O. Allocations D.O. Simulation Effluent Limitations

RMI Discharge Name Permit Number Disc Flow (mgd)

0.71	Links at Gettys	PA0246484	0.1100
Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)
CBOD5	25		
NH3-N	25	50	
Dissolved Oxygen			5

Record: < Back 1 of 1 Next > No Filter Search

Print < Back Next > Archive Cancel

NPDES Permit Fact Sheet
Links At Gettysburg

NPDES Permit No. PA0246484

rptEffLimits

WQM 7.0 Effluent Limits

SWP Basin	Stream Code	Stream Name					
13D	59641	ROCK CREEK					
RML	Name	Permit Number	Disc. Flow (mg/s)	Parameter	Eff. Limit 30-day Ave. (mg/L)	Eff. Limit Maximum (mg/L)	Eff. Limit Minimum (mg/L)
0.710	Links at Gettys	PA0246484	0.010	CBOD5	25	25	50
				NH3-N	25	50	
				Dissolved Oxygen	5		

Wednesday, February 5, 2025 Version 1.1 Page 1 of 1

rpt_WLA

WQM 7.0 Wasteload Allocations

SWP Basin	Stream Code	Stream Name					
13D	59641	ROCK CREEK					
NH3-N Acute Allocations							
RML	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.710 Links at Gettys	16.11	30	16.11	50	0	0	0
NH3-N Chronic Allocations							
RML	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.710 Links at Gettys	1.86	25	1.86	25	0	0	0
Dissolved Oxygen Allocations							
RML	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Baseline Multiple (mg/L)	Baseline WLA (mg/L)	Critical Reach	Percent Reduction
0.710 Links at Gettys	25	25	25	25	5	0	0

Wednesday, February 5, 2025 Version 1.1 Page 1 of 1

Page: 1 No Filter

rptDOSim

WQM 7.0 D.O. Simulation

SWP Basin	Stream Code	Stream Name		
13D	59641	ROCK CREEK		
RML	Time	Discharge Flow (mg/s)	Analyst Temperature (°C)	Analyst pH
0.710	Reach Width (ft)	Reach Depth (ft)	Reach W:DRatio	Reach Velocity (fps)
30.343	Reach CDO (mg/L)	Reach Kc (1/day)	Reach NH3-N (mg/L)	Reach Kn (1/day)
3.45	Reach DO (mg/L)	Reach Kd (1/day)	W Equation	Reach DO Goal (mg/L)
6.00	Reach T (°C)			
Reach Time (Time/ft)				
0.200				
Sub Reach Results				
Time	Reach DO (mg/L)	NH3-N (mg/L)	D.O. (mg/L)	
0.000	3.39	1.54	7.66	
0.060	3.32	1.51	7.71	
0.120	3.26	1.47	7.37	
0.180	3.20	1.44	7.45	
0.240	3.13	1.41	7.34	
0.290	3.07	1.38	7.24	
0.320	3.01	1.36	7.16	
0.350	2.96	1.31	7.09	
0.380	2.90	1.28	7.03	
0.420	2.84	1.26	6.97	

Wednesday, February 5, 2025 Version 1.1 Page 1 of 1

rptModelSpecs

WQM 7.0 Modeling Specifications

Parameter	Value	Description
WLA Method	BMRR	Use Inputted Q1-10 and Q50-10 Flows
Q1-10/QT40 Ratio	0.64	Use Inputted W/L Ratio
Q50-10/QT40 Ratio	1.36	Use Inputted Reach Travel Times
D.O. Saturation	90.0%	Temperature Adjust %
D.O. Goal	5	Use Balanced Technology

Wednesday, February 5, 2025 Version 1.1 Page 1 of 1

Page: 1 No Filter

NPDES Permit Fact Sheet
Links At Gettysburg

NPDES Permit No. PA0246484

rptHydro

WQM 7.0 Hydrodynamic Outputs

SWP Basin		Stream Code		Stream Name									
13D	590H1	ROCK CREEK											
RML	Streams	Flow	Width	Net	Disch	Reach	Depth	Width	WD	Velocity	Reach	Analysic	Analysic
(cfs)	(cfs)	(cfs)	(ft)	(cfs)	(ft)	(ft)	(ft)	(ft)	Ratio	(fps)	(days)	Temp	pH
Q7-10 Flow	0.710	2.52	0.00	2.52	-1702	0.00167	.655	30.34	46.31	0.14	0.30	20.32	7.00
Q1-10 Flow	0.710	1.62	0.00	1.62	-1702	0.00167	NA	NA	NA	0.11	0.43	20.48	7.00
Q30-10 Flow	0.710	3.43	0.00	3.43	-1702	0.00167	NA	NA	NA	0.16	0.22	20.24	7.00

rptGeneral

Input Data WQM 7.0

SWP Basin		Stream Code		Stream Name					
13D	590H1	ROCK CREEK							
RML	Streams	Flow	Width	Elavation	Damage	Slope	PWS	Widnowsel	Apply
(cfs)	(cfs)	(cfs)	(ft)	(ft)	(sq mi)	(ft/ft)	(mpg)	(mpg)	FC
0.710	370.73	63.10	0.00000	0.00	<input checked="" type="checkbox"/>				

Stream Data

Design Cond.		Design	Permit	Design	Design	Design	Design	Design
Design	Cond.	LFY	Disc. Flow	Disc. Flow	Disc. Flow	Disc. Flow	Disc. Temp	Disc. pH
Q7-10	0.040	0.00	0.00	0.0000	0.00	0.00	20.00	7.00
Q1-10	0.00	0.00	0.00	0.0000	0.00	0.00	20.00	7.00
Q30-10	0.00	0.00	0.00	0.0000	0.00	0.00	20.00	7.00

Discharge Data

Name		Permit Number	Design	Design	Design	Design	Design	Design
Design	Cond.	Disc. Flow	Disc. Flow	Disc. Flow	Disc. Temp	Disc. pH	Disc. Temp	Disc. pH
Links at Gettysb.		PA0246484	0.1100	0.1100	0.1100	0.0000	25.00	7.00

Parameter Data

Parameter Name		Disc. Conc.	Trib. Conc.	Streams Conc.	Date Coef.
Parameter Name		(mpg/L)	(mpg/L)	(mpg/L)	(1/day)
CBO-05		25.00	2.00	0.00	1.50
Dissolved Oxygen		5.00	8.24	0.00	0.00
NH3-N		25.00	0.00	0.00	0.70

Wednesday, February 5, 2020

Version 1.1

Page: 1 of 1

Wednesday, February 5, 2020

Version 1.1

Page: 1 of 2

rptGeneral

Input Data WQM 7.0

SWP Basin		Stream Code		Stream Name					
13D	590H1	ROCK CREEK							
RML	Streams	Flow	Width	Elavation	Damage	Slope	PWS	Widnowsel	Apply
(cfs)	(cfs)	(cfs)	(ft)	(ft)	(sq mi)	(ft/ft)	(mpg)	(mpg)	FC
0.000	370.74	63.50	0.00000	0.00	<input checked="" type="checkbox"/>				

Stream Data

Design Cond.		Design	Permit	Design	Design	Design	Design	Design
Design	Cond.	LFY	Disc. Flow	Disc. Flow	Disc. Flow	Disc. Flow	Disc. Temp	Disc. pH
Q7-10	0.040	0.00	0.00	0.0000	0.0	0.00	20.00	7.00
Q1-10	0.00	0.00	0.00	0.0000	0.00	0.00	20.00	7.00
Q30-10	0.00	0.00	0.00	0.0000	0.00	0.00	20.00	7.00

Discharge Data

Name		Permit Number	Design	Design	Design	Design	Design	Design
Design	Cond.	Disc. Flow	Disc. Flow	Disc. Flow	Disc. Temp	Disc. pH	Disc. Temp	Disc. pH
Links at Gettysb.		PA0246484	0.0000	0.0000	0.0000	25.00	7.00	

Parameter Data

Parameter Name		Disc. Conc.	Trib. Conc.	Streams Conc.	Date Coef.
Parameter Name		(mpg/L)	(mpg/L)	(mpg/L)	(1/day)
CBO-05		25.00	2.00	0.00	1.50
Dissolved Oxygen		5.00	8.24	0.00	0.00
NH3-N		25.00	0.00	0.00	0.70

Wednesday, February 5, 2020

Version 1.1

Page: 2 of 2

Page: 14 **2** 1 | > | > | > | > | > | No Filter |

12

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Daily Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50.0	2/month	Grab
TSS	XXX	XXX	XXX	30.0	XXX	60.0	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
UV Transmittance (%)	XXX	XXX	Report	XXX	XXX	XXX	1/week	Measured
Total Nitrogen	Report Annl Avg	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	Calculation
Total Nitrogen (lbs)	XXX	Report Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation
Total Phosphorus	XXX	XXX	XXX	2.0	XXX	4.0	2/month	8-Hr Composite

Compliance Sampling Location:

Other Comments:

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [REDACTED])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input checked="" type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: BCW-PMT-033
<input type="checkbox"/>	Other: [REDACTED]