

Application Type Renewal
Facility Type Industrial
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL INDUSTRIAL WASTE (IW)
AND IW STORMWATER**

Application No. PA0246760
APS ID 370112
Authorization ID 1373944

Applicant and Facility Information

| | | | |
|---------------------------|--|------------------|---|
| Applicant Name | <u>Franklin County General Authority</u> | Facility Name | <u>FCGA – Filter Backwash WTP</u> |
| Applicant Address | <u>5000 Letterkenny Road Suite 230</u> <u>Chambersburg, PA 17201-8384</u> | Facility Address | <u>554 Coffey Avenue</u> <u>Chambersburg, PA 17201</u> |
| Applicant Contact | <u>Ron Artley</u> | Facility Contact | <u>Ron Artley</u> |
| Applicant Phone | <u>(717) 267-9602</u> | Facility Phone | <u>(717) 267-6025</u> |
| Client ID | <u>119241</u> | Site ID | <u>532837</u> |
| SIC Code | <u>4941</u> | Municipality | <u>Greene Township</u> |
| SIC Description | <u>Trans. & Utilities - Water Supply</u> | County | <u>Franklin</u> |
| Date Application Received | <u>October 22, 2021</u> | EPA Waived? | <u>Yes</u> |
| Date Application Accepted | <u></u> | If No, Reason | <u></u> |
| Purpose of Application | <u>NPDES Renewal.</u> | | |

Summary of Review

Franklin County General Authority (FCGA) has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of its NPDES permit. The permit was last reissued on November 21, 2016 and became effective on December 1, 2016. The permit expired on November 30, 2021.

Based on the review, it is recommended that the permit be drafted.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

| Approve | Deny | Signatures | Date |
|---------|------|--|-------------------|
| X | | <i>Jinsu Kim</i> Jinsu Kim / Environmental Engineering Specialist | February 11, 2022 |
| x | | <i>Maria D. Bebenek for</i> Daniel W. Martin, P.E. / Environmental Engineer Manager | March 1, 2022 |
| x | | <i>Maria D. Bebenek</i> Maria D. Bebenek, P.E. / Program Manager | March 1, 2022 |

Discharge, Receiving Waters and Water Supply Information

| | | | |
|--|---|------------------------------|--------------------|
| Outfall No. | 001 | Design Flow (MGD) | .14 |
| Latitude | 39° 59' 43" | Longitude | -77° 38' 40" |
| Quad Name | Chambersburg | Quad Code | 1924 |
| Wastewater Description: Water Treatment Effluent | | | |
| Receiving Waters | Dry Swale to Unnamed Tributary of Conococheague Creek (CWF, MF) | Stream Code | |
| NHD Com ID | 49484520 | RMI | See comments below |
| Drainage Area | See comments below | Yield (cfs/mi ²) | See comments below |
| Q7-10 Flow (cfs) | See comments below | Q7-10 Basis | See comments below |
| Elevation (ft) | | Slope (ft/ft) | |
| Watershed No. | 13-C | Chapter 93 Class. | CWF, MF |
| Existing Use | | Existing Use Qualifier | |
| Exceptions to Use | | Exceptions to Criteria | |
| Assessment Status | Impaired | | |
| Cause(s) of Impairment | SILTATION, | | |
| Source(s) of Impairment | AGRICULTURE, RURAL (RESIDENTIAL AREAS) | | |
| TMDL Status | | Name | |
| Nearest Downstream Public Water Supply Intake | Hagerstown MD | | |
| PWS Waters | Potomac River | Flow at Intake (cfs) | |
| PWS RMI | | Distance from Outfall (mi) | 59.44 |

Drainage Area

The discharge is to a dry swale and then to Unnamed Tributary of Conococheague Creek. Based on the site condition, a drainage area at the point of discharge is not available.

StreamStats

Low-flow statistics are not available at the point of discharge given that the discharge is to a dry swale and the nearest tributary is about 0.2 miles from the site.

Public Water Supply Intake

The fact sheet developed for the last permit renewal indicates that the nearest downstream water supply intake is located at Hagerstown MD on Potomac River, approximately 60 miles from the site. Given the distance, the discharge is not expected to impact the water supply.

Treatment Facility Summary

The Franklin County General Authority (FCGA) Water Treatment Plant is located in Franklin County. Influent waste is supplied by filter back wash water coming from the FCGA Drinking Water Filtration plant about 4 times per week. Backwashes are generally held in the clarifier 1 or 2 days before manually discharging into a dry swale. Prior to discharge, effluent is dechlorinated. The sludge solids are discharged into the collection system of the FCGA WWTP at South Patrol Road (PA0030597) for treatment and disposal.

The application reported the design flow rate of 0.14 MGD with maximum flow of 0.180 MGD. The average is about 0.0163 MGD.

Compliance History

| | |
|--------------------------------|--|
| Summary of DMRs: | A summary of 12-month DMR data is presented on the next page. |
| Summary of Inspections: | <p>07/22/20: Brandon Bettinger, DEP Water Quality Specialist, conducted a routine inspection via phone call and noted that all treatment units are operable. No violation was noted at the time of inspection.</p> <p>10/24/17: Patrick Bowen, former DEP Water Quality Specialist, conducted a routine inspection and noted that no abnormal conditions noted at the outfall. No violation was noted at the time of inspection.</p> |
| Other Comments: | Since the last permit reissuance, there were no permit violations. There is no open violation associated with this permittee or facility. |

Effluent Data

DMR Data for Outfall 001 (from January 1, 2021 to December 31, 2021)

| Parameter | DEC-21 | NOV-21 | OCT-21 | SEP-21 | AUG-21 | JUL-21 | JUN-21 | MAY-21 | APR-21 | MAR-21 | FEB-21 | JAN-21 |
|--|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|
| Flow (MGD) Average Monthly | 0.01980 5 | 0.01422 7 | 0.00745 5 | 0.01783 6 | 0.01102 0 | 0.02621 4 | 0.01141 2 | 0.00971 1 | 0.01345 7 | 0.02333 2 | 0.02834 4 | 0.02460 5 |
| Flow (MGD) Daily Maximum | 0.08067 3 | 0.07523 8 | 0.04954 6 | 0.12557 6 | 0.05111 9 | 0.18080 7 | 0.03594 0 | 0.04502 4 | 0.04058 0 | 0.09146 9 | 0.09000 6 | 0.11695 2 |
| pH (S.U.) Minimum | 6.7 | 6.8 | 6.3 | 6.2 | 6.7 | 6.5 | 6.6 | 6.4 | 6.5 | 6.3 | 6.4 | 6.3 |
| pH (S.U.) Maximum | 7.3 | 7.4 | 6.5 | 6.6 | 7.1 | 7.0 | 7.1 | 6.6 | 6.9 | 7.0 | 6.8 | 6.5 |
| TRC (mg/L) Average Monthly | 0.01 | 0.0087 | 0.0067 | 0.0072 | 0.01 | 0.01 | 0.0065 | 0.01 | 0.0075 | 0.01 | 0.0117 | 0.0086 |
| TRC (mg/L) Instantaneous Maximum | 0.01 | 0.03 | 0.02 | 0.02 | 0.02 | 0.02 | 0.02 | 0.01 | 0.02 | 0.03 | 0.02 | 0.02 |
| TSS (lbs/day) Average Monthly | 0.792 | 0.402 | 0.788 | 0.923 | 0.827 | 0.297 | 0.255 | 0.434 | 0.785 | 0.338 | 2.795 | 1.349 |
| TSS (lbs/day) Daily Maximum | 0.941 | 0.571 | 1.020 | 1.532 | 1.066 | 0.407 | 0.365 | 0.751 | 1.221 | 0.407 | 5.258 | 2.371 |
| TSS (mg/L) Average Monthly | 2.50 | 2.5 | 4.225 | 2.9 | 2.50 | 2.00 | 2 | 2.00 | 8.5 | 2.20 | 4.5 | 5 |
| TSS (mg/L) Daily Maximum | 2.50 | 2.5 | 4.6 | 3.3 | 2.50 | 2.00 | 2 | 2.00 | 12.6 | 2.4 | 7 | 5 |
| Total Aluminum (lbs/day) Average Monthly | 0.086 | 0.033 | 0.102 | 0.060 | 0.154 | 0.03 | 0.026 | 0.061 | 0.117 | 0.078 | 0.745 | 0.16 |
| Total Aluminum (lbs/day) Daily Maximum | 0.120 | 0.046 | 0.129 | 0.093 | 0.085 | 0.041 | 0.037 | 0.110 | 0.156 | 0.092 | 1.457 | 0.147 |
| Total Aluminum (mg/L) Average Monthly | 0.26 | 0.2 | 0.5485 | 0.205 | 0.25 | 0.20 | 0.2 | 0.25 | 1.2905 | 0.51 | 1.07 | 0.255 |
| Total Aluminum (mg/L) Daily Maximum | 0.32 | 0.20 | 0.58 | 0.21 | 0.30 | 0.20 | 0.20 | 0.29 | 1.61 | 0.54 | 1.94 | 0.31 |
| Total Iron (lbs/day) Average Monthly | 0.049 | 0.033 | 0.037 | 0.059 | 0.066 | 0.03 | 0.026 | 0.044 | 0.018 | 0.031 | 0.111 | 0.054 |
| Total Iron (lbs/day) Daily Maximum | 0.051 | 0.046 | 0.044 | 0.093 | 0.085 | 0.041 | 0.037 | 0.075 | 0.019 | 0.034 | 0.188 | 0.095 |
| Total Iron (mg/L) Average Monthly | 0.16 | 0.2 | 0.2 | 0.2 | 0.20 | 0.20 | 0.2 | 0.20 | 0.2 | 0.20 | 0.225 | 0.2 |

**NPDES Permit Fact Sheet
FCGA – Filter Backwash WTP**

NPDES Permit No. PA0246760

| Parameter | DEC-21 | NOV-21 | OCT-21 | SEP-21 | AUG-21 | JUL-21 | JUN-21 | MAY-21 | APR-21 | MAR-21 | FEB-21 | JAN-21 |
|---|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|
| Total Iron (mg/L) Daily Maximum | 0.20 | 0.2 | 0.2 | 0.2 | 0.20 | 0.20 | 0.2 | 0.20 | 0.2 | 0.20 | 0.25 | 0.2 |
| Total Manganese (lbs/day) Average Monthly | 0.005 | 0.005 | 0.018 | 0.015 | 0.039 | 0.023 | 0.004 | 0.004 | 0.003 | 0.006 | 0.03 | 0.005 |
| Total Manganese (lbs/day) Daily Maximum | 0.008 | 0.006 | 0.024 | 0.018 | 0.052 | 0.029 | 0.005 | 0.006 | 0.004 | 0.009 | 0.059 | 0.009 |
| Total Manganese (mg/L) Average Monthly | 0.014 | 0.031 | 0.094 | 0.063 | 0.114 | 0.158 | 0.035 | 0.014 | 0.036 | 0.034 | 0.043 | 0.016 |
| Total Manganese (mg/L) Daily Maximum | 0.0213 | 0.036 | 0.107 | 0.086 | 0.121 | 0.172 | 0.044 | 0.016 | 0.046 | 0.052 | 0.078 | 0.018 |

Existing Effluent Limits and Monitoring Requirements

A table below summarizes effluent limits and monitoring requirements specified in the existing permit.

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|-------------------------------|-------------------------------------|------------------|-----------------------|--------------------|------------------|---------------------|--|----------------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Daily Maximum | Minimum | Average Monthly | Daily Maximum | Instant. Maximum | | |
| Flow (MGD) | Report | Report | XXX | XXX | XXX | XXX | 1/discharge | Measured |
| pH (S.U.) | XXX | XXX | 6.0 | XXX | 9.0 | XXX | 1/discharge | Grab |
| Total Residual Chlorine (TRC) | XXX | XXX | XXX | 0.5 | XXX | 1.0 | 1/discharge | Grab |
| Total Suspended Solids | 35 | 70 | XXX | 30 | 60 | 75 | 2/month | Grab |
| Aluminum, Total | 4.8 | 9.6 | XXX | 4 | 8 | 10 | 2/month | Grab |
| Iron, Total | 2.4 | 4.8 | XXX | 2 | 4 | 5 | 2/month | Grab |
| Manganese, Total | 1.2 | 2.4 | XXX | 1 | 2 | 2.5 | 2/month | Grab |

Development of Effluent Limitations and Monitoring Requirements

| | | | |
|---|----------------|--------------------------|-----------------|
| Outfall No. | 001 | Design Flow (MGD) | .14 |
| Latitude | 39° 59' 43.00" | Longitude | -77° 38' 40.00" |
| Wastewater Description: Water Treatment Effluent | | | |

The discharge from this facility is to a dry swale. Since this is an existing facility, the *Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers* (DEP Document ID: 391-2000-014, effective April 12, 2008) doesn't apply. However, since the facility was built in around 2004, the August 1997 *Implementation Guidance for Evaluating Wastewater Discharges to Drainage Ditches and Swales* applies to this discharge which stated conditions where the minimum treatment is required for industrial discharges. This minimum treatment requirement is shown below.

| Parameter | Limit (mg/l) | SBC |
|------------------|--------------|-----------------|
| Suspended Solids | 30 | Average Monthly |
| | 60 | Daily Maximum |
| Iron, Total | 2.0 | Average Monthly |
| | 4.0 | Daily Maximum |
| Aluminum, Total | 4.0 | Average Monthly |
| | 8.0 | Daily Maximum |
| Manganese, Total | 1.0 | Average Monthly |
| | 2.0 | Daily Maximum |
| Flow | Monitor | Average Monthly |
| pH | 6.0 | Minimum |
| | 9.0 | Maximum |

The guidance document *Technology Based Control Requirements for Water Treatment Plant Wastes* (DEP Document ID: 362-2183-003) states "Due to the cost of finished water quality concern, BAT options may not be feasible. Therefore, it may not be appropriate to require further effluent reduction to controls beyond the BPT options. Except where the recycle of wastewater is feasible, BAT and BCT should be equivalent to BPT." Recycle of wastewater is not feasible at this plant due to the technology currently employed to treat the raw water. Therefore, BPT requirements will determine the limits. TRC effluent limits of 0.5 mg/L (average monthly) and 1.6 mg/L (instantaneous maximum) will continue to be included in the permit as the finished water is used to backwash the filter.

DMR datasets were reviewed and have been summarized as follows:

| AVG.MON | DMR Data from February 2017 to January 2022 (60 Datasets) | | | | | | |
|-----------|---|--------------|--------------|-----------------|--------------------------------------|-----------------------------------|-------------------------|
| | AVG, mg/L | MAX, mg/L | MIN, mg/L | MEDIAN, mg/L | 90 th PERCENTILE, mg/L | No. Exceedance (Permit Limits) | No. Exceedance (WQC) |
| TSS | 4.29 | 16.5 | 0 | 4.3625 | 9.5 | 0 | N/A |
| Iron | 0.141 | 0.28 | 0 | 0.2 | 0.234 | 0 | 0 |
| Aluminum | 0.69 | 2.8 | 0.092 | 0.3 | 1.945 | 0 | 21 |
| Manganese | 0.087 | 0.485 | 0.007 | 0.0325 | 0.2825 | 0 | 0 |

| Daily MAX | DMR Data from February 2017 to January 2022 (60 Datasets) | | | | | | |
|-----------|---|--------------|--------------|-----------------|--------------------------------------|-----------------------------------|-------------------------|
| | AVG, mg/L | MAX, mg/L | MIN, mg/L | MEDIAN, mg/L | 90 th PERCENTILE, mg/L | No. Exceedance (Permit Limits) | No. Exceedance (WQC) |
| TSS | 5.70 | 20 | 0 | 5 | 14 | 0 | N/A |
| Iron | 0.161 | 0.36 | 0 | 0.2 | 0.298 | 0 | 0 |
| Aluminum | 0.879 | 3.1 | 0.1 | 0.38 | 2.29 | 0 | 23 |
| Manganese | 0.107 | 0.5 | 0.0074 | 0.04 | 0.327 | 0 | 0 |

Data shows none of pollutants, except for Aluminum is discharged at levels of concern. While Aluminum effluent concentrations have exceeded the water quality criteria, given that the discharge is not directly to the stream and such exceedance only occurred less than 50%. Based on the review, existing limits are still appropriate.

The facility is not subject to the requirements of the Chesapeake Bay Tributary Strategy.

Unless stated otherwise in this fact sheet, permit requirements proposed in this fact sheet are at least as stringent as existing permit requirements. A Class A Wild Trout Fishery is not impacted by this discharge.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|-----------------|-------------------------------------|------------------|-----------------------|--------------------|------------------|---------------------|--|----------------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Daily Maximum | Minimum | Average Monthly | Daily Maximum | Instant. Maximum | | |
| Flow (MGD) | Report | Report | XXX | XXX | XXX | XXX | 1/discharge | Measured |
| pH (S.U.) | XXX | XXX | 6.0 Inst Min | XXX | XXX | 9.0 | 1/discharge | Grab |
| TRC | XXX | XXX | XXX | 0.5 | XXX | 1.0 | 1/discharge | Grab |
| TSS | 35 | 70 | XXX | 30 | 60 | 75 | 2/month | Grab |
| Total Aluminum | 4.8 | 9.6 | XXX | 4.0 | 8.0 | 10 | 2/month | Grab |
| Total Iron | 2.4 | 4.8 | XXX | 2 | 4 | 5 | 2/month | Grab |
| Total Manganese | 1.2 | 2.4 | XXX | 1 | 2 | 2.5 | 2/month | Grab |

| Tools and References Used to Develop Permit | |
|---|--|
| <input type="checkbox"/> | WQM for Windows Model (see Attachment [redacted]) |
| <input type="checkbox"/> | Toxics Management Spreadsheet (see Attachment [redacted]) |
| <input type="checkbox"/> | TRC Model Spreadsheet (see Attachment [redacted]) |
| <input type="checkbox"/> | Temperature Model Spreadsheet (see Attachment [redacted]) |
| <input type="checkbox"/> | Water Quality Toxics Management Strategy, 361-0100-003, 4/06. |
| <input type="checkbox"/> | Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97. |
| <input type="checkbox"/> | Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98. |
| <input type="checkbox"/> | Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96. |
| <input type="checkbox"/> | Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97. |
| <input type="checkbox"/> | Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97. |
| <input type="checkbox"/> | Pennsylvania CSO Policy, 385-2000-011, 9/08. |
| <input type="checkbox"/> | Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03. |
| <input type="checkbox"/> | Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97. |
| <input type="checkbox"/> | Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97. |
| <input type="checkbox"/> | Implementation Guidance Design Conditions, 391-2000-006, 9/97. |
| <input type="checkbox"/> | Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004. |
| <input type="checkbox"/> | Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997. |
| <input type="checkbox"/> | Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99. |
| <input type="checkbox"/> | Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004. |
| <input type="checkbox"/> | Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97. |
| <input type="checkbox"/> | Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008. |
| <input type="checkbox"/> | Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994. |
| <input type="checkbox"/> | Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09. |
| <input type="checkbox"/> | Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97. |
| <input type="checkbox"/> | Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97. |
| <input type="checkbox"/> | Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99. |
| <input type="checkbox"/> | Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999. |
| <input type="checkbox"/> | Design Stream Flows, 391-2000-023, 9/98. |
| <input type="checkbox"/> | Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98. |
| <input type="checkbox"/> | Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97. |
| <input type="checkbox"/> | Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07. |
| <input type="checkbox"/> | SOP: [redacted] |
| <input type="checkbox"/> | Other: [redacted] |