

Application Type Renewal  
Facility Type Municipal  
Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0247103  
APS ID 473744  
Authorization ID 1434081

**Applicant and Facility Information**

Applicant Name	<b>Northeastern York County Sewer Authority</b>	Facility Name	<b>Northeastern York County STP Saginaw</b>
Applicant Address	200 N Main Street PO Box 516 Mount Wolf, PA 17347-0516	Facility Address	175 Chestnut Street 175 Chestnut Street Mount Wolf, PA 17347-0516
Applicant Contact	Patrice Poet	Facility Contact	Patrice Poet
Applicant Phone	(717) 266-1493	Facility Phone	(717) 266-1493
Client ID	25250	Site ID	610101
Ch 94 Load Status	Not Overloaded	Municipality	East Manchester Township
Connection Status	No Limitations	County	York
Date Application Received	<u>March 28, 2023</u>	EPA Waived?	Yes
Date Application Accepted	<u>April 19, 2023</u>	If No, Reason	
Purpose of Application	<u>NPDES Permit Renewal</u>		

**Summary of Review**

The Northeastern York County Sewer Authority (NYCSA) has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of a NPDES permit for the Saginaw STP. The permit was last reissued on September 27, 2018. The permit expired on September 30, 2023 but the terms and conditions of the permit have been administratively extended since that time.

Based on the review outlined in this fact sheet, it is recommended that the permit be drafted, and a notice of the draft permit be published in the *Pennsylvania Bulletin* for public comments for 30 days. A file review of documents associated with the discharge or permittee may be available at the PA DEP southcentral regional office (SCRO), 909 Elmerton Avenue, Harrisburg, PA 17110. To make an appointment for file reviews, contact the SCRO file review coordinator at 717.705.4700.

Sludge use and disposal description and location(s): Mt. Wolf STP

**Public Participation**

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
x		Aaron Baar Aaron Baar / Project Manager	May 26, 2024
x		Maria D. Bebeneck for Daniel W. Martin, P.E. / Environmental Engineer Manager	June 11, 2024

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.3
Latitude	40° 4' 14.14"	Longitude	-76° 40' 22.43"
Quad Name	York Haven	Quad Code	1832
Wastewater Description:	Sewage Effluent		
Receiving Waters	Hartman Run/Susquehanna River (WWF)	Stream Code	06685
NHD Com ID	57464701	RMI	37.5
Drainage Area	25600 sq. mi.	Yield (cfs/mi <sup>2</sup> )	0.056
Q <sub>7-10</sub> Flow (cfs)	1440	Q <sub>7-10</sub> Basis	USGS StreamStats
Elevation (ft)	250	Slope (ft/ft)	
Watershed No.	7-H	Chapter 93 Class.	WWF/MF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Impaired (Aquatic Life)		
Cause(s) of Impairment	Agriculture		
Source(s) of Impairment			
TMDL Status	Name		
Nearest Downstream Public Water Supply Intake	Wrightsville Water Supply Company		
PWS Waters	Susquehanna River	Flow at Intake (cfs)	
PWS RMI	28.51	Distance from Outfall (mi)	~9 miles

#### Drainage Area

The discharge is to either Hartman Run or the Susquehanna River depending on the depth of the Susquehanna. Hartman Run joins the Susquehanna under low flow conditions a short distance downstream of Outfall 001, so the receiving water is generally assumed to be the Susquehanna River for the purpose of this review. The discharge of the Saginaw STP is at RMI 37.5 on the Susquehanna. A drainage area upstream of the discharge is determined to be 25,600 sq.mi. according to USGS PA StreamStats available at <https://streamstats.usgs.gov/ss/>.

#### Stream Flow

According to StreamStats, the watershed has a local Q<sub>7-10</sub> of 1440 cfs. This information was used to obtain a LFY, a chronic 30-day (Q<sub>30-10</sub>) and acute (Q<sub>1-10</sub>) exposure stream flows for the discharge point as follows (Guidance No. 391-2000-023).

$$\begin{aligned}
 Q_{7-10} &= 1440 \text{ cfs} \\
 Q_{30-10} &= 1.36 * 1440 \text{ cfs} = 1958 \text{ cfs} \\
 Q_{1-10} &= 0.64 * 1440 \text{ cfs} = 921.6 \text{ cfs} \\
 \text{LFY} &= 1440 \text{ cfs} / 25,600 \text{ mi}^2 = 0.056 \text{ cfs/mi}^2
 \end{aligned}$$

#### Hartman Run/Susquehanna River

25 Pa Code §93.9 classifies the receiving water, Hartman Run/Susquehanna River, with a WWF/MF Existing Use designation. Effluent limits for this discharge have been developed to ensure that existing in-stream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. The discharge is in a stream segment listed as not attaining use; the cause of the impairment has been identified as agriculture (see *Local Watershed TMDL* below).

*Local Watershed Total Maximum Daily Loads (TMDLs)*

According to PA's 2024 integrated water quality monitoring and assessment report, Hartman Run/Susquehanna River in the vicinity of the proposed point of discharge is impaired for aquatic life due agriculture. The aquatic life impairment is listed as Category 5 in the 2024 integrated report, indicating that the waters are impaired for one or more uses by a pollutant that requires the development of a TMDL. No TMDL has been developed to date, so no local watershed TMDL has been taken into consideration during this review.

*Public Water Supply Intake*

The nearest downstream public water supply intake is the Wrightsville Water Supply Co. on the Susquehanna River in York County, approximately 9 miles downstream of this discharge. Considering the distance and nature, the discharge is not expected to significantly affect the water supply.

*Class A Wild Trout Streams*

The receiving stream is not a Class A Wild Trout stream; therefore, no Class A Wild Trout Fishery is impacted by this discharge.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Saginaw WWTP				
<b>WQM Permit No.</b>	<b>Issuance Date</b>			
WQM 6703408	April 6, 2005			
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage	Secondary	Activated Sludge	Hypochlorite	0.3
<hr/>				
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
0.501	500	Not Overloaded	Aerobic Digestion	Other WWTP

The NYCSA owns and operates the sanitary wastewater treatment facility located in East Manchester Township, York County. This NPDES permit covers discharges of sewage treated by the Saginaw STP. The facility only serves portions of East Manchester Township; all sewer systems are 100% separated. With an annual average design flow 0.300 MGD and a hydraulic design capacity of 0.501 MGD, this facility utilizes an extended aeration system consisting of The WWTP train is as follows:

Comminutor (1) ⇒ Bar Screen (2) ⇒ EQ Tank (1) ⇒ Aeration Tank (2) ⇒ SEQUOX Tank (2) ⇒ Clarifier (2) ⇒ Chlorine Contact Tank (1) ⇒ Discharge

Chemical additions to the treatment process include sodium hypochlorite and alum. Two sludge digesters are also on site. Waste sludge from the Saginaw STP is hauled to the Mt. Wolf STP. There is no industrial/commercial user contributing industrial wastewater to the sewer system.

<b>Compliance History</b>	
<b>Summary of Inspections:</b>	<p>Since the last renewal of the facility's NPDES permit, the following inspections have been logged:</p> <p>August 29, 2019: A routine CEI was conducted by Austen Randecker. No violations were noted. Recommendations were made regarding maintaining chlorine standards on-site and updating the Emergency Response plan.</p> <p>May 26, 2020: An administrative inspection was conducted via phone by Austen Randecker. No violations were noted.</p> <p>A Consent Assessment of Civil Penalty was entered into on September 8, 2022 for failing to meet pathogen reduction requirements before land applying biosolids.</p>

Other Comments: As of May 26, 2024, there are no open violations associated with this facility.

Existing Effluent Limitations and Monitoring Requirements

Parameter	Mass Units (lbs/day)		Concentrations (mg/L)			Minimum Measurement Frequency	Required Sample Type	
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0 Daily Max	XXX	1/day	Grab
DO	XXX	XXX	5.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.1	XXX	0.4	1/day	Grab
CBOD5	62.5	100	XXX	25.0	40.0	50	1/week	24-Hr Composite
BOD5 Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
TSS	75	112.5	XXX	30.0	45.0	60	1/week	24-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
Nitrate-Nitrite	XXX	XXX	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Nitrate-Nitrite (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	1/month	Calculation
Total Nitrogen (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
Ammonia Nov 1 - Apr 30	15.0	XXX	XXX	6.0	XXX	12	1/week	24-Hr Composite
Ammonia May 1 - Oct 31	5.0	XXX	XXX	2.0	XXX	4	1/week	24-Hr Composite
Ammonia (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation

Parameter	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)			Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type	
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
TKN	XXX	XXX	XXX	Report	XXX	XXX	1/week	24-Hr Composite
TKN (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
Total Phosphorus	5.0	XXX	XXX	2.0	XXX	4	1/week	24-Hr Composite
Total Phosphorus (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation

Compliance Sampling Location: Outfall 001

**Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date )**

Parameter	Effluent Limitations						Monitoring Requirements			
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)							
	Monthly	Annual	Monthly	Monthly Average	Maximum	Instant. Maximum				
Total Nitrogen (lbs)	XXX	Report Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation		
Ammonia (lbs)	XXX	Report Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation		
Total Phosphorus (lbs)	XXX	Report Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation		

Compliance Sampling Location: Outfall 001

Compliance History

DMR Data for Outfall 001 (from April 1, 2023 to March 31, 2024)

Parameter	MAR-24	FEB-24	JAN-24	DEC-23	NOV-23	OCT-23	SEP-23	AUG-23	JUL-23	JUN-23	MAY-23	APR-23
Flow (MGD) Average Monthly	0.122	0.119	0.19	0.141	0.094	0.097	0.095	0.09	0.097	0.09	0.091	0.098
Flow (MGD) Daily Maximum	0.295	0.177	0.717	0.417	0.168	0.173	0.178	0.117	0.135	0.122	0.131	0.226
pH (S.U.) Instantaneous Minimum	6.22	6.71	6.24	6.44	6.29	6.27	6.34	7.01	7.08	6.48	7.01	7.0
pH (S.U.) Instantaneous Maximum	8.04	7.65	7.55	7.81	7.73	7.86	7.89	8.24	7.98	7.91	7.79	7.75
DO (mg/L) Instantaneous Minimum	6.54	6.11	5.55	6.4	6.57	5.84	5.03	5.09	5.13	5.13	5.1	5.83
TRC (mg/L) Average Monthly	< 0.03	< 0.02	0.05	< 0.04	0.02	0.04	0.04	0.03	< 0.03	< 0.04	< 0.02	0.04
TRC (mg/L) Instantaneous Maximum	0.13	0.08	0.16	0.1	0.1	0.1	0.11	0.1	0.09	0.1	0.07	0.14
CBOD5 (lbs/day) Average Monthly	< 3.1	< 2.5	5.7	< 9.6	< 2.1	< 1.7	< 2.2	< 2.2	3.2	< 2.1	< 1.9	< 1.7
CBOD5 (lbs/day) Weekly Average	6.0	3.0	12.0	< 20.0	< 3.0	2.0	3.0	3.0	4.0	3.0	3.0	< 2.0
CBOD5 (mg/L) Average Monthly	< 3.0	< 3.0	4.0	< 6.0	< 2.0	< 2.0	< 3.0	< 3.1	4.0	< 3.0	< 3.0	< 2.4
CBOD5 (mg/L) Weekly Average	5.0	3.0	6.0	< 12.0	3.0	3.0	4.0	4.5	7.0	3.0	3.0	< 2.4
BOD5 (lbs/day) Raw Sewage Influent   Average Monthly	170	211	271	205	182	150	162	166	124	180.0	186	189
BOD5 (lbs/day) Raw Sewage Influent   Daily Maximum	217	250	313	393	301	192	176	184	147	189	236	217
BOD5 (mg/L) Raw Sewage Influent   Average Monthly	190	240	217	183	217	213	213	234	170	233.0	256	262

NPDES Permit Fact Sheet  
Northeastern York County STP Saginaw

NPDES Permit No. PA0247103

TSS (lbs/day) Average Monthly	2.0	5.0	14.0	50.0	3.0	4.0	3.0	2.0	3.0	2.0	1.0	1.0
TSS (lbs/day) Raw Sewage Influent   Average Monthly	203	235	270	233	232	184	211	204	210	227.0	220	209
TSS (lbs/day) Raw Sewage Influent   Daily Maximum	270	268	343	370	417	209	244	234	227	256.0	285	224
TSS (lbs/day) Weekly Average	4.6	9.8	33.2	117.6	4.3	7.7	3.5	4.7	5.5	3.7	2.3	1.5
TSS (mg/L) Average Monthly	2.0	6.0	10.0	31.0	4.0	5.0	4.0	2.2	4.0	3.0	2.0	1.5
TSS (mg/L) Raw Sewage Influent   Average Monthly	238	268	214	210	274	264	277	286	288	294.0	305	289
TSS (mg/L) Weekly Average	4.0	11.0	25.0	70.0	5.0	10.0	5.0	6.0	7.0	5.0	3.0	1.5
Fecal Coliform (No./100 ml) Geometric Mean	19	27	100	9	< 5	12	< 11	15	< 2.0	< 2.0	< 3	< 1
Fecal Coliform (No./100 ml) Instantaneous Maximum	345	210	687	20	16	24	770	51	12.0	6.0	30	1
Nitrate-Nitrite (mg/L) Average Monthly	19.4	< 21.4	< 10.4	< 20.93	< 28.4	30.4	< 19.4	< 7.2	< 2.9	< 2.4	< 6.5	< 6.7
Nitrate-Nitrite (lbs) Total Monthly	687	< 481	< 280	< 767	< 561	723	< 413	< 162	< 70	< 53.0	< 168	< 154
Total Nitrogen (mg/L) Average Monthly	21.9	< 21.9	< 11.31	< 27.68	< 28.9	< 30.5	< 19.9	< 8.4	< 4.7	< 3.8	7.12	< 8.7
Total Nitrogen (lbs) Total Monthly	776	< 493	< 304	< 1115	< 571	< 725	< 423	< 189	< 114	< 84.0	184	< 200
Total Nitrogen (lbs) Total Annual							< 8738					
Ammonia (lbs/day) Average Monthly	< 0.2	0.2	< 0.2	< 0.6	0.2	< 0.07	< 0.08	0.2	0.3	0.5	0.9	2.0
Ammonia (mg/L) Average Monthly	< 0.22	0.20	< 0.2	< 0.1	< 0.1	< 0.1	< 0.1	0.31	0.42	0.7	1.0	2.9
Ammonia (mg/L) Instantaneous Maximum	0.55	0.39	0.33	1.0	0.48	< 0.1	< 0.1	0.46	1.0	1.4	4.1	5.7
Ammonia (lbs) Total Monthly	< 7	5	< 7	< 18	7	< 2	< 2	7	9	16.0	27	61

NPDES Permit Fact Sheet  
Northeastern York County STP Saginaw

NPDES Permit No. PA0247103

Ammonia (lbs) Total Annual							< 177					
TKN (mg/L) Average Monthly	< 2.5	< 0.5	0.91	< 6.8	< 0.5	< 0.5	< 0.5	1.2	1.8	1.4	0.62	2.0
TKN (lbs) Total Monthly	< 89	< 11	24	< 348	< 10	< 12	< 11	27	44	31.0	16	46
Total Phosphorus (lbs/day) Average Monthly	0.5	0.4	1.0	1.6	0.5	0.5	0.4	0.3	0.4	0.4	0.6	0.5
Total Phosphorus (mg/L) Average Monthly	0.53	0.47	0.63	1.09	0.55	0.71	0.58	0.41	0.55	0.49	0.83	0.76
Total Phosphorus (mg/L) Instantaneous Maximum	0.75	0.61	0.97	3.3	0.78	0.78	0.63	0.53	0.8	0.75	1.3	0.93
Total Phosphorus (lbs) Total Monthly	15.9	12.1	29.7	50.1	13.5	15.4	13.3	9.0	12.5	11.4	18	16.3
Total Phosphorus (lbs) Total Annual							339					

Compliance History

Effluent Violations for Outfall 001, from: May 1, 2023 To: March 31, 2024

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
TSS	12/31/23	Wkly Avg	117.6	lbs/day	112.5	lbs/day
TSS	12/31/23	Avg Mo	31.0	mg/L	30.0	mg/L
TSS	12/31/23	Wkly Avg	70.0	mg/L	45.0	mg/L
Ammonia	05/31/23	IMAX	4.1	mg/L	4.0	mg/L

Other Comments: The May 2023 DMR includes a Non-Compliance Form that states that the above ammonia violation was the result of impaired blower operation resulting in under aeration of the mixed liquor. The December 2023 DMR includes a Non-Compliance Form that states that the above TSS violations were the result of high flows resulting the plant being put into storm mode. The reviewer notes that putting a plant into storm mode is a technique to hold solids in a plant during periods of high flow, so it is not clear why this is being identified as the cause of the TSS excursion.

Development of Effluent Limitations				
Outfall No.	001	Design Flow (MGD)	.3	
Latitude	40° 4' 16.00"	Longitude	-76° 40' 24.00"	
Wastewater Description:	Sewage Effluent			

### Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: These standards apply, subject to water quality analysis and BPJ where applicable.

### Water Quality-Based Limitations

#### *CBOD<sub>5</sub>, NH<sub>3</sub>-N and Dissolved Oxygen (DO)*

WQM 7.0 version 1.0b is a water quality model designed to assist DEP to determine appropriate permit requirements for CBOD<sub>5</sub>, NH<sub>3</sub>-N and DO. DEP's guidance no. 391-2000-007 provides the technical methods contained in WQM 7.0 for conducting wasteload allocation and for determining recommended NPDES effluent limits for point source discharges. The model was utilized using data derived by USGS StreamStats and the model output indicated that existing WQBELs for ammonia and CBOD<sub>5</sub> are still protective of water quality.

The model also determined that the facility's existing DO limits of 5 mg/L are still protective of water quality.

#### *Total Dissolved Solids (TDS)*

The requirement to monitor TDS and its constituents is not needed given that the maximum concentration of TDS reported in the application is less than 1,000 mg/L.

#### *Toxics*

A reasonable potential (RP) analysis is not required for minor facilities with no commercial or industrial contributions.

#### *E. Coli Monitoring*

In conformity with the Department's *Establishing Effluent Limitations for Individual Sewage Permits* (SOP No. BCW-PMT-033) and as authorized by § 92a.61 of the PA Code, quarterly E. Coli monitoring has been proposed in this permit. The collection method will be via grab sample.

### Best Professional Judgment (BPJ) Limitations

#### *Dissolved Oxygen*

A minimum of 5.0 mg/L for DO is an existing effluent limit and will remain unchanged in the draft permit as recommended by DEP's SOP. This requirement has also been assigned to other sewage facilities in the region. 5.0 mg/L is taken directly from 25 Pa. Code § 93.7(a) and it is also determined to be appropriate according to water quality modeling.

**Total Residual Chlorine (TRC)**

Chlorine is currently used for disinfection and the current NPDES permit contains water quality based effluent limits for TRC. It is necessary to utilize DEP's TRC\_CALC excel worksheet to determine appropriate permit requirements for the upcoming permit term. The worksheet indicated that existing limits of 0.1 mg/L (average monthly) and 0.4 mg/L (instantaneous maximum) are no longer protective of water quality. The worksheet indicates that limits of 0.1 mg/L (average monthly) and 0.3 mg/L (IMAX) are needed. Based on the facility's DMR data, the facility is already configured to meet the proposed new IMAX limit.

**Total Phosphorus & Total Nitrogen**

DEP's SOP no. BPNPSM-PMT-033 (Establishing Effluent Limitations for Individual Sewage Permits) recommends monitoring requirements for Total Phosphorus and Total Nitrogen for all sewage facilities. Therefore, routine monitoring for TKN, Nitrate-Nitrite, and TN are recommended to be continued in this permit. Sampling frequency for TKN, Nitrate-Nitrite, TN, and TP are currently required 1/week, which is consistent with Table 6.3 in Guidance Doc. 362-0400-001, which recommends the testing of conventional pollutants weekly for facilities with flows between 0.1 mgd to 1.0 mgd. No change is proposed in this permit renewal.

Historically, an average monthly Total Phosphorus limit of 2.0 mg/L was recommended in NPDES permits, per DEP phosphorus guidance 391-2000-018, to control phosphorus effluent levels for any facilities that are expected to contribute 0.25% or more of the total phosphorus loading of the entire basin. DEP has previously determined that this facility meets the criteria and the limit has been continuously imposed in the permit. It is recommended to maintain this limit in the draft permit.

**Additional Considerations**

***Flow Monitoring***

The requirement to monitor the volume of effluent will remain in the draft permit per 40 CFR § 122.44(i)(1)(ii).

***Chesapeake Bay TMDL***

The Department formulated a strategy in April 2007, to comply with the EPA's and Chesapeake Bay Foundation's requirements to reduce point source loadings of Total Nitrogen (TN) and Total Phosphorus (TP) to the Bay. In the Strategy, sewage dischargers have been prioritized by Central Office based on their delivered TN loadings to the Bay. The highest priority (Phases 1, 2, and 3) dischargers received annual loading caps based on their design flow on August 29, 2005 and concentrations of 6 mg/l TN and 0.8 mg/l TP. Phase 4 (0.2 -0.4mgd) and Phase 5 (below 0.2mgd) facilities were required to monitor and report TN and TP during permit renewal at a monitoring frequency following Table 6-3 of DEP's Technical Guidance for Development and Specification of effluent Limitations (No. 362-0400-001).

EPA published the Chesapeake Bay Total Maximum Daily Load (TMDL) in December of 2010. Despite extensive restoration efforts during the past 25 years, the TMDL was prompted by insufficient progress and continued poor water quality in the Chesapeake Bay and its tidal tributaries.

In order to address the TMDL, Pennsylvania developed, in addition to the Bay Strategy, a Chesapeake Watershed Implementation Plan (WIP) Phase 1 in January 2011, Phase 2 in March 2012 and Phase 3 in December 2019. In accordance with the Phase 3 WIP, re-issuing permits for significant dischargers follow the same phased approach formulated in the original Bay strategy, whilst Phase 4 and Phase 5 will be required to monitor and report TN and TP during permit renewal.

The Phase 3 WIP categorizes this facility as a phase 4 sewage facility that has a design flow less than 0.4 MGD but greater than 0.2 MGD. The WIP recommends the following:

1. Renewed or amended permits for facilities that do not increase design flow (compared to the date of the latest prior permit action) will contain monitoring and reporting for TN and TP throughout the permit term at a frequency no less than monthly.
2. Renewed or amended permits that include an increase in design flow will contain Cap Loads based on the lesser of a) existing TN and TP concentrations at current design average annual flow or b) 7,306 lbs/yr TN and 974 lbs/yr TP.

There is no proposed increased in design flow. Therefore, monitoring and reporting for TN and TP will remain in the permit.

*Monitoring Frequency and Sample Type*

Unless discussed otherwise above, the permit's monitoring frequency and sample type for all parameters will remain unchanged from the last permit renewal.

*Antidegradation Requirements*

All effluent limitations and monitoring requirements have been developed to ensure that existing instream water uses and the level of water quality necessary to protect the existing uses are maintained and protected.

*Anti-backsliding Requirement*

All effluent limits proposed in this fact sheet are as stringent as effluent limits specified in the existing permit renewal unless noted otherwise above. This approach is in accordance with 40 CFR §122.44(l)(1).

*Annual Fees*

An annual fee clause was added to the permit in accordance with 25 Pa. Code § 92a.62. The facility covered by the permit is classified in the Minor Sewage Facility  $\geq 0.05$  and  $< 1$  MGD fee category, which has an annual fee of \$1,000.

*Mass Loading Limitations*

Unless stated otherwise in this fact sheet, mass loading effluent limits are calculated based on the formula: design flow (average annual) (MGD) x concentration limit (mg/L) at design flow x conversion factor (8.34).

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Monthly	Annual	Monthly	Monthly Average	Maximum	Instant. Maximum		
Total Nitrogen (lbs)	XXX	Report Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation
Ammonia (lbs)	XXX	Report Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation
Total Phosphorus (lbs)	XXX	Report Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation

Compliance Sampling Location: Outfall 001

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**


Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0 Daily Max	XXX	1/day	Grab
DO	XXX	XXX	5.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.1	XXX	0.3	1/day	Grab
CBOD5	62.5	100	XXX	25.0	40.0	50	1/week	24-Hr Composite
BOD5 Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
TSS	75	112.5	XXX	30.0	45.0	60	1/week	24-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
Nitrate-Nitrite	XXX	XXX	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Nitrate-Nitrite (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	1/month	Calculation

Outfall 001, Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Total Nitrogen (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
Ammonia Nov 1 - Apr 30	15.0	XXX	XXX	6.0	XXX	12	1/week	24-Hr Composite
Ammonia May 1 - Oct 31	5.0	XXX	XXX	2.0	XXX	4	1/week	24-Hr Composite
Ammonia (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
TKN	XXX	XXX	XXX	Report	XXX	XXX	1/week	24-Hr Composite
TKN (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
Total Phosphorus	5.0	XXX	XXX	2.0	XXX	4	1/week	24-Hr Composite
Total Phosphorus (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation

Compliance Sampling Location: Outfall 001

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [REDACTED])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [REDACTED])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [REDACTED]
<input type="checkbox"/>	Other: [REDACTED]



1A	B	C	D	E	F	G				
<b>2 TRC EVALUATION</b>										
3 Input appropriate values in B4:B8 and E4:E7										
4	1440	= Q stream (cfs)		0.5	= CV Daily					
5	0.3	= Q discharge (MGD)		0.5	= CV Hourly					
6	30	= no. samples		1	= AFC_Partial Mix Factor					
7	0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor					
8	0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)					
9	0.1	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)					
	0	= % Factor of Safety (FOS)		0	= Decay Coefficient (K)					
10	Source	Reference	AFC Calculations	Reference	CFC Calculations					
11	TRC	1.3.2.iii	WLA_afc = 989.806	1.3.2.iii	WLA_cfc = 964.975					
12	PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581					
13	PENTOXSD TRG	5.1b	LTA_afc = 368.825	5.1d	LTA_cfc = 560.991					
14										
15	Source	Effluent Limit Calculations								
16	PENTOXSD TRG	5.1f	AML MULT = 1.231							
17	PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.100			BAT/BPJ				
18			INST MAX LIMIT (mg/l) = 0.327							
19										
20	WLA_afc	$(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))...\\...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$								
21	LTAMULT_afc	$\text{EXP}((0.5*\text{LN}(cvh^2+1))-2.326*\text{LN}(cvh^2+1)^{0.5})$								
22	LTA_afc	$wla_afc*LTAMULT_afc$								
23	WLA_cfc	$(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))...\\...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$								
24	LTAMULT_cfc	$\text{EXP}((0.5*\text{LN}(cvd^2/2/no\_samples+1))-2.326*\text{LN}(cvd^2/2/no\_samples+1)^{0.5})$								
25	LTA_cfc	$wla_cfc*LTAMULT_cfc$								
26	AML MULT	$\text{EXP}(2.326*\text{LN}(cvd^2/2/no\_samples+1)^{0.5}-0.5*\text{LN}(cvd^2/2/no\_samples+1))$								
27	AVG MON LIMIT	$\text{MIN}(\text{BAT\_BPJ},\text{MIN}(\text{LTA\_afc},\text{LTA\_cfc})*\text{AML\_MULT})$								
28	INST MAX LIMIT	$1.5*((\text{av\_mon\_limit}/\text{AML\_MULT})/\text{LTAMULT\_afc})$								

## StreamStats Report

Region ID: PA

Workspace ID: PA20240522123226769000

Clicked Point (Latitude, Longitude): 40.07377, -76.66075

Time: 2024-05-22 08:32:57 -0400



 [Collapse All](#)

### ► Basin Characteristics

Parameter	Parameter Description	Value	Unit
BSLOPD	Mean basin slope measured in degrees	8.1927	degrees
CARBON	Percentage of area of carbonate rock	6.29	percent
DRNAREA	Area that drains to a point on a stream	25600	square miles
ELEV	Mean Basin Elevation	1342	feet
FOREST	Percentage of area covered by forest	68.5655	percent
GLACIATED	Percentage of basin area that was historically covered by glaciers	46.1965	percent
PRECIP	Mean Annual Precipitation	40	inches
ROCKDEP	Depth to rock	4.5	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	1.76	miles per square mile
URBAN	Percentage of basin with urban development	2.7768	percent

➤ Low-Flow Statistics

Low-Flow Statistics Parameters [2.0 Percent (554 square miles) Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	25600	square miles	4.78	1150
BSLOPD	Mean Basin Slope degrees	8.1927	degrees	1.7	6.4
ROCKDEP	Depth to Rock	4.5	feet	4.13	5.21
URBAN	Percent Urban	2.7768	percent	0	89

Low-Flow Statistics Parameters [43.0 Percent (11100 square miles) Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	25600	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	40	inches	35	50.4
STRDEN	Stream Density	1.76	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	4.5	feet	3.32	5.65
CARBON	Percent Carbonate	6.29	percent	0	99

Low-Flow Statistics Parameters [6.0 Percent (1600 square miles) Low Flow Region 3]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	25600	square miles	2.33	1720
ELEV	Mean Basin Elevation	1342	feet	898	2700
PRECIP	Mean Annual Precipitation	40	inches	38.7	47.9

Low-Flow Statistics Parameters [48.0 Percent (12300 square miles) Low Flow Region 5]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	25600	square miles	4.84	982
PRECIP	Mean Annual Precipitation	40	inches	33.1	47.1
GLACIATED	Percent of Glaciation	46.1965	percent	0	100
FOREST	Percent Forest	68.5655	percent	41	100

Low-Flow Statistics Disclaimers [2.0 Percent (554 square miles) Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors. Weighted flows were not calculated. Users should be careful to evaluate the applicability of the provided estimates. Percentage of area falls outside where region is undefined. Whole estimates have been provided using available regional equations.

Low-Flow Statistics Flow Report [2.0 Percent (554 square miles) Low Flow Region 1]

Statistic	Value	Unit
7 Day 2 Year Low Flow	9210	ft^3/s
30 Day 2 Year Low Flow	10200	ft^3/s
7 Day 10 Year Low Flow	7210	ft^3/s
30 Day 10 Year Low Flow	7580	ft^3/s
90 Day 10 Year Low Flow	8060	ft^3/s

Low-Flow Statistics Disclaimers [43.0 Percent (11100 square miles) Low Flow Region 2]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors. Weighted flows were not calculated. Users should be careful to evaluate the applicability of the provided estimates. Percentage of area falls outside where region is undefined. Whole estimates have been provided using available regional equations.

Low-Flow Statistics Flow Report [43.0 Percent (11100 square miles) Low Flow Region 2]

Statistic	Value	Unit
7 Day 2 Year Low Flow	5840	ft^3/s
30 Day 2 Year Low Flow	6900	ft^3/s
7 Day 10 Year Low Flow	4350	ft^3/s
30 Day 10 Year Low Flow	5130	ft^3/s
90 Day 10 Year Low Flow	6390	ft^3/s

Low-Flow Statistics Disclaimers [6.0 Percent (1600 square miles) Low Flow Region 3]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors. Weighted flows were not calculated. Users should be careful to evaluate the applicability of the provided estimates. Percentage of area falls outside where region is undefined. Whole estimates have been provided using available regional equations.

Low-Flow Statistics Flow Report [6.0 Percent (1600 square miles) Low Flow Region 3]

Statistic	Value	Unit
7 Day 2 Year Low Flow	2390	ft^3/s
30 Day 2 Year Low Flow	2950	ft^3/s
7 Day 10 Year Low Flow	1440	ft^3/s
30 Day 10 Year Low Flow	1790	ft^3/s
90 Day 10 Year Low Flow	2450	ft^3/s

Low-Flow Statistics Disclaimers [48.0 Percent (12300 square miles) Low Flow Region 5]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors. Weighted flows were not calculated. Users should be careful to evaluate the applicability of the provided estimates.

Percentage of area falls outside where region is undefined. Whole estimates have been provided using available regional equations.

Low-Flow Statistics Flow Report [48.0 Percent (12300 square miles) Low Flow Region 5]

Statistic	Value	Unit
7 Day 2 Year Low Flow	3550	ft <sup>3</sup> /s
30 Day 2 Year Low Flow	4460	ft <sup>3</sup> /s
7 Day 10 Year Low Flow	2290	ft <sup>3</sup> /s
30 Day 10 Year Low Flow	2980	ft <sup>3</sup> /s
90 Day 10 Year Low Flow	3840	ft <sup>3</sup> /s

*Low-Flow Statistics Citations*

**Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p.**  
(<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.20.1

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1

## StreamStats Report

Region ID: PA

Workspace ID: PA20240522123935145000

Clicked Point (Latitude, Longitude): 40.06231, -76.64020

Time: 2024-05-22 08:40:10 -0400



 [Collapse All](#)

### ► Basin Characteristics

Parameter	Parameter Description	Value	Unit
BSLOPD	Mean basin slope measured in degrees	8.1925	degrees
CARBON	Percentage of area of carbonate rock	6.29	percent
DRNAREA	Area that drains to a point on a stream	25600	square miles
ELEV	Mean Basin Elevation	1342	feet
FOREST	Percentage of area covered by forest	68.5627	percent
GLACIATED	Percentage of basin area that was historically covered by glaciers	46.1932	percent
PRECIP	Mean Annual Precipitation	40	inches
ROCKDEP	Depth to rock	4.5	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	1.76	miles per square mile
URBAN	Percentage of basin with urban development	2.7771	percent

➤ Low-Flow Statistics

Low-Flow Statistics Parameters [2.0 Percent (556 square miles) Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	25600	square miles	4.78	1150
BSLOPD	Mean Basin Slope degrees	8.1925	degrees	1.7	6.4
ROCKDEP	Depth to Rock	4.5	feet	4.13	5.21
URBAN	Percent Urban	2.7771	percent	0	89

Low-Flow Statistics Parameters [43.0 Percent (11100 square miles) Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	25600	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	40	inches	35	50.4
STRDEN	Stream Density	1.76	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	4.5	feet	3.32	5.65
CARBON	Percent Carbonate	6.29	percent	0	99

Low-Flow Statistics Parameters [6.0 Percent (1600 square miles) Low Flow Region 3]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	25600	square miles	2.33	1720
ELEV	Mean Basin Elevation	1342	feet	898	2700
PRECIP	Mean Annual Precipitation	40	inches	38.7	47.9

Low-Flow Statistics Parameters [48.0 Percent (12300 square miles) Low Flow Region 5]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	25600	square miles	4.84	982
PRECIP	Mean Annual Precipitation	40	inches	33.1	47.1
GLACIATED	Percent of Glaciation	46.1932	percent	0	100
FOREST	Percent Forest	68.5627	percent	41	100

Low-Flow Statistics Disclaimers [2.0 Percent (556 square miles) Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors. Weighted flows were not calculated. Users should be careful to evaluate the applicability of the provided estimates. Percentage of area falls outside where region is undefined. Whole estimates have been provided using available regional equations.

Low-Flow Statistics Flow Report [2.0 Percent (556 square miles) Low Flow Region 1]

Statistic	Value	Unit
7 Day 2 Year Low Flow	9210	ft^3/s
30 Day 2 Year Low Flow	10200	ft^3/s
7 Day 10 Year Low Flow	7210	ft^3/s
30 Day 10 Year Low Flow	7580	ft^3/s
90 Day 10 Year Low Flow	8060	ft^3/s

Low-Flow Statistics Disclaimers [43.0 Percent (11100 square miles) Low Flow Region 2]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors. Weighted flows were not calculated. Users should be careful to evaluate the applicability of the provided estimates. Percentage of area falls outside where region is undefined. Whole estimates have been provided using available regional equations.

Low-Flow Statistics Flow Report [43.0 Percent (11100 square miles) Low Flow Region 2]

Statistic	Value	Unit
7 Day 2 Year Low Flow	5840	ft^3/s
30 Day 2 Year Low Flow	6900	ft^3/s
7 Day 10 Year Low Flow	4350	ft^3/s
30 Day 10 Year Low Flow	5130	ft^3/s
90 Day 10 Year Low Flow	6390	ft^3/s

Low-Flow Statistics Disclaimers [6.0 Percent (1600 square miles) Low Flow Region 3]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors. Weighted flows were not calculated. Users should be careful to evaluate the applicability of the provided estimates. Percentage of area falls outside where region is undefined. Whole estimates have been provided using available regional equations.

Low-Flow Statistics Flow Report [6.0 Percent (1600 square miles) Low Flow Region 3]

Statistic	Value	Unit
7 Day 2 Year Low Flow	2390	ft^3/s
30 Day 2 Year Low Flow	2950	ft^3/s
7 Day 10 Year Low Flow	1440	ft^3/s
30 Day 10 Year Low Flow	1790	ft^3/s
90 Day 10 Year Low Flow	2450	ft^3/s

Low-Flow Statistics Disclaimers [48.0 Percent (12300 square miles) Low Flow Region 5]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors. Weighted flows were not calculated. Users should be careful to evaluate the applicability of the provided estimates.

Percentage of area falls outside where region is undefined. Whole estimates have been provided using available regional equations.

Low-Flow Statistics Flow Report [48.0 Percent (12300 square miles) Low Flow Region 5]

Statistic	Value	Unit
7 Day 2 Year Low Flow	3550	ft <sup>3</sup> /s
30 Day 2 Year Low Flow	4460	ft <sup>3</sup> /s
7 Day 10 Year Low Flow	2290	ft <sup>3</sup> /s
30 Day 10 Year Low Flow	2980	ft <sup>3</sup> /s
90 Day 10 Year Low Flow	3840	ft <sup>3</sup> /s

*Low-Flow Statistics Citations*

**Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p.**  
(<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.20.1

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1

## StreamStats Report

Region ID: PA

Workspace ID: PA20240522130659108000

Clicked Point (Latitude, Longitude): 40.07416, -76.67642

Time: 2024-05-22 09:07:19 -0400



+/- Collapse All

### ► Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
BSLOPD	Mean basin slope measured in degrees	4.4525	degrees
DRNAREA	Area that drains to a point on a stream	5.37	square miles
ROCKDEP	Depth to rock	4.4	feet
URBAN	Percentage of basin with urban development	14.6461	percent

### ► Low-Flow Statistics

#### Low-Flow Statistics Parameters [Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	5.37	square miles	4.78	1150
BSLOPD	Mean Basin Slope degrees	4.4525	degrees	1.7	6.4
ROCKDEP	Depth to Rock	4.4	feet	4.13	5.21
URBAN	Percent Urban	14.6461	percent	0	89

#### Low-Flow Statistics Flow Report [Low Flow Region 1]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	0.95	ft <sup>3</sup> /s	46	46
30 Day 2 Year Low Flow	1.3	ft <sup>3</sup> /s	38	38
7 Day 10 Year Low Flow	0.421	ft <sup>3</sup> /s	51	51
30 Day 10 Year Low Flow	0.599	ft <sup>3</sup> /s	46	46
90 Day 10 Year Low Flow	0.994	ft <sup>3</sup> /s	41	41

*Low-Flow Statistics Citations*

**Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)**

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.


Application Version: 4.20.1

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1

## StreamStats Report

Region ID: PA  
Workspace ID: PA20240522131013135000  
Clicked Point (Latitude, Longitude): 40.07065, -76.67337  
Time: 2024-05-22 09:10:33 -0400



[Collapse All](#)

### ► Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
BSLOPD	Mean basin slope measured in degrees	5.2382	degrees
DRNAREA	Area that drains to a point on a stream	1.23	square miles
ROCKDEP	Depth to rock	4.9	feet
URBAN	Percentage of basin with urban development	9.303	percent

### ► Low-Flow Statistics

#### Low-Flow Statistics Parameters [Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	1.23	square miles	4.78	1150
BSLOPD	Mean Basin Slope degrees	5.2382	degrees	1.7	6.4
ROCKDEP	Depth to Rock	4.9	feet	4.13	5.21
URBAN	Percent Urban	9.303	percent	0	89

#### Low-Flow Statistics Disclaimers [Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 1]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.381	ft^3/s
30 Day 2 Year Low Flow	0.478	ft^3/s
7 Day 10 Year Low Flow	0.18	ft^3/s
30 Day 10 Year Low Flow	0.235	ft^3/s
90 Day 10 Year Low Flow	0.345	ft^3/s

*Low-Flow Statistics Citations*

**Stuckey, M.H.,2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)**

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.20.1

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1

**WQM 7.0 Effluent Limits**

<b>SWP Basin</b>		<b>Stream Code</b>	<b>Stream Name</b>				
<b>07K</b>	<b>6685</b>	<b>SUSQUEHANNA RIVER</b>					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
37.500	Saginaw STP	PA0247103	0.300	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			5

## WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>				
07K	6685	SUSQUEHANNA RIVER					
<b>NH3-N Acute Allocations</b>							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
37.500	Saginaw STP	16.76	50	16.76	50	0	0
<b>NH3-N Chronic Allocations</b>							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
37.500	Saginaw STP	1.89	25	1.89	25	0	0
<b>Dissolved Oxygen Allocations</b>							
RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>	
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)
37.50	Saginaw STP	25	25	25	25	5	5
						0	0

### WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
07K	6685	SUSQUEHANNA RIVER		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	Analysis Temperature (°C)	Analysis pH	
37.500	0.300	20.002	7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
979.915	1.080	907.739	1.362	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
2.01	0.006	0.01	0.700	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
8.242	3.513	Tsivoglou	6	
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>			
0.022	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.002	2.01	0.01	8.24
	0.004	2.01	0.01	8.24
	0.007	2.01	0.01	8.24
	0.009	2.01	0.01	8.24
	0.011	2.01	0.01	8.24
	0.013	2.01	0.01	8.24
	0.016	2.01	0.01	8.24
	0.018	2.01	0.01	8.24
	0.020	2.01	0.01	8.24
	0.022	2.01	0.01	8.24

## WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>			<u>Stream Code</u>			<u>Stream Name</u>						
07K			6685			SUSQUEHANNA RIVER						
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
<b>Q7-10 Flow</b>												
37.500	1440.00	0.00	1440.00	.4641	0.00055	1.08	979.92	907.74	1.36	0.022	20.00	7.00
<b>Q1-10 Flow</b>												
37.500	921.60	0.00	921.60	.4641	0.00055	NA	NA	NA	1.06	0.029	20.00	7.00
<b>Q30-10 Flow</b>												
37.500	1958.40	0.00	1958.40	.4641	0.00055	NA	NA	NA	1.62	0.019	20.00	7.00

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC	
07K	6685	SUSQUEHANNA RIVER			37.500	250.00	25600.00	0.00000	0.00	<input checked="" type="checkbox"/>	
<b>Stream Data</b>											
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)	Stream pH
Q7-10	0.100	0.00	1440.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00
Q1-10		0.00	0.00	0.000	0.000						
Q30-10		0.00	0.00	0.000	0.000						
<b>Discharge Data</b>											
	Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor		Disc Temp (°C)	Disc pH		
	Saginaw STP	PA0247103	0.3000	0.3000	0.3000	0.000		25.00	7.00		
<b>Parameter Data</b>											
	Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)						
	CBOD5	25.00	2.00	0.00	1.50						
	Dissolved Oxygen	5.00	8.24	0.00	0.00						
	NH3-N	25.00	0.00	0.00	0.70						

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC			
07K	6685	SUSQUEHANNA RIVER			37.000	248.54	25605.00	0.00000	0.00	<input checked="" type="checkbox"/>			
<b>Stream Data</b>													
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)			
Q7-10	0.100	0.00	1440.50	0.000	0.000	0.0	0.00	0.00	20.00	7.00			
Q1-10		0.00	0.00	0.000	0.000								
Q30-10		0.00	0.00	0.000	0.000								
<b>Discharge Data</b>													
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH						
		0.0000	0.0000	0.0000	0.000	25.00	7.00						
<b>Parameter Data</b>													
Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)								
CBOD5		25.00	2.00	0.00	1.50								
Dissolved Oxygen		3.00	8.24	0.00	0.00								
NH3-N		25.00	0.00	0.00	0.70								