

Application Type Renewal
Facility Type Industrial
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL INDUSTRIAL WASTE (IW)
AND IW STORMWATER**

Application No. PA0247154
APS ID 484376
Authorization ID 1301704

Applicant and Facility Information

Applicant Name	<u>Possum Valley Municipal Authority Adams County</u>	Facility Name	<u>Possum Valley Municipal Authority Water System</u>
Applicant Address	<u>609 Clearview Road Aspers, PA 17304-9703</u>	Facility Address	<u>70 Opossum Hill Road Aspers, PA 17304</u>
Applicant Contact	<u>Jeffrey Taylor</u>	Facility Contact	<u>Jeffery Taylor</u>
Applicant Phone	<u>(717) 677-8551</u>	Facility Phone	<u>(717) 677-8551</u>
Client ID	<u>6159</u>	Site ID	<u>454084</u>
SIC Code	<u>4952</u>	Municipality	<u>Menallen Township</u>
SIC Description	<u>Trans. & Utilities - Sewerage Systems</u>	County	<u>Adams</u>
Date Application Received	<u>January 2, 2020</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>January 15, 2020</u>	If No, Reason	<u></u>
Purpose of Application	<u>NPDES permit renewal.</u>		

Summary of Review

Possum Valley Municipal Authority (PVMA) has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of its NPDES permit. The permit was last reissued on June 29, 2015 and became effective on July 1, 2015. The permit will expire on June 30, 2020.

This facility is not covered under Effluent Limitation Guidelines (ELG). The discharge flow design is 0.0065 MGD. The facility discharges membrane filter backwash water at a rate of 0.0006 MGD. The discharge through Outfall 001 is into an Unnamed Tributary (UNT) to Opossum Creek.

The WQM Part II permit is not needed for PVWA facility because this is not treatment of wastewater. Additionally, backwash is a combination of compressed air and filtered water, and not treated before discharge to surface.

Based on the review outline in this fact sheet, it is recommended that the permit be drafted and published in the Pennsylvania Bulletin for public comments for 30 days.

Approve	Deny	Signatures	Date
X		<i>Hilaryle</i> Hilary H. Le / Environmental Engineering Specialist	June 12, 2020
		Daniel W. Martin, P.E. / Environmental Engineer Manager	
		Maria D. Bebenek, P.E. / Clean Water Program Manager	

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.0006
Latitude	39° 59' 29.00"	Longitude	-77° 14' 14.65"
Quad Name	Biglerville	Quad Code	
Wastewater Description: Water Treatment Effluent			
Receiving Waters	Unnamed Tributary to Opossum Creek (TSF)	Stream Code	09107
NHD Com ID	57469817	RMI	0.13 mile
Drainage Area	0.26 mi. ²	Yield (cfs/mi ²)	0.37
Q ₇₋₁₀ Flow (cfs)	0.095	Q ₇₋₁₀ Basis	USGS StreamStats
Elevation (ft)	700	Slope (ft/ft)	
Watershed No.	7-F	Chapter 93 Class.	TSF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment			
Source(s) of Impairment			
TMDL Status	End date 7/8/2013	Name	Opossum Creek
Nearest Downstream Public Water Supply Intake	Wrightsville Water Supply Co., York County		
PWS Waters	Susquehanna River	Flow at Intake (cfs)	
PWS RMI	29 miles	Distance from Outfall (mi)	Approximate 80 miles

Changes Since Last Permit Issuance: none

Drainage Area

The discharge is to unnamed tributary of Swift Run at RMI 0.13 miles. A drainage area upstream of the discharge is estimated to be 0.26 mi.², according to USGS StreamStats available at <https://streamstats.usgs.gov/ss/>.

Stream Flow

According to USGS StreamStats, the Q₇₋₁₀ at the discharge point is 0.095 cfs and the drainage area is 0.26 mi.² which results in a Q₇₋₁₀ low flow yield of 0.37 cfs/mi.². This information is used to obtain a chronic or 30-day (Q₃₀₋₁₀), and an acute or 1-day (Q₁₋₁₀) exposure stream flow for the discharge point as follows (Guidance No. 391-2000-023):

$$\begin{aligned}
 Q_{7-10} &= 0.095 \text{ cf} \\
 \text{Low Flow Yield} &= 0.095 \text{ cfs} / 0.26 \text{ mi.}^2 \approx 0.365 \text{ (0.37) cfs/mi.}^2 \\
 Q_{30-10} &= 1.36 * 0.095 \text{ cfs} \approx 0.129 \text{ cfs} \\
 Q_{1-10} &= 0.64 * 0.095 \text{ cfs} \approx 0.061 \text{ cfs}
 \end{aligned}$$

The resulting Q₇₋₁₀ dilution ratio is: $Q_{\text{stream}} / Q_{\text{discharge}} = 0.095 \text{ cfs} / [0.0006 \text{ MGD} * (1.547 \text{ cfs/MGD})] = 102.3:1$

Public Water Supply

The nearest downstream public water supply intake is the Wrightsville Water Supply Co. on Susquehanna River in York County, approximately 80 miles downstream of this discharge. Given the nature and dilution, the discharge is not expected to significantly impact the water supply.

Treatment Facility Summary				
Treatment Facility Name: Possum Valley Municipal Authority Water Filtration Plant				
WQM Permit No.		Issuance Date		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Industrial				
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal

Changes Since Last Permit Issuance: none

The process wastewater is backwash from drinking water membrane filter.

Compliance History	
Summary of DMRs:	See DMR reported from May 1, 2019 to April 30, 2020 Table below (Page # 4).
Summary of Inspections:	<p>11/20/2017: Mr. Bowen, DEP WQS, conducted compliance evaluation inspection. Effluent was clear. The field test results were within permit limits. There were no violations noted during inspection.</p> <p>3/1/2016: Mr. Haines, DEP WQS, conducted compliance evaluation inspection. Effluent was clear. The field test results were within permit limits. The industrial waste discharge is made up of the filter backwash from the two membrane filtration units used to filter the drinking water.</p>
Other Comments:	There are currently no open violations associated with the permittee or the facility.

Other Comments: The DMR data did not indicate any limit exceedances.

Compliance History

DMR Data for Outfall 001 (from May 1, 2019 to April 30, 2020)

Parameter	APR-20	MAR-20	FEB-20	JAN-20	DEC-19	NOV-19	OCT-19	SEP-19	AUG-19	JUL-19	JUN-19	MAY-19
Flow (MGD) Average Monthly		0.0006					0.0006			0.0006	0.0006	
Flow (MGD) Daily Maximum		0.0006					0.0006			0.0006	0.0006	
pH (S.U.) Minimum		6.6					6.6			6.3	6.5	
pH (S.U.) Maximum		6.7					6.8			6.7	6.5	
TRC (mg/L) Average Monthly		< 0.1					< 0.1			< 0.1	< 0.1	
TRC (mg/L) Instantaneous Maximum		< 0.1					< 0.1			< 0.1	< 0.1	
TSS (mg/L) Average Monthly		4.0			5			3			1	
TSS (mg/L) Daily Maximum		4.0			5			3			1	
Total Aluminum (mg/L) Average Monthly		0.2			0.1			0.2			0.1	
Total Aluminum (mg/L) Daily Maximum		0.22			0.13			0.16			0.1	
Total Iron (mg/L) Average Monthly		0.3			0.4			0.5			0.3	
Total Iron (mg/L) Daily Maximum		0.28			0.4			0.45			0.31	
Total Manganese (mg/L) Average Monthly		0.005			< 0.1			0.01			0.01	
Total Manganese (mg/L) Daily Maximum		0.005			< 0.05			0.014			0.014	

Development of Effluent Limitations

Outfall No. <u>001</u>	Design Flow (MGD) <u>0.0006</u>
Latitude <u>39° 59' 29.00"</u>	Longitude <u>-77° 14' 15.00"</u>
Wastewater Description: <u>Water Treatment Effluent</u>	

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Parameter	Limit (mg/l)	SBC	Federal Regulation	State Regulation
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Water Quality-Based Limitations / Best Professional Judgment (BPJ) Limitations

Effluent Limitations Evaluation:

Evaluation of effluent limitations for this facility is based on Best Practicable Control Technology Currently Available (BPT), according to guidance document 362-2183-003 (*Technology-Based Control Requirements for Water Treatment Plant Wastes*). The attached TRC Excel spreadsheet calculator, which uses the equations and calculations from guidance document 391-2000-015, was also used. However, the TRC limits from the BPT document will be used in the permit since they are more stringent. The existing instantaneous maximum TRC limitation will be changed from 1.6 mg/L to 1.0 mg/L to reflect the requirements of 362-2183-003 and remain in the proposed permit due to anti-backsliding requirements. Additionally, past DMRs and inspection reports show that the facility has been consistently achieving concentrations under these limits.

Guidance document 362-2183-003 defines Best Practicable Control Technology Currently Available (BPT) effluent control requirements for filter backwash wastewater as follows:

Parameter	Monthly Average (mg/L)	Daily Maximum (mg/L)
Total Suspended Solids	30	60
Total Iron	2	4
Total Aluminum	4	8
Total Manganese	1	2
Flow	Monitor	
pH	6 to 9 at all times	
Total Residual Chlorine	0.5	1.0

PENTOXSD was run for Total Iron, Total Aluminum, and Total Manganese (see attached data). The model results indicate limits that are less stringent than the above technology limits for all three parameters. Therefore, the renewed permit will reflect the above BPT limitations. These limits will remain in the proposed permit.

Toxics:

The attached toxics screening analysis spreadsheet indicates phenolics as a parameter of concern. However, since the phenolics sample was non-detect and no public water supply exists nearby, PENTOXSD was not run for phenolics.

No additional toxics monitoring requirements are recommended for the permit.

Chesapeake Bay Strategy:

This is a non-significant industrial discharge facility that will not need a Total Phosphorus (TP) or Total Nitrogen (TN) loading cap.

A TN and TP “Monitor & Report” requirement will not be necessary since this facility discharges wastewater without any chemical additives containing nitrogen or phosphorus. The Supplement to Phase II Watershed Implementation Plan states the following:

“For non-significant IW facilities, monitoring and reporting of TN and TP will be required throughout the permit term in renewed or amended permits anytime the facility has the potential to introduce a net TN or TP increase to the load contained within the intake water used in processing. In general, facilities that discharge groundwater and cooling water with no addition of chemicals containing N or P do not require monitoring.”

The effluent limits for this discharge have been developed to ensure that existing in-stream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High Quality Waters are impacted by this discharge. No Exceptional Value Waters are impacted by this discharge.

303(d) Listed Streams:

This discharge is not located on a 303(d) listed stream segment. A TMDL is currently proposed for Opossum Creek in order to address siltation issues. This facility is not contained in the draft TMDL as it does not contribute a significant sediment load to the Opossum Creek watershed.

Class A Wild Trout Fisheries:

No Class A Wild Trout Fisheries are impacted by this discharge.

WQM 7.0 / PENTOXSD Data:

The following two nodes were used in the modeling effort.

Node 1: Outfall 001 on UNT Opossum Creek (09107)
 Elevation: 700 ft (USGS National Map Viewer)
 Drainage Area: 0.26 mi.² (USGS PA StreamStats)
 River Mile Index: 0.13 (PA DEP eMapPA)
 Low Flow Yield: 0.37 cfs/mi.²
 Discharge Flow: 0.0006 MGD

Node 2: Just before confluence with Opossum Creek
 Elevation: 653 ft (USGS National Map Viewer)
 Drainage Area: 0.27 mi.² (USGS PA StreamStats)
 River Mile Index: 0.01 (PA DEP eMapPA)
 Low Flow Yield: 0.37 cfs/mi.²
 Discharge Flow: 0.0 MGD

TOXICS SCREENING ANALYSIS
 WATER QUALITY POLLUTANTS OF CONCERN
 VERSION 2.7

CLEAR FORM

Facility: **Possum Valley MA** NPDES Permit No.: **PA0247154** Outfall: **001**
 Analysis Hardness (mg/L): **44** Discharge Flow (MGD): **0.0065** Analysis pH (SU): **7**
 Stream Flow, Q₇₋₁₀ (cfs): **0.095**

	Parameter	Maximum Concentration in Application or DMRs (µg/L)	Most Stringent Criterion (µg/L)	Candidate for PENTOXSD Modeling?	Most Stringent WQBEL (µg/L)	Screening Recommendation
Group 1	Total Dissolved Solids		500000			
	Chloride		250000			
	Bromide	<	N/A			
	Sulfate		250000			
	Fluoride	<	2000			
Group 2	Total Aluminum	< 1.5	750	No (Value < QL)	13,946.26	
	Total Antimony	<	5.6			
	Total Arsenic		10			
	Total Barium	<	2400			
	Total Beryllium	<	N/A			
	Total Boron	<	1600			
	Total Cadmium	<	0.271			
	Total Chromium	<	N/A			
	Hexavalent Chromium	<	10.4			
	Total Cobalt	<	19			
	Total Copper	<	9.3			
	Total Cyanide	<	N/A			
	Total Iron	< 3	1500	No	43,516.80	
	Dissolved Iron		300			
	Total Lead	<	3.2			
	Total Manganese	< 0.06	1000	No	29,011.20	
	Total Mercury	<	0.05			
	Total Molybdenum	<	N/A			
	Total Nickel		52.2			
	Total Phenols (Phenolics)		5			
	Total Selenium	<	5.0			
	Total Silver	<	3.8			
	Total Thallium	<	0.24			
Total Zinc	<	119.8				

TRC EVALUATION

Input appropriate values in A3:A9 and D3:D9

0.095	= Q stream (cfs)	0.5	= CV Daily
0.0006	= Q discharge (MGD)	0.5	= CV Hourly
30	= no. samples	1	= AFC_Partial Mix Factor
0.3	= Chlorine Demand of Stream	1	= CFC_Partial Mix Factor
0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)
0.5	= BAT/BPJ Value	720	= CFC_Criteria Compliance Time (min)
0	= % Factor of Safety (FOS)		=Decay Coefficient (K)

Source	Reference	AFC Calculations	Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 32.668	1.3.2.iii	WLA_cfc = 31.841
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 12.173	5.1d	LTA_cfc = 18.511

Source	Effluent Limit Calculations
PENTOXSD TRG 5.1f	AML MULT = 1.231
PENTOXSD TRG 5.1g	AVG MON LIMIT (mg/l) = 0.500 INST MAX LIMIT (mg/l) = 1.635

BAT/BPJ

WLA_afc	$(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))......+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$
LTAMULT_afc	$EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)$
LTA_afc	wla_afc*LTAMULT_afc
WLA_cfc	$(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))......+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$
LTAMULT_cfc	$EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)$
LTA_cfc	wla_cfc*LTAMULT_cfc
AML MULT	$EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))$
AVG MON LIMIT	MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)
INST MAX LIMIT	$1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)$

Analysis Results
✕

Effluent Limits

Hydrodynamics
Wasteload Allocations
Effluent Limits

RMI	Name	Permit Number	Disc Flow (mgd)
0.13	Possum Valley	PA0247154	0.0006

Parameter	Effluent Limit (µg/L)	Governing Criterion	Max. Daily Limit (µg/L)	Most Stringent	
				WQBEL (µg/L)	WQBEL Criterion
▶ ALUMINUM	13946.26	AFC	21758.4	13946.26	AFC
MANGANESE	29011.2	THH	45262.14	29011.2	THH
TOTAL IRON	43516.8	CFC	67893.21	43516.8	CFC

Record: 1 of 3 No Filter

Record: 1 of 1 No Filter

Number of Samples 4

Print
< Back
Next >
Archive
Cancel

Analysis Results WQM 7.0

Hydrodynamics | **NH3-N Allocations** | D.O. Allocations | D.O. Simulation | **Effluent Limitations**

RMI	Discharge Name	Permit Number	Disc Flow (mgd)
0.13	Possum Valley	PA0247154	0.0006

Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)	
CBOD5	25			
NH3-N	25	50		
Dissolved Oxygen			5	

Record: 1 of 1 | No Filter | Search

Existing Effluent Limitations and Monitoring Requirements

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Quarterly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Daily when Discharging	Estimate
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	Daily when Discharging	Grab
TRC	XXX	XXX	XXX	0.5 Avg Mo	XXX	1.0	Daily when Discharging	Grab
TSS	XXX	XXX	XXX	30.0	60.0	75	1/quarter	24-Hr Composite
Total Aluminum	XXX	XXX	XXX	4.0	8.0	10	1/quarter	24-Hr Composite
Total Iron	XXX	XXX	XXX	2.0	4.0	5	1/quarter	24-Hr Composite
Total Manganese	XXX	XXX	XXX	1.0	2.0	2.5	1/quarter	24-Hr Composite

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Quarterly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Daily when Discharging	Estimate
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	Daily when Discharging	Grab
TRC	XXX	XXX	XXX	0.5 Avg Mo	XXX	1.0	Daily when Discharging	Grab
TSS	XXX	XXX	XXX	30.0	60.0	75.0	1/quarter	24-Hr Composite
Total Aluminum	XXX	XXX	XXX	4.0	8.0	10.0	1/quarter	24-Hr Composite
Total Iron	XXX	XXX	XXX	2.0	4.0	5.0	1/quarter	24-Hr Composite
Total Manganese	XXX	XXX	XXX	1.0	2.0	2.5	1/quarter	24-Hr Composite

Compliance Sampling Location:

Other Comments:

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [redacted])
<input checked="" type="checkbox"/>	PENTOXSD for Windows Model (see Attachment [redacted])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Toxics Screening Analysis Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [redacted]
<input type="checkbox"/>	Other: [redacted]

Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	0.26	square miles
BSLOPD	Mean basin slope measured in degrees	9.2	degrees
ROCKDEP	Depth to rock	5.2	feet
URBAN	Percentage of basin with urban development	0	percent

Low-Flow Statistics Parameters_[Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	0.26	square miles	4.78	1150
BSLOPD	Mean Basin Slope degrees	9.2	degrees	1.7	6.4
ROCKDEP	Depth to Rock	5.2	feet	4.13	5.21
URBAN	Percent Urban	0	percent	0	89

Low-Flow Statistics Disclaimers_[Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors

Low-Flow Statistics Flow Report_[Low Flow Region 1]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.175	ft ³ /s
30 Day 2 Year Low Flow	0.19	ft ³ /s
7 Day 10 Year Low Flow	0.0954	ft ³ /s
30 Day 10 Year Low Flow	0.108	ft ³ /s

Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	0.27	square miles
BSLOPD	Mean basin slope measured in degrees	9.1	degrees
ROCKDEP	Depth to rock	5.2	feet
URBAN	Percentage of basin with urban development	0	percent

Low-Flow Statistics Parameters_[Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	0.27	square miles	4.78	1150
BSLOPD	Mean Basin Slope degrees	9.1	degrees	1.7	6.4
ROCKDEP	Depth to Rock	5.2	feet	4.13	5.21
URBAN	Percent Urban	0	percent	0	89

Low-Flow Statistics Disclaimers_[Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors

Low-Flow Statistics Flow Report_[Low Flow Region 1]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.179	ft ³ /s
30 Day 2 Year Low Flow	0.195	ft ³ /s
7 Day 10 Year Low Flow	0.0975	ft ³ /s
30 Day 10 Year Low Flow	0.11	ft ³ /s
90 Day 10 Year Low Flow	0.124	ft ³ /s

rptEffLimits
—
□
✕

WGM 7.0 Effluent Limits

WPF: 8017 System Code: 8017 Name: T&S 8017 to Possum Creek

WPF	Name	Permit Number	Discharge Point	Eff. Limit 30-day Ave. (mg/L)	Eff. Limit Maximum (mg/L)	Eff. Limit Minimum (mg/L)
0130	Possum Valley	PA0247154	0001 CROOK	25	30	20
			0002 N	25	30	20
			Discharge Oxygen			5

Filedy, June 10, 2020
Version: 105a
Page 1 of 1

Page: 1 | No Filter

rpt_WLA
—
□
✕

WGM 7.0 Wasteload Allocations

WPF: 8017 Name: T&S 8017 to Possum Creek

WPF	Discharge Name	Effluent Concentration (mg/L)	Effluent WLA (mg/L)	Multiple Effluent WLA (mg/L)	Multiple Effluent WLA (mg/L)	Critical Reach	Percent Reduction
0130	Possum Valley	500	50	500	50	0	0

WPF	Discharge Name	Effluent Concentration (mg/L)	Effluent WLA (mg/L)	Multiple Effluent WLA (mg/L)	Multiple Effluent WLA (mg/L)	Critical Reach	Percent Reduction
0130	Possum Valley	180	20	180	20	0	0

WPF	Discharge Name	Effluent Concentration (mg/L)	Effluent WLA (mg/L)	Multiple Effluent WLA (mg/L)	Multiple Effluent WLA (mg/L)	Critical Reach	Percent Reduction
0130	Possum Valley	25	25	25	25	0	0

Filedy, June 10, 2020
Version: 105a
Page 1 of 1

Page: 1 | No Filter

rptDOSim

WQM 7.0 D.O. Simulation

WQM Rule	Stream Code	Stream Name
07P	007	T41.08 07 W02possum Creek

WQM Rule	Stream Code	Stream Name	WQM Rule	Stream Code	Stream Name
07P	007	T41.08 07 W02possum Creek	07P	007	T41.08 07 W02possum Creek

Substrate Reaction

Substrate	Reaction Rate	Reaction Order	Reaction Unit
0000	0.00	0.00	0.00
0001	0.00	0.00	0.00
0002	0.00	0.00	0.00
0003	0.00	0.00	0.00
0004	0.00	0.00	0.00
0005	0.00	0.00	0.00
0006	0.00	0.00	0.00
0007	0.00	0.00	0.00

Friday, June 13, 2020 Version 1.0b Page 1 of 1

Page: 1 No Filter

rptModelSpecs

WQM 7.0 Modeling Specifications

Parameter	Value	Use Specified Q1-10 and Q20-10 Plots
W.S. Method	EMPR	<input type="checkbox"/>
Q1-10 Q20-10 Ratio	0.66	<input type="checkbox"/>
Q20-10 Q27-10 Ratio	1.36	<input type="checkbox"/>
Q1-10 Ratio	0.02%	<input checked="" type="checkbox"/>
Q2-10 Ratio	0	<input checked="" type="checkbox"/>

Friday, June 13, 2020 Version 1.0b Page 1 of 1

Page: 1 No Filter

rptHydro

WQM 7.0 Hydrodynamic Outputs

WQM Rule	Stream Code	Stream Name
07P	007	T41.08 07 W02possum Creek

Flow	Flow Rate	Flow Velocity	Flow Depth	Flow Width	Flow Area	Flow Slope	Flow Friction	Flow Velocity	Flow Depth	Flow Width	Flow Area	Flow Slope	Flow Friction
Q7-10 Flow	0.12	0.12	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Q1-10 Flow	0.12	0.06	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Q26-10 Flow	0.12	0.12	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Friday, June 13, 2020 Version 1.0b Page 1 of 1

Page: 1 No Filter

rptGeneral

Input Data WQM 7.0

WQM Rule	Stream Code	Stream Name	RSS	Flow Rate	Flow Velocity	Flow Depth	Flow Width	Flow Area	Flow Slope	Flow Friction	Flow Velocity	Flow Depth	Flow Width	Flow Area	Flow Slope	Flow Friction
07P	007	T41.08 07 W02possum Creek	6.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Design Curve	Flow Rate	Flow Velocity	Flow Depth	Flow Width	Flow Area	Flow Slope	Flow Friction
Q7-10	0.12	0.12	0.00	0.00	0.00	0.00	0.00
Q1-10	0.12	0.06	0.00	0.00	0.00	0.00	0.00
Q26-10	0.12	0.12	0.00	0.00	0.00	0.00	0.00

Parameter Name	Value	Unit
Chlorine	0.00	mg/L
Dissolved Oxygen	0.00	mg/L
NH3-N	0.00	mg/L

Friday, June 13, 2020 Version 1.0b Page 1 of 1

Page: 1 No Filter

