



Application Type  
Facility Type  
Major / Minor

Renewal  
Industrial  
Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL INDUSTRIAL WASTE (IW)  
AND IW STORMWATER**

Application No. PA0247201  
APS ID 488519  
Authorization ID 1460256

**Applicant and Facility Information**

Applicant Name	<u>City of Lancaster</u>	Facility Name	<u>Susquehanna Water Treatment Plant</u>
Applicant Address	<u>120 N Duke Street, PO Box 1599</u>	Facility Address	<u>900 S 15th Street</u>
	<u>Lancaster, PA 17608-1599</u>		<u>Columbia, PA 17512</u>
Applicant Contact	<u>Jeremy Brumbach</u>	Facility Contact	<u>Jeremy Brumbach</u>
Applicant Phone	<u>(717) 844-4463</u>	Facility Phone	<u>(717) 844-4463</u>
Client ID	<u>210852</u>	Site ID	<u>618478</u>
SIC Code	<u>4941</u>	Municipality	<u>West Hempfield Township</u>
SIC Description	<u>Trans. &amp; Utilities - Water Supply</u>	County	<u>Lancaster</u>
Date Application Received	<u>October 31, 2023</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>November 8, 2023</u>	If No, Reason	
Purpose of Application	<u>NPDES Renewal.</u>		

**Summary of Review**

City of Lancaster has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of its National Pollutant Discharge Elimination System (NPDES) permit. The existing permit was issued April 30, 2019, and became effective on May 1, 2019, authorizing discharge of treated industrial wastewater from the facility into Strickler Run. The existing permit expiration date was April 30, 2024, and the permit has been administratively extended since that time.

Changes in this renewal: Dissolved Iron monitoring has been added to the permit.

Sludge use and disposal description and location(s): Land application

Supplemental information for this facility is provided at the end of this fact sheet.

**Public Participation**

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Benjamin R. Lockwood Benjamin R. Lockwood / Environmental Engineering Specialist	January 22, 2025
X		Maria D. Bebeneck for Daniel W. Martin, P.E. / Environmental Engineer Manager	January 28, 2025

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	2.2
Latitude	40° 1' 25"	Longitude	76° 28' 50"
Quad Name		Quad Code	
Wastewater Description:	Water Treatment Effluent		
Receiving Waters	Strickler Run (WWF)	Stream Code	7875
NHD Com ID	57465349	RMI	1.52
Drainage Area	5.75 mi <sup>2</sup>	Yield (cfs/mi <sup>2</sup> )	
Q <sub>7-10</sub> Flow (cfs)	0.901	Q <sub>7-10</sub> Basis	USGS PA StreamStats
Elevation (ft)	263	Slope (ft/ft)	
Watershed No.	7-G	Chapter 93 Class.	WWF
Existing Use	N/A	Existing Use Qualifier	N/A
Exceptions to Use	N/A	Exceptions to Criteria	N/A
Assessment Status	Impaired		
Cause(s) of Impairment	Siltation, Cause Unknown		
Source(s) of Impairment	Agriculture, Urban Runoff/Storm Sewers		
TMDL Status	N/A	Name	N/A
Nearest Downstream Public Water Supply Intake	Safe Harbor Dam Power Plant		
PWS Waters	Susquehanna River	Flow at Intake (cfs)	
PWS RMI		Distance from Outfall (mi)	11

Changes Since Last Permit Issuance: USGS PA StreamStats provided a drainage area of 5.75 mi<sup>2</sup> and a Q<sub>7-10</sub> of 0.901 cfs at the point of discharge.

Other Comments: The City of Lancaster operates a water treatment plant that withdraws 26 million gallons per day (mgd) of water from the Susquehanna River. The treatment plant was upgraded to a membrane treatment system. The membrane system backwashes to a clarifier, which discharges effluent to Strickler Run. Settled solids are sent to a centrifuge, and then land applied.

<b>Compliance History</b>	
<b>Summary of DMRs:</b>	A summary of the past 12-month DMR effluent data is presented on the next page of this fact sheet.
<b>Summary of Inspections:</b>	<p>7/16/2020: An administrative inspection was conducted. The facility was operating normally, and all treatment units were online and operable. There were no outstanding issues at the facility at the time of inspection.</p> <p>3/11/2024: An incident response inspection was conducted. On 3/11, approximately 55 gallons of sodium hypochlorite spilled as a result of an open isolation valve while cleaning was being performed on the inline strainers for the sodium hypochlorite pumps. The spilled material was directed to the containment pit via floor drains. An open valve in the containment pit allowed the sodium hypochlorite to enter the WTP's EQ tank where it was pumped to the clarifier before discharging to Strickler Run. Maintenance staff neutralized the sodium hypochlorite in the tanks with sodium bisulfite. At the time of DEP inspection, approximately 40 dead fish were observed along the stream bank, and a slightly turbid discharge was observed.</p> <p>4/12/2024: A Notice of Violation (NOV) was issued due to the fish kill that occurred on 3/11/24.</p> <p>5/16/2024: A routine inspection was conducted. At the time of inspection, the EQ tank and rapid mix tank had a light brown appearance. The clarifiers were clear. A clear discharge from Outfall 001 was observed and no concerns were noted. Field testing results were within permitted limits.</p>

Other Comments: There are currently no open violations for this Applicant.

Compliance History

DMR Data for Outfall 001 (from August 1, 2023 to July 31, 2024)

Parameter	JUL-24	JUN-24	MAY-24	APR-24	MAR-24	FEB-24	JAN-24	DEC-23	NOV-23	OCT-23	SEP-23	AUG-23
Flow (MGD)				1.23177								
Average Monthly	1.45594	1.4722	1.36819	7	1.28352	1.34938	1.28903	1.26365	1.2634	1.20945	1.46137	1.42245
Flow (MGD)												
Daily Maximum	1.579	1.644	1.498	1.504	1.468	1.492	1.475	1.513	1.499	1.460	1.721	1.692
pH (S.U.)												
Instantaneous Minimum	7.3	7.1	6.9	7.0	6.2	6.7	6.4	6.8	7.0	6.8	7.3	7.2
pH (S.U.)												
Instantaneous Maximum	7.6	7.6	7.6	7.7	7.6	7.6	7.3	7.6	7.6	7.6	7.6	7.6
TRC (lbs/day)												
Average Monthly	0.38516 5384	0.36698 02	0.44146 045	0.43602 898	0.44049 694	0.49202 763	0.42539 728	0.40115 435	0.40625 048	0.32782 186	0.49834 552	0.49799 562
TRC (mg/L)												
Average Monthly	0.032	0.030	0.039	0.042	0.0412	0.04	0.040	0.038	0.04	0.033	0.041	0.042
TRC (mg/L)												
Instantaneous Maximum	0.09	0.09	0.09	0.09	0.357	0.09	0.09	0.09	0.09	0.08	0.09	0.08
TSS (lbs/day)												
Average Monthly	< 60.7125 0968	< 53.7168 975	< 115.248 4154	101.445 2233	73.5936 0605	< 66.7737 0538	< 83.3166 7405	66.1309 872	65.3278 0581	< 40.3473 0581	< 67.9469 7385	< 62.8752 0619
TSS (lbs/day)												
Daily Maximum	92.074	68.5548	178.392 6	148.752 24	114.591 6	120.271 14	129.766 23	92.0861 1	105.834 6	< 48.7056	< 98.7039	104.750 4
TSS (mg/L)												
Average Monthly	< 5	< 4.38	< 10.10	9.88	6.9	< 6.20	< 7.75	6.3	< 6.20	< 4.0	< 5.58	< 5.30
TSS (mg/L)												
Daily Maximum	8	5.0	15.0	14.0	10.0	11.0	11.5	8.5	10.8	< 4.0	7.5	8.0
Total Aluminum (lbs/day)												
Average Monthly	6.49927 4161	4.46617 6335	6.10702 494	7.09602 9161	5.99720 986	5.38833 0667	8.28865 7884	< 3.50415 1215	11.7669 2226	4.99045 7387	8.23285 7549	6.25667 6179
Total Aluminum (lbs/day)												
Daily Maximum	9.87	5.97784 88	10.1207 5	12.0291 42	11.9175 26	8.76888 57	16.3618 29	5.55761 4	18.0315 5	6.91616 6	12.0183 74	7.23120 23
Total Aluminum (mg/L)												
Average Monthly	0.535	0.364	0.535	0.691	0.5603	0.4788	0.7710	< 0.3325	1.12	0.4975	0.676	0.5274
Total Aluminum (mg/L)												
Daily Maximum	0.75	0.483	0.851	0.959	1.04	0.802	1.45	0.513	1.84	0.568	0.883	0.618

NPDES Permit Fact Sheet  
Susquehanna Water Treatment Plant

NPDES Permit No. PA0247201

Total Iron (lbs/day) Average Monthly	< 2.15529 4094	< 2.01975 5346	< 3.03297 3149	3.91912 4321	3.00261 9127	2.89676 4743	3.60142 7226	< 1.88908 0016	2.43662 4825	< 1.45754 6422	2.31872 857	< 1.47104 256
Total Iron (lbs/day) Daily Maximum	3.856	4.25654 18	5.17699 68	8.24101 76	5.11073 04	5.32415 76	4.94670 56	2.99003 82	3.62581 5	2.64230 8	3.37546 56	1.94231 32
Total Iron (mg/L) Average Monthly	< 0.178	< 0.165	< 0.266	0.382	0.281	0.2654	0.335	< 0.179	0.231	< 0.145	0.190	< 0.124
Total Iron (mg/L) Daily Maximum	0.293	0.336	0.424	0.657	0.446	0.487	0.527	0.276	0.370	0.217	0.248	0.166
Total Manganese (lbs/day) Average Monthly	< 0.0375	4.79768 6331	0.67779 7611	0.82440 295	0.45494 2292	0.66172 4819	0.48108 6174	0.36885 8023	< 0.12380 6883	< 0.12356 3624	< 0.15234 7475	< 0.14710 4256
Total Manganese (lbs/day) Daily Maximum	0.5524	14.3153 6	0.87660 92	1.47694 82	0.63364 7	1.03870 53	0.57543 09	0.75835 62	0.18035 68	0.17915 62	0.21770 88	0.23310 53
Total Manganese (mg/L) Average Monthly	< 0.0375	0.391	0.0594	0.0803	0.0425	0.05880	0.0448	0.035	< 0.01175	< 0.01225	< 0.01250 0	< 0.012
Total Manganese (mg/L) Daily Maximum	0.048	1.13	0.082	0.139	0.058	0.095	0.051	0.07	0.016	0.016	0.016	0.018

Compliance History

Effluent Violations for Outfall 001, from: September 1, 2023 To: July 31, 2024

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
TRC	03/31/24	IMAX	0.357	mg/L	.16	mg/L
Total Aluminum	11/30/23	Avg Mo	1.12	mg/L	.75	mg/L
Total Aluminum	01/31/24	Avg Mo	0.7710	mg/L	.75	mg/L
Total Aluminum	11/30/23	Daily Max	1.84	mg/L	1.5	mg/L

**Existing Effluent Limitations and Monitoring Requirements**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day)		Concentrations (mg/L)				Minimum Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
Total Residual Chlorine (TRC)	0.9	XXX	XXX	0.05	XXX	0.16	1/day	Grab
Total Suspended Solids	Report	Report	XXX	30	60	75	1/week	8-Hr Composite
Aluminum, Total	13.6	27.3	XXX	0.75	1.5	1.9	1/week	8-Hr Composite
Iron, Total	34.5	69.1	XXX	1.9	3.8	4.8	1/week	8-Hr Composite
Manganese, Total	Report	Report	XXX	1.0	2.0	2.5	1/week	8-Hr Composite

Samples taken in compliance with the monitoring requirements specified above shall be taken at the following location(s):

at Outfall 001

Development of Effluent Limitations			
Outfall No.	001	Design Flow (MGD)	2.2
Latitude	40° 1' 25"	Longitude	76° 28' 50"
Wastewater Description: Water Treatment Effluent			

### pH

PA Code 95.2(1) requires effluent pH limits of not less than 6.0 and not greater than 9.0 at all times in the effluent. The permit will continue to require pH limits of 6.0 to 9.0 SU.

### Toxics

Effluent sample results for toxic pollutants reported on the renewal application were entered into DEP's Toxics Management Spreadsheet Version 1.3 to develop appropriate permit requirements for toxic pollutants of concern. The Toxics Management Spreadsheet combines the functions of PENTOXSD and DEP's Toxics Screening Analysis. Based on effluent sample results reported on the application, limits are necessary for Total Aluminum, and monitoring is required for Dissolved Iron, Total Iron, and Total Manganese. Default stream pH and hardness inputs were used for this model run. This data was analyzed based on the guidelines found in DEP's Water Quality Toxics Management Strategy (Document No. 361-0100-003) and DEP's SOP No. BPNPSM-PMT-033. Spreadsheet results are attached to this fact sheet. The Toxics Management Spreadsheet uses the following logic:

- a. Establish average monthly and IMAX limits in the draft permit where the maximum reported concentration exceeds 50% of the WQBEL.
- b. For non-conservative pollutants, establish monitoring requirements where the maximum reported concentration is between 25% - 50% of the WQBEL.
- c. For conservative pollutants, establish monitoring requirements where the maximum reported concentration is between 10%-50% of the WQBEL.

Since the reported maximum concentration was greater than 50% of the respective WQBEL, per DEP's SOP No. BPNPSM-PMT-033, limits are required for Total Aluminum. The WQBEL developed for Total Aluminum was an average monthly of 0.75 mg/l, which is the same as the existing permit limit. Limits are already imposed in the existing permit for Total Iron and Total Manganese, which will remain in the renewal. Dissolved Iron monitoring will be added to the permit, with the same sample type and frequency of the other parameters.

### Total Dissolved Solids

DEP's SOP No. BPNPSM-PMT-032 recommends monitoring for TDS when the discharge concentrations exceed 1,000 mg/l. The maximum effluent sampling result reported in the application for TDS is 203 mg/l. Based upon this data, TDS monitoring will not be required as part of the renewal.

### Chesapeake Bay Total Maximum Daily Load (TMDL)

DEP developed a strategy to comply with the EPA and Chesapeake Bay Foundation requirements by reducing point source loadings of Total Nitrogen (TN) and Total Phosphorus (TP). This strategy can be located in the *Pennsylvania Chesapeake Watershed Implementation Plan* (WIP), dated January 11, 2011. Subsequently, an update to the WIP was published as the Phase 2 WIP. As part of the Phase 2 WIP, a *Phase 2 Watershed Implementation Plan Wastewater Supplement* (Phase 2 Supplement) was developed, providing an update on TMDL implementation for point sources and DEP's current implementation strategy for wastewater. A new update to the WIP was published as the Phase 3 WIP in August 2019. As part of the Phase 3 WIP, a *Phase 3 Watershed Implementation Plan Wastewater Supplement* (Phase 3 Supplement) was developed, and was most recently revised on July 29, 2022, and is the basis for the development of any Chesapeake Bay related permit parameters. Significant industrial wastewater dischargers are facilities that discharge more than 75 lbs/day of TN or 25 lbs/day of TP on an average annual basis and the rest are classified as non-significant dischargers. This facility is classified as a non-significant discharger with little or no potential to introduce nutrients to the receiving stream; therefore, no monitoring for TP and TN series will be required at this time.

### Total Residual Chlorine

The attached computer printout utilizes the equations and calculations as presented in the Department's May 1, 2003 Implementation Guidance for Total Residual Chlorine (TRC) (ID No. 391-2000-015) for developing chlorine limitations. The

Guidance references Chapter 92, Section 92.2d (3) which establishes a standard BAT limit of 0.5 mg/l unless a facility-specific BAT has been developed. The attached printout indicates that a water quality limit of 0.05 mg/l monthly average and 0.16 mg/l instantaneous maximum would be needed to prevent toxicity concerns. This is consistent with the existing permit limits.

**Anti-Degradation**

The effluent limits for this discharge have been developed to ensure that existing instream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High Quality Waters are impacted by this discharge. No Exceptional Value Waters are impacted by this discharge.

**303(d) Listed Streams**

The discharge is located on a stream segment that is designated on the 303(d) list as impaired. There is an aquatic life impairment for siltation due to agriculture and an unknown cause due to urban runoff/storm sewers.

**Class A Wild Trout Fisheries**

No Class A Wild Trout Fisheries are impacted by this discharge.

**Anti-Backsliding**

Pursuant to 40 CFR § 122.44(l)(1), all proposed permit requirements addressed in this fact sheet are at least as stringent as the requirements implemented in the existing

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
TRC	0.9	XXX	XXX	0.05	XXX	0.16	1/day	Grab
TSS	Report	Report	XXX	30	60	75	1/week	8-Hr Composite
Dissolved Iron	XXX	XXX	XXX	XXX	Report	XXX	1/week	8-Hr Composite
Total Aluminum	13.6	27.3	XXX	0.75	1.5	1.9	1/week	8-Hr Composite
Total Iron	34.5	69.1	XXX	1.9	3.8	4.8	1/week	8-Hr Composite
Total Manganese	Report	Report	XXX	1.0	2.0	2.5	1/week	8-Hr Composite

Compliance Sampling Location: Outfall 001

Other Comments: None

Tools and References Used to Develop Permit	
<input type="checkbox"/>	WQM for Windows Model (see Attachment [REDACTED])
<input checked="" type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input checked="" type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input checked="" type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: BCW-PMT-032
<input type="checkbox"/>	Other: [REDACTED]


City of Lancaster Susquehanna Water Treatment Plant PA0247201 Outfall 001

Region ID: PA

Workspace ID: PA20240925154258023000

Clicked Point (Latitude, Longitude): 40.02395, -76.47997

Time: 2024-09-25 11:43:25 -0400



[Collapse All](#)

► Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
BSLOPD	Mean basin slope measured in degrees	4.4248	degrees
DRNAREA	Area that drains to a point on a stream	5.75	square miles
ROCKDEP	Depth to rock	5.1	feet
URBAN	Percentage of basin with urban development	11.5078	percent

► Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	5.75	square miles	4.78	1150
BSLOPD	Mean Basin Slope degrees	4.4248	degrees	1.7	6.4
ROCKDEP	Depth to Rock	5.1	feet	4.13	5.21
URBAN	Percent Urban	11.5078	percent	0	89

Low-Flow Statistics Flow Report [Low Flow Region 1]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR<sup>2</sup>: Pseudo R Squared (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	1.79	ft <sup>3</sup> /s	46	46
30 Day 2 Year Low Flow	2.26	ft <sup>3</sup> /s	38	38
7 Day 10 Year Low Flow	0.901	ft <sup>3</sup> /s	51	51
30 Day 10 Year Low Flow	1.16	ft <sup>3</sup> /s	46	46

Statistic	Value	Unit	SE	ASEp
90 Day 10 Year Low Flow	1.74	ft <sup>3</sup> /s	41	41

*Low-Flow Statistics Citations*

**Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)**

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.24.0

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1

City of Lancaster Susquehanna Water Treatment Plant RMI = 0.0

Region ID: PA

Workspace ID: PA20240925154524363000

Clicked Point (Latitude, Longitude): 40.01777, -76.49761

Time: 2024-09-25 11:45:52 -0400



[Collapse All](#)

► Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
BSLOPD	Mean basin slope measured in degrees	4.6024	degrees
DRNAREA	Area that drains to a point on a stream	6.05	square miles
ROCKDEP	Depth to rock	5.1	feet
URBAN	Percentage of basin with urban development	11.9889	percent

► Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	6.05	square miles	4.78	1150
BSLOPD	Mean Basin Slope degrees	4.6024	degrees	1.7	6.4
ROCKDEP	Depth to Rock	5.1	feet	4.13	5.21
URBAN	Percent Urban	11.9889	percent	0	89

Low-Flow Statistics Flow Report [Low Flow Region 1]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR<sup>2</sup>: Pseudo R Squared (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	2	ft <sup>3</sup> /s	46	46
30 Day 2 Year Low Flow	2.5	ft <sup>3</sup> /s	38	38
7 Day 10 Year Low Flow	1.02	ft <sup>3</sup> /s	51	51
30 Day 10 Year Low Flow	1.3	ft <sup>3</sup> /s	46	46

Statistic	Value	Unit	SE	ASEp
90 Day 10 Year Low Flow	1.92	ft <sup>3</sup> /s	41	41

*Low-Flow Statistics Citations*

**Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)**

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.24.0

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1

TRC\_CALC

1A	B	C	D	E	F	G
<b>2 TRC EVALUATION</b>						
3 Input appropriate values in B4:B8 and E4:E7						
4	0.901	= Q stream (cfs)		0.5	= CV Daily	
5	2.2	= Q discharge (MGD)		0.5	= CV Hourly	
6	30	= no. samples		1	= AFC_Partial Mix Factor	
7	0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor	
8	0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)	
9	0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)	
	0	= % Factor of Safety (FOS)			= Decay Coefficient (K)	
10	Source	Reference	AFC Calculations	Reference	CFC Calculations	
11	TRC	1.3.2.III	WLA_afc = 0.103	1.3.2.III	WLA_cfc = 0.093	
12	PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581	
13	PENTOXSD TRG	5.1b	LTA_afc = 0.039	5.1d	LTA_cfc = 0.054	
14	15 Source Effluent Limit Calculations					
16	PENTOXSD TRG	5.1f	AML MULT = 1.231			
17	PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.047	AFC		
18			INST MAX LIMIT (mg/l) = 0.155			
<p>WLA_afc      <math>(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))...\\ ...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)</math></p> <p>LTAMULT_afc      <math>EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)</math></p> <p>LTA_afc      <math>wla_afc*LTAMULT_afc</math></p> <p>WLA_cfc      <math>(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))...\\ ...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)</math></p> <p>LTAMULT_cfc      <math>EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)</math></p> <p>LTA_cfc      <math>wla_cfc*LTAMULT_cfc</math></p> <p>AML MULT      <math>EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))</math></p> <p>AVG MON LIMIT      <math>MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)</math></p> <p>INST MAX LIMIT      <math>1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)</math></p>						



## Discharge Information

Instructions **Discharge** Stream

Facility: **Susquehanna Water Treatment Plant** NPDES Permit No.: **PA0247201** Outfall No.: **001**

Evaluation Type: **Major Sewage / Industrial Waste** Wastewater Description: **Water Treatment Effluent**

Discharge Characteristics						
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)			Complete Mix Times (min)
			AFC	CFC	THH	
2.2	80	7.9				

			0 if left blank		0.5 if left blank		0 if left blank		1 if left blank		
			Trib Conc	Stream Conc	Daily CV	Hourly CV	Strea m CV	Fate Coeff	FOS	Criteri a Mod	Chem Transl
<b>Group 1</b>	Total Dissolved Solids (PWS)	mg/L	203								
	Chloride (PWS)	mg/L	57.2								
	Bromide	mg/L	< 1								
	Sulfate (PWS)	mg/L	34.5								
	Fluoride (PWS)	mg/L	< 0.2								
<b>Group 2</b>	Total Aluminum	µg/L	1270								
	Total Antimony	µg/L	< 0.4								
	Total Arsenic	µg/L	< 1								
	Total Barium	µg/L	29								
	Total Beryllium	µg/L	< 0.4								
	Total Boron	µg/L	< 50								
	Total Cadmium	µg/L	< 0.1								
	Total Chromium (III)	µg/L	< 1								
	Hexavalent Chromium	µg/L	0.33								
	Total Cobalt	µg/L	< 1								
	Total Copper	µg/L	< 2								
	Free Cyanide	µg/L									
	Total Cyanide	µg/L									
	Dissolved Iron	µg/L	69								
	Total Iron	µg/L	214								
	Total Lead	µg/L	< 1								
	Total Manganese	µg/L	597								
	Total Mercury	µg/L	< 0.2								
	Total Nickel	µg/L	2								
	Total Phenols (Phenolics) (PWS)	µg/L	< 5								
	Total Selenium	µg/L	< 2								
	Total Silver	µg/L	< 0.2								
	Total Thallium	µg/L	< 0.4								
	Total Zinc	µg/L	< 10								
	Total Molybdenum	µg/L									
	Acrolein	µg/L	<								
	Acrylamide	µg/L	<								
	Acrylonitrile	µg/L	<								
	Benzene	µg/L	<								
	Bromoform	µg/L	<								







## Stream / Surface Water Information

Instructions   **Discharge**   Stream

Susquehanna Water Treatment Plant, NPDES Permit No. PA0247201, Outfall 001

Toxics Management Spreadsheet  
Version 1.4, May 2023

Receiving Surface Water Name:

No. Reaches to Model: 1

- Statewide Criteria
- Great Lakes Criteria
- ORSANC0 Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi <sup>2</sup> )*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	007875	1.52	263	5.75			Yes
End of Reach 1	007875	0	227	6.05			Yes

Q<sub>7-10</sub>

Location	RMI	LFY (cfs/mi <sup>2</sup> )*	Flow (cfs)	W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary	Stream	Analysis
Point of Discharge	1.52	0.1	0.901						Hardness	pH*	Hardness
End of Reach 1	0	0.1	1.02						100	7	100

Q<sub>h</sub>

Location	RMI	LFY (cfs/mi <sup>2</sup> )*	Flow (cfs)	W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary	Stream	Analysis
Point of Discharge	1.52								Hardness	pH	Hardness
End of Reach 1	0								100	7	100



## Model Results

Susquehanna Water Treatment Plant, NPDES Permit No. PA0247201, Outfall 001

<input type="button" value="Instructions"/>	<input checked="" type="button" value="Results"/>	<input type="button" value="RETURN TO INPUTS"/>	<input type="button" value="SAVE AS PDF"/>	<input type="button" value="PRINT"/>
---	---	---	--	--------------------------------------

Hydrodynamics

Wasteload Allocations

Pollutants	Stream		Trib Conc ( $\mu\text{g/L}$ )	Fate Coef	WQC ( $\mu\text{g/L}$ )	WLA ( $\mu\text{g/L}$ )	Comments
	Conc ( $\mu\text{g/L}$ )	CV					
Total Dissolved Solids (PWS)	0	0	0	0	N/A	N/A	
Chloride (PWS)	0	0	0	0	N/A	N/A	
Sulfate (PWS)	0	0	0	0	N/A	N/A	
Fluoride (PWS)	0	0	0	0	N/A	N/A	
Total Aluminum	0	0	0	0	750	949	
Total Antimony	0	0	0	0	1,100	1,391	
Total Arsenic	0	0	0	0	340	430	Chem Translator of 1 applied
Total Barium	0	0	0	0	21,000	26,559	
Total Boron	0	0	0	0	8,100	10,244	
Total Cadmium	0	0	0	0	1,703	1,79	2.26 Chem Translator of 0.951 applied
Total Chromium (III)	0	0	0	0	494.843	1,566	1.981 Chem Translator of 0.316 applied
Hexavalent Chromium	0	0	0	0	16	16.3	20.6 Chem Translator of 0.982 applied
Total Cobalt	0	0	0	0	95	95.0	120 Chem Translator of 0.96 applied
Total Copper	0	0	0	0	11,427	11.9	15.1 Chem Translator of 0.816 applied
Dissolved Iron	0	0	0	0	N/A	N/A	
Total Iron	0	0	0	0	N/A	N/A	
Total Lead	0	0	0	0	53.518	65.6	82.9 Chem Translator of 0.85 applied
Total Manganese	0	0	0	0	N/A	N/A	
Total Mercury	0	0	0	0	1,400	1,65	2.08 Chem Translator of 0.85 applied
Total Nickel	0	0	0	0	404.780	406	513 Chem Translator of 0.998 applied
Total Phenols (Phenolics) (PWS)	0	0	0	0	N/A	N/A	
Total Selenium	0	0	0	0	N/A	N/A	Chem Translator of 0.922 applied
Total Silver	0	0	0	0	2,392	2,81	3.56 Chem Translator of 0.85 applied
Total Thallium	0	0	0	0	65	65.0	82.2 Chem Translator of 0.978 applied
Total Zinc	0	0	0	0	101,277	104	131 Chem Translator of 0.978 applied

**CFC** CCT (min): **0.852** PMF: **1** Analysis Hardness (mg/l): **84.186** Analysis pH: **7.51**

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQA Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0	0	0	N/A	N/A	N/A	
Chloride (PWS)	0	0	0	0	N/A	N/A	N/A	
Sulfate (PWS)	0	0	0	0	N/A	N/A	N/A	
Fluoride (PWS)	0	0	0	0	N/A	N/A	N/A	
Total Aluminum	0	0	0	0	N/A	N/A	N/A	
Total Antimony	0	0	0	0	220	220	278	
Total Arsenic	0	0	0	0	150	150	190	Chem Translator of 1 applied
Total Barium	0	0	0	0	4,100	4,100	5,185	
Total Boron	0	0	0	0	1,600	1,600	2,024	
Total Cadmium	0	0	0	0.218	0.24	0.3	Chem Translator of 0.916 applied	
Total Chromium (III)	0	0	0	64.369	74.8	94.7	Chem Translator of 0.86 applied	
Hexavalent Chromium	0	0	0	0	10	10.4	13.1	Chem Translator of 0.962 applied
Total Cobalt	0	0	0	0	19	19.0	24.0	
Total Copper	0	0	0	7.731	8.05	10.2	Chem Translator of 0.96 applied	
Dissolved Iron	0	0	0	N/A	N/A	N/A	N/A	
Total Iron	0	0	0	1,500	1,500	1,897	WQC = 30 day average; PMF = 1	
Total Lead	0	0	0	2.086	2.56	3.23	Chem Translator of 0.816 applied	
Total Manganese	0	0	0	N/A	N/A	N/A	N/A	
Total Mercury	0	0	0	0.770	0.91	1.15	Chem Translator of 0.85 applied	
Total Nickel	0	0	0	44.959	45.1	57.0	Chem Translator of 0.997 applied	
Total Phenols (Phenolics) (PWS)	0	0	0	N/A	N/A	N/A	N/A	
Total Selenium	0	0	0	4,600	4.99	6.31	Chem Translator of 0.922 applied	
Total Silver	0	0	0	N/A	N/A	N/A	Chem Translator of 1 applied	
Total Thallium	0	0	0	0	13	13.0	16.4	
Total Zinc	0	0	0	102,106	104	131	Chem Translator of 0.986 applied	

**THH** CCT (min): **0.852** PMF: **1** Analysis Hardness (mg/l): **N/A** Analysis pH: **N/A**

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQA Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0	0	0	500,000	500,000	N/A	
Chloride (PWS)	0	0	0	0	250,000	250,000	N/A	
Sulfate (PWS)	0	0	0	0	250,000	250,000	N/A	
Fluoride (PWS)	0	0	0	0	2,000	2,000	N/A	
Total Aluminum	0	0	0	0	N/A	N/A	N/A	
Total Antimony	0	0	0	0	5.6	5.6	7.08	
Total Arsenic	0	0	0	0	10	10.0	12.6	
Total Barium	0	0	0	0	2,400	2,400	3,035	
Total Boron	0	0	0	0	3,100	3,100	3,921	
Total Cadmium	0	0	0	0	N/A	N/A	N/A	
Total Chromium (III)	0	0	0	0	N/A	N/A	N/A	

Hexavalent Chromium	0	0	0	0	N/A	N/A	N/A
Total Cobalt	0	0	0	0	N/A	N/A	N/A
Total Copper	0	0	0	0	N/A	N/A	N/A
Dissolved Iron	0	0	0	0	300	300	379
Total Iron	0	0	0	0	N/A	N/A	N/A
Total Lead	0	0	0	0	N/A	N/A	N/A
Total Manganese	0	0	0	0	1,000	1,000	1,265
Total Mercury	0	0	0	0	0.050	0.05	0.063
Total Nickel	0	0	0	0	610	610	771
Total Phenols (Phenolics) (PWS)	0	0	0	0	5	5.0	N/A
Total Selenium	0	0	0	0	N/A	N/A	N/A
Total Silver	0	0	0	0	N/A	N/A	N/A
Total Thallium	0	0	0	0	0.24	0.24	0.3
Total Zinc	0	0	0	0	N/A	N/A	N/A

CRL CCT (min): 4,882

PMF: 1

Analysis Hardness (mg/l): N/A

Analysis pH: N/A

Pollutants	Stream	Conc ( $\mu\text{g/L}$ )	Stream CV	Trib Conc ( $\mu\text{g/L}$ )	Fate Coef	WQC ( $\mu\text{g/L}$ )	WQ Obj ( $\mu\text{g/L}$ )	WLA (µg/L)	Comments	
									WQ Coef	WLA (µg/L)
Total Dissolved Solids (PWS)	0	0	0	0	0	N/A	N/A	N/A		
Chloride (PWS)	0	0	0	0	0	N/A	N/A	N/A		
Sulfate (PWS)	0	0	0	0	0	N/A	N/A	N/A		
Fluoride (PWS)	0	0	0	0	0	N/A	N/A	N/A		
Total Aluminum	0	0	0	0	0	N/A	N/A	N/A		
Total Antimony	0	0	0	0	0	N/A	N/A	N/A		
Total Arsenic	0	0	0	0	0	N/A	N/A	N/A		
Total Barium	0	0	0	0	0	N/A	N/A	N/A		
Total Boron	0	0	0	0	0	N/A	N/A	N/A		
Total Cadmium	0	0	0	0	0	N/A	N/A	N/A		
Total Chromium (III)	0	0	0	0	0	N/A	N/A	N/A		
Hexavalent Chromium	0	0	0	0	0	N/A	N/A	N/A		
Total Cobalt	0	0	0	0	0	N/A	N/A	N/A		
Total Copper	0	0	0	0	0	N/A	N/A	N/A		
Dissolved Iron	0	0	0	0	0	N/A	N/A	N/A		
Total Iron	0	0	0	0	0	N/A	N/A	N/A		
Total Lead	0	0	0	0	0	N/A	N/A	N/A		
Total Manganese	0	0	0	0	0	N/A	N/A	N/A		
Total Mercury	0	0	0	0	0	N/A	N/A	N/A		
Total Nickel	0	0	0	0	0	N/A	N/A	N/A		
Total Phenols (Phenolics) (PWS)	0	0	0	0	0	N/A	N/A	N/A		
Total Selenium	0	0	0	0	0	N/A	N/A	N/A		
Total Silver	0	0	0	0	0	N/A	N/A	N/A		
Total Thallium	0	0	0	0	0	N/A	N/A	N/A		
Total Zinc	0	0	0	0	0	N/A	N/A	N/A		

## Recommended WQBELs & Monitoring Requirements

No. Samples/Month:

Pollutants	Mass Limits			Concentration Limits			Governing WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units		
Total Aluminum	13.8	17.4	750	949	949	µg/L	750	AFC
Dissolved Iron	Report	Report	Report	Report	Report	µg/L	379	THH
Total Iron	Report	Report	Report	Report	Report	µg/L	1,897	CFC
Total Manganese	Report	Report	Report	Report	Report	µg/L	1,265	THH

**Other Pollutants without Limits or Monitoring**

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g.,  $\leq$  Target QL).

Pollutants	Governing WQBEL	Units	Comments
Total Dissolved Solids (PWS)	N/A	N/A	PWS Not Applicable
Chloride (PWS)	N/A	N/A	PWS Not Applicable
Bromide	N/A	N/A	No WQS
Sulfate (PWS)	N/A	N/A	PWS Not Applicable
Fluoride (PWS)	N/A	N/A	Discharge Conc < TQL
Total Antimony	N/A	N/A	Discharge Conc < TQL
Total Arsenic	N/A	N/A	Discharge Conc < TQL
Total Barium	3,035	$\mu\text{g/L}$	Discharge Conc $\leq$ 10% WQBEL
Total Beryllium	N/A	N/A	No WQS
Total Boron	2,024	$\mu\text{g/L}$	Discharge Conc < TQL
Total Cadmium	0.3	$\mu\text{g/L}$	Discharge Conc < TQL
Total Chromium (III)	94.7	$\mu\text{g/L}$	Discharge Conc < TQL
Hexavalent Chromium	13.1	$\mu\text{g/L}$	Discharge Conc $\leq$ 10% WQBEL
Total Cobalt	24.0	$\mu\text{g/L}$	Discharge Conc < TQL
Total Copper	10.2	$\mu\text{g/L}$	Discharge Conc < TQL
Total Lead	3.23	$\mu\text{g/L}$	Discharge Conc < TQL
Total Mercury	0.063	$\mu\text{g/L}$	Discharge Conc < TQL
Total Nickel	57.0	$\mu\text{g/L}$	Discharge Conc $\leq$ 10% WQBEL
Total Phenols (Phenolics) (PWS)			
Total Selenium	6.31	$\mu\text{g/L}$	Discharge Conc < TQL
Total Silver	2.81	$\mu\text{g/L}$	Discharge Conc < TQL
Total Thallium	0.3	$\mu\text{g/L}$	Discharge Conc $\leq$ 10% WQBEL
Total Zinc	104	$\mu\text{g/L}$	