

Application Type  
Facility Type  
Major / Minor

Renewal  
Municipal  
Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0247391  
APS ID 507058  
Authorization ID 1497191

**Applicant and Facility Information**

Applicant Name	<u>North Codorus Township</u>	Facility Name	<u>North Codorus Township STP</u>
Applicant Address	<u>1986 Stoverstown Road</u>	Facility Address	<u>3923 Old Joseph Road</u>
	<u>Spring Grove, PA 17362-7804</u>		<u>York, PA 17408</u>
Applicant Contact	<u>Mark Derr</u>	Facility Contact	<u>Ryan Swope</u>
Applicant Phone	<u>(717) 225-4812</u>	Facility Phone	<u>(484) 653-9733</u>
Client ID	<u>86222</u>	Site ID	<u>459530</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>North Codorus Township</u>
Connection Status	<u>No Limitations</u>	County	<u>York</u>
Date Application Received	<u>August 28, 2024</u>	EPA Waived?	<u>No</u>
Date Application Accepted	<u>September 6, 2024</u>	If No, Reason	<u>Significant CB Discharge</u>
Purpose of Application	<u>Renewal of existing NPDES permit</u>		

**Summary of Review**

North Codorus Township has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of a NPDES permit for the North Codorus Township STP. The permit was last reissued on February 6, 2020 with an effective date of February 6, 2020. The permit expired on January 31, 2025, but the terms and conditions of the permit have been administratively extended since that time.

Based on the review outlined in this fact sheet, it is recommended that the permit be drafted, and a notice of the draft permit be published in the *Pennsylvania Bulletin* for public comments for 30 days.

Sludge use and disposal description and location(s): Springettsbury STP

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
x		<i>Aaron Baar</i> Aaron Baar / Project Manager	May 16, 2025
x		<i>Maria D. Bebeneck</i> for Daniel W. Martin, P.E. / Environmental Engineer Manager	June 30, 2025

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	.55
Latitude	39° 53' 42.99"	Longitude	-76° 48' 26.05"
Quad Name	1931	Quad Code	West York
Wastewater Description:	Sewage Effluent		
Receiving Waters	Unnamed Tributary to Codorus Creek (WWF)	Stream Code	08196
NHD Com ID	57470913	RMI	0.53
Drainage Area	4.02 mi <sup>2</sup>	Yield (cfs/mi <sup>2</sup> )	0.0116
Q <sub>7-10</sub> Flow (cfs)	0.0465	Q <sub>7-10</sub> Basis	USGS StreamStats
Elevation (ft)	430.72	Slope (ft/ft)	
Watershed No.	7-H	Chapter 93 Class.	WWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment			
Source(s) of Impairment			
TMDL Status		Name	
Background/Ambient Data		Data Source	
pH (SU)	7.0	Assumed, default value	
Temperature (°C)	25.0	WWF, default value	
Hardness (mg/L)	100	Assumed, default value	
Other: Ammonia (mg/L)	0.1	Assumed, default value	
Nearest Downstream Public Water Supply Intake		Wrightsville Water Supply Company	
PWS Waters	Susquehanna River	Flow at Intake (cfs)	
PWS RMI	43.54	Distance from Outfall (mi)	28.34

#### Drainage Area

The discharge is to a UNT to Codorus Creek at RMI 0.53. A drainage area upstream of the discharge is determined to be 4.02 sq.mi. according to USGS StreamStats available at <https://streamstats.usgs.gov/ss/>.

#### Stream Flow

According to StreamStats, the watershed has a Q<sub>7-10</sub> of 0.0465 cfs and a Q<sub>30-10</sub> of 0.0834 cfs. This information was used to obtain a Low Flow Yield (LFY), a chronic Q<sub>30-10</sub>:Q<sub>7-10</sub> ratio and acute (Q<sub>1-10</sub>) exposure stream flows for the discharge point as follows (Guidance No. 391-2000-023).

$$\begin{aligned}
 Q_{7-10} &= 0.0465 \text{ cfs} \\
 Q_{30-10} &= 0.0834 \text{ cfs} \\
 Q_{1-10} &= 0.64 \text{ cfs (default)}
 \end{aligned}$$

$$\begin{aligned}
 Q_{30-10}:Q_{7-10} &= 0.0834 \text{ cfs} / 0.0465 \text{ cfs} = 1.7935 \\
 \text{LFY} &= 0.0465 \text{ cfs} / 4.02 \text{ mi}^2 = 0.0116 \text{ cfs/mi}^2
 \end{aligned}$$

*UNT to Codorus Creek*

25 Pa Code §93.9 classifies the receiving water, UNT to Codorus Creek, with a Warm Water Fishery (WWF) Existing Use designation. Effluent limits for this discharge have been developed to ensure that existing in-stream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. The discharge is in a stream segment listed as attaining uses.

*Local Watershed Total Maximum Daily Loads (TMDLs)*

According to PA's 2024 Integrated Water Quality Monitoring and Assessment Report, UNT to Codorus Creek in the vicinity of the point of discharge is impaired for recreation due to an unknown source of pathogens. The waterway's impairment is listed as Category 5 in the 2024 Integrated Report, indicating that the receiving water is impaired for one or more uses by a pollutant that require the development of a TMDL. No TMDL has been developed for UNT to Codorus Creek to date, so no local watershed TMDL has been taken into consideration during this review.

*Public Water Supply Intake*

The nearest downstream public water supply intake is the Wrightsville Water Supply Company intake on the Susquehanna River. Considering the distance and nature, the discharge is not expected to affect the water supply.

*Class A Wild Trout Streams*

The receiving stream is not a Class A Wild Trout stream; therefore, no Class A Wild Trout Fishery is impacted by this discharge.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> North Codorus Township STP				
<b>WQM Permit No.</b>	<b>Issuance Date</b>			
6704402 T-1	July 22, 2015			
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary With Ammonia And Phosphorus	Sequencing Batch Reactor	Ultraviolet	0.55
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
1.38	1147	Not Overloaded	Aerobic Digestion	Other WWTP

North Codorus Township owns and operates the sanitary wastewater treatment facility located in North Codorus Township, York County. The facility serves North Codorus Township and New Salem Borough; wastes are generally residential in nature, and all sewer systems are 100% separated. With an annual average design flow of 0.55 MGD and a hydraulic design capacity of 1.38 MGD, the existing facility consists of an influent screening unit, two SBRs, a post-equalization basin, a UV disinfection system and the outfall (Outfall 001). The facility utilizes an aerobic digester. PAC is utilized to precipitate phosphorus.

Compliance History	
<b>Summary of DMRs:</b>	DMR results for the past year are presented below.
<b>Summary of Inspections:</b>	<p>Since the last renewal of the facility's NPDES permit, the following inspections have been logged in WMS:</p> <p><b>October 30, 2024:</b> A routine CEI was conducted by Shawn Lesitsky. No violations or recommendations were noted. The following unresolved non-compliance was documented:</p> <ol style="list-style-type: none"><li>1. 25 Pa. Code 92a.61(c): Failure to monitor pollutants as required by the NPDES permit. Digester supernatant returns prior to screening. Influent sampler pulls post decant return. Recommend digester supernatant not be introduced during sample collection.</li></ol> <p><b>May 12, 2020:</b> An administrative inspection was conducted via phone call by Austen Randecker. No violations or recommendations were noted.</p> <p><b>February 5, 2020:</b> A routine CEI was conducted by Austen Randecker. No violations or recommendations were noted.</p> <p><b>March 12, 2019:</b> A routine CEI was conducted by Austen Randecker. The following violation was issued:</p> <ol style="list-style-type: none"><li>1. A grab sample collected by the Department for Total Suspended Solids (result 110 mg/L, permit max value IMAX 60 mg/L) exceeded the permit limit established in Part A.1.A of your NPDES permit.</li></ol> <p>A recommendation was made to maintain a secondary thermometer in both influent and effluent composite samplers.</p>

Other Comments: As of May 16, 2025, there are no open violations associated with this facility.

**Existing Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Instantaneous Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
CBOD5	64.0	96	XXX	14.0	21.0	28	1/week	8-Hr Composite
BOD5		Report Daily Max	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Raw Sewage Influent	Report		XXX					
TSS	137	206	XXX	30.0	45.0	60	1/week	8-Hr Composite
TSS	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
UV Intensity (mW/cm <sup>2</sup> )	XXX	XXX	Report	XXX	XXX	XXX	1/day	Measured
Nitrate-Nitrite	XXX	XXX	XXX	Report	XXX	XXX	2/week	8-Hr Composite
Nitrate-Nitrite (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/week	Calculation
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	1/month	Calculation
Total Nitrogen (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation

Outfall 001, Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Instantaneous Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Total Nitrogen (lbs) Effluent Net	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
Ammonia Nov 1 - Apr 30	20.6	XXX	XXX	4.5	XXX	9	2/week	8-Hr Composite
Ammonia May 1 - Oct 31	6.8	XXX	XXX	1.5	XXX	3	2/week	8-Hr Composite
Ammonia (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
TKN	XXX	XXX	XXX	Report	XXX	XXX	2/week	8-Hr Composite
TKN (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
Total Phosphorus	9.0	XXX	XXX	2.0	XXX	4	2/week	8-Hr Composite
Total Phosphorus (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
Total Phosphorus (lbs) Effluent Net	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
Total Copper (ug/L)	XXX	XXX	XXX	Report	Report Daily Max	XXX	1/week	24-Hr Composite
Total Lead (ug/L)	XXX	XXX	XXX	Report	Report Daily Max	XXX	1/week	24-Hr Composite
Total Zinc (ug/L)	XXX	XXX	XXX	Report	Report Daily Max	XXX	1/week	24-Hr Composite

Compliance Sampling Location: Outfall 001

Compliance History

DMR Data for Outfall 001 (from April 1, 2024 to March 31, 2025)

Parameter	MAR-25	FEB-25	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24	APR-24
Flow (MGD) Average Monthly	0.1872	0.1889	0.1831	0.1846	0.01782	0.1812	0.18194 4	0.19247 9	0.18024 1	0.18087 6	0.18965 7	0.20799 4
Flow (MGD) Daily Maximum	0.2592	0.2695	0.2619	0.273	0.2308	0.2454	0.24454 4	0.35383 8	0.20614 9	0.24091 9	0.25811 4	0.54990 4
pH (S.U.) Instantaneous Minimum	7.09	6.45	7.01	7.13	6.44	7.15	7.22	6.34	7.03	6.28	6.75	7.05
pH (S.U.) Instantaneous Maximum	7.64	7.53	7.56	7.62	7.63	7.6	7.64	7.58	7.34	7.64	7.36	7.33
DO (mg/L) Instantaneous Minimum	8.46	8.8	8.66	8.24	7.62	6.01	6.98	5.85	5.10	5.02	6.46	7.79
CBOD5 (lbs/day) Average Monthly	< 5.0	< 4.0	< 4.0	< 4.0	< 4.0	< 4.0	< 4.0	< 4.0	< 5.0	< 4.0	< 4.0	< 5.0
CBOD5 (lbs/day) Weekly Average	7	5	4.0	< 5	< 5	< 4.0	4	< 5.0	9.0	7.0	< 4	8.0
CBOD5 (mg/L) Average Monthly	< 3.0	< 3.0	< 3.0	< 2.0	< 2.0	< 2.0	< 2.0	< 2.0	< 3.0	< 3.0	< 2.0	< 3.0
CBOD5 (mg/L) Weekly Average	5.0	3.0	3.0	< 2.0	3.0	< 2.0	3.0	3.0	5.0	5.0	< 2.0	5.0
BOD5 (lbs/day) Raw Sewage Influent   Average Monthly	350.9	422.98	269.89	476.46	523.23	445.48	411.26	457	469.47	423.59	448.34	516.46
BOD5 (lbs/day) Raw Sewage Influent   Daily Maximum	442.95	500.06	280.37	508.60	935.17	501.73	449.31	581.37	558.16	548.31	507.93	670.81
BOD5 (mg/L) Raw Sewage Influent   Average Monthly	227.5	285.75	188.75	312	330.75	291.20	284.00	276.50	297.20	301.50	294.50	321.40
TSS (lbs/day) Average Monthly	3	4	2	3	2	4	3	4	7	2.0	3	3.0
TSS (lbs/day) Raw Sewage Influent   Average Monthly	265.58	379.58	139.82	489.68	387.87	493.72	444.50	469.88	536.35	386.08	528.02	507.54

NPDES Permit Fact Sheet  
North Codorus Township STP

NPDES Permit No. PA0247391

TSS (lbs/day) Raw Sewage Influent   Daily Maximum	413.09	497.73	176.17	519.54	546.63	617.68	524.20	524.07	568.31	530.17	576.16	618.92
TSS (lbs/day) Weekly Average	8	5	3	7	4	6	5	6	12	4.0	5	7.0
TSS (mg/L) Average Monthly	2.0	3.0	1.0	1.0	2.0	3.0	2.0	3.0	4.0	2.0	2.0	2.0
TSS (mg/L) Raw Sewage Influent   Average Monthly	171.00	257.00	97.75	322.40	245.00	321.60	306.00	289	340.80	277.00	347	315.20
TSS (mg/L) Weekly Average	4.0	3.0	2.0	3.0	2.0	4.0	3.0	4.0	7.0	3.0	3.0	4.0
Fecal Coliform (No./100 ml) Geometric Mean	6	< 4	< 3	14	4	2	8	19	14	5	1	6.0
Fecal Coliform (No./100 ml) Instantaneous Maximum	10	11	4	921	10	4	11	99	49	14	2	58.0
UV Intensity (mW/cm <sup>2</sup> ) Instantaneous Minimum	9.3	9.3	9.2	9.2	9.3	9.3	9.4	9.6	9.7	9.8	4.1	4.1
Nitrate-Nitrite (mg/L) Average Monthly	< 4.3	< 6.4	< 6.6	< 4.4	< 5.9	< 6.6	< 5.4	< 3.5	< 5.13	< 8.23	< 9.84	< 5.18
Nitrate-Nitrite (lbs) Total Monthly	< 206	< 270	< 296	< 217	< 269	< 305	< 250	< 171	< 243	< 356	< 458	< 248
Total Nitrogen (mg/L) Average Monthly	< 5.9	< 7.7	< 7.8	< 6	< 7.2	< 7.8	< 6.29	< 4.71	< 7.38	< 9.42	< 10.8	< 6.94
Total Nitrogen (lbs) Effluent Net   Total Monthly	< 283	< 326	< 348	< 298	< 330	< 360	< 293	< 229	< 350	< 408	< 503	< 334
Total Nitrogen (lbs) Total Monthly	< 283	< 326	< 348	< 298	< 330	< 360	< 293	< 229	< 350	< 408	< 503	< 334
Total Nitrogen (lbs) Effluent Net   Total Annual								3907.22				
Total Nitrogen (lbs) Total Annual								3907.22				
Ammonia (lbs/day) Average Monthly	< 0.2	< 0.3	< 0.2	< 0.2	< 0.2	< 0.1	< 0.2	< 0.2	< 0.7	< 0.2	< 0.2	< 0.3
Ammonia (mg/L) Average Monthly	0.15	< 0.21	< 0.15	< 0.11	< 0.1	< 0.1	< 0.1	< 0.1	< 0.48	< 0.12	< 0.1	< 0.17
Ammonia (lbs) Total Monthly	< 7.2	< 9.1	< 6.6	< 5.6	< 4.5	< 4.6	< 4.6	< 4.9	< 22.5	< 5.0	< 4.7	< 8.1

NPDES Permit Fact Sheet  
North Codorus Township STP

NPDES Permit No. PA0247391

Ammonia (lbs) Total Annual							96.95					
TKN (mg/L) Average Monthly	1.6	< 1.3	< 1.16	1.6	< 1.3	1.2	< 0.92	1.21	2.3	< 1.19	< 1	< 1.8
TKN (lbs) Total Monthly	77	< 56	< 52	81	< 61	55	< 43	58	107	< 52	< 45	< 86
Total Phosphorus (lbs/day) Average Monthly	0.7	0.9	0.8	0.6	1.0	1.0	0.8	1.0	2.0	2.0	1.0	1.0
Total Phosphorus (mg/L) Average Monthly	0.43	0.58	0.53	0.39	0.65	0.93	0.54	0.8	1.09	1.09	0.85	0.64
Total Phosphorus (lbs) Effluent Net   Total Monthly	20	25	24	19	29	43	25	38	52	47	39	31
Total Phosphorus (lbs) Total Monthly	20	25	24	19	29	43	25	38	52	47	39	31
Total Phosphorus (lbs) Effluent Net   Total Annual							446.18					
Total Phosphorus (lbs) Total Annual							446.18					
Total Copper (ug/L) Average Monthly	< 0.005	< 0.005	< 0.005	< 0.005	< 0.005	< 0.005	< 0.005	< 0.008	< 0.005	< 0.005	< 0.005	< 0.005
Total Copper (ug/L) Daily Maximum	< 0.005	< 0.005	< 0.005	< 0.005	< 0.005	0.005	< 0.005	< 0.01	0.007	0.006	< 0.005	< 0.005
Total Lead (ug/L) Average Monthly	< 0.001	< 0.001	< 0.001	< 0.001	< 0.001	< 0.001	< 0.001	< 0.006	< 0.001	< 0.001	< 0.001	< 0.001
Total Lead (ug/L) Daily Maximum	< 0.001	< 0.001	< 0.001	< 0.001	< 0.001	< 0.001	< 0.001	< 0.01	< 0.001	< 0.001	< 0.001	0.003
Total Zinc (ug/L) Average Monthly	< 0.038	0.051	0.052	0.044	0.045	0.048	0.043	0.043	0.045	0.047	0.054	0.044
Total Zinc (ug/L) Daily Maximum	0.051	0.057	0.054	0.049	0.048	0.063	0.045	0.043	0.053	0.052	0.058	0.051

Compliance History

As of May 16, 2025, there are no open violations associated with this facility.

**Development of Effluent Limitations**

Outfall No. 001  
Latitude 39° 53' 43.00"  
Wastewater Description: Sewage Effluent

Design Flow (MGD) .55  
Longitude -76° 48' 26.00"

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: These standards apply, subject to water quality analysis and BPJ where applicable.

**Water Quality-Based Limitations**

*CBOD5, NH3-N and Dissolved Oxygen (DO)*

1. WQM 7.0 version 1.0b is a water quality model designed to assist DEP to determine appropriate permit requirements for CBOD5, NH3-N and DO. DEP's guidance no. 391-2000-007 provides the technical methods contained in WQM 7.0 for conducting wasteload allocation and for determining recommended NPDES effluent limits for point source discharges. The model was utilized using data derived by USGS StreamStats and the model output indicated that existing WQBELs for CBOD5 is still protective of water quality. However, the model also determined that existing WQBEL of 1.5 mg/L for ammonia (warm weather) is no longer protective of water quality. A new WQBEL of 1.3 mg/L for ammonia (warm weather) is proposed in this permit. Instantaneous limits for ammonia were updated with the Department's standard 2.0x multiplier. Updated winter limits were calculated with the Department's standard 3.0x multiplier for ammonia. Based on DMR data, the facility can already meet the proposed limits. Updated mass limits for both warm and cold weather were determined by multiplying the proposed ammonia limits by 8.34 (conversion factor) and 0.55 mgd (the facility's design annual average flow rate).

The model also determined that the facility's existing DO limits of 5 mg/L are still protective of water quality.

See attached for model inputs and outputs.

**Toxics**

A reasonable potential (RP) analysis was done for Total Copper, Total Lead and Total Zinc. The Department's Toxics Management Spreadsheet (Version 1.4) was used to perform the RP analysis for these parameters at a pH of 7.2 (average daily pH from the last 12-months of DMRs) and a discharge hardness of 100 mg/L. The last 12-months of DMR data was pulled for Total Copper, Total Lead and Total Zinc and the values were evaluated using TOXCONC. The analysis indicates that a 1/week monitoring requirement for Total Copper and Total Zinc is still appropriate. The requirement to calculate and report pounds of Total Copper and Total Zinc discharged is proposed to be added to this permit for data collection purposes. The flow monitoring requirements for Total Copper and Total Zinc is proposed to be decreased from 24-hour composite sampling to 8-hour composite sampling to align with other sampling requirements at the facility. CWA section 402(o)(2) outlines specific exceptions to the general

prohibition against revising an existing TBEL that was developed on a case-by-case basis using BPJ to reflect subsequently promulgated, less stringent effluent guidelines in a renewed, reissued, or modified permit. CWA section 402(o)(2) provides, in part, that relaxed limitations may be allowed where errors were made in the previous permit. It is the Department's position that the previously required 24-composite sampling was not consistent with the Department's Guidance (*Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits* (PA Doc No. 362-0400-001)) and should have been originally permitted with an 8-hour composite sampling requirement. The proposed 8-hour composite sampling requirement is at least as strict as that required by *Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits* (PA Doc No. 362-0400-001)

After populating the model with the highest recorded Total Lead concentration collected at Outfall 001 in the last year (51 of 52 samples were non-detect), the model indicated that Total Lead does not need limits or monitoring; therefore, the Department proposes to proceed with the removal of the existing Total Lead monitoring requirement. CWA section 402(o)(2) outlines specific exceptions to the general prohibition against revising an existing TBEL that was developed on a case-by-case basis using BPJ to reflect subsequently promulgated, less stringent effluent guidelines in a renewed, reissued, or modified permit. CWA section 402(o)(2) provides, in part, that relaxed limitations may be allowed where:

- New information (other than revised regulations, guidance, or test methods) is available that was not available at the time of permit issuance and that would have justified a less stringent effluent limitation. If the effluent limitation was based on water quality standards, any changes must result in a decrease in pollutants discharged.

During the last permit renewal, the testing frequency was increased from 1/year to 1/week for all three parameters to determine the need for monitoring or limits moving forward. The Department considers the weekly data collected during the last permit cycle to be new information (other than revised regulations, guidance, or test methods) that was not available at the time of permit issuance. The Department further notes that the applicant states that there are no commercial or industrial users tributary to the treatment plant.

At least one Total Lead sample will need to be collected and reported as part of the permit renewal process. If future sample results show reasonable potential, monitoring or discharge limits will be implemented in future renewals as appropriate.

The full TMS report is presented at the end of this report.

#### *E. Coli Monitoring*

In conformity with the Department's *Establishing Effluent Limitations for Individual Sewage Permits* (SOP No. BCW-PMT-033) and as authorized by § 92a.61 of the PA Code, quarterly E. Coli monitoring has been proposed in this permit. The collection method will be via grab sample.

### **Best Professional Judgment (BPJ) Limitations**

#### *Ultraviolet Disinfection*

The existing UV system is equipped with an intensity sensor; therefore, UV intensity is proposed to be continued as the monitoring parameter for the UV system.

#### *TDS / Sulfate / Chloride / Bromide / 1,4-Dioxane:*

Total Dissolved Solids (TDS) and its major constituents including sulfate, chloride, and bromide have emerged as pollutants of concern in several major watersheds in the Commonwealth. The conservative nature of these solids allows them to accumulate in surface waters and they may remain a concern even if the immediate downstream public water supply is not directly impacted. Under the authority of § 92a.61, statewide guidance distributed by the Department's Central Office on January 23, 2014 stated the following:

*For point source discharges and upon issuance or reissuance of an individual NPDES permit:*

- *Where the concentration of TDS in the discharge exceeds 1,000 mg/L, or the net TDS load from a discharge exceeds 20,000 lbs/day, and the discharge flow exceeds 0.1 MGD, Part A of the permit should include monitor and report for TDS, sulfate, chloride, and bromide. Discharges of 0.1 MGD*

*or less should monitor and report for TDS, sulfate, chloride, and bromide if the concentration of TDS in the discharge exceeds 5,000 mg/L.*

- *Where the concentration of bromide in a discharge exceeds 1 mg/L and the discharge flow exceeds 0.1 MGD, Part A of the permit should include monitor and report for bromide. Discharges of 0.1 MGD or less should monitor and report for bromide if the concentration of bromide in the discharge exceeds 10 mg/L.*
- *Where the concentration of 1,4-dioxane (CAS 123-91-1) in a discharge exceeds 10 µg/L and the discharge flow exceeds 0.1 MGD, Part A of the permit should include monitor and report for 1,4-dioxane. Discharges of 0.1 MGD or less should monitor and report for 1,4-dioxane if the concentration of 1,4-dioxane in the discharge exceeds 100 µg/L.*

The table below compares the above thresholds for monitoring requirements with the concentrations documented in the current application:

*Department Monitoring Thresholds and Expected Discharge Concentrations for TDS and Related Parameters*

Parameter	Threshold for Discharges >0.1 MGD	Threshold for Discharges ≤0.1 MGD	Max. Concentration in Application
TDS	1,000 mg/L or 20,000 lbs/day	5,000 mg/L	382 mg/L
Sulfate	NA	NA	41 mg/L
Chloride	NA	NA	86 mg/L
Bromide	1 mg/L	10 mg/L	<0.2 mg/L
1,4-Dioxane	10 µg/L	100 µg/L	Not Tested

Based on the sampling results in the application, no additional limits are proposed in the draft permit. 1,4-Dioxane was not evaluated as minor permits are not required to sample the parameter.

#### *Total Phosphorus & Total Nitrogen*

DEP's SOP no. BPNPSM-PMT-033 (Establishing Effluent Limitations for Individual Sewage Permits) recommends monitoring requirements for Total Phosphorus and Total Nitrogen for all sewage facilities. Therefore, routine monitoring for Total Phosphorus and Total Nitrogen are recommended to be continued in this permit. Sampling frequency for is currently required 2/week, which is consistent with Table 6.3 in Guidance Doc. 362-0400-001. No change is proposed.

## Additional Considerations

### *Flow Monitoring*

The requirement to monitor the volume of effluent will remain in the draft permit per 40 CFR § 122.44(i)(1)(ii).

### *Chesapeake Bay TMDL*

The Department formulated a strategy in April 2007, to comply with the EPA's and Chesapeake Bay Foundation's requirements to reduce point source loadings of Total Nitrogen (TN) and Total Phosphorus (TP) to the Bay. In the Strategy, sewage dischargers have been prioritized by Central Office based on their delivered TN loadings to the Bay. The highest priority (Phases 1, 2, and 3) dischargers received annual loading caps based on their design flow on August 29, 2005 and concentrations of 6 mg/l TN and 0.8 mg/l TP. Phase 4 (0.2 -0.4mgd) and Phase 5 (below 0.2mgd) facilities were required to monitor and report TN and TP during permit renewal at a monitoring frequency following Table 6-3 of DEP's Technical Guidance for Development and Specification of effluent Limitations (No. 362-0400-001).

EPA published the Chesapeake Bay Total Maximum Daily Load (TMDL) in December of 2010. Despite extensive restoration efforts during the past 25 years, the TMDL was prompted by insufficient progress and continued poor water quality in the Chesapeake Bay and its tidal tributaries.

In order to address the TMDL, Pennsylvania developed, in addition to the Bay Strategy, a Chesapeake Watershed Implementation Plan (WIP) Phase 1 in January 2011, Phase 2 in March 2012 and Phase 3 in December 2019. In accordance with the Phase 3 WIP, re-issuing permits for significant dischargers follow the same phased approach formulated in the original Bay strategy, whilst Phase 4 and Phase 5 will be required to monitor and report TN and TP during permit renewal.

The Phase 3 WIP categorizes this facility as a Phase 2 sewage facility. The Phase 3 WIP requires a minimum monitoring frequency for TN species and TP in new or renewed Phase 2 NPDES permits for Significant Sewage dischargers twice a week. Twice weekly monitoring of these pollutants will be continued in this permit.

The Phase 3 WIP assigns the following cap loads to the facility:

NPDES Permit No.	Phase	Facility	Latest Permit Issuance Date	Permit Expiration Date	Cap Load Compliance Start Date	TN Cap Load (lbs/yr)	TN Offsets Included in Cap Load (lbs/yr)	TP Cap Load (lbs/yr)	TN Delivery Ratio	TP Delivery Ratio
PA0247391	2	North Codorus Township	7/22/2015	1/31/2019	10/1/2006	13,394	-	1,674	0.961	0.436

### *Monitoring Frequency and Sample Type*

The existing permit currently has weekly concentration and mass discharge limits for CBOD5 and TSS. The Department's SOP No. BCW-PMT-033 (Establishing Effluent Limitations for Individual Sewage Permits, Section 1, Part A, Note 9) states that, "In general, weekly average limits for CBOD5 and TSS will not be imposed where the sampling frequency is less than 1/week." Given that existing and proposed monitoring for CBOD5 and TSS will be 2/month, it appears that the weekly limits were assigned erroneously. The draft permit proposes eliminating the weekly limits for CBOD5 and TSS.

Extraneous reporting limits for NOx and TKN were eliminated from the permit. All data required to be submitted in the previous permit is required to be submitted in this renewal,

Unless discussed otherwise above, the permit's monitoring frequency and sample type for all parameters will remain unchanged from the last permit renewal.

### *Antidegradation Requirements*

All effluent limitations and monitoring requirements have been developed to ensure that existing instream water uses and the level of water quality necessary to protect the existing uses are maintained and protected.

*Anti-backsliding Requirement*

All effluent limits proposed in this fact sheet are as stringent as effluent limits specified in the existing permit renewal unless noted otherwise above. This approach is in accordance with 40 CFR §122.44(l)(1).

*Annual Fees*

An annual fee clause is continued in the permit in accordance with 25 Pa. Code § 92a.62. The facility covered by the permit is classified in the Minor Sewage Facility  $\geq 0.05$  and  $< 1$  MGD fee category, which has an annual fee of \$1,000.

*Mass Loading Limitations*

Unless stated otherwise in this fact sheet, mass loading effluent limits are calculated based on the formula: design flow (average annual) (MGD) x concentration limit (mg/L) at design flow x conversion factor (8.34).

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Monthly	Annual	Monthly	Monthly Average	Maximum	Instant. Maximum		
Total Nitrogen (lbs) Effluent Net	XXX	13394 Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation
Total Nitrogen (lbs)	XXX	Report Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation
Ammonia (lbs)	XXX	Report Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation
Total Phosphorus (lbs) Effluent Net	XXX	1674 Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation
Total Phosphorus (lbs)	XXX	Report Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation

Compliance Sampling Location: Outfall 001

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Instantaneous Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
CBOD5	64.0	XXX	XXX	14.0	XXX	28	1/week	8-Hr Composite
BOD5								8-Hr Composite
Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	1/week	Composite
TSS								8-Hr Composite
Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	1/week	Composite
TSS	137.0	XXX	XXX	30.0	XXX	60	1/week	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
UV Intensity (mW/cm <sup>2</sup> )	XXX	XXX	Report	XXX	XXX	XXX	1/day	Measured
Nitrate-Nitrite	Report	XXX	XXX	Report	XXX	XXX	2/week	8-Hr Composite
Nitrate-Nitrite (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
Total Nitrogen	Report	XXX	XXX	Report	XXX	XXX	1/month	Calculation

Outfall 001, Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Instantaneous Minimum	Average Monthly	Maximum	Instant. Maximum		
Total Nitrogen (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
Total Nitrogen (lbs) Effluent Net	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
Ammonia Nov 1 - Apr 30	17.8	XXX	XXX	3.9	XXX	7.8	2/week	Composite
Ammonia May 1 - Oct 31	5.9	XXX	XXX	1.3	XXX	2.6	2/week	8-Hr Composite
Ammonia (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
TKN	Report	XXX	XXX	Report	XXX	XXX	2/week	8-Hr Composite
TKN (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
Total Phosphorus	9.0	XXX	XXX	2.0	XXX	4	2/week	8-Hr Composite
Total Phosphorus (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
Total Phosphorus (lbs) Effluent Net	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
Total Copper (ug/L)	Report	XXX	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Total Zinc (ug/L)	Report	XXX	XXX	Report	XXX	XXX	1/week	8-Hr Composite

Compliance Sampling Location: Outfall 001

Tools and References Used to Develop Permit	
<input type="checkbox"/>	WQM for Windows Model (see Attachment [REDACTED])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [REDACTED]
<input type="checkbox"/>	Other: [REDACTED]




## StreamStats Report

Region ID: PA

Workspace ID: PA20250516112542409000

Clicked Point (Latitude, Longitude): 39.89530, -76.80727

Time: 2025-05-16 07:26:22 -0400



[Collapse All](#)

### » Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
BSLOPD	Mean basin slope measured in degrees	5.6772	degrees
DRNAREA	Area that drains to a point on a stream	4.02	square miles
ROCKDEP	Depth to rock	3	feet
URBAN	Percentage of basin with urban development	1.9892	percent

### » Low-Flow Statistics

#### Low-Flow Statistics Parameters [Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
BSLOPD	Mean Basin Slope degrees	5.6772	degrees	1.7	6.4
DRNAREA	Drainage Area	4.02	square miles	4.78	1150
ROCKDEP	Depth to Rock	3	feet	4.13	5.21
URBAN	Percent Urban	1.9892	percent	0	89

#### Low-Flow Statistics Disclaimers [Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 1]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.149	ft <sup>3</sup> /s
30 Day 2 Year Low Flow	0.243	ft <sup>3</sup> /s
7 Day 10 Year Low Flow	0.0465	ft <sup>3</sup> /s
30 Day 10 Year Low Flow	0.0834	ft <sup>3</sup> /s
90 Day 10 Year Low Flow	0.165	ft <sup>3</sup> /s

*Low-Flow Statistics Citations*

**Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)**

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.28.1

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1


## StreamStats Report

Region ID: PA

Workspace ID: PA20250516112935900000

Clicked Point (Latitude, Longitude): 39.90129, -76.80688

Time: 2025-05-16 07:30:15 -0400



[Collapse All](#)

### » Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
BSLOPD	Mean basin slope measured in degrees	5.7809	degrees
DRNAREA	Area that drains to a point on a stream	4.37	square miles
ROCKDEP	Depth to rock	3.8	feet
URBAN	Percentage of basin with urban development	1.8647	percent

### » Low-Flow Statistics

#### Low-Flow Statistics Parameters [Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
BSLOPD	Mean Basin Slope degrees	5.7809	degrees	1.7	6.4
DRNAREA	Drainage Area	4.37	square miles	4.78	1150
ROCKDEP	Depth to Rock	3.8	feet	4.13	5.21
URBAN	Percent Urban	1.8647	percent	0	89

#### Low-Flow Statistics Disclaimers [Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 1]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.453	ft^3/s
30 Day 2 Year Low Flow	0.641	ft^3/s
7 Day 10 Year Low Flow	0.179	ft^3/s
30 Day 10 Year Low Flow	0.269	ft^3/s
90 Day 10 Year Low Flow	0.445	ft^3/s

*Low-Flow Statistics Citations*

**Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)**

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.28.1

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1

**WQM 7.0 Effluent Limits**

SWP Basin 07H	Stream Code 8196	Stream Name Trib 08196 to Codorus Creek					
		Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
0.530	N Codorus Twp	PA0247391	0.550	CBOD5	14		
				NH3-N	1.38	2.76	
				Dissolved Oxygen			5

## WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>				
07H	8196	Trib 08196 to Codorus Creek				

### **NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
	0.530 N Codorus Twp	9.15	3	9.15	3	0	0

### **NH3-N Chronic Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
	0.530 N Codorus Twp	1.26	1.38	1.26	1.38	0	0

### **Dissolved Oxygen Allocations**

RMI	Discharge Name	CBOD5		NH3-N		Dissolved Oxygen		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
	0.53 N Codorus Twp	14	14	1.38	1.38	5	5	0	0

## WQM 7.0 D.O.Simulation

<b>SWP Basin</b>	<b>Stream Code</b>	<b>Stream Name</b>		
<b>07H</b>	<b>8196</b>	<b>Trib 08196 to Codorus Creek</b>		
RMI	Total Discharge Flow (mgd)		Analysis Temperature (°C)	Analysis pH
0.530	0.550		25.000	7.187
Reach Width (ft)	Reach Depth (ft)		Reach WDRatio	Reach Velocity (fps)
11.948	0.493		24.218	0.152
Reach CBOD5 (mg/L)	Reach Kc (1/days)		Reach NH3-N (mg/L)	Reach Kn (1/days)
13.38	1.486		1.31	1.029
Reach DO (mg/L)	Reach Kr (1/days)		Kr Equation	Reach DO Goal (mg/L)
5.168	25.579		Owens	5
Reach Travel Time (days)	<b>Subreach Results</b>			
0.212	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.021	12.86	1.28	5.81
	0.042	12.36	1.25	6.21
	0.064	11.88	1.23	6.47
	0.085	11.41	1.20	6.64
	0.106	10.97	1.17	6.76
	0.127	10.54	1.15	6.86
	0.149	10.13	1.12	6.93
	0.170	9.74	1.10	7.00
	0.191	9.36	1.08	7.05
	0.212	8.99	1.05	7.10

## WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.7935	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>			<u>Stream Code</u>			<u>Stream Name</u>								
07H			8196			Trib 08196 to Codorus Creek								
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH		
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)			
<b>Q7-10 Flow</b>														
0.530	0.05	0.00	0.05	.8509	0.00855	.493	11.95	24.22	0.15	0.212	25.00	7.19		
<b>Q1-10 Flow</b>														
0.530	0.03	0.00	0.03	.8509	0.00855	NA	NA	NA	0.15	0.215	25.00	7.19		
<b>Q30-10 Flow</b>														
0.530	0.08	0.00	0.08	.8509	0.00855	NA	NA	NA	0.16	0.208	25.00	7.18		

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC				
<b>Stream Data</b>												
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	pH	Stream Temp (°C)	pH
Q7-10	0.000	0.05	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							
<b>Discharge Data</b>									Disc Temp (°C)	Disc pH		
	Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor						
	N Codorus Twp	PA0247391	0.5500	0.5500	0.5500	0.000	25.00	7.20				
<b>Parameter Data</b>									Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
	Parameter Name											
	CBOD5		14.00	2.00	0.00	1.50						
	Dissolved Oxygen		5.00	8.24	0.00	0.00						
	NH3-N		1.50	0.00	0.10	0.70						

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation	Drainage Area	Slope	PWS Withdrawal	Apply FC			
			(ft)	(sq mi)	(ft/ft)	(mgd)					
07H	8196	Trib 08196 to Codorus Creek	0.001	406.83	4.37	0.00000	0.00	<input checked="" type="checkbox"/>			
<b>Stream Data</b>											
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)	Stream pH
Q7-10	0.000	0.18	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00
Q1-10		0.00	0.00	0.000	0.000						
Q30-10		0.00	0.00	0.000	0.000						
<b>Discharge Data</b>											
	Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH			
			0.0000	0.0000	0.0000	0.000	0.00	7.00			
<b>Parameter Data</b>											
	Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)					
	CBOD5		25.00	2.00	0.00	1.50					
	Dissolved Oxygen		3.00	8.24	0.00	0.00					
	NH3-N		25.00	0.00	0.00	0.70					

NPDES Permit Fact Sheet  
North Codorus Township STP

NPDES Permit No. PA0247391

Facility:	North Codorus Township STP		
NPDES #:	PA0247391		
Outfall No:	001		
Sample(s)/Month:	4		
Reviewer/Permit Engineer:	Aaron Baar		
Parameter Name	Total Copper	Total Lead	Total Zinc
Units	mg/L	mg/L	mg/L
Detection Limit	0.004	0.001	0.005
Sample Date	When entering values below the detection limit, enter "ND" or use the < notation (e.g. <0.02)		
3/4/25	<0.005	<0.001	0.051
3/11/25	<0.005	<0.001	0.051
3/18/25	<0.005	<0.001	0.047
3/25/25	<0.005	<0.001	<0.001
2/4/25	<0.005	<0.001	0.052
2/11/25	<0.005	<0.001	0.045
2/18/25	<0.005	<0.001	0.057
2/25/25	<0.005	<0.001	0.05
1/7/25	<0.005	<0.001	0.048
1/14/25	<0.005	<0.001	0.052
1/21/25	<0.005	<0.001	0.052
1/28/2025	<0.005	<0.001	0.054
2/4/2024	<0.005	<0.001	0.042
12/11/2024	<0.005	<0.001	0.049
12/18/2024	<0.005	<0.001	0.042
12/25/2024	<0.005	<0.001	0.044
12/31/2024	<0.005	<0.001	0.041
11/7/2024	<0.005	<0.001	0.044
11/14/2024	<0.005	<0.001	0.044
11/21/2024	<0.005	<0.001	0.044
11/28/2024	<0.005	<0.001	0.048
10/1/24	<0.005	<0.001	0.042
10/8/24	<0.005	<0.001	0.046
10/15/24	<0.005	<0.001	0.063
10/22/24	<0.005	<0.001	0.044
10/29/24	<0.005	<0.001	0.044
9/3/24	<0.005	<0.001	0.04
9/10/24	<0.005	<0.001	0.042
9/17/24	<0.005	<0.001	0.045
9/24/24	<0.005	<0.001	0.045
8/6/24	<0.01	<0.001	0.043
8/13/24	<0.01	<0.001	0.043
8/20/24	<0.005	<0.001	0.041
8/27/24	<0.005	<0.001	0.043
7/2/2024	0.007	<0.001	0.053
7/9/2024	<0.005	<0.001	0.041
7/16/2024	<0.005	<0.001	0.044
7/23/2024	<0.005	<0.001	0.041
7/30/2024	<0.005	<0.001	0.047
6/4/2024	<0.005	<0.001	0.052
6/11/2024	<0.005	<0.001	0.047
6/18/2024	<0.005	<0.001	0.047
6/25/2024	0.006	<0.001	0.043
5/7/2024	<0.005	<0.001	0.058
5/14/2024	<0.005	<0.001	0.057
5/21/2024	<0.005	<0.001	0.053
5/28/2024	<0.005	<0.001	0.048
4/2/2024	<0.005	<0.001	0.04
4/9/2024	<0.005	<0.001	0.037
4/16/2024	<0.005	0.003	0.042

1

5/16/2025

## NPDES Permit Fact Sheet North Codorus Township STP

NPDES Permit No. PA0247391

## NPDES Permit Fact Sheet North Codorus Township STP

NPDES Permit No. PA0247391



Toxics Management Spreadsheet  
Version 1.4, May 2023

## Discharge Information

**Instructions      Discharge      Stream**

Facility: **North Codorus Township STP**

NPDES Permit No.: **PA0247391**

Outfall No.: 001

Evaluation Type: **Custom / Additives**

Wastewater Description: **Treated Sewage**

Discharge Characteristics								
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)			Complete Mix Times (min)		
			AFC	CFC	THH	CRL	Q <sub>7-10</sub>	Q <sub>h</sub>
0.55	100	7.2						



## Stream / Surface Water Information

Instructions    Discharge    Stream

North Codorus Township STP, NPDES Permit No. PA0247391, Outfall 001

Receiving Surface Water Name: UNT to Codorus Creek

No. Reaches to Model: 1

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi <sup>2</sup> )*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	008196	0.53	430.72	4.02			Yes
End of Reach 1	008196	0.001	406.83	4.37			Yes

Q<sub>7-10</sub>

Location	RMI	LFY (cfs/mi <sup>2</sup> )*	Flow (cfs)	W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary	Stream	Analysis	
Point of Discharge	0.53	0.0465	Stream	Tributary					Hardness	pH	Hardness*	pH*
End of Reach 1	0.001	0.179									100	7

Q<sub>h</sub>

Location	RMI	LFY (cfs/mi <sup>2</sup> )*	Flow (cfs)	W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary	Stream	Analysis	
Point of Discharge	0.53		Stream	Tributary					Hardness	pH	Hardness*	pH*
End of Reach 1	0.001											



## Model Results

[Instructions](#) [Results](#) [RETURN TO INPUTS](#) [SAVE AS PDF](#) [PRINT](#)  All  Inputs  Results  Limits

North Codorus Township STP, NPDES Permit No. PA0247391, Outfall 001

**Hydrodynamics**

**Wasteload Allocations**

**AFC** CCT (min):  PMF:  Analysis Hardness (mg/l):  Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Copper	0	0	0	0	13.439	14.0	14.8	Chem Translator of 0.96 applied
Total Lead	0	0	0	0	64.581	81.6	86.1	Chem Translator of 0.791 applied
Total Zinc	0	0	0	0	117.180	120	126	Chem Translator of 0.978 applied

**CFC** CCT (min):  PMF:  Analysis Hardness (mg/l):  Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Copper	0	0	0	0	8.956	9.33	9.84	Chem Translator of 0.96 applied
Total Lead	0	0	0	0	2.517	3.18	3.36	Chem Translator of 0.791 applied
Total Zinc	0	0	0	0	118.139	120	126	Chem Translator of 0.986 applied

**THH** CCT (min):  PMF:  Analysis Hardness (mg/l):  Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Copper	0	0	0	0	N/A	N/A	N/A	N/A
Total Lead	0	0	0	0	N/A	N/A	N/A	N/A
Total Zinc	0	0	0	0	N/A	N/A	N/A	N/A

**CRL** CCT (min):  PMF:  Analysis Hardness (mg/l):  Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Copper	0	0	0	0	N/A	N/A	N/A	N/A

Total Lead	0	0	0	0	N/A	N/A	N/A
Total Zinc	0	0	0	0	N/A	N/A	N/A

**Recommended WQBELs & Monitoring Requirements**

No. Samples/Month: 4

Pollutants	Mass Limits				Concentration Limits			Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units	Governing WQBEL	
Total Copper	Report	Report	Report	Report	Report	mg/L	0.01	CFC Discharge Conc > 10% WQBEL (no RP)
Total Zinc	Report	Report	Report	Report	Report	mg/L	0.12	AFC Discharge Conc > 10% WQBEL (no RP)

**Other Pollutants without Limits or Monitoring**

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

Pollutants	Comments		
	Governing WQBEL	Units	Comments
Total Lead	3.36	µg/L	Discharge Conc ≤ 10% WQBEL