

Application Type Renewal
Wastewater Type Sewage
Facility Type SRSTP

**NPDES PERMIT FACT SHEET
INDIVIDUAL SFTF/SRSTP**

Application No. PA0247405
APS ID 277539
Authorization ID 1411951

Applicant, Facility and Project Information

Applicant Name	<u>David Stup & Penny Stup</u>	Facility Name	<u>Stup Res</u>
Applicant Address	<u>5394 Big Creek Road</u> <u>Clearville, PA 15535</u>	Facility Address	<u>5394 Big Creek Road</u> <u>Clearville, PA 15535</u>
Applicant Contact	<u>David Stup</u>	Facility Contact	<u>David Stup</u>
Applicant Phone	<u>(814) 784-5708</u>	Facility Phone	<u>(814) 784-5708</u>
Client ID	<u>43893</u>	Site ID	<u>127353</u>
SIC Code	<u>6514</u>	Municipality	<u>Monroe Township</u>
SIC Description	<u>Fin, Ins & Real Est - Dwelling Operators, Except Apartments</u>	County	<u>Bedford</u>
Date Application Received	<u>September 29, 2022</u>	WQM Required	<u>Issued</u>
Date Application Accepted	<u>October 12, 2022</u>	WQM App. No.	<u>0585409</u>
Project Description	<u>NPDES renewal for an existing SRSTP.</u>		

Summary of Review

This fact sheet supports the issuance for the NPDES permit for discharge of treated sewage from the single residence sewage treatment plant (SRSTP) located in Monroe Township, Bedford County. DEP received the renewal NPDES permit application on September 29, 2022. Individual NPDES and WQM permits are required since the proposed system is not included in the Department's Manual (*Small Flow Treatment Facility Manual 362-0300-002*).

As per 25 Pa. Code § 92a.53, all applicable effluent limits and standards are considered in development of the permit. The limits noted in the permit suggest that any applicable water quality standards will not be violated.

The limits discussed in the permit are based on several factors that were determined by the Standard Operating Procedure for Small Flow Treatment Facilities (SOP No. BCW-PMT-003).

The TSS limits were prescribed based on The Department's Water Quality Antidegradation Implementation Guidance ID No. 391-0300-002

The Fecal Coliform limits listed in the permit were required by the Bureau of Clean Water, as stated in Chapters 92a and 93.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania*

Approve	Deny	Signatures	Date
		Jared Lescavage / Project Manager	November 1, 2022
x		Scott M Arwood Scott M. Arwood, P.E. / Environmental Engineer Manager	11/2/2022

Summary of Review

Bulletin at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Discharge and Stream Data – 2 - Receiving Waters and PWS

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.0004</u>
Latitude	<u>39° 53' 49.68"</u>	Longitude	<u>-78° 21' 7.70"</u>
Quad Name	_____	Quad Code	_____
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Unnamed Tributary of West Branch Sideling Hill Creek (EV)</u>	Stream Code	<u>61427</u>
NHD Com ID	<u>36404692</u>	RMI	<u>1.21</u>
Drainage Area	<u>0.0959</u>	Yield (cfs/mi ²)	_____
Q ₇₋₁₀ Flow (cfs)	_____	Q ₇₋₁₀ Basis	<u>StreamStats</u>
Elevation (ft)	_____	Slope (ft/ft)	_____
Watershed No.	<u>13-B</u>	Chapter 93 Class.	<u>EV</u>
Existing Use	_____	Existing Use Qualifier	_____
Exceptions to Use	_____	Exceptions to Criteria	_____
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	_____		
Source(s) of Impairment	_____		
TMDL Status	_____	Name	_____
Background/Ambient Data	_____	Data Source	_____
pH (SU)	_____		_____
Temperature (°F)	_____		_____
Hardness (mg/L)	_____		_____
Other:	_____		_____
Nearest Downstream Public Water Supply Intake	<u>No PWS from subject site to Maryland border. MD border is about 19 miles from subject site</u>		
PWS Waters	_____	Flow at Intake (cfs)	_____
PWS RMI	_____	Distance from Outfall (mi)	_____

Changes Since Last Permit Issuance: Addition of pH to the proposed effluent limits.

Other Comments: None

Compliance History	
Summary of DMRs:	N/A
Summary of Inspections:	N/A

Other Comments: **None**

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Annual Average	Maximum	Instant. Maximum		
Flow (MGD)	Report Annl Avg	XXX	XXX	XXX	XXX	XXX	1/year	Estimate
TRC	XXX	XXX	XXX	Report Avg Mo	XXX	XXX	1/month	Grab
pH (S.U.)	XXX	XXX	XXX	5.0 Annl Avg	9.0 Annl Avg	XXX	1/year	Grab
BOD5	XXX	XXX	XXX	10.0	XXX	20	1/year	Grab
TSS	XXX	XXX	XXX	10.0	XXX	20	1/year	Grab
Fecal Coliform (No./100 ml)	XXX	XXX	XXX	200	XXX	1000	1/year	Grab

Compliance Sampling Location: Outfall 001

Other Comments: None