

Application Type Renewal
 Facility Type Non-Municipal
 Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0247821
 APS ID 1065341
 Authorization ID 1399560

Applicant and Facility Information

Applicant Name	<u>Planks Field Planned Comm Inc.</u>	Facility Name	<u>Planks Field Planned Comm STP</u>
Applicant Address	<u>PO Box 4208</u> <u>Gettysburg, PA 17325-4208</u>	Facility Address	<u>Double Play Drive</u> <u>Gettysburg, PA 17325</u>
Applicant Contact	<u>William Eyler</u>	Facility Contact	<u>Troy Martin</u>
Applicant Phone	<u>(443) 398-0560</u>	Facility Phone	<u>(717) 420-7331</u>
Client ID	<u>326676</u>	Site ID	<u>652312</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Straban Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Adams</u>
Date Application Received	<u>June 10, 2022</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>June 15, 2022</u>	If No, Reason	<u></u>
Purpose of Application	<u>NPDES permit renewal</u>		

Summary of Review

William. F. Hill & Assoc., on behalf of the Planks Field Planned Community Wastewater Treatment Plant, has applied to the Pennsylvania Department of Environmental Protection (DEP) for renewal and issuance of the NPDES permit. The permit was reissued on December 21, 2017 and became effective on January 1, 2018. The permit will be expired on December 31, 2022.

The facility has an average annual design flow of 0.018 MGD and a hydraulic design capacity of 0.024 MGD.

The WQM Part II No. 0105408 original was issued on January 26, 2006, and transferred from ADCIM LLC to Planks Field Planned Community, Inc. on March 31, 2016.

Sludge use and disposal description and location(s): N/A due to the sludge is hauled by Smith's Septic.

Changes from the previous permit: The TRC monthly average limit of 0.16 mg/L and IMAX limit of 0.5 mg/L, which are more stringent, will appear in the proposed permit. The E. Coli. monitoring and report requirements will add to the permit.

Based on the review outline in this fact sheet, it is recommended that the permit be drafted and published in the Pennsylvania Bulletin for public comments for 30 days.

Approve	Deny	Signatures	Date
X		<i>Hilaryle</i> Hilary H. Le / Environmental Engineering Specialist	November 4, 2022
X		/s/ Daniel W. Martin, P.E. / Environmental Engineer Manager	November 16, 2022

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.018
Latitude	39° 53' 6"	Longitude	-77° 12' 9"
Quad Name	Biglerville	Quad Code	1928
Wastewater Description: Sewage Effluent			
Receiving Waters	Rock Creek (WWF)	Stream Code	59041
NHD Com ID	134238676	RMI	16.69 miles
Drainage Area	1.5 mi. ²	Yield (cfs/mi ²)	0.019
Q ₇₋₁₀ Flow (cfs)	0.028	Q ₇₋₁₀ Basis	USGS StreamStats
Elevation (ft)	506	Slope (ft/ft)	
Watershed No.	13-D	Chapter 93 Class.	WWF & MF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Impaired		
Cause(s) of Impairment	NUTRIENTS, NUTRIENTS		
Source(s) of Impairment	AGRICULTURE, MUNICIPAL POINT SOURCE DISCHARGES		
TMDL Status	Name		
Nearest Downstream Public Water Supply Intake	City of Frederick, MD		
PWS Waters	Monocacy River	Flow at Intake (cfs)	
PWS RMI		Distance from Outfall (mi)	Approximate 50.0 miles

Changes Since Last Permit Issuance:

Drainage Area

The discharge is to Rock Creek at RMI 16.69 mile. A drainage area upstream of the discharge is estimated to be 1.5 mi.², according to USGS StreamStats available at <https://streamstats.usgs.gov/ss/>.

Stream Flow

According to StreamStats, the point of first use has a Q₇₋₁₀ of 0.028 cfs and a drainage area of 1.5 mi.², which results in a Q₇₋₁₀ low flow yield of 0.019 cfs/mi.². This information is used to obtain a chronic or 30-day (Q₃₀₋₁₀), and an acute or 1-day (Q₁₋₁₀) exposure stream flow for the discharge point as follows (Guidance No. 391-2000-023):

$$\begin{aligned}
 Q_{7-10} &= 0.028 \text{ cfs} \\
 \text{Low Flow Yield} &= 0.028 \text{ cfs} / 1.5 \text{ mi.}^2 = 0.019 \text{ cfs/mi.}^2 \\
 Q_{30-10} &= 1.36 * 0.028 \text{ cfs} = 0.038 \text{ cfs} \\
 Q_{1-10} &= 0.64 * 0.028 \text{ cfs} = 0.018 \text{ cfs}
 \end{aligned}$$

The resulting Q₇₋₁₀ dilution ratio is: $Q_{\text{stream}} / Q_{\text{discharge}} = 0.028 \text{ cfs} / [0.018 \text{ MGD} * (1.547 \text{ cfs/MGD})] = 1.01:1$

Rock Creek

25 Pa. Code § 93.9z classifies Rock Creek as Warm Water and Migratory Fishes (WWF & MF) surface water. Based on the 2022 Integrated Report, Rock Creek, assessment unit ID 15114, is impaired for nutrients from an agriculture source & municipal point source discharge. A TMDL currently does not exist for this stream segment, therefore, no TMDL has been taken into consideration during this review.

Public Water Supply

The nearest downstream public water supply intake is the City of Frederick, MD on Monocacy River, which is more than 50.0 miles downstream of this discharge. Given the nature and dilution, the discharge is not expected to significantly impact the water supply.

Treatment Facility Summary				
Treatment Facility Name: Keller Farm Subdivision STP				
WQM Permit No.		Issuance Date		
0105408		1/26/2006		
0105408 T-1		3/31/2016		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Extended Aeration	Chlorine With Dechlorination	0.018
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.024	48	Not Overloaded		

Changes Since Last Permit Issuance: none

Per the site inspection dated December 4, 2017, the plant consists of the following treatment units:

- One bar screen
- One EQ tank
- One anoxic tank
- Three aeration tanks
- One clarifier
- One chlorine contact tank
- One post aeration
- One sludge holding

The WWTP train is proposed to be configured as follows:

Influent Screening (1) ⇒ Equalization Tank (1) ⇒ Anoxic Tank (1) ⇒ Aeration Tanks (3) ⇒ Clarifier (1) ⇒ Chlorine contact (1) ⇒ Post Aeration Unit (1) ⇒ Discharge

The chemicals used Alum for phosphorus removal, Sodium Sulfite 92% for dechlorination, and Chlorine solution 12% for disinfection.

Compliance History	
Summary of DMRs:	The DMRs reported from October 1, 2021 to September 30, 2022 are summarized in the Table below (Pages # 4, & 5).
Summary of Inspections:	<p>7/18/2022: Mr. Hoy, DEP's WQET, conducted a compliance evaluation inspection. There were no violations noted during the inspection. Recommendations were keeping the composite sampler fridge temperature at 6 °C or cooler; and submit the sludge production & disposal for each month with check box when no sludge is hauled. The filed test results were within the permit limited. The outfall 001 was clear.</p> <p>12/4/2017: Mr. Bowen, DEP WQS, conducted a compliance evaluation inspection. The field test results were within permitted limits. There were no violations identified during inspection. Effluent appeared clear.</p> <p>10/17/2016: Mr. Haines, DEP WQS, conducted a compliance evaluation inspection. The field test results were within permitted limits. Effluent appeared clear. There were no violations identified during inspection.</p>
Other Comments:	There are no open violations against the facility or the permittee.

Compliance History

DMR Data for Outfall 001 (from October 1, 2021 to September 30, 2022)

Parameter	SEP-22	AUG-22	JUL-22	JUN-22	MAY-22	APR-22	MAR-22	FEB-22	JAN-22	DEC-21	NOV-21	OCT-21
Flow (MGD) Average Monthly	0.00464 4	0.00483 2	0.00449 7	0.00497 6	0.00661 6	0.00572 3	0.00568 6	0.00511 5	0.00553 46	0.00462 9	0.00440 4	0.00418 85
Flow (MGD) Daily Maximum	0.00798 1	0.00865 9	0.00702 4	0.01011 9	0.02625	0.00999 7	0.01721 7	0.00908 9	0.01342	0.00743 6	0.00692 7	0.00775 1
pH (S.U.) Daily Minimum	7.4	7.4	7.2	7.1	7.1	7.4	7.5	7.2	7.2	7.6	7.6	7.3
pH (S.U.) Instantaneous Maximum	7.8	7.8	7.4	7.7	7.5	7.8	7.8	7.7	7.9	7.8	7.8	7.8
DO (mg/L) Daily Minimum	7.7	7.9	7.6	7.8	7.9	8.5	8.4	9.8	9.1	9.0	7.4	7.7
TRC (mg/L) Average Monthly	0.02	0.03	0.03	0.03	0.03	0.03	0.04	0.05	0.07	0.04	0.10	0.10
TRC (mg/L) Instantaneous Maximum	0.04	0.09	0.09	0.07	0.15	0.09	0.10	0.07	0.20	0.09	0.14	0.24
CBOD5 (mg/L) Average Monthly	< 2.0	< 2.0	< 2.0	< 3.0	3.0	< 2.0	3.0	3.0	< 3.0	< 2.4	< 2.9	< 2.4
TSS (mg/L) Average Monthly	3.0	5.0	3.0	2.0	7.0	5.0	2.0	2.0	8.0	1.0	1.0	1.5
Fecal Coliform (No./100 ml) Geometric Mean	< 1.0	< 1.0	< 13	< 2.0	< 2.0	6.0	< 2.0	< 1.0	< 1.0	1.0	18	< 2.0
Fecal Coliform (No./100 ml) Instantaneous Maximum	2.0	2.0	157	5.0	3.0	38	4.0	2.0	< 1.0	< 1.0	105	3.0
Nitrate-Nitrite (mg/L) Average Quarterly	< 38.02			< 58.8			< 43.07			< 5.9		
Nitrate-Nitrite (lbs) Total Quarterly	< 255			< 598			< 196			< 28		
Total Nitrogen (mg/L) Average Quarterly	< 39.56			< 60.39			< 44.68			< 18.7		
Total Nitrogen (lbs) Total Quarterly	< 265			< 613			< 203			< 88		
Ammonia (mg/L) Average Monthly	< 0.10	< 0.10	< 0.10	< 0.10	< 0.10	< 0.10	< 0.10	< 0.10	3.10	1.2	< 0.10	< 0.10
Ammonia (mg/L) Average Quarterly	< 1.0			< 0.10			< 1.1			< 0.46		

**NPDES Permit Fact Sheet
Planks Field Planned Comm STP**

NPDES Permit No. PA0247821

Ammonia (lbs) Total Quarterly	< 1.0			< 2.0			< 24			< 6		
TKN (mg/L) Average Quarterly	< 1.53			< 1.51			< 1.61			12.76		
TKN (lbs) Total Quarterly	< 10			< 15.0			< 7.0			60		
Total Phosphorus (mg/L) Average Monthly	1.2	0.60	1.7	1.6	0.60	1.2	0.50	0.50	0.40	0.40	0.60	0.80
Total Phosphorus (mg/L) Average Quarterly	1.18			1.10			0.49			0.57		
Total Phosphorus (lbs) Total Quarterly	15			22.0			8.0			9		

Development of Effluent Limitations

Outfall No. <u>001</u>	Design Flow (MGD) <u>0.018</u>
Latitude <u>39° 53' 6.00"</u>	Longitude <u>-77° 12' 9.00"</u>
Wastewater Description: <u>Sewage Effluent</u>	

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments:

Water Quality-Based Limitations

Ammonia (NH₃-N), Carbonaceous Biochemical Oxygen Demand (CBOD₅), & Dissolved Oxygen (D.O.):

WQM 7.0 version 1.1 is a water quality model designed to assist DEP to determine appropriate effluent limits for CBOD₅, NH₃-N and D.O. The model simulates two basic processes. In the NH₃-N module, the model simulates the mixing and degradation of NH₃-N in the stream and compares calculated instream NH₃-N concentrations to NH₃-N water quality criteria. In the D.O. module, the model simulates the mixing and consumption of D.O. in the stream due to the degradation of CBOD₅ and NH₃-N and compares calculated instream D.O. concentrations to D.O. water quality criteria. The model was utilized for this permit renewal by using Q₇₋₁₀ and current background water quality levels of the stream.

Ammonia (NH₃-N):

NH₃-N calculations were based on the Department's Implementation Guidance of Section 93.7 Ammonia Criteria, dated 11/4/97 (ID No. 391-2000-013). The following data is necessary to determine the in-stream NH₃-N criteria used in the attached computer model of the stream:

- * Discharge pH 7.0 (Default per 391-2000-007)
- * Discharge Temperature 25°C (Default per 391-2000-007)
- * Stream pH 7.0 (Default per 391-2000-006)
- * Stream Temperature 20°C (Default for WWF per 391-2000-003)
- * Background NH₃-N 0 mg/L (Assumed since no nearby upstream WWTPs)

Regarding NH₃-N limits, the attached computer printout of the WQM 7.0 stream model (version 1.1) indicates that a limit of 3.94 mg/L NH₃-N as a monthly average (AML) and 7.88 mg/L NH₃-N instantaneous maximum (IMAX) are necessary to protect the aquatic life from toxicity effects. However, the existing permit limits of 3.5 mg/l average monthly & 7.0 mg/L IMAX for summer and 11.0 mg/l average monthly & 22.0 mg/L IMAX for winter are more stringent and will remain in the proposed permit. Monitoring frequency will also remain the same of 2/month. DMR data and site inspections reflect that the plant is capable of meeting this limit.

CBOD₅:

The WQM 7.0 model (ver. 1.1) suggests a monthly average CBOD₅ limit of 25.0 mg/l which is the same as existing permit. Instantaneous Maximum limit will be 50.0 mg/l. The minimum monitoring frequency will remain the same as 2/month.

The D.O. goal is 6.0 mg/L. However, a minimum D.O. of 5.0 mg/L is required per 25 Pa. Code § 93.7. It is recommended that this limit be maintained in the proposed permit to ensure the protection of water quality standards. This approach is consistent with DEP's current Standard Operating Procedure (SOP) No. BPNPSM-PMT-033 and has been applied to other point source dischargers throughout the state.

pH:

The effluent discharge pH should remain above 6.0 and below 9.0 standard units according to 25 Pa. Code § 95.2(1).

Fecal Coliform:

The recent coliform guidance in 25 Pa. Code § 92a.47.(a)(4) requires a summer technology limit of 200/100 ml as a geometric mean and an instantaneous maximum not greater than 1,000/100ml and 25 Pa. Code § 92a.47.(a)(5) requires a winter limit of 2,000/100ml as a geometric mean and an instantaneous maximum not greater than 10,000/100ml.

E. Coli:

As recommended by DEP's SOP No. BCW-PMT-033, version 1.9 revised March 22, 2021, a routine monitoring for E. Coli will be included in the permit under 25 Pa. Code § 92a.61. This requirement applies to all sewage dischargers greater than 0.002 MGD in their new and reissued permits. A monitoring frequency of 1/year will be included in the permit to be consistent with the recommendation from this SOP.

Total Residual Chlorine (TRC):

Based on the attached TRC Excel Spreadsheet calculator, which uses the equations and calculations from the Department's May 1, 2003 Implementation Guidance for Total Residual Chlorine (ID No. 391-2000-015), and 0.028 cfs of Q₇₋₁₀ at discharge indicated monthly average limit of 0.16 mg/L and an instantaneous maximum limit of 0.5 mg/L are more stringent and will replace in the proposed permit. Based on the DMRs from the past year, the facility has been consistently achieving these limits.

Total Suspended Solids (TSS):

The existing limits of 30.0 mg/L average monthly, and 60.0 mg/L instantaneous maximum will remain in the proposed permit. Recent DMRs and inspection reports show that the facility has been consistently achieving concentrations below these limits.

Total Phosphorus:

The existing permit limits of 2.0 mg/l as a monthly average and 4.0 mg/l as an instantaneous maximum are being continued in this renewal, consistent with DEP's Technical Guidance for Phosphorus (391-2000-018) and 25 Pa. Code § 96.5.

Total Nitrogen:

Monitoring requirements for Total Nitrogen are being added to all NPDES permits in the State if the permit does not already include them, as authorized by 25 Pa. Code § 92a.61. Controlling nutrients in waterways requires data collection. The existing minimum monitoring and report calculation of monthly for Total Nitrogen permit will remain in the proposed permit.

Toxics:

DEP utilizes a Toxics Management Spreadsheet (TMS) (last modified on March 2021, ver. 1.3) to facilitate calculations necessary for completing a reasonable potential analysis and determining WQBELs for toxic pollutants. The effluent testing information renewal application (page 7) indicates that there are no toxic pollutants of concern.

Stormwater:

There is no known stormwater outfall associated with this facility.

Chesapeake Bay Strategy:

According to DEP's Chesapeake Bay Phase II Watershed Implementation Plan (WIP) Wastewater Supplement, this facility is considered a phase 5 non-significant sewage discharger with design flow less than 0.2 MGD but greater than 0.002 MGD. In general, DEP will issue permits for all phase 5 facilities with monitoring and reporting for Total Nitrogen (TN) and Total Phosphorus (TP) throughout the permit term at a frequency no less than annually. Furthermore, DEP's SOP No. BPNPSM-PMT-033 states that in general, at a minimum, monitoring for TN and TP should be included in new and reissued permits for sewage discharges with design flows > 2,000 gpd. At this time, the Department is not requiring a total maximum annual nitrogen or phosphorus loading cap. Ammonia-Nitrogen, Nitrate-Nitrite as N, Total Kjeldahl Nitrogen, TN, and TP monitoring is already included in the existing permit and will remain in the proposed renewal.

The quarterly "Monitor & Report" requirements for Ammonia-Nitrogen, Nitrate-Nitrite as N, and Total Kjeldahl Nitrogen; and quarterly calculation "Monitor & Report" for TN will remain in the proposed permit. The yearly calculation "report" for TP & TN will remain in the proposed permit.

Antidegradation (93.4):

The effluent limits for this discharge have been developed to ensure that existing in-stream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High-Quality Waters are impacted by this discharge. No Exceptional Value Waters are impacted by this discharge.

Class A Wild Trout Fisheries:

No Class A Wild Trout Fisheries are impacted by this discharge.

303(d) Listed Streams:

The stream is listed as attaining its designated use(s).

Additional Considerations

Flow Monitoring

Flow monitoring is recommended by the permit guidance and is also required by 25 Pa. Code §§ 92a.27 and 92a.61.

Influent Monitoring

As a result of negotiation with EPA, influent monitoring of TSS and BOD₅ are required for any POTWs; therefore, influent sampling of BOD₅ and TSS will be included in the draft permit. A 24-hr composite sample type will be required to be consistent with the proposed sampling frequency for TSS and CBOD₅ in the effluent.

WQM 7.0:

The following data were used in the attached computer model (WQM 7.0) of the stream:

- Discharge pH 7.0 (Default per 391-2000-007)
- Discharge Temperature 25°C (Default per 391-2000-013)
- Stream pH 7.0 (Default per 392-2000-013)
- Stream Temperature 20°C (Default per 392-2000-013)

The following two nodes were used in modeling:

Node 1: Outfall 001 on Rock Creek (59041)
Elevation: 506 ft (USGS National Map Viewer)
Drainage Area: 1.5 mi² (USGS PA StreamStats)
River Mile Index: 16.69 (PA DEP eMapPA)
Low Flow Yield: 0.019 cfs/mi²
Discharge Flow: 0.018 MGD

Node 2: At confluence with Unnamed Tributary 59195
Elevation: 487 ft (USGS National Map Viewer)
Drainage Area: 2.29 mi² (USGS PA StreamStats)
River Mile Index: 15.36 (PA DEP eMapPA)
Low Flow Yield: 0.019 cfs/mi²
Discharge Flow: 0.0 MGD

USGS StreamStats

SELECT A STATE / REGION
Pennsylvania

IDENTIFY A STUDY AREA
Basin Delineated

SELECT SCENARIOS

BUILD A REPORT Report Built

Step 1: You can modify computed basin characteristics here, then select the types of reports you wish to generate. Then click the "Build Report" button

Show Basin Characteristics

Select available reports to display:

- Basin Characteristics Report
- Scenario Flow Reports

Open Report

POWERED BY WIM

USGS Home Contact USGS Search USGS
Accessibility FOIA Privacy Policy & Notices

Collapse All

Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
CARBON	Percentage of area of carbonate rock	0	percent
DRNAREA	Area that drains to a point on a stream	1.5	square miles
PRECIP	Mean Annual Precipitation	41	inches
ROCKDEP	Depth to rock	4	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	2.25	miles per square mile

Low-Flow Statistics

Low-Flow Statistics Parameters [99.8 Percent (1.5 square miles) Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	1.5	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	41	inches	35	50.4
STRDEN	Stream Density	2.25	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	4	feet	3.32	5.65
CARBON	Percent Carbonate	0	percent	0	99

Low-Flow Statistics Disclaimers [99.8 Percent (1.5 square miles) Low Flow Region 2]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [99.8 Percent (1.5 square miles) Low Flow Region 2]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.0817	ft ³ /s
30 Day 2 Year Low Flow	0.123	ft ³ /s
7 Day 10 Year Low Flow	0.028	ft ³ /s
30 Day 10 Year Low Flow	0.043	ft ³ /s
90 Day 10 Year Low Flow	0.0795	ft ³ /s

Report About Help

Layers

- Base Maps
- Application Layers
- National Layers
- PA Map Layers

USGS StreamStats

SELECT A STATE / REGION
Pennsylvania

IDENTIFY A STUDY AREA
Basin Delineated

SELECT SCENARIOS

BUILD A REPORT Report Built

Step 1: You can modify computed basin characteristics here, then select the types of reports you wish to generate. Then click the "Build Report" button

Show Basin Characteristics

Select available reports to display:

- Basin Characteristics Report
- Scenario Flow Reports

Open Report

POWERED BY WIM

USGS Home Contact USGS Search USGS
Accessibility FOIA Privacy Policy & Notices

Collapse All

Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
CARBON	Percentage of area of carbonate rock	0	percent
DRNAREA	Area that drains to a point on a stream	2.29	square miles
PRECIP	Mean Annual Precipitation	41	inches
ROCKDEP	Depth to rock	4	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	2.1	miles per square mile

Low-Flow Statistics

Low-Flow Statistics Parameters [99.8 Percent (2.29 square miles) Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	2.29	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	41	inches	35	50.4
STRDEN	Stream Density	2.1	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	4	feet	3.32	5.65
CARBON	Percent Carbonate	0	percent	0	99

Low-Flow Statistics Disclaimers [99.8 Percent (2.29 square miles) Low Flow Region 2]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [99.8 Percent (2.29 square miles) Low Flow Region 2]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.139	ft ³ /s
30 Day 2 Year Low Flow	0.207	ft ³ /s
7 Day 10 Year Low Flow	0.0492	ft ³ /s
30 Day 10 Year Low Flow	0.0747	ft ³ /s
90 Day 10 Year Low Flow	0.136	ft ³ /s

Report About Help

Layers

- Base Maps
- Application Layers
- National Layers
- PA Map Layers

Analysis Results WQM 7.0

Hydrodynamics | NH3-N Allocations | D.O. Allocations | D.O. Simulation | **Effluent Limitations**

RMI	Discharge Name	Permit Number	Disc Flow (mgd)
16.69	Planks Field	PA0247821	0.0180

Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)
CBOD5	25		
NH3-N	3.94	7.88	
Dissolved Oxygen			5

Record: 1 of 1 | No Filter | Search

Print | < Back | Next > | Archive | Cancel

rptEffLimits

WQM 7.0 Effluent Limits

WQP Basin		Stream Code		Stream Name			
110	69041	ROCK CREEK					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Eff. Limit 30-day Ave. (mg/L)	Eff. Limit Maximum (mg/L)	Eff. Limit Minimum (mg/L)
16.690	Planks Field	PA0247821	0.018	CBOD5	25		
				NH3-N	3.94	7.88	
				Dissolved Oxygen			5

Wednesday, November 2, 2022 | Version 1.1 | Page 1 of 1

Page: 1 of 1 | No Filter

rpt_WLA

WQM 7.0 Wasteload Allocations

WQP Basin		Stream Code		Stream Name			
110	69041	ROCK CREEK					
NH3-N Acute Allocations							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
16.690	Planks Field	13.05	21.99	13.05	21.99	0	0
NH3-N Chronic Allocations							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
16.690	Planks Field	1.65	3.94	1.65	3.94	0	0
Dissolved Oxygen Allocations							
RMI	Discharge Name	CBOD5		NH3-N		Dissolved Oxygen	
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)
16.69	Planks Field	25	25	3.94	3.94	5	5
						0	0

Wednesday, November 2, 2022 | Version 1.1 | Page 1 of 1

Page: 1 of 1 | No Filter

rptDOSim

WQM 7.0 D.O. Simulation

SWP Basin	Stream Code	Stream Name
13D	69041	ROCK CREEK

RM	Total Discharge Flow (mgd)	Analysis Temperature (°C)	Analysis pH
16.690	0.018	22.471	7.000

Reach Width (ft)	Reach Depth (ft)	Reach WTRatio	Reach Velocity (ft/s)
4.713	0.328	14.360	0.038

Reach CBOD5 (mg/L)	Reach Kc (1/day)	Reach NH-N (mg/L)	Reach Kn (1/day)
13.37	0.761	1.95	0.847

Reach DO (mg/L)	Reach DO Goal (mg/L)
6.660	6

Reach Travel Time (days)	Subreach Results			
2.228	TravTime (days)	CBOD5 (mg/L)	NH-N (mg/L)	D.O. (mg/L)
	0.223	11.05	1.61	7.66
	0.446	9.14	1.34	7.86
	0.668	7.56	1.11	7.88
	0.891	6.25	0.92	7.88
	1.114	5.17	0.76	7.88
	1.337	4.28	0.63	7.88
	1.560	3.54	0.52	7.88
	1.783	2.92	0.43	7.88
	2.005	2.42	0.36	7.88
	2.228	2.00	0.30	7.88

Wednesday, November 2, 2022 Version 1.1 Page 1 of 1

rptModelSpecs

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows
WLA Method	EMFR	Use Inputted WLD Ratio <input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times <input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr <input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balance Technology <input checked="" type="checkbox"/>
D.O. Goal	6	

Wednesday, November 2, 2022 Version 1.1 Page 1 of 1

rptHydro

WQM 7.0 Hydrodynamic Outputs

SWP Basin	Stream Code	Stream Name
13D	69041	ROCK CREEK

RM	Stream Flow (cfs)	PWS Flow (cfs)	Net Stream Flow (cfs)	Disc. Flow (cfs)	Reach Analysis (cfs)	Depth (ft)	Width (ft)	WLD Ratio	Velocity (ft/s)	Reach Time (days)	Analysis Temp (°C)	Analysis pH
16.690	0.03	0.00	0.03	0.278	0.00271	.328	4.71	14.38	0.04	2.228	22.47	7.00

Q7-10 Flow
16.690 0.02 0.00 0.02 0.278 0.00271 NA NA NA 0.03 2.494 23.02 7.00

Q1-10 Flow
16.690 0.02 0.00 0.02 0.278 0.00271 NA NA NA 0.04 2.029 22.09 7.00

Q30-10 Flow
16.690 0.04 0.00 0.04 0.278 0.00271 NA NA NA 0.04 2.029 22.09 7.00

Wednesday, November 2, 2022 Version 1.1 Page 1 of 1

rptGeneral

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RM	Elevation (ft)	Discharge Rate (cfs)	Slope (ft/ft)	PWS Wetland (mgd)	Apply FC
13D	69041	ROCK CREEK	16.690	506.00	1.50	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data


Design Cond.	UPY (dam)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Flow (cfs)	Rch Time (days)	Rch Velocity (ft/s)	Rch Depth (ft)	Rch Width (ft)	Rch Temp (°C)	Tributary pH	Stream Temp (°C)	pH
Q7-10	0.010	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Disc Flow (mgd)	Disc Flow (mgd)	Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Planks Field	PA0247821	0.0180	0.0180	0.0180	0.000	25.00	7.00

Parameter Data				
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Rate Obs (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NH-N	25.00	0.00	0.00	0.70

Wednesday, November 2, 2022 Version 1.1 Page 1 of 2

TRC EVALUATION					
Input appropriate values in A3:A9 and D3:D9					
0.028	= Q stream (cfs)	0.5	= CV Daily		
0.018	= Q discharge (MGD)	0.5	= CV Hourly		
30	= no. samples	1	= AFC_Partial Mix Factor		
0.3	= Chlorine Demand of Stream	1	= CFC_Partial Mix Factor		
0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)		
0.5	= BAT/BPJ Value	720	= CFC_Criteria Compliance Time (min)		
0	= % Factor of Safety (FOS)		= Decay Coefficient (K)		
Source	Reference	AFC Calculations		Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 0.340		1.3.2.iii	WLA_cfc = 0.324
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 0.127		5.1d	LTA_cfc = 0.188
Source	Effluent Limit Calculations				
PENTOXSD TRG	5.1f	AML_MULT = 1.231			
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.156		AFC	
		INST MAX LIMIT (mg/l) = 0.510			
WLA_afc	$(.019/e^{-k \cdot AFC_tc}) + [(AFC_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC_tc}) \dots + Xd + (AFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$				
LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$				
LTA_afc	wla_afc * LTAMULT_afc				
WLA_cfc	$(.011/e^{-k \cdot CFC_tc}) + [(CFC_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC_tc}) \dots + Xd + (CFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$				
LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no_samples + 1)) - 2.326 \cdot LN(cvd^2 / no_samples + 1)^{0.5})$				
LTA_cfc	wla_cfc * LTAMULT_cfc				
AML_MULT	$EXP(2.326 \cdot LN((cvd^2 / no_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no_samples + 1))$				
AVG MON LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)				
INST MAX LIMIT	$1.5 \cdot ((av_mon_limit / AML_MULT) / LTAMULT_afc)$				



Existing Effluent Limitations and Monitoring Requirements

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
D.O.	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.2	XXX	0.6	1/day	Grab
CBOD ₅	XXX	XXX	XXX	25.0	XXX	50	2/month	24-Hr Composite
TSS	XXX	XXX	XXX	30.0	XXX	60	2/month	24-Hr Composite
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	2/month	Grab
Ammonia May 1 - Oct 31	XXX	XXX	XXX	3.5	XXX	7	2/month	24-Hr Composite
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	11.0	XXX	22	2/month	24-Hr Composite
Total Phosphorus	XXX	XXX	XXX	2.0	XXX	4	2/month	24-Hr Composite

Existing Effluent Limitations and Monitoring Requirements

Chesapeake Bay

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Monthly	Annual	Monthly	Monthly Average	Maximum	Instant. Maximum		
Ammonia--N	Report Total Qrtly	Report	XXX	Report Avg. Qrtly	XXX	XXX	1/quarter	24-Hr Composite
Kjeldahl--N	Report Total Qrtly	XXX	XXX	Report Avg. Qrtly	XXX	XXX	1/quarter	24-Hr Composite
Nitrate-Nitrite as N	Report Total Qrtly	XXX	XXX	Report Avg. Qrtly	XXX	XXX	1/quarter	24-Hr Composite
Total Nitrogen	Report Total Qrtly	Report	XXX	Report Avg. Qrtly	XXX	XXX	1/quarter	Calculation
Total Phosphorus	Report Total Qrtly	Report	XXX	Report Avg. Qrtly	XXX	XXX	1/quarter	24-Hr Composite

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
D.O.	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.16	XXX	0.5	1/day	Grab
CBOD ₅	XXX	XXX	XXX	25.0	XXX	50.0	2/month	24-Hr Composite
TSS	XXX	XXX	XXX	30.0	XXX	60.0	2/month	24-Hr Composite
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Ammonia May 1 - Oct 31	XXX	XXX	XXX	3.5	XXX	7.0	2/month	24-Hr Composite
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	11.0	XXX	22.0	2/month	24-Hr Composite
Total Phosphorus	XXX	XXX	XXX	2.0	XXX	4.0	2/month	24-Hr Composite

Compliance Sampling Location:

Other Comments:

Proposed Effluent Limitations and Monitoring Requirements
--

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Monthly	Annual	Monthly	Monthly Average	Maximum	Instant. Maximum		
Ammonia--N	Report Total Qrtly	Report	XXX	Report Avg. Qrtly	XXX	XXX	1/quarter	24-Hr Composite
Kjeldahl--N	Report Total Qrtly	XXX	XXX	Report Avg. Qrtly	XXX	XXX	1/quarter	24-Hr Composite
Nitrate-Nitrite as N	Report Total Qrtly	XXX	XXX	Report Avg. Qrtly	XXX	XXX	1/quarter	24-Hr Composite
Total Nitrogen	Report Total Qrtly	Report	XXX	Report Avg. Qrtly	XXX	XXX	1/quarter	Calculation
Total Phosphorus	Report Total Qrtly	Report	XXX	Report Avg. Qrtly	XXX	XXX	1/quarter	24-Hr Composite

Compliance Sampling Location:

Other Comments:

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [redacted])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [redacted])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input checked="" type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [redacted]
<input type="checkbox"/>	Other: [redacted]