



Application Type

Renewal

Facility Type

Non-Municipal

Major / Minor

Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No.

**PA0248088**

APS ID

**823945**

Authorization ID

**1507279**

**Applicant and Facility Information**

Applicant Name	<b>PA American Water Co.</b>	Facility Name	<b>Franklin WWTP</b>
Applicant Address	852 Wesley Drive	Facility Address	55 Scott School Road
	Mechanicsburg, PA 17055-4436		Orrtanna, PA 17353-9639
Applicant Contact	Vincent Ortolani	Facility Contact	David Boore
Applicant Phone	(610) 406-1398	Facility Phone	(717) 689-0493
Client ID	87712	Site ID	665661
Ch 94 Load Status	Not Overloaded	Municipality	Franklin Township
Connection Status	No Limitations	County	Adams
Date Application Received	November 18, 2024	EPA Waived?	Yes
Date Application Accepted	November 21, 2024	If No, Reason	
Purpose of Application	NPDES permit renewal.		

**Summary of Review**

PA American Water Company submitted a NPDES renewal application for discharge of treated sewage from the Franklin Waste-Water Treatment Facility located in Franklin Township, Adams County. The permit was last issued on May 13, 2020, and became effective on June 1, 2020. The existing permit expired on May 31, 2025.

The Franklin Wastewater Treatment Facility has 70% sewers from Franklin Township and 30% sewer from Hamilton-Ban Township. The NPDES permit No. PA0248088 was amended on July 29, 2014, to correct the flow of 0.2 MGD while the hydraulic design flow of 0.5 MGD. The NPDES PA0248088 amendment was issued on 2/16/2022 to replace the chlorine monitor & requirements to UV light intensity (mW/cm<sup>2</sup>) monitor & report.

The Water Quality Management (WQM) Permit No. 016404 was issued on April 17, 2007, and 016404 T-1 transfer was issued on April 22, 2014 to change the ownership from the Franklin Township, Adams County to Pennsylvania American Water Company. The WQM Part II 0106404 A-1 amendment was issued on July 1, 2020 to replace chlorine disinfection with UV disinfection.

Sludge use and disposal description and location(s): N/A because sludge is hauled by facility's contractor.

Changes from the previous permit: The E. Coli. monitoring and report requirements will add to the proposed permit.

Based on the review outline in this fact sheet, it is recommended that the permit be drafted and publish in the Pennsylvania Bulletin for public comments for 30 days.

Approve	Deny	Signatures	Date
X		Hilaryle Hilary H. Le / Environmental Engineering Specialist	March 7, 2025
X		Maria D. Bebenek for Daniel W. Martin, P.E. / Environmental Engineer Manager	March 18, 2025

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.2
Latitude	39° 51' 47.00"	Longitude	-77° 19' 2.00"
Quad Name	Fairfield	Quad Code	
Wastewater Description:	Sewage Effluent		
Receiving Waters	Unnamed Tributary to Marsh Creek (CWF)	Stream Code	59009
NHD Com ID	53319832	RMI	1.92 miles
Drainage Area	1.85 mi. <sup>2</sup>	Yield (cfs/mi <sup>2</sup> )	See comments below
Q <sub>7-10</sub> Flow (cfs)	See comments below	Q <sub>7-10</sub> Basis	
Elevation (ft)	584	Slope (ft/ft)	
Watershed No.	13-D	Chapter 93 Class.	CWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Impaired		
Cause(s) of Impairment	Flow Regime Modification,		
Source(s) of Impairment	Highway/Road/Bridge Runoff (Non-Construction Related), Rural (Residential Areas)		
TMDL Status	Name		
Nearest Downstream Public Water Supply Intake	Gettysburg Municipal Authority, Adams County		
PWS Waters	Marsh Creek	Flow at Intake (cfs)	
PWS RMI	8.12 miles	Distance from Outfall (mi)	Approximate 9.0 miles

Changes Since Last Permit Issuance:

#### Drainage Area

The discharge is to Unnamed Tributary 59009 to Marsh Creek at RMI 1.92 miles. A drainage area upstream of the discharge is estimated to be 1.85 mi.<sup>2</sup>, according to USGS PA StreamStats available at <https://streamstats.usgs.gov/ss/>.

#### Streamflow

The entire watershed of UNT 59009 is also too small. Therefore, the upper portion of Marsh Creek (until just after its confluence with Mummasburg Run) was chosen as a proper representative drainage area. According to USGS StreamStats, the Q<sub>7-10</sub> at the exit point of this watershed is 1.11 cfs and the drainage area is 21.3 mi.<sup>2</sup> which results in a Q<sub>7-10</sub> low flow yield of 0.052 cfs/mi.<sup>2</sup>. This information is used to obtain a chronic or 30-day (Q<sub>30-10</sub>), and an acute or 1-day (Q<sub>1-10</sub>) exposure stream flow for the discharge point as follows (Guidance No. 391-2000-023):

$$\begin{aligned}
 \text{Low Flow Yield} &= 1.11 \text{ cfs} / 21.3 \text{ mi.}^2 \approx 0.052 \text{ cfs/mi.}^2 \\
 Q_{7-10} &= 0.052 \text{ cfs/mi.}^2 * 1.85 \text{ mi.}^2 \approx 0.096 \text{ cfs} \\
 Q_{30-10} &= 1.36 * 0.096 \text{ cfs} \approx 0.13 \text{ cfs} \\
 Q_{1-10} &= 0.64 * 0.096 \text{ cfs} \approx 0.061 \text{ cfs}
 \end{aligned}$$

The resulting dilution ratio (under Q<sub>7-10</sub> conditions) is: Q<sub>stream</sub> / Q<sub>discharge</sub> = 0.096 cfs / [0.20 MGD \* (1.55 cfs/MGD)] = 0.3:1

#### Unnamed Tributary to Marsh Creek

25 Pa Code § 93.9z classifies Tributaries 59009 to Marsh Creek as cold-water fishes. The eMap PA lists Unnamed Tributary to Marsh Creek as impaired due to small residential runoff and road runoff caused by flow regime modification. A TMDL does not currently exist for this stream segment.

#### Public Water Supply

The nearest downstream public water supply is Gettysburg Municipal Authority facility, Adams County on Marsh Creek Reservoir, approximately 9.0 miles downstream of the discharge point. Based on the nature of discharge, the discharge is not expected to impact the public water supply standards.

Treatment Facility Summary												
<b>Treatment Facility Name:</b> Franklin Township Cashtown McKnightstown STP												
<table border="1"> <thead> <tr> <th>WQM Permit No.</th><th>Issuance Date</th></tr> </thead> <tbody> <tr> <td>0106404</td><td>4/17/2007</td></tr> <tr> <td>0106404 T-1</td><td>4/22/2014</td></tr> <tr> <td>0106404 A-1</td><td>7/1/2020</td></tr> </tbody> </table>		WQM Permit No.	Issuance Date	0106404	4/17/2007	0106404 T-1	4/22/2014	0106404 A-1	7/1/2020			
WQM Permit No.	Issuance Date											
0106404	4/17/2007											
0106404 T-1	4/22/2014											
0106404 A-1	7/1/2020											
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)								
Sewage	Secondary With Ammonia And Phosphorus	Sequencing Batch Reactor	Ultraviolet	0.2								
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal								
0.5	459	Not Overloaded	Aerobic Digestion	Other WWTP								

Changes Since Last Permit Issuance:

**Other Comments:**

The WWTP train is as follows:

Mechanical Screen (1) ⇒ Bar Screen (1) ⇒ SBR Tanks (2) ⇒ UV Disinfection (1) ⇒ Cascade (1) ⇒ Discharge

**Industrial/Commercial Users:**

There are no industrial/commercial users contributing to this treatment plant.

**Biosolids Management:**

Liquid biosolids are hauled off site by facility's contractor.

Compliance History	
<b>Summary of DMRs:</b>	DMRs reported last 12 months are summarized in the Table below.
<b>Summary of Inspections:</b>	2/1/2024: Mr. Hoy, DEP WQS, conducted a compliance evaluation inspection. The discharge was clear. The field test results indicated in permit limits. There were no violations noted during inspection. Recommendation was to ensure the influent composite sampler has proper refrigeration. Requests were 1. Correct hauler name be provided on sludge hauling supplemental reports. 2. The sludge use and disposal records going back at least 5 years are readily available to review for future inspections. 3. The general work plan and system specific management plan completed, signed by the owner, and available for review upon request. 4. The composite samples are flow proportional to ensure samples are collected during discharges.
<b>Other comments:</b>	There are no open violations associated with this facility or permittee.

Other Comments: 

Compliance History

DMR Data for Outfall 001 (from February 1, 2024 to January 31, 2025)

Parameter	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24	APR-24	MAR-24	FEB-24
Flow (MGD) Average Monthly	0.0552	0.0596	0.0545	0.0599	0.0573	0.0679	0.0546	0.0539	0.0656	0.1092	0.0987	0.0844
Flow (MGD) Daily Maximum	0.0751	0.1182	0.0765	0.1198	0.0927	0.2003	0.0748	0.0832	0.1208	0.4575	0.2173	0.1504
pH (S.U.) Daily Minimum	6.9	6.9	6.9	6.7	6.8	6.8	6.6	6.8	6.9	6.9	6.9	6.9
pH (S.U.) Instantaneous Maximum	7.6	7.8	7.4	7.5	7.1	7.3	7.2	7.3	7.3	8.1	7.4	7.3
DO (mg/L) Daily Minimum	6.3	6.1	5.5	5.8	5.4	5.3	5.1	5.2	5.2	5.9	5.9	5.9
CBOD5 (lbs/day) Average Monthly	< 3.0	3.0	< 2.0	3.0	3.0	< 2.0	4.0	2.0	< 1.0	< 3.0	< 3.0	< 2.0
CBOD5 (lbs/day) Weekly Average	5.0	4.0	4.0	5.0	4.0	4.0	4.0	2.0	2.0	< 5.0	3.0	3.0
CBOD5 (mg/L) Average Monthly	< 7.0	5.0	< 4.1	4.9	6.9	< 4.2	8.0	3.8	< 2.9	< 3.3	3.6	< 3.0
CBOD5 (mg/L) Weekly Average	9.9	7.6	6.9	8.7	6.9	5.8	9.8	4.0	3.6	4.9	5.1	3.6
BOD5 (lbs/day) Raw Sewage Influent   Weekly Average	110	144	125	152	119	110	86	308	303	293	332	222
BOD5 (lbs/day) Raw Sewage Influent   Daily Maximum	129	261	191	250	128	189	98	489	336	550	420	261
BOD5 (mg/L) Raw Sewage Influent Average Monthly	249	247	250	291	232	239	200	608	617	340	486	302
TSS (lbs/day) Average Monthly	4.4	3.8	1.5	3.3	2.5	0.8	1.0	1.2	1.7	1.5	1.8	1.6
TSS (lbs/day) Raw Sewage Influent Average Monthly	63	181	138	193	147	144	77	398	423	180	268	275
TSS (lbs/day) Raw Sewage Influent   Daily Maximum	84	335	187	348	185	244	109	496	519	248	285	408
TSS (lbs/day) Weekly Average	9.4	7.3	2.3	9.1	4.5	1.7	1.9	1.5	3.3	1.9	2.9	2.5

## NPDES Permit Fact Sheet

## Franklin WWTP

## NPDES Permit No. PA0248088

TSS (mg/L) Average Monthly	9.0	7.0	3.0	5.0	5.0	2.0	2.0	3.0	4.0	2.0	3.0	2.0
TSS (mg/L) Raw Sewage Influent Average Monthly	138	308	281	346	284	313	178	803	849	256	3585	398
TSS (mg/L) Weekly Average	19.0	17.0	5.0	10.0	8.0	4.0	5.0	4.0	7.0	3.0	3.0	2.0
Fecal Coliform (No./100 ml) Geometric Mean	< 1	< 1.0	< 1.0	< 1.0	< 1.0	< 2.0	< 2	< 2.0	< 1.0	< 1.0	< 1.0	< 1.0
Fecal Coliform (No./100 ml) Instantaneous Maximum	< 1	3.0	1.0	< 1.0	< 1.0	39	68	5.0	1.0	< 1.0	2.0	1.0
UV Intensity (mW/cm <sup>2</sup> ) Daily Minimum	66.3	66.7	66.9	69	66.1	62.6	68.3	67.3	70.7	71.8	69.9	69.9
Nitrate-Nitrite (mg/L) Average Monthly	< 5.78	< 18.8	< 20.9	< 17.4	< 19.2	< 17.1	19.4	< 14.4	< 14.4	< 9.7	< 9.1	< 10.93
Nitrate-Nitrite (lbs) Total Monthly	< 69	< 394	< 274	< 259	< 10	< 217	< 272	231	231	< 196	< 195	< 202
Total Nitrogen (lbs/day) Average Monthly	12.0	< 15	< 10	< 9.0	10	< 7.0	< 9.0	< 8.0	< 8.0	< 7.0	< 7.0	< 7.0
Total Nitrogen (mg/L) Average Monthly	31.28	< 20.7	< 22	< 17.9	19.72	< 18.2	< 20.3	< 15.2	< 16.4	< 10.3	9.6	< 11.43
Total Nitrogen (lbs) Total Annual		3579										
Ammonia (lbs/day) Average Monthly	8.3	1.0	< 0.6	< 0.06	< 0.05	< 0.05	< 0.04	< 0.05	< 0.09	< 0.1	< 0.08	< 0.3
Ammonia (mg/L) Average Monthly	18.0	< 2.0	< 1.0	< 0.01	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.25
Ammonia (lbs) Total Monthly	257.0	31.1	< 17.3	< 1.7	< 1.6	< 1.5	< 1.3	< 1.5	< 2.9	< 3.2	< 2.4	< 7.8
Ammonia (lbs) Total Annual		146										
TKN (mg/L) Average Monthly	26	< 2.0	< 1.1	< 0.5	< 0.57	< 1.1	< 0.9	< 0.8	2.0	< 0.5	< 0.5	< 0.5
TKN (lbs) Total Monthly	317	< 56	< 14	< 8.0	< 9.0	< 14	< 13	< 14.0	< 29	< 10	< 11.0	< 9.0
Total Phosphorus (lbs/day) Average Monthly	2.1	2.2	1.5	3.4	3.3	2.1	5.2	4.4	1.9	2.8	1.6	1.4
Total Phosphorus (mg/L) Average Monthly	5.2	3.3	3.6	6.3	5.7	5.3	12	7.8	3.5	4.1	2.5	2.2

NPDES Permit Fact Sheet  
Franklin WWTP

NPDES Permit No. PA0248088

Total Phosphorus (lbs)	63.9	69.5	46.3	106.8	99.0	66.0	180.4	130.8	58.0	79.0	49.7	39.7
Total Monthly												
Total Phosphorus (lbs)		967										
Total Annual												

Existing Effluent Limitations and Monitoring Requirements

Outfall 001,

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
D.O.	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
UV Intensity (mW/cm <sup>2</sup> )	XXX	XXX	Report	XXX	XXX	XXX	1/day	Measured
CBOD <sub>5</sub>	41.7	66.7 Wkly Avg	XXX	25.0	40.0	50.0	1/week	24-Hr Composite
TSS	50.0	75.1 Wkly Avg	XXX	30.0	45.0	60.0	1/week	24-Hr Composite
Biochemical Oxygen Demand (BOD <sub>5</sub> ) Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Total Suspended Solids Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	1/week	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	1/week	Grab
Ammonia May 1 - Oct 31	4.2	XXX	XXX	2.5	XXX	5.0	1/week	24-Hr Composite
Ammonia Nov 1 - Apr 30	12.5	XXX	XXX	7.5	XXX	15.0	1/week	24-Hr Composite
Total Phosphorus	Report	XXX	XXX	Report	XXX	XXX	2/month	24-Hr Composite

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Monthly	Annual	Monthly	Average Monthly	Maximum	Instant. Maximum		
Ammonia--N	Report	Report	XXX	XXX	XXX	XXX	1/week	24-Hr Composite
Kjeldahl--N	Report	XXX	XXX	Report	XXX	XXX	2/month	24-Hr Composite
Nitrate-Nitrite as N	Report	XXX	XXX	Report	XXX	XXX	2/month	24-Hr Composite
Total Nitrogen	Report	Report	XXX	Report	XXX	XXX	2/month	Calculation
Total Phosphorus	Report	Report	XXX	Report	XXX	XXX	2/month	24-Hr Composite

**Development of Effluent Limitations**

Outfall No. 001  
Latitude 39° 51' 47.00"  
Wastewater Description: Sewage Effluent

Design Flow (MGD) 0.2  
Longitude -77° 19' 2.00"

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: The facility utilizes UV for disinfection.

**Water Quality-Based Limitations**

**Ammonia (NH<sub>3</sub>-N):**

NH<sub>3</sub>-N calculations were first based on the Department's Implementation Guidance of Section 93.7 Ammonia Criteria, dated 11/4/97 (ID No. 391-2000-013). The following data is necessary to determine the in-stream NH<sub>3</sub>-N criteria used in the attached computer model of the stream:

Discharge pH = 7.0 (Default)  
Discharge Temperature = 20°C (Default)  
Stream pH = 7.0 (Default)  
Stream Temperature = 20°C (Default for CWF)  
Background NH<sub>3</sub>-N = 0 (Default)

Analysis Results WQM 7.0

Hydrodynamics		NH <sub>3</sub> -N Allocations		D.O. Allocations		D.O. Simulation		Effluent Limitations			
RMI	Discharge Name	Permit Number Disc Flow (mgd)									
1.92	Franklin WWTP	PA0248088 0.2000									
		Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)						
		CBOD <sub>5</sub>	25								
		NH <sub>3</sub> -N	2.68	5.36	5						
		Dissolved Oxygen									
Record: 1 of 1 < Back Next > No Filter Search											
Print		< Back		Next >		Archive		Cancel			

The model input data and results are attached. The printout of the WQM 7.0 output indicates that at a discharge of 0.200 MGD, limits (rounded according to the NPDES Technical Guidance 362-0400-001) of 2.5 mg/L NH<sub>3</sub>-N as a monthly average and 5.0 mg/L NH<sub>3</sub>-N instantaneous maximum are necessary to protect the aquatic life from toxicity effects. The existing summer limits of 2.5 mg/L and 5.0 mg/L will remain in the proposed permit. Mass limits are calculated as follows:

Average monthly summer mass limit: 2.5 mg/L x 0.20 MGD x 8.34 = 4.2 lbs/day

The winter effluent limit will be set at three-times the summer limits; therefore, the average monthly winter limit for NH<sub>3</sub>-N will be 7.5 mg/L (2.5 mg/L x 3). For the same reason, the instantaneous maximum limit for the winter season will be 15 mg/L (5 mg/L x 3). Recent DMRs and inspection reports indicate that these limits are being attained easily.

Average monthly winter mass limit: 7.5 mg/L x 0.20 MGD x 8.34 = 12.5 lbs/day

***Carbonaceous Biochemical Oxygen Demand (CBOD<sub>5</sub>):***

The attached computer printout of the WQM 7.0 stream model indicates that a monthly average limit of 25.0 mg/L, or secondary treatment, is adequate to protect the water quality of the stream. The existing limits of 25.0 mg/L average monthly (AML), 40.0 mg/L average weekly limit (AWL), and 50.0 mg/L instantaneous maximum will remain in the proposed permit as per guidance document 391-2000-014. Recent DMRs and inspection reports show that the facility has been consistently achieving these limits. Mass limits are calculated as follows:

Average monthly mass limit: 25.0 mg/L x 0.20 MGD x 8.34 = 41.7 (42.0) lbs/day

Average weekly mass limit: 40.0 mg/L x 0.20 MGD x 8.34 = 66.7 (67.0) lbs/day

***Dissolved Oxygen (D.O.):***

A minimum D.O. of 5.0 mg/L is required per 25 Pa. Code § 93.7. This is consistent with the previous permit and current Department criteria.

***pH:***

The effluent discharge pH should remain above 6 and below 9 standard units according to 25 Pa Code § 95.2(2).

***Fecal Coliform:***

The recent coliform guidance in 25 Pa. Code § 92a.47.(a)(4) requires a summer technology limit of 200/100 ml as a geometric mean and an instantaneous maximum not greater than 1,000/100 ml and 25 Pa. Code § 92a.47.(a)(5) requires a winter limit of 2,000/100 ml as a geometric mean and an instantaneous maximum not greater than 10,000/100 ml.

***E. Coli:***

As recommended by DEP's SOP No. BCW-PMT-033, version 2.0 revised February 5, 2024, a routine monitoring for E. Coli will be included in the proposed permit under 25 Pa. Code § 92a.61. This requirement applies to all sewage dischargers greater than 0.002 MGD in their new and reissued permits. A monitoring frequency of 1/quarter will be included in the permit to be consistent with the recommendation from this SOP.

***Total Suspended Solids (TSS):***

There is no water quality criterion for TSS. A limit of 30.0 mg/L AML will be required based on the minimum level of effluent quality attainable by secondary treatment as defined in 40 CFR 133.102b(1) and 25 PA § 92a.47(a)(1), and an AWL of 45.0 mg/L per 40CFR 133.102(b)(2) and 25 PA § 92a.47(a)(2). Past DMRs and inspection reports show that the facility has been consistently achieving these limits. Mass limits are calculated as follows:

Average monthly mass limit: 30.0 mg/L x 0.20 MGD x 8.34 = 50.0 lbs/day

Average weekly mass limit: 45.0 mg/L x 0.20 MGD x 8.34 = 75.1 lbs/day

***Chesapeake Bay Strategy:***

The Department formulated a strategy to comply with the EPA and Chesapeake Bay Foundation requirements by reducing point source loadings of Total Nitrogen (TN) and Total Phosphorus (TP). Sewage discharges have been prioritized by Central Office based on their delivered TN loadings to the Bay. The highest priority (Phases I, II, and III) dischargers will receive annual loading caps based on their design flow on August 29, 2005 and concentrations of 6 mg/L TN and 0.8 mg/L TP. These limits may be achieved through a combination of treatment technology, credits, or offsets. Phase IV (0.2 - 0.4 MGD) will be required to monitor and report TN and TP during permit renewal monthly and Phase V (below 0.2 MGD) will monitor during current permit renewal once a year. However, any facility in Phases IV and V that undergoes expansion is subjected to cap load right away. This plant is classified as phase IV, it will be required to monitor and report TP and TN 2/month. TN and TP "Monitor & Report" requirements will remain in the proposed permit.

The UV system daily monitor and report the UV light intensity ( $\text{mW/cm}^2$ ) will remain in the proposed permit.

### **Additional Considerations**

#### *Flow Monitoring*

The requirement to monitor the volume of effluent will remain in the proposed permit per 40 CFR § 122.44(i)(1)(ii).

#### *Monitoring Frequency and Sample Type*

The facility currently is required to collect daily effluent grab samples for D.O., and pH; one per week effluent 24-hr composite samples of  $\text{CBOD}_5$ , TSS, and Ammonia-Nitrogen; one per week effluent grab samples of Fecal Coliform; two per month effluent 24-hr composite samples of Nitrate-Nitrite as N, Total Kjeldahl Nitrogen, and TP; and two per month effluent calculation samples of TN. Based on the best professional judgement of the author, the existing monitoring frequencies are sufficient and necessary. Therefore, the existing monitoring frequencies will remain the same as those specified in the proposed permit.

### **Antidegradation (93.4)**

The effluent limits for this discharge have been developed to ensure that existing in-stream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High-Quality Waters are impacted by this discharge. No Exceptional Value Waters are impacted by this discharge.

### **303d Listed Streams**

eMap PA lists UNT to Marsh Creek as impaired at the discharge point for "flow regime modification" due to small residential runoff and road runoff. A TMDL has not yet been developed.

### **Class A Wild Trout Fisheries**

No Class A Wild Trout Fisheries are impacted by this discharge.

### **WQM 7.0**

Two nodes were incorporated in the modeling effort.

Discharge pH	=	7.0	(Default)
Discharge Temperature	=	20°C	(Default)
Stream pH	=	7.0	(Default)
Stream Temperature	=	20°C	(Default for CWF)
Background $\text{NH}_3\text{-N}$	=	0	(Default)

#### Node 1: Outfall 001 on UNT Marsh Creek (59009)

Elevation:	584 ft (USGS National Map Viewer)
Drainage Area:	1.85 mi. <sup>2</sup> (USGS PA StreamStats)
River Mile Index:	1.92 (PA DEP eMapPA)
Low Flow Yield:	0.052 cfs/mi. <sup>2</sup>
Discharge Flow:	0.200 MGD (NPDES Application)

#### Node 2: Just before confluence with UNT Marsh Creek with Marsh Creek

Elevation:	539 ft (USGS National Map Viewer)
Drainage Area:	3.05 mi. <sup>2</sup> (USGS PA StreamStats)
River Mile Index:	0.001 (PA DEP eMapPA)
Low Flow Yield:	0.052 cfs/mi. <sup>2</sup>
Discharge Flow:	0.000 MGD

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Daily Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
D.O.	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
UV Intensity (mW/cm <sup>2</sup> )	XXX	XXX	Report	XXX	XXX	XXX	1/day	Measured
CBOD <sub>5</sub>	41.7	66.7	XXX	25.0	40.0	50	1/week	24-Hr Composite
BOD <sub>5</sub> Raw Sewage Influent	Report Wkly Avg	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
TSS	50.0	75.1	XXX	30.0	45.0	60	1/week	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
Ammonia Nov 1 - Apr 30	12.5	XXX	XXX	7.5	XXX	15	1/week	24-Hr Composite
Ammonia May 1 - Oct 31	4.2	XXX	XXX	2.5	XXX	5	1/week	24-Hr Composite
Total Phosphorus	Report	XXX	XXX	Report	XXX	XXX	2/month	24-Hr Composite

Compliance Sampling Location: 



Other Comments: 

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Monthly	Annual	Monthly	Average Monthly	Maximum	Instant. Maximum		
Ammonia--N	Report	Report	XXX	XXX	XXX	XXX	1/week	24-Hr Composite
Kjeldahl--N	Report	XXX	XXX	Report	XXX	XXX	2/month	24-Hr Composite
Nitrate-Nitrite as N	Report	XXX	XXX	Report	XXX	XXX	2/month	24-Hr Composite
Total Nitrogen	Report	Report	XXX	Report	XXX	XXX	2/month	Calculation
Total Phosphorus	Report	Report	XXX	Report	XXX	XXX	2/month	24-Hr Composite



# NPDES Permit Fact Sheet

## Franklin WWTP

NPDES Permit No. PA0248088

Parameter Code	Parameter Description	Value	Unit
CARBON	Percentage of area of carbonate rock	0	percent
DRNAREA	Area that drains to a point on a stream	21.3	square miles
PRECIP	Mean Annual Precipitation	42	inches
ROCKDEP	Depth to rock	4.7	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	2.28	miles per square mile

Parameter Code	Parameter Description	Value	Unit
CARBON	Percentage of area of carbonate rock	0	percent
DRNAREA	Area that drains to a point on a stream	21.3	square miles
PRECIP	Mean Annual Precipitation	42	inches
ROCKDEP	Depth to rock	4.7	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	2.28	miles per square mile

Parameter Code	Parameter Description	Value	Unit
CARBON	Percentage of area of carbonate rock	0	percent
DRNAREA	Area that drains to a point on a stream	21.3	square miles
PRECIP	Mean Annual Precipitation	42	inches
ROCKDEP	Depth to rock	4.7	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	2.28	miles per square mile

Parameter Code	Parameter Description	Value	Unit
CARBON	Percentage of area of carbonate rock	0	percent
DRNAREA	Area that drains to a point on a stream	21.3	square miles
PRECIP	Mean Annual Precipitation	42	inches
ROCKDEP	Depth to rock	4.7	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	2.28	miles per square mile

Parameter Code	Parameter Description	Value	Unit
CARBON	Percentage of area of carbonate rock	0	percent
DRNAREA	Area that drains to a point on a stream	21.3	square miles
PRECIP	Mean Annual Precipitation	42	inches
ROCKDEP	Depth to rock	4.7	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	2.28	miles per square mile

Parameter Code	Parameter Description	Value	Unit
CARBON	Percentage of area of carbonate rock	0	percent
DRNAREA	Area that drains to a point on a stream	21.3	square miles
PRECIP	Mean Annual Precipitation	42	inches
ROCKDEP	Depth to rock	4.7	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	2.28	miles per square mile

Analysis Results WQM 7.0

Hydrodynamics NH3-N Allocations D.O. Allocations D.O. Simulation Effluent Limitations

RMI	Discharge Name	Permit Number	Disc Flow (mgd)
1.92	Franklin WWTP	PA0248088	0.2000
Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)
CBOD5	25		
NH3-N	2.68	5.36	
Dissolved Oxygen			5

Record: 1 of 1 No Filter Search

Print < Back Next > Archive Cancel

rptEffLimits

WQM 7.0 Effluent Limits

SWP Basin	Stream Code	Stream Name					
13D	59009	Trib 59009 to Marsh Creek					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Eff. Limit 30-day Ave. (mg/L)	Eff. Limit Maximum (mg/L)	Eff. Limit Minimum (mg/L)
1.920	Franklin WWTP	PA0248088	0.200	CBOD5	25		
				NH3-N	2.68	5.36	
				Dissolved Oxygen			5

Thursday, March 6, 2025 Version 1.1 Page 1 of 1

rpt\_WLA

WQM 7.0 Wasteload Allocations

SWP Basin	Stream Code	Stream Name							
13D	59009	Trib 59009 to Marsh Creek							
NH3-N Allocations									
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction		
1.920 Franklin WWTP		16.76	20.1	16.76	20.1	0	0		
NH3-N Chronic Allocations									
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction		
1.920 Franklin WWTP		1.89	2.68	1.89	2.68	0	0		
Dissolved Oxygen Allocations									
RMI	Discharge Name	CBOD5 Baseline (mg/L)	CBOD5 Multiple (mg/L)	NH3-N Baseline (mg/L)	NH3-N Multiple (mg/L)	Dissolved Oxygen Baseline (mg/L)	Dissolved Oxygen Multiple (mg/L)	Critical Reach	Percent Reduction
1.920 Franklin WWTP		25	25	2.68	2.68	5	5	0	0

Thursday, March 6, 2025 Version 1.1 Page 1 of 1

Page: 1 No Filter

NPDES Permit Fact Sheet  
Franklin WWTP

NPDES Permit No. PA0248088

**rptDOSim**

**WQM 7.0 D.O. Simulation**

SWP Basin	Stream Code	Stream Name
130	580009	Trib 580009 to March Creek
RM	Total Discharge Flow (cfs)	Available Temperature (°C)
1.920	0.00	19.14
Reach Width (ft)	Reach Depth (ft)	Reach W/D Ratio
4.115	0.440	16.138
Reach CDO (mg/L)	Reach R/H (days)	Reach Nitr (mg/L)
0.768	1.41	0.78
Reach DO (mg/L)	Reach R/H (days)	Reach DO (mg/L)
22.561	0.50	8.700
Reach Travel Time (days)		W.Equation
5.070		Others
Sub Reach Results		D.O.
Travel Time (days)	mg/L	mg/L
0.107	16.00	1.90
0.214	14.44	1.76
0.321	12.42	1.64
0.428	10.80	1.52
0.535	9.17	1.41
0.642	7.69	1.31
0.749	6.78	1.21
0.856	5.92	1.13
0.963	5.01	1.04
1.070	4.31	0.97
		8.24

Thursday, March 6, 2025      Version 1.1      Page 1 of 1

**rptModelSpecs**

**WQM 7.0 Modeling Specifications**

Parameter	Value	Notes
W/LA Method	Both	Use Inputted Q1-10 and Q30-10 Flows
EMPR		Use Inputted W/D Ratio
Q1-10/Q1-10 Ratio	0.61	Use Inputted Reach Travel Times
Q30-10/Q1-10 Ratio	1.36	
Temperature Adjust. %	10.00%	
D.O. Saturation	90.00%	
D.O. Goal	5	Use Balanced Technology

Thursday, March 6, 2025      Version 1.1      Page 1 of 1

**rptHydro**

**WQM 7.0 Hydrodynamic Outputs**

SWP Basin	Stream Code	Stream Name								
130	580009	Trib 580009 to March Creek								
RM	Stream Flow (cfs)	Net Stream Flow (cfs)	Net Stream Flow (cfs)	Reach Depth (ft)	Width (ft)	W/D Ratio	Velocity (ft/s)	Travel Time (days)	Available Temp (°C)	Analysis pH
1.920	0.10	0.00	0.10	30.94	0.00044	.44	0.41	19.14	0.11	7.00
<b>Q1-10 Flow</b>										
1.920	0.06	0.00	0.06	30.94	0.00044	NA	NA	NA	0.10	7.00
<b>Q30-10 Flow</b>										
1.920	0.13	0.00	0.13	30.94	0.00044	NA	NA	NA	0.11	7.00

Thursday, March 6, 2025      Version 1.1      Page 1 of 1

**rptGeneral**

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RM	Deviation	Downstream	Slope	PWS	Whitman	Apply PC
130	580009	Trib 580009 to March Creek	1.920	50.00	1.85	0.00000	0.00	<input checked="" type="checkbox"/>	

**Stream Data**

Design Cond.	LFY	Trib Flow (cfs)	Stream Flow (cfs)	Rds	Rich	WD Ratio	Rich Width (ft)	Rich Depth (ft)	Reach Temp (°C)	Stream pH
Q1-10	0.052	0.00	0.00	0.0000	0.0	0.00	0.00	0.00	20.00	7.00
Q1-10	0.00	0.00	0.00	0.0000	0.0	0.00	0.00	0.00	0.00	0.00
Q30-10	0.00	0.00	0.00	0.0000	0.0	0.00	0.00	0.00	0.00	0.00

**Discharge Data**

Name	Permit Number	Design Discharge (mgd)	Permit Discharge (mgd)	Design Dia. Flow (mgd)	Permit Dia. Flow (mgd)	Design Dia. Flow (mgd)	Permit Dia. Flow (mgd)	Design Dia. Flow (mgd)	Permit Dia. Flow (mgd)
Franklin WWTP	PA0248088	0.2000	0.2000	0.2000	0.0000	0.0000	0.0000	0.0000	0.0000

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Rate Const (1/day)
CO2	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NH4N	25.00	0.00	0.00	0.70

Thursday, March 6, 2025      Version 1.1      Page 1 of 2

16

rptGeneral

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft)	PWS Withdrawal (mgd)	Apply PC
13D	59009	Trib 59009 to Marsh Creek	0.001	536.00	3.05	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow (cfs)	Stream Flow (cfs)	Rich Trav Time (days)	Rich Velocity (fps)	WD Ratio	Rich Width (ft)	Rich Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)	Stream pH
Q740	0.052	0.00	0.00	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q140	0.00	0.00	0.00	0.000							
Q3640	0.00	0.00	0.00	0.000							

Discharge Data

Name	Permit Number	Existing Disc. Flow (mgd)	Permitted Disc. Flow (mgd)	Design Disc. Flow (mgd)	Recover Factor	Disc. Temp (°C)	Disc. pH
Franklin WWTP	PA0248088	0.0000	0.0000	0.0000	0.000	20.00	7.00

Parameter Data

Parameter Name	Disc. Conc. (mg/L)	Trib. Conc. (mg/L)	Streams Conc. (mg/L)	Fate (day)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NH3N	25.00	0.00	0.00	0.70

Thursday, March 6, 2025

Version 1.1

Page 2 of 2

Page: 14  <input type="button"

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [REDACTED])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input checked="" type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: BCW-PMT-033
<input type="checkbox"/>	Other: [REDACTED]