

Application Type Renewal
Facility Type Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. **PA0252522**
APS ID **1113199**
Authorization ID **1484189**

Applicant and Facility Information

Applicant Name	Somerset Township Municipal Authority	Facility Name	Lavansville STP
Applicant Address	PO Box 247	Facility Address	Bunyan Drive
	Somerset, PA 15501-0247		Somerset, PA 15501
Applicant Contact	Carolyn Zambanini	Facility Contact	Carolyn Zambanini
Applicant Phone	(814) 445-5842	Facility Phone	(814) 445-5842
Client ID	25312	Site ID	619929
Ch 94 Load Status		Municipality	Somerset Township
Connection Status		County	Somerset
Date Application Received	<u>May 2, 2024</u>	EPA Waived?	Yes
Date Application Accepted		If No, Reason	
Purpose of Application	Permit Renewal		

Summary of Review

Applicant requests renewal of an NPDES permit to discharge treated sewage from Lavansville STP and was previously issued on October 3, 2019. The discharge is to the West Branch Coxes Creek, which is classified as a warm water fishery.

Municipalities served by the STP are Somerset Township and Somerset Borough.

The treatment process consists of screening, an SBR treatment system and ultra-violet disinfection.
No upgrades are proposed at this renewal.

DMR review shows the discharge is in compliance with the existing permit limits. No comments received from Operations Section.

There are no changes to the receiving stream, the discharge, influent characteristics etc.
Recommended effluent limits are similar to the existing permit limits.

Sludge use and disposal description and location(s): Sludge is disposed at other Sewage Treatment Plants.

Approve	Deny	Signatures	Date
X		<i>Sara Abraham</i> Sara Reji Abraham, E.I.T. / Project Manager	June 17, 2024
X		<i>Pravin Patel</i> Pravin C. Patel, P.E. / Environmental Engineer Manager	06/18/2024

Summary of Review

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Act 14 Notifications:

Somerset Township - March 15, 2024
Somerset County - March 15, 2024

Permits Conditions:

- A. No Stormwater
- B. Acquire Necessary Property Rights
- C. Proper Sludge Disposal
- D. Chlorine Optimization
- E. Operator Notification
- F. Hauled-In Waste Restrictions
- G. Solids Management

Discharge, Receiving Waters and Water Supply Information

Outfall No.	001	Design Flow (MGD)	.15
Latitude	40 0' 29.94"	Longitude	-79° 7' 11.26"
Quad Name	Somerset	Quad Code	1813
Wastewater Description:	Treated Sewage Effluent		
Receiving Waters	West Branch Coxes Creek (WWF)	Stream Code	38979
NHD Com ID	69916487	RMI	3.4
Drainage Area	7.84	Yield (cfs/mi ²)	0.064
Q ₇₋₁₀ Flow (cfs)	0.5	Q ₇₋₁₀ Basis	Previous fact sheet
Watershed No.	19-F	Chapter 93 Class.	WWF
Assessment Status	Impaired		
Cause(s) of Impairment	Siltation		
Source(s) of Impairment	Agriculture		
TMDL Status	Final	Name	Coxes Creek Watershed

Treatment Facility Summary				
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary with NH3-N removal	SBR	Ultraviolet	0.15
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.15	330	Not Overloaded	Aerobic	Other STP

Compliance History

DMR Data for Outfall 001 (from May 1, 2023 to April 30, 2024)

Parameter	APR-24	MAR-24	FEB-24	JAN-24	DEC-23	NOV-23	OCT-23	SEP-23	AUG-23	JUL-23	JUN-23	MAY-23
Flow (MGD) Average Monthly	0.1088	0.0889	0.083		0.070	0.062	0.056	0.0526	0.0572	0.060	0.055	0.064
Flow (MGD) Daily Maximum	0.336	0.175	0.211		0.118	0.157	0.097	0.068	0.088	0.097	0.098	0.156
pH (S.U.) Instantaneous Minimum	6.81	6.52	6.8	6.83	6.82	6.9	6.9	6.83	6.7	7.1	7.01	6.9
pH (S.U.) Instantaneous Maximum	7.16	7.25	7.48	7.96	7.59	7.5	7.53	7.46	7.52	7.6	7.39	7.5
DO (mg/L) Instantaneous Minimum	5.49	5.54	4.1	6.3	7.0	7.65	4.17	4.61	4.14	4.6	4.25	5.1
CBOD5 (lbs/day) Average Monthly	1.9	3.0	2.0	5.0	1.0	1.0	2.0	1.0	1.0	2.0	3.0	1.0
CBOD5 (lbs/day) Weekly Average	2.5	5.0	6.0	14.0	2.0	2.0	4.0	1.0	1.0	5.0	11.0	2.0
CBOD5 (mg/L) Average Monthly	2.8	3.0	3.0	6.0	2	2	4.0	2.0	2.0	4.0	7.0	2.0
CBOD5 (mg/L) Weekly Average	5.0	4.0	6.0	14.0	3	3	10.0	2.0	3.0	10.0	22.0	3.0
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	46.0	526	164	187	129	195	112	98.0	67	129.0	352.0	343
BOD5 (lbs/day) Raw Sewage Influent Daily Maximum	68.0	1505	336	462	148	329	145	123.0	80	233.0	743.0	583
BOD5 (mg/L) Raw Sewage Influent Average Monthly	75.3	640	259	190	231	399	223	217	151	223	160.0	685
TSS (lbs/day) Average Monthly	2.5	2.0	2.0	8.0	3.0	1.0	2.0	1.0	1.0	2.0	1.0	1.0

TSS (lbs/day) Raw Sewage Influent Average Monthly	69.0	211	36	90	264	252	115	189.0	81	125.0	72.0	284.0
TSS (lbs/day) Raw Sewage Influent Daily Maximum	103.0	335	54	138	657	569	151	247.0	101	252.0	83.0	456.0
TSS (lbs/day) Weekly Average	3.6	2.0	2.0	21.0	7.0	1.0	4.0	2.0	1.0	3.0	1.0	1.0
TSS (mg/L) Average Monthly	3.4	2.0	3.0	8.0	6.0	2.0	4.0	3.0	3.0	4.0	2.0	2.0
TSS (mg/L) Raw Sewage Influent Average Monthly	104.2	271	75	128	444	539	231	85.0	187	209	174	582.0
TSS (mg/L) Weekly Average	4.0	3.0	4.0	24.0	15.0	2.0	6.0	4.0	3.0	6.0	2.0	3.0
Fecal Coliform (No./100 ml) Geometric Mean	2.0	3.0	7	6.0	3	3.0	10	3.0	2.0	2.0	1.0	1.0
Fecal Coliform (No./100 ml) Instantaneous Maximum	9.0	5.0	30	39.0	4	5.0	17	10.0	3.0	4.0	1.0	2.0
UV Transmittance (%) Daily Minimum	0.1	0.1	0.0	0.1	0.1	0.1	0.2	0.1	0.1	0.1	0.1	0.1
Total Nitrogen (mg/L) Daily Maximum					5.23							
Ammonia (lbs/day) Average Monthly	0.6	1.0	1.0	1.0	0.001	0.05	0.001	0.001	0.001	0.01	0.001	0.001
Ammonia (lbs/day) Weekly Average	2.1	3.0	3.0	3.0	0.001	0.06	0.001	0.001	0.001	0.01	0.001	0.001
Ammonia (mg/L) Average Monthly	1.1	1.4	2.7	1.9	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
Ammonia (mg/L) Weekly Average	4.3	4.4	6.5	3.6	0.2	0.1	0.1	0.1	0.1	0.1	0.3	0.2
Total Phosphorus (mg/L) Daily Maximum					1.83							

Compliance History

Development of Effluent Limitations

Outfall No. 001
Latitude 40° 0' 30.00"
Wastewater Description: Sewage Effluent

Design Flow (MGD) .3
Longitude -79° 7' 11.00"

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine*	0.5	Average Monthly	-	92a.48(b)(2)

*TRC limit is not needed. Disinfection via UV system.

Water Quality-Based Limitations

The following limitations were determined:

Parameter	Limit (mg/l)	SBC	Basis
CBOD5	25	Average Monthly	WQM 7.0**
NH3-N	5	Average Monthly	
Dissolved Oxygen	4	Inst. Min.	
E. Coli*	Report	Inst. Max.	SOP
Total Nitrogen	Report	Daily Max.	BPJ & SOP
Total Phosphorus	Report	Daily Max.	BPJ & SOP

*E. Coli monitoring is included in the draft permit according to the DEP SOP guidance (Chapter 92.a.61). This is a new requirement and is consistent with the requirements of other similar discharges in the area.

**WQM 7.0 model run is conducted at this time and the limits are similar to the limits established in the existing permit. See the attached WQM 7.0 model report. Copy of the previous pollution report is also attached for reference.

Anti-Backsliding

N/A

Mass Loading Limits: MLLs are applicable for publicly owned treatment works. Current policy requires average monthly mass loading limits be established for CBOD5, TSS, and NH₃-N and average weekly mass loading limits be established

for CBOD5 and TSS when applicable. Reporting of both Monthly Mass Limits and weekly Mass Limits for TSS, CBOD5 and NH3-N are continued in the draft permit.

Average Monthly mass loading limits (lbs/day) are based on the formula: design flow (MGD) x concentration limit (mg/L) x conversion factor (8.34).

Raw Sewage Influent Monitoring: For POTWs with design flows greater than 2,000 GPD, influent BOD₅ and TSS monitoring must be established in the permit. The monitoring for influent parameters will be consistent with the same frequency and sample type as is used for the effluent parameters. These monitoring requirements are existing and continued in the draft permit.

Total Nitrogen and Total Phosphorus: Nutrient monitoring is required for all sewage wastewater treatment facilities with design flows greater than 2,000gpd. Discharges greater than 2,000 GPD but less than 1.0MGD require monitoring, at a minimum, for Total Nitrogen and Total Phosphorus in new and reissued permits at a frequency of 1/year. These monitoring requirements are existing and continued in the draft permit.

A Dissolved Oxygen minimum limitation of 4.0 mg/L was previously imposed in the permit. The D.O. limit was based on the previous standard in 25 PA Code Chapter 93 and best professional judgment. This limit is imposed for activated sludge treatment systems where D.O. is critical to their operation. This limit is the same based on the WQM 7.0 model report and continued in the draft permit.

TDS: Discharge loadings of TDS authorized by DEP, under NPDES permits or other authority that were issued or reissued prior to the effective date of §95.10 (August 21, 2010), are exempt from the treatment requirements of §95.10 until the net loading is to be increased. This facility was permitted prior to August 21, 2010 and no increase in flow or TDS net loading is proposed. TDS effluent loadings are not applicable. Reference: DEPARTMENT OF ENVIRONMENTAL PROTECTION Bureau of Water Standards and Facility Regulation DOCUMENT NUMBER: 385-2100-002 TITLE: Policy and Procedure for NPDES Permitting of Discharges of Total Dissolved Solids (TDS) -- 25 Pa. Code §95.10

Total Copper, Total Lead and Total Zinc sampling results are provided. Review shows no concern for these parameters.

In accordance with the provisions of 40 CFR § 133.102(a)(4)(iii), the draft permit requires that the 30-day average percent removal of BOD5 (or CBOD5) and TSS be no less than 85 %.

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
19F	38979	WEST BRANCH COXES CREEK	3.400	1986.00	7.84	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	pH	Stream Temp	pH
	(cfs/m)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.100	0.00	0.50	0.000	0.000	0.0	0.00	0.00	20.00	7.00	25.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow	Permitted Disc Flow	Design Disc Flow	Reserve Factor	Disc Temp	Disc pH
		(mgd)	(mgd)	(mgd)			
Lavansville STP	PA0252522	0.0000	0.0000	0.1500	0.000	25.00	7.00
Parameter Data							
Parameter Name		Disc Conc	Trib Conc	Stream Conc	Fate Coef		
		(mg/L)	(mg/L)	(mg/L)	(1/days)		
CBOD5		25.00	2.00	0.00	1.50		
Dissolved Oxygen		4.00	8.24	0.00	0.00		
NH3-N		5.00	0.00	0.00	0.70		

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC																																	
19F	38979	WEST BRANCH COXES CREEK			2.700	1980.00	7.98	0.00000	0.00	<input checked="" type="checkbox"/>																																	
Stream Data																																											
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)																																	
<table> <tr> <td>Q7-10</td><td>0.100</td><td>0.00</td><td>0.51</td><td>0.000</td><td>0.000</td><td>0.0</td><td>0.00</td><td>0.00</td><td>20.00</td><td>7.00</td></tr> <tr> <td>Q1-10</td><td></td><td></td><td>0.00</td><td>0.000</td><td>0.000</td><td></td><td></td><td></td><td>25.00</td><td>0.00</td></tr> <tr> <td>Q30-10</td><td></td><td></td><td>0.00</td><td>0.000</td><td>0.000</td><td></td><td></td><td></td><td></td><td></td></tr> </table>											Q7-10	0.100	0.00	0.51	0.000	0.000	0.0	0.00	0.00	20.00	7.00	Q1-10			0.00	0.000	0.000				25.00	0.00	Q30-10			0.00	0.000	0.000					
Q7-10	0.100	0.00	0.51	0.000	0.000	0.0	0.00	0.00	20.00	7.00																																	
Q1-10			0.00	0.000	0.000				25.00	0.00																																	
Q30-10			0.00	0.000	0.000																																						
Discharge Data																																											
		Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH																																		
				0.0000	0.0000	0.0000	0.000	25.00	7.00																																		
Parameter Data																																											
			Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)																																				
			CBOD5	25.00	2.00	0.00	1.50																																				
			Dissolved Oxygen	3.00	8.24	0.00	0.00																																				
			NH3-N	25.00	0.00	0.00	0.70																																				

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>			<u>Stream Code</u>			<u>Stream Name</u>							
19F			38979			WEST BRANCH COXES CREEK							
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH	
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)		
Q7-10 Flow													
3.400	0.50	0.00	0.50	.2321	0.00162	.503	14.24	28.28	0.10	0.419	25.00	7.00	
Q1-10 Flow													
3.400	0.32	0.00	0.32	.2321	0.00162	NA	NA	NA	0.09	0.490	25.00	7.00	
Q30-10 Flow													
3.400	0.68	0.00	0.68	.2321	0.00162	NA	NA	NA	0.12	0.370	25.00	7.00	

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
19F	38979	WEST BRANCH COXES CREEK					
NH3-N Acute Allocations							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
3.400	Lavansville STP	11.07	10	11.07	10	0	0
NH3-N Chronic Allocations							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
3.400	Lavansville STP	1.37	5	1.37	5	0	0
Dissolved Oxygen Allocations							
RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>	
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)
3.40	Lavansville STP	25	25	5	5	4	4
						0	0

WQM 7.0 D.O.Simulation

SWP Basin	Stream Code	Stream Name		
19F	38979	WEST BRANCH COXES CREEK		
<u>RMI</u> 3.400	<u>Total Discharge Flow (mgd)</u> 0.150	<u>Analysis Temperature (°C)</u> 25.000	<u>Analysis pH</u> 7.000	
<u>Reach Width (ft)</u> 14.237	<u>Reach Depth (ft)</u> 0.503	<u>Reach WDRatio</u> 28.284	<u>Reach Velocity (fps)</u> 0.102	
<u>Reach CBOD5 (mg/L)</u> 9.29	<u>Reach Kc (1/days)</u> 1.191	<u>Reach NH3-N (mg/L)</u> 1.58	<u>Reach Kn (1/days)</u> 1.029	
<u>Reach DO (mg/L)</u> 6.898	<u>Reach Kr (1/days)</u> 18.867	<u>Kr Equation</u> Owens	<u>Reach DO Goal (mg/L)</u> 5	
<u>Reach Travel Time (days)</u> 0.419	<u>TravTime (days)</u>	Subreach Results		
		CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
		0.042	8.73	1.52
		0.084	8.20	1.45
		0.126	7.70	1.39
		0.168	7.23	1.33
		0.209	6.79	1.28
		0.251	6.38	1.22
		0.293	5.99	1.17
		0.335	5.62	1.12
		0.377	5.28	1.08
		0.419	4.96	1.03
				7.46

WQM 7.0 Effluent Limits

SWP Basin 19F	Stream Code 38979	Stream Name WEST BRANCH COXES CREEK					
		Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
3.400	Lavansville STP	PA0252522	0.000	CBOD5	25		
				NH3-N	5	10	
				Dissolved Oxygen			4

POLLUTION REPORT

(I) Project Description

New Discharge
 Existing Discharge

Change
Preliminary

A. NPDES Application/Permit No. Somerset Twp. (PA 0252522)
Part II Permit Nos. _____

B. Applicant, Case Name or Permittee: LAVANSVILLE
West End STP

Municipality: Somerset Twp
County: Somerset

C. Type Waste

Sewage
 Industrial
 Mine

D. Source and characteristics

Domestic Wastewater

E. USGS Quad: Somerset Quad

F. Latitude (or in. N) 40° 00' 30" OUTFALL 001
Longitude (or in. W) 79° 07' 11"

(II) Water Uses and Criteria

A. Receiving waters West Branch Coxes Creek (above golf course) Stream code 38979
Chapter 93 classification WWF R.M.I. _____
D.A. 7.84 sq.mi. Yield 0.064 cfs/sq.mi.
Flow 0.5 cfs. Based on data from Water Resources Bull. #12
Station 03078800, Coxes Creek near Rockwood PA revised.
Elevation _____ ft.

Exceptions to standard
water use lists: None

Water Quality Criteria-Exceptions
to Specific Criteria: None

Add _____

Add _____

Delete _____

Delete _____

Impoundment _____

Special Downstream Uses: _____

B. Secondary Waters R.M.I. _____
Distance from discharge _____ mi. Ch. 93 classification _____
D.A. _____ sq.mi. Yield _____ cfs/sq.mi.
Flow _____ cfs. Based on data from _____
Elevation _____ ft. Stream Code _____

Exceptions to standard
water use lists: None

Water Quality Criteria-Exceptions
to Specific Criteria: _____

Add _____

Add _____

Delete _____

Delete _____

Impoundment _____

Special Downstream Uses: _____

Downstream PWS: location _____

distance from discharge _____ mi. intake _____ mgd.
stream flow at intake _____ cfs.

ANALYSIS

DISCHARGE

RATE 0.30 MGD

FILE: c:\raywqam\untitled.wqm
Preliminary Limits Lavansville STP 300 000gpd

REACH # 1
Headwaters and Tributary data

No. of Reaches : 1

Rh	Q7-10 (cfs)	T (c)	pH (su)	DO (mg/l)	CBOD5 (mg/l)	NH3-N (mg/l)
HW	0.5000	25	7	7.12	2	.1
1	0.0000					

FILE: c:\raywqam\untitled.wqm
Preliminary Limits Lavansville STP 300 000gpd

Stream Characteristics

Rh	Q7-10 (cfs)	T (c)	pH (su)	DO (mg/l)	CBOD5 (mg/l)	NH3-N (mg/l)
1	.5	25	7	7.12	2	.1

Q 1-10/Q 7-10 = .64
Q 30-10/Q 7-10 = 1.36

FILE: c:\raywqam\untitled.wqm
Preliminary Limits Lavansville STP 300 000gpd

DISCHARGE # 1
Discharger Data
Q7-10 Design Conditions

Rh	FLOW (MGD)	T (c)	pH (su)	DO (mg/l)	CBOD5 (mg/l)	NH3-N (mg/l)	KC (1/days)
1	0.3000	20	7	2	25	25	1.5

FILE: c:\raywqam\untitled.wqm
Preliminary Limits Lavansville STP 300 000gpd

REACH # 1
Reach Characteristics

Rh	D.O. GOAL (/D)	RCH. KN (FT/FT)	RCH. SL. (FT/FT)	DRAIN LEN. (FT.)	DRAIN AREA (MI^2)	W/D
1	5	.6	0.00150	2000	7.84	10

3

FILE: c:\raywqam\untitled.wqm
Preliminary Limits Lavansville STP 300 000gpd

REACH # 1
Reach Characteristics
Rh KR TT
(/D) (Days)
--- -----
1 0 0

FILE: c:\raywqam\Lavansv.wqm
Preliminary Limits Lavansville STP 300 000gpd

NH3-N Discharge Allocations at Q30-10 (EMPR)

DIS	Q	BASE. CONC.	MULT. CONC.	CRIT. RCH.	PCT. RED.	NH3-N CRIT. (mg/1)
---	---	---	---	---	---	---
1	0.3000	3.67	3.67	0	0	1.55

FILE: c:\raywqam\Lavansv.wqm
Preliminary Limits Lavansville STP 300 000gpd

NH3-N Discharge Allocations at Q1-10 (EMPR)

DIS	Q	BASE. CONC.	MULT. CONC.	CRIT. RCH.	PCT. RED.	NH3-N CRIT. (mg/l)
---	---	---	---	---	---	---
1	0.3000	14.03	14.03	0	0	8.35

FILE: c:\raywqam\Lavansv.wqm
Preliminary Limits Lavansville STP 300 000gpd

(Total) Discharge = .3 MGD

Temp	=	22.6	pH	=	7	Width	=	9.02
CBOD-5	=	13.07	NH3-N	=	1.82	Depth	=	0.90
D.O.	=	4.66	D.O. Goal	=	5	Velocity	=	0.118
KC'	=	1.361	KN	=	.6	W/D RATIO	=	10
KR	=	6.283	(OWENS)					
Dis.	1		Rch.	1		Trvl Time:	.195	

Tr.Tm. (Days)	CBOD-5 (mg/l)	NH3-N (mg/l)	D.O. (mg/l)
0.020	12.69	1.79	4.47
0.039	12.31	1.77	4.33
0.059	11.95	1.74	4.21
0.078	11.59	1.72	4.13
0.098	11.25	1.69	4.08
0.117	10.92	1.67	4.04
0.137	10.60	1.64	4.03
0.156	10.28	1.62	4.03
0.176	9.98	1.60	4.05
0.195	9.69	1.58	4.07

L.S.
FBCRASH
OISCHAWL
D.O.

5

FILE: c:\raywqam\Lavansv.wqm
Preliminary Limits Lavansville STP 300 000gpd

D.O. Allocations (EMPR)

DIS #	Q	---NH3-N---		---CBOD5---		CRIT.	PCT.
		IND.	CUM.	IND.	CUM.	RCH.	REM.
		Conc.	Conc.	Conc.	Conc.		
	(MGD)	(mg/l)	(mg/l)	(mg/l)	(mg/l)	(%)	
1	0.3000	3.7	3.7	19.8	19.8	0	0

FILE: c:\raywqam\Lavansv.wqm
Preliminary Limits Lavansville STP 300 000gpd

Effluent Limitations Display

DIS #	Q	NH3-N	TOX.	DISS.	OXYGEN	
		1	30	C-BOD5	NH3-N	EFF.
	MGD	DAY	DAY	30-DAY	30-DAY	D.O.
1	.3	7.3	3.7	19.8	3.7	3

TRY TO INCORPORATE
D.O. TO 5

FILE: c:\raywqam\Lavansv.wqm
Preliminary Limits Lavansville STP 300 000gpd

SECOND

RVM

DISCHARGE # 1
Discharger Data
Q7-10 Design Conditions

Rh	FLOW (MGD)	T (c)	pH (su)	DO (mg/l)	CBOD5 (mg/l)	NH3-N (mg/l)	KC (1/days)
1	0.3000	20	7	5	25	25	1.5

1

FILE: c:\raywqam\Lavansv.wqm
Preliminary Limits Lavansville STP 300 000gpd

NH3-N Discharge Allocations at Q30-10 (EMPR)

DIS	Q	BASE. CONC.	MULT. CONC.	CRIT. RCH.	PCT. RED.	NH3-N CRIT. (mg/l)
1	0.3000	3.67	3.67	0	0	1.55

7

FILE: c:\raywqam\Lavansv.wqm
Preliminary Limits Lavansville STP 300 000gpd

NH3-N Discharge Allocations at Q1-10 (EMPR)

DIS	Q	BASE.	MULT.	CRIT.	PCT.	NH3-N
		CONC.	CONC.	RCH.	RED.	CRIT.
	(mgd)	(mg/l)	(mg/l)		(%)	(mg/l)
---	---	---	---	---	---	---
1	0.3000	14.03	14.03	0	0	8.35

FILE: c:\raywqam\Lavansv.wqm
Preliminary Limits Lavansville STP 300 000gpd

(Total) Discharge = .3 MGD
Temp = 22.6 pH = 7 Width = 9.02
CBOD-5 = 13.07 NH3-N = 1.82 Depth = 0.90
D.O. = 6.1 D.O. Goal = 5 Velocity = 0.118
KC' = 1.361 KN = .6 W/D RATIO = 10
KR = 6.283 (OWENS)
Dis. 1 Rch. 1 Trvl Time: .195

Tr.Tm. (Days)	CBOD-5 (mg/l)	NH3-N (mg/l)	D.O. (mg/l)
0.020	12.69	1.79	5.75
0.039	12.31	1.77	5.46
0.059	11.95	1.74	5.21
0.078	11.59	1.72	5.02
0.098	11.25	1.69	4.86
0.117	10.92	1.67	4.73
0.137	10.60	1.64	4.64
0.156	10.28	1.62	4.57
0.176	9.98	1.60	4.52
0.195	9.69	1.58	4.50

L 5.0

No Recovery

FILE: c:\raywqam\Lavansv.wqm
Preliminary Limits Lavansville STP 300 000gpd

D.O. Allocations (EMPR)

DIS #	Q	---NH3-N---		---CBOD5---		CRIT.	PCT.
		IND.	CUM.	IND.	CUM.	RCH.	REM.
		Conc.	Conc.	Conc.	Conc.		
		(MGD)	(mg/l)	(mg/l)	(mg/l)	(mg/l)	(%)
---	---	---	---	---	---	---	---
1	0.3000	3.7	3.7	21.5	21.5	0	0

FILE: c:\raywqam\Lavansv.wqm
Preliminary Limits Lavansville STP 300 000gpd

THru Run

DISCHARGE # 1
Discharger Data
Q7-10 Design Conditions

Rh	FLOW (MGD)	T (c)	pH (su)	DO (mg/l)	CBOD5 (mg/l)	NH3-N (mg/l)	KC (1/day)
1	0.3000	20	7	5	20	3.5	1.2

↑ ↑ ↑

UVNT >

(WQAM63.EXE) Release 1.2 01-09-2007 07:35:29

10

FILE: c:\raywqam\Lavansv.wqm
Preliminary Limits Lavansville STP 300 000gpd

REACH # 1
Reach Characteristics

Rh	D.O. GOAL	KN (/D)	RCH. SL. (FT/FT)	RCH. LEN. (FT.)	DRAIN AREA (MI ²)	W/D
--	--	--	--	--	--	--
1	5	.6	0.00150	3000	7.84	10

FILE: c:\raywqam\Lavansv.wqm
Preliminary Limits Lavansville STP 300 000gpd

REACH # 1
Reach Characteristics

Rh	KR (/D)	TT (Days)
--	--	--
1	0	0

11

FILE: c:\raywqam\Lavansv.wqm
Preliminary Limits Lavansville STP 300 000gpd

(Total) Discharge = .3 MGD
Temp = 22.6 pH = 7 Width = 9.02
CBOD-5 = 10.66 NH3-N = 1.74 Depth = 0.90
D.O. = 6.1 D.O. Goal = 5 Velocity = 0.118
KC' = 1.06 KN = .6 W/D RATIO = 10
KR = 6.283 (OWENS)
Dis. 1 Rch. 1 Trvl Time: .293

Tr.Tm. (Days)	CBOD-5 (mg/l)	NH3-N (mg/l)	D.O. (mg/l)
0.029	10.30	1.70	5.89
0.059	9.94	1.66	5.73
0.088	9.60	1.63	5.62
0.117	9.27	1.59	5.55
0.147	8.95	1.56	5.51
0.176	8.64	1.53	5.49
0.205	8.35	1.49	5.49
0.235	8.06	1.46	5.51
0.264	7.78	1.43	5.55
0.293	7.51	1.40	5.59

RECOVERS

> 5.0

FILE: c:\raywqam\Lavansv.wqm
Preliminary Limits Lavansville STP 300 000gpd

Effluent Limitations Display

DIS #	Q MGD	NH3-N 1 DAY	TOX. 30 DAY	DISS. C-BOD5 30-DAY	OXYGEN NH3-N 30-DAY	EFF. D.O. 30-DAY
1	.3	7	3.5	20	3.5	5

Summer
Limits

12

FILE: c:\raywqam\Lavansv.wqm
Preliminary Limits Lavansville STP 300 000gpd

REACH # 1
Headwaters and Tributary data

WINTER

No. of Reaches : 1

Rh	Q7-10 (cfs)	T (c)	pH (su)	DO (mg/l)	CBOD5 (mg/l)	NH3-N (mg/l)
HW	1.0000	5	7	10.5	2	.1
1	0.0000					

FILE: c:\raywqam\Lavansv.wqm
Preliminary Limits Lavansville STP 300 000gpd

DISCHARGE # 1
Discharger Data
Q7-10 Design Conditions

Rh	FLOW (MGD)	T (c)	pH (su)	DO (mg/l)	CBOD5 (mg/l)	NH3-N (mg/l)	KC (1/days)
1	0.3000	15	7	5	25	25	1.5

13

FILE: c:\raywqam\Lavansv.wqm
Preliminary Limits Lavansville STP 300 000gpd

Rh	REACH # 1					
	Reach Characteristics					
	D.O. GOAL	KN (/D)	RCH. SL. (FT/FT)	RCH. LEN. (FT.)	DRAIN AREA (MI^2)	W/D
1	5	.6	0.00150	3000	7.84	10

FILE: c:\raywqam\Lavansv.wqm
Preliminary Limits Lavansville STP 300 000gpd

Rh	REACH # 1	
	Reach Characteristics	
	KR (/D)	TT (Days)
1	0	0

14

FILE: c:\raywqam\Lavansv.wqm
Preliminary Limits Lavansville STP 300 000gpd

NH3-N Discharge Allocations at Q30-10 (EMPR)

DIS	Q	BASE. CONC.	MULT. CONC.	CRIT. RCH.	PCT. RED.	NH3-N CRIT. (mg/l)
1	0.3000	15.75	15.75	0	0	4.08

FILE: c:\raywqam\Lavansv.wqm
Preliminary Limits Lavansville STP 300 000gpd

NH3-N Discharge Allocations at Q1-10 (EMPR)

DIS	Q	BASE. CONC.	MULT. CONC.	CRIT. RCH.	PCT. RED.	NH3-N CRIT. (mg/l)
1	0.3000	48.84	48.84	0	0	20.59

15

FILE: c:\raywqam\Lavansv.wqm
Preliminary Limits Lavansville STP 300 000gpd

(Total) Discharge = .3 MGD
Temp = 8.2 pH = 7 Width = 9.89
CBOD-5 = 9.29 NH3-N = 5.06 Depth = 0.99
D.O. = 8.76 D.O. Goal = 5 Velocity = 0.150
KC' = 1.26 KN = .6 W/D RATIO = 10
KR = 2.133 (TSIVOGLOU)
Dis. 1 Rch. 1 Trvl Time: .232

Tr.Tm. (Days)	CBOD-5 (mg/l)	NH3-N (mg/l)	D.O. (mg/l)
0.023	9.13	5.03	8.55
0.046	8.98	5.00	8.35
0.070	8.83	4.98	8.17
0.093	8.68	4.95	8.00
0.116	8.53	4.92	7.85
0.139	8.39	4.89	7.70
0.162	8.25	4.87	7.57
0.186	8.11	4.84	7.45
0.209	7.97	4.81	7.34
0.232	7.84	4.78	7.23

No
Forecast

FILE: c:\raywqam\Lavansv.wqm
Preliminary Limits Lavansville STP 300 000gpd

DISCHARGE # 1
Discharger Data
Q7-10 Design Conditions

Rh	FLOW (MGD)	T (c)	pH (su)	DO (mg/l)	CBOD5 (mg/l)	NH3-N (mg/l)	KC (1/day)
1	0.3000	15	7	5	25	10.5	1.5

16

FILE: c:\raywqam\Lavansv.wqm
Preliminary Limits Lavansville STP 300 000gpd

(Total) Discharge = .3 MGD
Temp = 8.2 pH = 7 Width = 9.89
CBOD-5 = 9.29 NH3-N = 3.4 Depth = 0.99
D.O. = 8.76 D.O. Goal = 5 Velocity = 0.150
KC' = 1.26 KN = .6 W/D RATIO = 10
KR = 2.133 (TSIVOGLOU)
Dis. 1 Rch. 1 Trvl Time: .232

Tr.Tm. (Days)	CBOD-5 (mg/l)	NH3-N (mg/l)	D.O. (mg/l)
0.023	9.13	3.38	8.59
0.046	8.98	3.36	8.43
0.070	8.83	3.34	8.29
0.093	8.68	3.32	8.15
0.116	8.53	3.30	8.03
0.139	8.39	3.28	7.92
0.162	8.25	3.27	7.82
0.186	8.11	3.25	7.72
0.209	7.97	3.23	7.64
0.232	7.84	3.21	7.56

TRY Nomogramt Velocity

1.46cfs TOTAL
SLOPE = .0015

VELOCITY = .71 x .3 = .213 FPS

TRAVEL TIME = .163 DAYS

17

FILE: c:\raywqam\Lavansv.wqm
Preliminary Limits Lavansville STP 300 000gpd

Rh	REACH # 1					
	Reach Characteristics					
	D.O. GOAL	KN (/D)	RCH. SL. (FT/FT)	RCH. LEN. (FT.)	DRAIN AREA (MI ²)	W/D
1	5	.6	0.00150	5000	7.84	10

FILE: c:\raywqam\Lavansv.wqm
Preliminary Limits Lavansville STP 300 000gpd

Rh	REACH # 1		
	Reach Characteristics		
	KR (/D)	TT (Days)	
1	0	.163	

18

FILE: c:\raywqam\Lavansv.wqm
Preliminary Limits Lavansville STP 300 000gpd

(Total) Discharge = .3 MGD
 Temp = 8.2 pH = 7 Width = 6.42
 CBOD-5 = 9.29 NH3-N = 3.4 Depth = 0.64
 D.O. = 8.76 D.O. Goal = 5 Velocity = 0.355
 KC' = 1.266 KN = .6 W/D RATIO = 10
 KR = 5.061 (TSIVOGLOU)
 Dis. 1 Rch. 1 Trvl Time: .163

Tr.Tm. (Days)	CBOD-5 (mg/l)	NH3-N (mg/l)	D.O. (mg/l)
0.016	9.18	3.38	8.78
0.033	9.07	3.37	8.80
0.049	8.96	3.36	8.82
0.065	8.86	3.34	8.84
0.082	8.75	3.33	8.86
0.098	8.65	3.32	8.88
0.114	8.54	3.30	8.91
0.130	8.44	3.29	8.93
0.147	8.34	3.28	8.95
0.163	8.24	3.27	8.97

> 5.0 ✓

STREAM
RECOVERIES

FILE: c:\raywqam\Lavansv.wqm
Preliminary Limits Lavansville STP 300 000gpd

D.O. Allocations (EMPR)

DIS #	Q (MGD)	---NH3-N---		---CBOD5---		CRIT. IND. (mg/l)	PCT. REM. (%)
		IND.	CUM.	IND.	CUM.		
		Conc.	Conc.	Conc.	Conc.		
		(mg/l)	(mg/l)	(mg/l)	(mg/l)		
1	0.3000	10.5	10.5	25	25	0	0

19

FILE: c:\raywqam\Lavansv.wqm
Preliminary Limits Lavansville STP 300 000gpd

WINTER

Effluent Limitations Display

DIS #	Q MGD	NH3-N DAY	TOX. DAY	DISS. 30-DAY	OXYGEN 30-DAY	EFF. D.O.
1	.3	21	10.5	25	10.5	5

III. Effluent Limitations:

A. Outfall 001

B. Discharge Volume 0.30 MGD

Parameter	lbs/day			mg/l		
	Monthly Avg. (Sewage)	Weekly Avg. (Industrial Waste)	Daily Max. Daily Avg.	Monthly Avg. (Sewage)	Weekly Avg. (Industrial Waste)	Daily Max. Daily Avg.
1. <u>CBOD₅</u>						
2. <u>May 1 to Oct 31</u>	50.1	75.1		20	30	40
3. <u>Nov 1 to Apr 30</u>	62.6	93.9		25	38	50
4. <u>TSS</u>	25.1	112.7		30	45	60
5. <u>NH₃-N</u>						
6. <u>5/1 to 10/31</u>	8.8	13.1		3.5	5.3	7.0
7. <u>11/1 to 4/30</u>	25.0	37.6		10.0	15.0	20.0
8. <u>DO</u>				MINIMUM of	5.0	
9. <u>pH</u>				6.0	10	9.0
10. <u>Fecal Coliform</u>						
11. <u>5/1 to 9/30</u>				200/100mL	1000/100mL	
12. <u>10/1 to 4/30</u>				2000/100mL	10,000/100mL	
13.						
14. <u>TRC</u>				NO LIMIT		
15.				ULTRAVIOLET USED		
16.				FOR DISINFECTION		

Effluent Limitation Rational

1. EPA Guidelines
2. Regulation:
3. Water Quality Criteria CTATT 93

Approvals

Reviewer
Planning/WQ

Ray E. Lattuca

Date

4/11/07

Geologist or Aquatic Biologist

Date

Chief
Planning/WQ

D. J. L.

Date

5/3/07

08 Renewal PL-28 7/22/08

PL-28
(Rev. 7/22/92)

Proposed Effluent Limitations and Monitoring Requirements

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Daily Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Recorded
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/weekday	Grab
Dissolved Oxygen	XXX	XXX	4.0 Inst Min	XXX	XXX	XXX	1/weekday	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5)	31.3	47.6	XXX	25	38	50	1/week	24-Hr Composite
Biochemical Oxygen Demand (BOD5)		Report Daily Max	XXX	Report	XXX	XXX		24-Hr Composite
Raw Sewage Influent	Report		XXX				1/week	24-Hr Composite
Total Suspended Solids	37.6	56.3	XXX	30	45	60	1/week	24-Hr Composite
Total Suspended Solids Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
Ultraviolet light transmittance (%)	XXX	XXX	Report	XXX	XXX	XXX	1/weekday	Measured
Total Nitrogen	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/year	Grab
Ammonia-Nitrogen Nov 1 - Apr 30	18.8	28.2	XXX	15.0	22.5	30	1/week	24-Hr Composite
Ammonia-Nitrogen May 1 - Oct 31	6.3	9.4	XXX	5.0	7.5	10	1/week	24-Hr Composite

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Daily Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Total Phosphorus	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/year	Grab

