



Application Type  
Facility Type  
Major / Minor

Renewal  
Industrial  
Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL INDUSTRIAL WASTE (IW)  
AND IW STORMWATER**

Application No. **PA0252662**  
APS ID **1092906**  
Authorization ID **1447440**

**Applicant and Facility Information**

Applicant Name	<u>Central Indiana County Water Authority</u>	Facility Name	<u>Central Indiana County Water Authority</u>
Applicant Address	30 E Wiley Street Homer City, PA 15748-1543	Facility Address	30 E Wiley Street Homer City, PA 15748-1543
Applicant Contact	Robert Nymick	Facility Contact	
Applicant Phone	(724) 479-8005	Facility Phone	
Client ID	51998	Site ID	249978
SIC Code	4941	Municipality	Center Township
SIC Description	Trans. & Utilities - Water Supply	County	Indiana
Date Application Received	<u>June 23, 2023</u>	EPA Waived?	Yes
Date Application Accepted		If No, Reason	
Purpose of Application	Permit renewal for discharge of treated industrial waste.		

**Summary of Review**

**1. General Discussion**

This factsheet supports the renewal of an existing NPDES permit for a discharge of treated industrial wastewater from Central Indiana County Water Authority (Authority) water treatment plant. The Authority owns and operates the water treatment plant that treats raw water to supply potable water. The wastewater generated from the water treatment process consists of filter backwash water, clarifier sludge and filter-to-waste water. The generated wastewater is treated utilizing a sludge dewatering system. Residual sludge generated by the sludge dewatering system (gravity thickener) is removed periodically and discharged into the sanitary sewer system. Treated effluent is discharged to Yellow Creek through Outfall 001. The existing permit limits were based on a wastewater flow of 0.0754mgd and will be continued during permit renewal. Yellow Creek is classified for Trout Stocking (TSF). The facility is not covered by ELG, but technology-based treatment limits developed by the Department are applicable. See technology limits section of the report for details. The existing permit was issued on December 18, 2018, with effective date of January 1, 2019, and expiration date of December 31, 2023. The permittee submitted a timely renewal application to the Department and has been operating under the terms and conditions in the existing permit pending permit renewal. Topographical map showing discharge location is attached as attachment A.

**1.2 Public Participation**

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		<i>J. Pascal Kwedza</i> J. Pascal Kwedza, P.E. / Environmental Engineer	April 8, 2025
X		Adam Olesnanik Adam Olesnanik, P.E. / Environmental Engineer Manager	April 14, 2025

**1.4 Discharge, Receiving Waters and Water Supply Information**

Outfall No.	001	Design Flow (MGD)	.0754
Latitude	40° 32' 52.44"	Longitude	-79° 9' 30.27"
Quad Name		Quad Code	
Wastewater Description: IW Process Effluent without ELG			
Receiving Waters	Yellow Creek (TSF)	Stream Code	44118
NHD Com ID	123720042	RMI	0.76
Drainage Area	66	Yield (cfs/mi <sup>2</sup> )	
Q <sub>7-10</sub> Flow (cfs)	5.11	Q <sub>7-10</sub> Basis	StreamStats
Elevation (ft)	1042	Slope (ft/ft)	
Watershed No.	18-D	Chapter 93 Class.	TSF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Impaired		
Cause(s) of Impairment	Metals, pH		
Source(s) of Impairment	Acid Mine Drainage		
TMDL Status	Final	Name	Kiskiminetas-Conemaugh River Watersheds TMDL
Background/Ambient Data		Data Source	
pH (SU)			
Temperature (°F)			
Hardness (mg/L)			
Other:			
Nearest Downstream Public Water Supply Intake		Saltsburg Municipal Water Authority	
PWS Waters		Flow at Intake (cfs)	
PWS RMI		Distance from Outfall (mi)	>35

Changes Since Last Permit Issuance: None

Comments: The nearest downstream water supply intake is approximately 35 miles downstream by Saltsburg Municipal Water Authority. Due to the distance and dilution, no impact is expected from this discharge on the intake.

**2.0 Existing Effluent Limitations and Monitoring Requirements**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Daily Max	XXX	XXX	XXX	XXX	2/month	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0	XXX	2/month	Grab
TRC	XXX	XXX	XXX	0.5	1.0	XXX	2/month	Grab
TSS	XXX	XXX	XXX	30.0	60.0	XXX	2/month	Grab
Total Aluminum	XXX	XXX	XXX	0.75	1.5	XXX	2/month	Grab
Total Iron	XXX	XXX	XXX	1.5	3.0	XXX	2/month	Grab
Total Manganese	XXX	XXX	XXX	1.0	2.0	XXX	2/month	Grab

**2.1 Compliance History**

**2.1.1 DMR Data for Outfall 001 (from February 1, 2024 to January 31, 2025)**

Parameter	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24	APR-24	MAR-24	FEB-24
Flow (MGD)												
Average Monthly	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01
Flow (MGD)												
Daily Maximum	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02
pH (S.U.)												
Daily Minimum	6.9	6.9	7.1	7.4	7.4	7.1	7.4	7.5	7.2	6.8	7.5	7.0
pH (S.U.)												
Daily Maximum	7.0	7.1	7.6	7.6	7.4	7.5	7.4	7.5	7.4	7.6	7.5	7.6
TRC (mg/L)												
Average Monthly	0.15	0.16	0.03	0.04	0.07	0.02	0.04	0.02	0.03	0.06	0.02	0.09
TRC (mg/L)												
Daily Maximum	0.18	0.19	0.03	0.04	0.09	0.03	0.04	0.03	0.03	0.06	0.02	0.11
TSS (mg/L)												
Average Monthly	6.0	5.0	3.0	7.0	7.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0
TSS (mg/L)												
Daily Maximum	8.0	6.0	3.0	10.0	9.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0
Total Aluminum (mg/L)												
Average Monthly	0.80	0.35	0.40	0.49	0.85	0.28	0.25	0.23	0.24	0.21	0.40	0.17
Total Aluminum (mg/L)												
Daily Maximum	0.94	0.47	0.46	0.87	1.09	0.30	0.26	0.25	0.27	0.26	0.55	0.19
Total Iron (mg/L)												
Average Monthly	0.08	0.08	0.05	0.12	0.14	0.14	0.04	0.02	0.04	0.06	0.06	0.04
Total Iron (mg/L)												
Daily Maximum	0.10	0.08	0.06	0.20	0.18	0.15	0.04	0.02	0.05	0.09	0.08	0.05
Total Manganese (mg/L)												
Average Monthly	0.44	0.13	0.16	0.17	0.34	0.16	0.38	0.60	0.52	0.24	0.22	0.07
Total Manganese (mg/L)												
Daily Maximum	0.77	0.18	0.17	0.19	0.42	0.19	0.55	0.64	0.71	0.31	0.22	0.10

**2.1.2 Effluent Violations for Outfall 001, from: March 1, 2024 To: January 31, 2025**

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
Total Aluminum	01/31/25	Avg Mo	0.80	mg/L	.75	mg/L
Total Aluminum	09/30/24	Avg Mo	0.85	mg/L	.75	mg/L

**2.1.3 Summary of DMRs:**

Discharge Monitoring Reports (DMRs) review for the facility for the last 12 months of operation presented on the table above indicate permit limits have been met most of the time. Two Total Aluminum violations were noted on DMRs during the period reviewed and presented in section 2.1.2. The violations appear to be operations related.

**2.1.4 Summary of Inspections:**

The facility was last inspected on 6/3/2021 during the past permit cycle. No violation was found during the inspection.

### 3.0 Development of Effluent Limitations

Outfall No.	001	Design Flow (MGD)	.0754
Latitude	40° 32' 52.00"	Longitude	-79° 9' 30.00"
<b>Wastewater Description:</b> IW Process Effluent without ELG			

#### 3.1 Technology-Based Limitation

Technology based (BPT) effluent limits for water treatment plant wastewater discharges are presented in the Department's October 1997 guidance document entitled "Technology-based control requirements for water treatment plant wastes DEP Document number 362-2183-003, 10-01-1997 as follows:

Parameter	Monthly Average (mg/l)	Daily Max (mg/l)
Suspended Solids	30	60
Iron (total)	2	4
Aluminum (total)	4	8
Manganese (total)	1	2
Flow	Monitor	
pH	6-9 at all time	
Total Residual Chlorine*	0.5	1.0

\*See TRC section of the report for details

#### 3.2 Water Quality-Based Limitations

##### 3.2.1 Stream flows

The drainage areas upstream and downstream of the discharge location and the Q<sub>7-10</sub> at discharge were calculated using USGS streamStats and the results are presented in attachments D and E. The calculated drainage area upstream of discharge is 66 sq. mi and the Q<sub>7-10</sub> flow is 5.11 cfs and the calculated drainage area downstream of the discharge 66.2 sq. mi.

##### 3.2.2 Kiskiminetas-Conemaugh River Watersheds Total Maximum Daily Load (TMDL)

TMDL establishes the amount of a pollutant that a waterbody can assimilate without exceeding its water quality standard for that pollutant. The Kiskiminetas-Conemaugh River Watersheds TMDL was finalized on January 29, 2010, and established wasteload allocation of 0.75mg/L Total Aluminum, 1.0 mg/L Total Manganese, and 1.5mg/L Total Iron for this facility. The TMDLs were based on chapter 93 criteria. Total Aluminum, criterion is expressed as an acute or maximum daily. Therefore, the water quality criterion for Total Aluminum (0.75 mg/L) is imposed as a maximum daily effluent limit (MDL). It is appropriate to set AML equal to MDL where MDL is set at the criterion because water quality concerns have been addressed by setting the MDL equal to the most stringent applicable criterion. The existing MDL of 1.5mg/L will be replaced with 0.75mg/L for this permit renewal. Total Manganese and Total Iron limits in the existing permit are consistent with the requirements of the TMDL.

##### 3.2.3 The following input data were used for TMS model:

- Discharge pH = 7.4 (DMR median July – Sept.)
- Stream pH = 7.0 (Default)
- Discharge Hardness = 49 mg/l
- Stream Hardness = 100 mg/l

##### 3.2.4 Toxics

A reasonable potential (RP) analysis was done for pollutant Groups 1 and 2 submitted with the application. DEP Toxics Management Spreadsheet (TMS) was used to calculate WQBELs. WQBELs recommended by the TMS are presented in attachment C. The results of the TMS indicate discharge levels for all pollutants were well below DEP's target quantitation limits and the calculated WQBELs, therefore, no monitoring or limitation was recommended. The existing TMDL limits for Total Manganese, Total Aluminum and Total Iron will remain in the permit.

### **3.2.5 Total Residual Chlorine**

The attached TRC result utilizes the equations and calculations as presented in the Department's May 1, 2003 Implementation Guidance for Total Residual Chlorine (TRC) (ID No. 391-2000-015) for developing chlorine limitations. The Guidance references Chapter 92a, Section 92a.48 (b) which establishes a standard BAT limit of 0.5 mg/l unless a facility-specific BAT has been developed. The attached results presented in attachment D indicates a technology limit of 0.5 mg/l monthly average and 1.6mg/l IMAX would be needed to prevent toxicity concerns. The existing permit of 0.5 mg/L monthly average and Daily Maximum of 1.0 mg/l based on the TBEL referenced in section 3.1 are protective and will continue in the permit.

### **3.2.6 Flow and pH**

The existing technology limit for pH limit between 6 - 9 S.U, and flow monitoring based on the TBEL referenced in section 3.1 will remain in the permit.

### **3.2.7 Total Suspended Solids (TSS):**

There is no water quality criteria for TSS. The existing TBEL referenced in section 3.2 will remain in the permit with a monitoring frequency of 2/month.

### **3.3.8 Chemical Additive Reporting Requirement**

Currently chemical additives usage are not proposed. Chemical additive reporting requirement are in PART C. II of the permit incase the permittee decides to use chemical additives in the future.

## **4.0 Other Requirements**

### **4.1 Anti-Backsliding**

Not applicable to this discharge

### **4.2 Antidegradation (93.4):**

The effluent limits for this discharge have been developed to ensure that existing instream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High-Quality Waters are impacted by this discharge. No Exceptional Value Waters are impacted by this discharge.

### **4.3 Class A Wild Trout Fisheries:**

No Class A Wild Trout Fisheries are impacted by this discharge.

### **4.4 303d Listed stream:**

The discharge is located on a 303d listed stream segment. A TMDL was developed approved for the Kiskiminetas-Conemaugh River watersheds on January 29, 2010, as discussed in section 3.3.4. The existing permit reflects the requirements specified for Total Aluminum, Total Manganese and Total Iron in the Kiskiminetas-Conemaugh River Watersheds TMDL.

### **4.5 Cleaning of Sedimentation Basin**

Reporting requirements during basin cleaning are in PART C. III of the permit.

**5.0 Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**


Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	2/month	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0	XXX	2/month	Grab
TRC	XXX	XXX	XXX	0.5	1.0	XXX	2/month	Grab
TSS	XXX	XXX	XXX	30.0	60.0	XXX	2/month	Grab
Total Aluminum	XXX	XXX	XXX	0.75	0.75	XXX	2/month	Grab
Total Iron	XXX	XXX	XXX	1.5	3.0	XXX	2/month	Grab
Total Manganese	XXX	XXX	XXX	1.0	2.0	XXX	2/month	Grab

Compliance Sampling Location: At outfall 001

6.0 Tools and References Used to Develop Permit	
<input type="checkbox"/>	WQM for Windows Model (see Attachment [REDACTED])
<input checked="" type="checkbox"/>	Toxics Management Spreadsheet (see Attachment B)
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment C)
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input checked="" type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: Establishing effluent limitation for individual industrial waste.
<input type="checkbox"/>	Other: [REDACTED]

Attachments

A. Topographical MAP



**B. Toxic Management Spreadsheet Results**



Toxics Management Spreadsheet  
Version 1.4, May 2023

## Discharge Information

Instructions	Discharge	Stream									
Facility: <u>Central Indiana Water Authority</u>	NPDES Permit No.: <u>PA0252662</u>	Outfall No.: <u>001</u>									
Evaluation Type: <u>Major Sewage / Industrial Waste</u>	Wastewater Description: <u>Inudustrial Waste</u>										
<b>Discharge Characteristics</b>											
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)				Complete Mix Times (min)				
			AFC	CFC	THH	CRL	$Q_{7-10}$	$Q_h$			
0.0754	49.2	7.4									
			0 if left blank		0.5 if left blank		0 if left blank		1 if left blank		
Discharge Pollutant	Units	Max Discharge Conc	Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteria Mod	Chem Transl
Group 1	Total Dissolved Solids (PWS)	mg/L	90								
	Chloride (PWS)	mg/L	15.2								
	Bromide	mg/L	< 10								
	Sulfate (PWS)	mg/L	28.2								
	Fluoride (PWS)	mg/L	< 10								
Group 2	Total Aluminum	µg/L	492								
	Total Antimony	µg/L	< 2								
	Total Arsenic	µg/L	< 2								
	Total Barium	µg/L	41.3								
	Total Beryllium	µg/L	< 1								
	Total Boron	µg/L	< 0.1								
	Total Cadmium	µg/L	< 0.2								
	Total Chromium (III)	µg/L	< 2								
	Hexavalent Chromium	µg/L	< 0.25								
	Total Cobalt	µg/L	< 1								
	Total Copper	µg/L	0.002								
	Free Cyanide	µg/L									
	Total Cyanide	µg/L	0.01								
	Dissolved Iron	µg/L	< 0.03								
	Total Iron	µg/L	0.06								
	Total Lead	µg/L	< 1								
	Total Manganese	µg/L	107								
	Total Mercury	µg/L	< 0.1								
	Total Nickel	µg/L	< 2								
	Total Phenols (Phenolics) (PWS)	µg/L	6								
	Total Selenium	µg/L	< 0.005								
	Total Silver	µg/L	< 0.4								
	Total Thallium	µg/L	< 0.002								
	Total Zinc	µg/L	5								
	Total Molybdenum	µg/L	2								

## Stream / Surface Water Information

Central Indiana Water Authority, NPDES Permit No. PA0252662, Outfall 001

Instructions **Discharge** Stream

Receiving Surface Water Name: **Yellow Creek**

No. Reaches to Model: **1**

Statewide Criteria  
 Great Lakes Criteria  
 ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi <sup>2</sup> )*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	044118	0.8	1042	66			Yes
End of Reach 1	044118	0.01	1002	66.2			Yes

**Q<sub>7-10</sub>**

Location	RMI	LFY (cfs/mi <sup>2</sup> )*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	0.8	0.1	5.11							100	7				
End of Reach 1	0.01	0.1													

**Q<sub>h</sub>**

Location	RMI	LFY (cfs/mi <sup>2</sup> )*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness	pH	Hardness	pH
Point of Discharge	0.8														
End of Reach 1	0.01														

## Model Results

Central Indiana Water Authority, NPDES Permit No. PA0252662, Outfall 001

Instructions **Results** [RETURN TO INPUTS](#) [SAVE AS PDF](#) [PRINT](#)  All  Inputs  Results  Limits

**Hydrodynamics**

**Wasteload Allocations**

**AFC**

CCT (min): **15**

PMF: **0.772**

Analysis Hardness (mg/l): **98.541**

Analysis pH: **7.01**

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Fluoride (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	750	750	26,114	
Total Antimony	0	0		0	1,100	1,100	38,301	
Total Arsenic	0	0		0	340	340	11,838	Chem Translator of 1 applied
Total Barium	0	0		0	21,000	21,000	731,195	
Total Boron	0	0		0	8,100	8,100	282,032	
Total Cadmium	0	0		0	1,985	2.1	73.2	Chem Translator of 0.945 applied
Total Chromium (III)	0	0		0	562,946	1,781	62,029	Chem Translator of 0.316 applied
Hexavalent Chromium	0	0		0	15,730	16.0	558	Chem Translator of 0.982 applied
Total Cobalt	0	0		0	95	95.0	3,308	
Total Copper	0	0		0	13,254	13.8	481	Chem Translator of 0.96 applied
Dissolved Iron	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	63,556	80.1	2,790	Chem Translator of 0.793 applied
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Mercury	0	0		0	1,400	1.65	57.3	Chem Translator of 0.85 applied
Total Nickel	0	0		0	462,450	463	16,134	Chem Translator of 0.998 applied
Total Phenols (Phenolics) (PWS)	0	0		0	N/A	N/A	N/A	
Total Selenium	0	0		0	N/A	N/A	N/A	Chem Translator of 0.922 applied
Total Silver	0	0		0	3,136	3.69	128	Chem Translator of 0.85 applied
Total Thallium	0	0		0	65	65.0	2,263	
Total Zinc	0	0		0	115,730	118	4,120	Chem Translator of 0.978 applied

NPDES Permit Fact Sheet  
Central Indiana County Water Authority

NPDES Permit No. PA0252662

**CFC** CCT (min): **25.171** PMF: **1** Analysis Hardness (mg/l): **98.866** Analysis pH: **7.01**

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Fluoride (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Antimony	0	0		0	220	220	9,858	
Total Arsenic	0	0		0	148	148	6,632	Chem Translator of 1 applied
Total Barium	0	0		0	4,100	4,100	183,715	
Total Boron	0	0		0	1,600	1,600	71,694	
Total Cadmium	0	0		0	0.244	0.27	12.0	Chem Translator of 0.909 applied
Total Chromium (III)	0	0		0	73.426	85.4	3,826	Chem Translator of 0.86 applied
Hexavalent Chromium	0	0		0	10	10.4	466	Chem Translator of 0.962 applied

Model Results

4/2/2025

Page

Total Cobalt	0	0		0	19	19.0	851	
Total Copper	0	0		0	8,869	9.24	414	Chem Translator of 0.96 applied
Dissolved Iron	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	1,500	1,500	67,213	WQC = 30 day average; PMF = 1
Total Lead	0	0		0	2.486	3.14	141	Chem Translator of 0.793 applied
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Mercury	0	0		0	0.770	0.91	40.6	Chem Translator of 0.85 applied
Total Nickel	0	0		0	51.507	51.7	2,315	Chem Translator of 0.997 applied
Total Phenols (Phenolics) (PWS)	0	0		0	N/A	N/A	N/A	
Total Selenium	0	0		0	4,600	4.99	224	Chem Translator of 0.922 applied
Total Silver	0	0		0	N/A	N/A	N/A	Chem Translator of 1 applied
Total Thallium	0	0		0	13	13.0	583	
Total Zinc	0	0		0	117,003	119	5,317	Chem Translator of 0.986 applied

**THH** CCT (min): **25.171** PMF: **1** Analysis Hardness (mg/l): **N/A** Analysis pH: **N/A**

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	500,000	500,000	N/A	
Chloride (PWS)	0	0		0	250,000	250,000	N/A	
Sulfate (PWS)	0	0		0	250,000	250,000	N/A	
Fluoride (PWS)	0	0		0	2,000	2,000	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Antimony	0	0		0	5.6	5.6	251	
Total Arsenic	0	0		0	10	10.0	448	
Total Barium	0	0		0	2,400	2,400	107,541	
Total Boron	0	0		0	3,100	3,100	138,907	
Total Cadmium	0	0		0	N/A	N/A	N/A	
Total Chromium (III)	0	0		0	N/A	N/A	N/A	
Hexavalent Chromium	0	0		0	N/A	N/A	N/A	
Total Cobalt	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	N/A	N/A	N/A	
Dissolved Iron	0	0		0	300	300	13,443	
Total Iron	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Manganese	0	0		0	1,000	1,000	44,809	
Total Mercury	0	0		0	0.003	0.003	0.14	
Total Nickel	0	0		0	610	610	27,333	
Total Phenols (Phenolics) (PWS)	0	0		0	5	5.0	N/A	
Total Selenium	0	0		0	N/A	N/A	N/A	
Total Silver	0	0		0	N/A	N/A	N/A	
Total Thallium	0	0		0	0.24	0.24	10.8	
Total Zinc	0	0		0	N/A	N/A	N/A	

NPDES Permit Fact Sheet  
Central Indiana County Water Authority

NPDES Permit No. PA0252662

CRL

CCT (min): 8.066

PMF: 1

Analysis Hardness (mg/l): N/A

Analysis pH: N/A

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Fluoride (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Antimony	0	0		0	N/A	N/A	N/A	
Total Arsenic	0	0		0	N/A	N/A	N/A	
Total Barium	0	0		0	N/A	N/A	N/A	
Total Boron	0	0		0	N/A	N/A	N/A	
Total Cadmium	0	0		0	N/A	N/A	N/A	
Total Chromium (III)	0	0		0	N/A	N/A	N/A	
Hexavalent Chromium	0	0		0	N/A	N/A	N/A	
Total Cobalt	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	N/A	N/A	N/A	
Dissolved Iron	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Mercury	0	0		0	N/A	N/A	N/A	

Model Results

4/2/2025

Page 1

Total Nickel	0	0		0	N/A	N/A	N/A	
Total Phenols (Phenolics) (PWS)	0	0		0	N/A	N/A	N/A	
Total Selenium	0	0		0	N/A	N/A	N/A	
Total Silver	0	0		0	N/A	N/A	N/A	
Total Thallium	0	0		0	N/A	N/A	N/A	
Total Zinc	0	0		0	N/A	N/A	N/A	

Recommended WQBELs & Monitoring Requirements

No. Samples/Month: 4

Model Results

4/2/2025

Page

Pollutants	Mass Limits		Concentration Limits				Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units			

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

Pollutants	Governing WQBEL	Units	Comments
Total Dissolved Solids (PWS)	N/A	N/A	PWS Not Applicable
Chloride (PWS)	N/A	N/A	PWS Not Applicable
Bromide	N/A	N/A	No WQS
Sulfate (PWS)	N/A	N/A	PWS Not Applicable
Fluoride (PWS)	N/A	N/A	PWS Not Applicable
Total Aluminum	16,738	µg/L	Discharge Conc ≤ 10% WQBEL
Total Antimony	N/A	N/A	Discharge Conc < TQL
Total Arsenic	N/A	N/A	Discharge Conc < TQL
Total Barium	107,541	µg/L	Discharge Conc ≤ 10% WQBEL
Total Beryllium	N/A	N/A	No WQS
Total Boron	71,694	µg/L	Discharge Conc < TQL
Total Cadmium	12.0	µg/L	Discharge Conc < TQL
Total Chromium (III)	3,826	µg/L	Discharge Conc < TQL
Hexavalent Chromium	357	µg/L	Discharge Conc < TQL
Total Cobalt	851	µg/L	Discharge Conc < TQL
Total Copper	308	µg/L	Discharge Conc ≤ 10% WQBEL
Total Cyanide	N/A	N/A	No WQS
Dissolved Iron	13,443	µg/L	Discharge Conc < TQL
Total Iron	67,213	µg/L	Discharge Conc ≤ 10% WQBEL
Total Lead	141	µg/L	Discharge Conc < TQL
Total Manganese	44,809	µg/L	Discharge Conc ≤ 10% WQBEL
Total Mercury	0.003	µg/L	Discharge Conc < TQL
Total Nickel	2,315	µg/L	Discharge Conc < TQL
Total Phenols (Phenolics) (PWS)		µg/L	PWS Not Applicable
Total Selenium	224	µg/L	Discharge Conc < TQL
Total Silver	82.4	µg/L	Discharge Conc < TQL
Total Thallium	10.8	µg/L	Discharge Conc < TQL
Total Zinc	2,641	µg/L	Discharge Conc ≤ 10% WQBEL
Total Molybdenum	N/A	N/A	No WQS


C. TRC Calculation Results

TRC EVALUATION									
Input appropriate values in A3:A9 and D3:D9									
Source		Reference		AFC Calculations		Reference		CFC Calculations	
TRC	1.3.2.iii	PENTOXSD TRG	5.1a	WLA_afc = 13.994		1.3.2.iii		WLA_cfc = 13.635	
PENTOXSD TRG	5.1b			LTAMULT_afc = 0.373		5.1c		LTAMULT_cfc = 0.581	
				LTA_afc= 5.214		5.1d		LTA_cfc = 7.927	
Source									
Effluent Limit Calculations									
PENTOXSD TRG	5.1f				AML MULT = 1.231				
PENTOXSD TRG	5.1g				AVG MON LIMIT (mg/l) = 0.500		BAT/BPJ		
					INST MAX LIMIT (mg/l) = 1.635				
WLA_afc					(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))... ...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)				
LTAMULT_afc					EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)				
LTA_afc					wla_afc*LTAMULT_afc				
WLA_cfc					(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))... ...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)				
LTAMULT_cfc					EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)				
LTA_cfc					wla_cfc*LTAMULT_cfc				
AML_MULT					EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))				
AVG_MON_LIMIT					MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)				
INST_MAX_LIMIT					1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)				

D. Upstream of Discharge StreamStats

### Discharge location StreamStats Report

Region ID: PA  
Workspace ID: PA20250330121316544000  
Clicked Point (Latitude, Longitude): 40.54795, -79.15845  
Time: 2025-03-30 08:13:45 -0400



 [Collapse All](#)

#### ► Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	66	square miles
ELEV	Mean Basin Elevation	1636	feet
PRECIP	Mean Annual Precipitation	47	inches

➤ Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 3]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	66	square miles	2.33	1720
ELEV	Mean Basin Elevation	1636	feet	898	2700
PRECIP	Mean Annual Precipitation	47	inches	38.7	47.9

Low-Flow Statistics Flow Report [Low Flow Region 3]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR<sup>2</sup>: Pseudo R Squared (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	9.24	ft <sup>3</sup> /s	43	43
30 Day 2 Year Low Flow	13	ft <sup>3</sup> /s	38	38
7 Day 10 Year Low Flow	5.11	ft <sup>3</sup> /s	54	54
30 Day 10 Year Low Flow	6.63	ft <sup>3</sup> /s	49	49
90 Day 10 Year Low Flow	9.33	ft <sup>3</sup> /s	41	41

*Low-Flow Statistics Citations*

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p.  
(<http://pubs.usgs.gov/sir/2006/5130/>)

E. Downstream of Discharge StreamStats


## Downstream StreamStats Report

Region ID: PA

Workspace ID: PA20250330122124093000

Clicked Point (Latitude, Longitude): 40.54431, -79.15928

Time: 2025-03-30 08:21:49 -0400



[Collapse All](#)

### ► Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	66.2	square miles
ELEV	Mean Basin Elevation	1634	feet
PRECIP	Mean Annual Precipitation	47	inches

➤ Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 3]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	66.2	square miles	2.33	1720
ELEV	Mean Basin Elevation	1634	feet	898	2700
PRECIP	Mean Annual Precipitation	47	inches	38.7	47.9

Low-Flow Statistics Flow Report [Low Flow Region 3]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR<sup>2</sup>: Pseudo R Squared (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	9.26	ft <sup>3</sup> /s	43	43
30 Day 2 Year Low Flow	13.1	ft <sup>3</sup> /s	38	38
7 Day 10 Year Low Flow	5.13	ft <sup>3</sup> /s	54	54
30 Day 10 Year Low Flow	6.64	ft <sup>3</sup> /s	49	49
90 Day 10 Year Low Flow	9.35	ft <sup>3</sup> /s	41	41

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p.  
(<http://pubs.usgs.gov/sir/2006/5130/>)