

Application Type Renewal  
Facility Type Industrial  
Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL INDUSTRIAL WASTE (IW)  
AND IW STORMWATER**

Application No. PA0253162  
APS ID 1020830  
Authorization ID 1322255

**Applicant and Facility Information**

Applicant Name	<u>Iron Cumberland, LLC</u>	Facility Name	<u>Alicia Harbor Facility</u>
Applicant Address	<u>855 Kirby Road</u> <u>Waynesburg, PA 15370</u>	Facility Address	<u>299 Alicia Road</u> <u>Greensboro, PA 15338</u>
Applicant Contact	<u>Noah Bezell</u>	Facility Contact	<u>Brittany N. Thompson</u>
Applicant Phone	<u>724-395-3231</u>	Facility Phone	<u>724-395-3238</u>
Client ID	<u>329531</u>	Site ID	<u>532876</u>
SIC Code	<u>4491</u>	Municipality	<u>Monongahela Township</u>
SIC Description	<u>Marine Cargo Handling</u>	County	<u>Greene</u>
Date Application Received	<u>July 31, 2020</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>August 4, 2020</u>	If No, Reason	<u></u>
Purpose of Application	<u>NPDES permit renewal and name change.</u>		

**Summary of Review**

The permittee is changing its name as well as renewing its NPDES permit. The permittee submitted a Notice of Intent (NOI) to transfer and amend NPDES Permit PA0253162 for Discharges of Industrial Wastewater. Also being transferred is the WQM Part II Permit (#3076405) for the small flow sewage treatment plant, and WQM Part II Permit (#3016200) for the recently modified sedimentation basin (Pond SW-1). These transfers are for a name change only. Ownership remains the same. The name change occurred on April 8, 2021.

The current permits are issued to:

Cumberland Contura, LLC  
855 Kirby Road  
PO Box 1020  
Waynesburg, PA 15370

Contact Person:

Noah Bezell – Environmental Compliance Manager  
724-395-3231  
[NBezell@ironenergy.com](mailto:NBezell@ironenergy.com)



For a facility located at:

299 Alicia Road  
Greensboro, PA 15338

The permits are being transferred to:

Iron Cumberland, LLC  
855 Kirby Road  
PO Box 1020  
Waynesburg, PA 15370

The permittee's NAICS Code is 213 – Support Activities for Coal Mining

Approve	Deny	Signatures	Date
X		 Mark S. Okrutny / Environmental Engineering Specialist	March 15, 2022
X		 Michael E. Fifth, P.E. / Environmental Engineer Manager	March 29, 2022

### Summary of Review

The Iron Cumberland Alicia Harbor Facility is a harbor barge load-out facility for coal with a sewage treatment plant on-site. Coal is taken from rail cars and put on a conveyer that loads the coal onto barges. The rail car loading area is at a higher elevation than the sewage treatment plant but all water that comes into contact with the loading area is conveyed to a treatment basin (Pond SW-1) at the same elevation as the sewage treatment plant. The sewage treatment plant treats sewage from employees of Cumberland Contura.

The facility is situated on the west bank of the Monongahela River. Water is discharged to the Monongahela River which is classified as a Warm Water Fishery. It was last inspected by the Department on September 19, 2014. No Violations were noted. The facility is bordered on the east by the Monongahela River and is bordered on the north, south and west by forested hillsides.

WQM Part II Permit 3076405 was originally issued on October 8, 1976 to the United States Steel Corporation and authorized construction of the sewage treatment plant (STP) which consists of: flow equalization, extended aeration, final clarification and chlorination.

The discharge from the STP was previously covered by a sewage NPDES permit. An inspection on August 3, 2005 determined that the facility should be covered by an industrial waste NPDES permit instead of a sewage NPDES permit. Thus, permit PA0253162 replaced sewage permit PA0216674 on October 1, 2015 and was issued to Cumberland Coal Resources.

On September 26, 2018 WQM Part II Permit 3016200 was issued for improvements to the coal pile settling pond (Pond SW-1) to include increased capacity, an impermeable liner, a sediment forebay, skimmer, and spillway modifications. The pond handles stormwater runoff from coal piles as well as uncontaminated stormwater runoff. Modifications to Pond SW-1 were completed on November 4, 2021.

On January 3, 2019 the NPDES permit was amended to include a new outfall (094) for uncontaminated stormwater. The permit was also transferred from Cumberland Coal Resources to Cumberland Contura, LLC.

The current NPDES permit has 7 outfalls with monitoring for the following parameters:

- 003 – small flow sewage treatment plant  
(flow, pH, Dissolved O2, TRC, CBOD5, TSS, Fecal Coliform, Total N, Ammonia Nitrogen, Total P)
- 095 – principal spillway from Pond SW-1 – industrial activity: coal loading, unloading, storage and transportation  
(flow, pH, TSS, TDS, Oil & Grease, Total Al, Dissolved Fe, Total Fe, Total Mn)
- 096 – emergency spillway from Pond SW-1 – industrial activity: coal loading, unloading, storage and transportation  
(flow, pH, TSS, TDS, Oil & Grease, Total Al, Dissolved Fe, Total Fe, Total Mn)
- 097 – stormwater that is not impacted by industrial activity  
(not monitored)
- 098 - stormwater that is not impacted by industrial activity  
(not monitored)
- 099 – stormwater that is not impacted by industrial activity  
(not monitored)
- 094 – stormwater that is not impacted by industrial activity  
(not monitored)

It is recommended that a draft permit be published for public comment in response to this application.

### Public Participation

**Summary of Review**

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>003</u>	Design Flow (MGD)	<u>0.004</u>
Latitude	<u>39° 50' 01.56"</u>	Longitude	<u>-79° 55' 25.42"</u>
Quad Name	<u>Masontown</u>	Quad Code	<u>2006</u>
Wastewater Description: <u>Treated sewage effluent</u>			
Receiving Waters	<u>Monongahela River (WWF)</u>	Stream Code	<u>37185</u>
NHD Com ID	<u>99417096</u>	RMI	<u>81.2</u>
Drainage Area	<u>4460 mi<sup>2</sup></u>	Yield (cfs/mi <sup>2</sup> )	<u>NA</u>
Q <sub>7-10</sub> Flow (cfs)	<u>560</u>	Q <sub>7-10</sub> Basis	<u>US Army Corps of Engineers</u>
Elevation (ft)	<u>770</u>	Slope (ft/ft)	<u>0.0001</u>
Watershed No.	<u>19-G</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u>WWF</u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u>Navigation</u>	Exceptions to Criteria	<u>None</u>
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>Polychlorinated Biphenyls (PCBs)</u>		
Source(s) of Impairment	<u>Source Unknown</u>		
TMDL Status	<u>Final</u>	Name	<u>Monongahela River TMDL</u>
Nearest Downstream Public Water Supply Intake	<u>Masontown Municipal Water Works</u>		
PWS Waters	<u>Monongahela River</u>	Flow at Intake (cfs)	<u>425</u>
PWS RMI	<u>78.87</u>	Distance from Outfall (mi)	<u>81.1</u>

Changes Since Last Permit Issuance: There have been no changes to the sewage treatment plant.

### **Outfall 003**

Outfall 003 discharges sewage effluent from a small package plant facility. The facility was permitted under the WQM permit 3076405 on October 8, 1976 to the United States Steel Corporation. Wastewater treatment at the facility consists of flow equalization, extended aeration, final clarification and chlorination.

### ***Technology Based Effluent Limitations***

Effluent standards will be implemented for CBOD<sub>5</sub> based upon 25 PA Code Chapter 92a.47(a)(1) and 40 CFR 133.102(a)(4)(i). Effluent standards for Total Suspended Solids will be implemented based upon 25 PA Code Chapter 92a.47(a)(1) and 40 CFR 133.102(b)(1). Effluent standards for Fecal Coliform will be implemented based upon 25 PA Code Chapter 92a.47(a)(4-5). Effluent standards for Total Residual Chlorine will be implemented based upon 25 PA Code Chapter 92a.48(b)(2). Effluent standards for pH will be implemented based upon 25 PA Code Chapter 95.2 and 40 CFR 133.102(c).

An effluent limitation for dissolved oxygen with a minimum of 4.0 mg/L will be implemented based on the standard in 25 PA Code Chapter 93 and best professional judgment. Monitoring will be required for total nitrogen and total phosphorus based upon 25 PA Code Chapter 92a.61. The effluent standards and technology based effluent limitations are summarized in Table 1, below.

**Table 1: Effluent standards and technology based effluent limitations.**

Parameter	Minimum	Monthly Average	Daily Maximum	Maximum	Instantaneous Maximum
CBOD5 (mg/L)	-	25	-	-	50
TSS (mg/L)	-	30	-	-	60
Total Residual Chlorine (mg/L)	-	0.5	-	-	1.6
Fecal Coliform (No./mL) (5/1 to 9/30)	-	200/100mL (Geo Mean)	30	-	1,000/100 mL
Fecal Coliform (No./mL) (10/1 to 4/30)		2,000/100 mL (Geo Mean)			10,000/ 100 mL
Dissolved Oxygen (mg/L)	4.0	-	-	-	-
pH (S.U.)	6.0	-	-	9.0	-

**Water Quality Based Effluent Limitations**

The discharge was modeled using WQM 7.0 for CBOD5, ammonia nitrogen and dissolved oxygen. The discharge was also modeled using the TRC spreadsheet for total residual chlorine. Both of these indicated that no water quality based effluent limitations are necessary. Ammonia nitrogen, total nitrogen and total phosphorus are pollutants of concern therefore monitoring will be included for those pollutants which is shown in Table 2, below.

**Table 2: Monitoring requirements based on water quality concerns.**

Parameter	Monthly Average	Daily Maximum
Ammonia Nitrogen (mg/L)	Report	Report
Total Nitrogen (mg/L)	-	Report
Total Phosphorus (mg/L)	-	Report

The Policy and Procedure for NPDES Permitting of Discharges of Total Dissolved Solids (TDS) stipulates that the mass loading approved prior to August 21, 2010 should be defined in a Part C condition. This discharge was approved previously in permit number PA0216674. The DEP chose to assign a new permit number (PA0253162) to this facility. Therefore, this discharge will still be considered to have been approved prior to August 21, 2010. It is not anticipated that Outfall 003 will discharge high levels of TDS. The DEP will rely on the permittee to report if there is a change in the quantity or quality of the wastewater being discharged.

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>095</u>	Design Flow (MGD)	<u>Precipitation Induced</u>
Latitude	<u>39° 49' 57.76"</u>	Longitude	<u>-79° 55' 24.81"</u>
Quad Name	<u>Masontown</u>	Quad Code	<u>2006</u>
Wastewater Description: <u>Stormwater associated with industrial activity,</u>			
Receiving Waters	<u>Monongahela River (WWF)</u>	Stream Code	<u>37185</u>
NHD Com ID	<u>99417096</u>	RMI	<u>81.1</u>
Drainage Area	<u>4460 mi<sup>2</sup></u>	Yield (cfs/mi <sup>2</sup> )	<u>NA</u>
Q <sub>7-10</sub> Flow (cfs)	<u>560</u>	Q <sub>7-10</sub> Basis	<u>US Army Corps of Engineers</u>
Elevation (ft)	<u>770</u>	Slope (ft/ft)	<u>0.0001</u>
Watershed No.	<u>19-G</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u>WWF</u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u>Navigation</u>	Exceptions to Criteria	<u>None</u>
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>Polychlorinated Biphenyls (PCBs)</u>		
Source(s) of Impairment	<u>Source Unknown</u>		
TMDL Status	<u>Final</u>	Name	<u>Monongahela River TMDL</u>
Nearest Downstream Public Water Supply Intake	<u>Masontown Municipal Water Works</u>		
PWS Waters	<u>Monongahela River</u>	Flow at Intake (cfs)	<u>425</u>
PWS RMI	<u>78.87</u>	Distance from Outfall (mi)	<u>81.1</u>

Changes Since Last Permit Issuance:

Modifications to Pond SW-1 were completed on November 4, 2021. Part II permit 3016200 was issued on September 26, 2018 for the rehabilitation/modification of the pond. Modifications include a diversion ditch, a 30 mil HDPE liner or compacted clay liner, addition of a sediment forebay, pond enlargement, and spillway modifications. The chemical treatment process involved is the addition of flocculant that will only be implemented as needed to reduce the Total Suspended Solids effluent concentration to <50 mg/l in accordance with the NPDES permit.

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>096</u>	Design Flow (MGD)	<u>Precipitation Induced</u>
Latitude	<u>39° 49' 57.76"</u>	Longitude	<u>-79° 55' 28.8"</u>
Quad Name	<u>Masontown</u>	Quad Code	<u>2006</u>
Wastewater Description: <u>Stormwater associated with industrial activity,</u>			
Receiving Waters	<u>Monongahela River (WWF)</u>	Stream Code	<u>37185</u>
NHD Com ID	<u>99416980</u>	RMI	<u>81.7300</u>
Drainage Area	<u>4460 mi<sup>2</sup></u>	Yield (cfs/mi <sup>2</sup> )	<u>NA</u>
Q <sub>7-10</sub> Flow (cfs)	<u>560</u>	Q <sub>7-10</sub> Basis	<u>US Army Corps of Engineers</u>
Elevation (ft)	<u>770</u>	Slope (ft/ft)	<u>0.0001</u>
Watershed No.	<u>19-G</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u>WWF</u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u>Navigation</u>	Exceptions to Criteria	<u>None</u>
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>Polychlorinated Biphenyls (PCBs)</u>		
Source(s) of Impairment	<u>Source Unknown</u>		
TMDL Status	<u>Final</u>	Name	<u>Monongahela River TMDL</u>
Nearest Downstream Public Water Supply Intake	<u>Masontown Municipal Water Works</u>		
PWS Waters	<u>Monongahela River</u>	Flow at Intake (cfs)	<u>425</u>
PWS RMI	<u>78.87</u>	Distance from Outfall (mi)	<u>81.1</u>

Changes Since Last Permit Issuance: Same as for Outfall 095.

### **Outfalls 095 & 096**

Outfall 095 will discharge stormwater associated with industrial activity after it has been treated by a sedimentation basin. The stormwater will come into contact with coal handling, loading, unloading, transportation and storage. As such, this stormwater is considered an industrial waste. Outfall 096 is the emergency overflow from the treatment basin and will, therefore, receive the same limits as Outfall 095.

### ***Technology Based Effluent Limitations***

Stormwater runoff from coal loading, unloading, handling, transportation and storage areas are not subject to Federal Effluent Limitation Guidelines. Effluent limitations are therefore based on applicable state regulations and guidelines and on the Department's Best Professional Judgment (BPJ). When establishing a limit for stormwater runoff from coal piles, the Department has determined that it is Best Professional Judgement to use the TSS limit provided in 40 CFR Part 423.12 Steam Electric Power Generating Point Source Category. The limit for TSS is 50 mg/l. The sampling frequency will be 1/month to ensure that BMPs for the handling of materials are effective.

This facility will handle, unload, load, transport and store clean coal. There will be no other coal managed on site. The only other technology based effluent limitation from an ELG that is available for coal runoff are the technology based effluent limitations from the federal ELG for coal preparation plants and coal preparation plant associated areas under 40 CFR Part 434, Subpart B §§ 434.20 – 434.25. The coal at this site will have already been cleaned at a coal preparation plant so it should be of a better quality than the coal found at a coal preparation plant. At a coal preparation plant the coal has not been sorted so the coal varies in quality. Since the facility only moves clean coal it is likely that the coal pile runoff at this

facility will be similar that from coal piles at steam-electric power generation facilities (i.e., similar concentrations and types of constituents).

DEP does not have specific coal chemistries available for review, however, it is likely that the coal stored at this facility is similar to the coal stored at steam electric generating facilities. Therefore, since the effluent limits from the ELG for Steam Electric Power Generation found in 40 CFR § 423.12(b)(1) and (b)(9) are national performance standards developed by EPA and DEP has determined that the facility operations and wastewater characteristics are similar it is acceptable to apply these effluent limitations at Outfall 095. The adoption of those performance standards and the technology basis for those standards is also appropriate because the same treatment technologies will be implemented at the Cumberland facility as would be implemented at a steam electric power generating plant (sedimentation). EPA’s effluent limit rationale as described in the Steam Electric ELG Development Document will substitute for DEP’s case-by-case BPJ effluent limit evaluation. BMPs from the former Appendix E of DEP’s PAG-03 General Permit (which contained effluent limitations for coal storage areas and which are in the current permit) will also be included in Part C of the renewed permit.

40 CFR § 423.12(b)(10) states that, “Any untreated overflow from facilities designed, constructed, and operated to treat the volume of coal pile runoff which is associated with a 10 year, 24 hour rainfall event shall not be subject to the limitations in paragraph (b)(9) of this section.” It has been determined that 40 CFR § 423.12(b)(9) is the most appropriate technology based effluent limitation. Therefore, if Cumberland does not comply with the effluent limitation in 40 CFR § 423.12(b)(9) and can demonstrate that this exceedance took place during a 10 year 24 hour or larger precipitation event (or snowmelt of equivalent volume) then this will not be considered an effluent violation. As such, the following Part C condition was added to the previous permit and will be retained in this renewal. The Condition reads:

*Any untreated overflow from facilities designed, constructed, and operated to treat the volume of runoff which is associated with a 10-year, 24-hour rainfall event shall not be subject to the 50 mg/L TSS limit at Outfalls 095 and 096. The burden of proof is on the permittee to show that untreated overflows occurred as a result of runoff volumes in excess of the 10-year, 24-hour rainfall event.*

Effluent standards for pH from 25 PA Code Chapter 95.2 (1) and dissolved iron from 25 PA Code Chapter 95.2 (4) will also be implemented. Oil & grease is a pollutant of concern due to the coal handling and railcar maintenance operations at the facility therefore the effluent standard from 25 PA Code Chapter 95.2 (2) (ii) for oil and grease will be applied. All applicable technology based effluent limitations are summarized in Table 3, below.

**Table 3: Applicable technology based effluent limitations and effluent standards.**

<b>Parameter</b>	<b>Minimum</b>	<b>Monthly Average</b>	<b>Daily Maximum</b>	<b>Maximum</b>
Iron, dissolved (mg/L)	-	Report	-	7.0
TSS (mg/L)	-	Report	50.0	-
Oil & Grease (mg/L)	-	15.0	30.0	-
pH (S.U.)	6.0	-	-	9.0

***Water Quality Based Effluent Limitations***

A water quality analysis for Outfall 095 using the Department’s Toxics Management Spreadsheet (TMS) was not performed because Outfall 095 is a precipitation induced discharge and will likely not discharge during low flow conditions.

The facility existed prior to August 21, 2010 so Outfall 095 is an existing discharge under Chapter 95.10 and is not subject to effluent limitations for Total Dissolved Solids (TDS). This discharge was approved previously in permit number PA0216674. The DEP chose to assign a new permit number (PA0253162) to this facility. Therefore, this discharge will still be considered to have been approved prior to August 21, 2010.

The Policy and Procedure for NPDES Permitting of Discharges of Total Dissolved Solids stipulates that the mass loading approved prior to August 21, 2010 should be defined in a Part C condition. However, there is no reliable way to calculate a discharge flow for stormwater that would make it possible to translate a discharge concentration of TDS into a mass. In conjunction with that, no sampling data for TDS exists for the facility. The current permit monitored the discharge for TDS but the eDMRs showed no discharge from Pond SW-1, presumably because the water infiltrated to the ground since the



pond was not lined or, for a time being was under construction for modifications. Now that the pond is lined with a synthetic liner there should be discharges from pond SW-1 via outfall 095 and possibly 096. Therefore, monitoring for TDS will be maintained in the renewed permit.

Runoff associated with coal storage is expected to discharge high concentrations of TDS but, since the facility only discharges intermittently it would take a large change in operation to effect an increase of 5,000 pounds per day of TDS. Monitoring for TDS will be continued to help establish the existing loading. The DEP will rely on the permittee to report if there is a change in the quantity or quality of the wastewater being discharged.

TDS and its major constituents including sulfate, chloride, and bromide have emerged as pollutants of concern in several major watersheds in the Commonwealth. The conservative nature of these solids allows them to accumulate in surface waters and they may remain a concern even if the immediate downstream public water supply is not directly impacted. Bromide has been linked to formation of disinfection byproducts at increased levels in public water systems.

The current permit for this facility includes monitoring at Pond SW-1 for sulfate, chloride and bromide in order to collect data on these parameters in relation to the amount of TDS produced as a consequence of actions associated with Triennial Review 13 and by the Environmental Quality Board directing the DEP to collect additional data related to sulfate, chloride, and 1,4-dioxane under the authority of §92a.61. At this time, the Department has determined that we have collected sufficient data from facilities over the past seven years that monitoring for sulfate, chloride and bromide in relation to the amount of TDS produced is no longer needed. Therefore, monitoring for sulfate, chloride and bromide is being discontinued for Pond SW-1 in the draft permit.

Iron, aluminum and manganese are typically present in discharges associated with coal storage so monitoring requirements will be imposed for those pollutants as well. Monitoring requirements are summarized in Table 4, below.

**Table 4: Monitoring requirements based on best water quality concerns.**

<b>Parameter</b>	<b>Monthly Average</b>	<b>Daily Maximum</b>
TDS (mg/L)	Report	Report
Aluminum (mg/L)	Report	Report
Iron (mg/L)	Report	Report
Manganese (mg/L)	Report	Report

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>097</u>	Design Flow (MGD)	<u>0.0 (stormwater)</u>
Latitude	<u>39° 49' 46.14"</u>	Longitude	<u>-79° 55' 23.91"</u>
Quad Name	<u>Masontown</u>	Quad Code	<u>2006</u>
Wastewater Description: <u>Stormwater that is not impacted by industrial activity (not monitored)</u>			
Receiving Waters	<u>Monongahela River (WWF)</u>	Stream Code	<u>37185</u>
NHD Com ID	<u>99417290</u>	RMI	<u>82.4700</u>
Drainage Area	<u>4460 mi<sup>2</sup></u>	Yield (cfs/mi <sup>2</sup> )	<u>US Army Corps of Engineers</u>
Q <sub>7-10</sub> Flow (cfs)	<u>560</u>	Q <sub>7-10</sub> Basis	<u>Engineers</u>
Elevation (ft)	<u>770</u>	Slope (ft/ft)	<u>0.0001</u>
Watershed No.	<u>19-G</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u>WWF</u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u>Navigation</u>	Exceptions to Criteria	<u></u>
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>Polychlorinated Biphenyls (PCBs)</u>		
Source(s) of Impairment	<u>Source Unknown</u>		
TMDL Status	<u>Final</u>	Name	<u>Monongahela River TMDL</u>
Nearest Downstream Public Water Supply Intake			
PWS Waters	<u>Monongahela River</u>	Flow at Intake (cfs)	<u>425</u>
PWS RMI	<u>78.87</u>	Distance from Outfall (mi)	<u>2.3</u>

Changes Since Last Permit Issuance:

Other Comments:

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>098</u>	Design Flow (MGD)	<u>0.0 (stormwater)</u>
Latitude	<u>39° 49' 43.15"</u>	Longitude	<u>-79° 55' 23.01"</u>
Quad Name	<u>Masontown</u>	Quad Code	<u>2006</u>
Wastewater Description: <u>Stormwater that is not impacted by industrial activity (not monitored)</u>			
Receiving Waters	<u>Monongahela River (WWF)</u>	Stream Code	<u>37185</u>
NHD Com ID	<u>99417290</u>	RMI	<u>82.4700</u>
Drainage Area	<u>4460</u>	Yield (cfs/mi <sup>2</sup> )	<u>US Army Corps of Engineers</u>
Q <sub>7-10</sub> Flow (cfs)	<u>560 mi<sup>2</sup></u>	Q <sub>7-10</sub> Basis	<u>Engineers</u>
Elevation (ft)	<u>770</u>	Slope (ft/ft)	<u>0.0001</u>
Watershed No.	<u>19-G</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u>WWF</u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u>Navigation</u>	Exceptions to Criteria	<u></u>
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>Polychlorinated Biphenyls (PCBs)</u>		
Source(s) of Impairment	<u>Source Unknown</u>		
TMDL Status	<u>Final</u>	Name	<u>Monongahela River TMDL</u>
Nearest Downstream Public Water Supply Intake			
PWS Waters	<u>Monongahela River</u>	Flow at Intake (cfs)	<u>425</u>
PWS RMI	<u>78.87</u>	Distance from Outfall (mi)	<u>2.3</u>

Changes Since Last Permit Issuance:

Other Comments:

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>099</u>	Design Flow (MGD)	<u>0.0 (stormwater)</u>
Latitude	<u>39° 49' 39.11"</u>	Longitude	<u>-79° 55' 22.98"</u>
Quad Name	<u>Masontown</u>	Quad Code	<u>2006</u>
Wastewater Description: <u>Stormwater that is not impacted by industrial activity (not monitored)</u>			
Receiving Waters	<u>Monongahela River (WWF)</u>	Stream Code	<u>37185</u>
NHD Com ID	<u>99417290</u>	RMI	<u>82.4700</u>
Drainage Area	<u>4460</u>	Yield (cfs/mi <sup>2</sup> )	<u>US Army Corps of Engineers</u>
Q <sub>7-10</sub> Flow (cfs)	<u>560 mi<sup>2</sup></u>	Q <sub>7-10</sub> Basis	<u>Engineers</u>
Elevation (ft)	<u>770</u>	Slope (ft/ft)	<u>0.0001</u>
Watershed No.	<u>19-G</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u>WWF</u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u>Navigation</u>	Exceptions to Criteria	<u></u>
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>Polychlorinated Biphenyls (PCBs)</u>		
Source(s) of Impairment	<u>Source Unknown</u>		
TMDL Status	<u>Final</u>	Name	<u>Monongahela River TMDL</u>
Nearest Downstream Public Water Supply Intake			
PWS Waters	<u>Monongahela River</u>	Flow at Intake (cfs)	<u>425</u>
PWS RMI	<u>78.87</u>	Distance from Outfall (mi)	<u>2.3</u>

Changes Since Last Permit Issuance:

Other Comments:

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>094</u>	Design Flow (MGD)	<u>0.0 (stormwater)</u>
Latitude	<u>39° 50' 00.39"</u>	Longitude	<u>-79° 55' 26.04"</u>
Quad Name	<u>Masontown</u>	Quad Code	<u>2006</u>
Wastewater Description: <u>Stormwater that is not impacted by industrial activity (not monitored)</u>			
Receiving Waters	<u>Monongahela River (WWF)</u>	Stream Code	<u>37185</u>
NHD Com ID	<u>99416980</u>	RMI	<u>0.6300</u>
Drainage Area	<u>4460</u>	Yield (cfs/mi <sup>2</sup> )	<u>US Army Corps of Engineers</u>
Q <sub>7-10</sub> Flow (cfs)	<u>560 mi<sup>2</sup></u>	Q <sub>7-10</sub> Basis	<u>Engineers</u>
Elevation (ft)	<u>770</u>	Slope (ft/ft)	<u>0.0001</u>
Watershed No.	<u>19-G</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u>WWF</u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u>Navigation</u>	Exceptions to Criteria	<u></u>
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>Polychlorinated Biphenyls (PCBs)</u>		
Source(s) of Impairment	<u>Source Unknown</u>		
TMDL Status	<u>Final</u>	Name	<u>Monongahela River TMDL</u>
Nearest Downstream Public Water Supply Intake			
PWS Waters	<u>Monongahela River</u>	Flow at Intake (cfs)	<u>425</u>
PWS RMI	<u>78.87</u>	Distance from Outfall (mi)	<u>2.3</u>

Changes Since Last Permit Issuance:

Outfall 094 was added in an amendment to the permit that was issued on January 3, 2019. Outfall 094 is situated between Outfalls 003 (north) and 096 (south).

Other Comments:

**Outfalls 097, 098, 099 and 094**

Outfalls 097, 098, 099 and 094 discharge stormwater from portions of the facility that do not come into contact with industrial activity. They will be listed as discharge points in Part C of the permit. No monitoring requirements will be imposed.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Cumberland Mine Harbor				
<b>WQM Permit No.</b>		<b>Issuance Date</b>		
3076405		October 13, 1976		
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Industrial	Secondary	Extended Aeration	Chlorination	0.0003
<b>Hydraulic Capacity (MGD)</b>				
<b>Organic Capacity (lbs/day)</b>		<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
0.0015		3.57	Not overloaded	Sludge holding tank
WWTP				

Changes Since Last Permit Issuance: none

Other Comments: This is a package plant. The plant consists of one comminutor with a bypass bar screen, one aeration tank, one settling tank, one sludge holding tank and a chlorine contact tank equipped with a Sanuril chlorinator. The plant has been designed to serve 42 men per day with an average flow of 1500 gal/day. The hydraulic loads are based on 35 gallons per capita and 0.085 pounds of BOD per capita.

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment)
<input type="checkbox"/>	PENTOXSD for Windows Model (see Attachment <span style="background-color: yellow;">          </span> )
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment)
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment <span style="background-color: yellow;">          </span> )
<input type="checkbox"/>	Toxics Screening Analysis Spreadsheet (see Attachment <span style="background-color: yellow;">          </span> )
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: Establishing Effluent Limitations for Individual Sewage Permits, Individual NPDES Sewage Applications, Individual NPDES Industrial Waste and Industrial Stormwater Applications
<input checked="" type="checkbox"/>	Other: StreamStats, Google Earth, US Army Corps of Engineers

## **Attachments**

Attachment A: StreamStats Drainage Area

Attachment B: Input Data WQM 7.0

Attachment C: WQM Hydrodynamics Outputs

Attachment D: WQM 7.0 Modeling Specifications

Attachment E: WQM 7.0 Waste Load Allocations

Attachment F: WQM 7.0 D.O. Simulation


Attachment G: WQM 7.0 Effluent Limits

Attachment H: TRC Evaluation

Attachment I: Site Map



**Attachment A:  
StreamStats Drainage Area**



**StreamStats Version 3 Beta** [Print](#)

**Basin Characteristics Ungaged Site Report**

Date: Fri July 17, 2015 12:51:59 PM GMT-4  
 NAD 1983 Latitude: 39.834 ( 39 50 02)  
 NAD 1983 Longitude: -79.9226 (-79 55 22)

Label	Value	Units	Definition
DRNAREA	4460	square miles	Area that drains to a point on a stream

**Attachment B:  
Input Data WQM 7.0**

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
19A	37185	MONONGAHELA RIVER	81.200	763.00	4460.00	0.00010	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
									Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.100	0.00	560.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Cumberland Harb	PA0253162	0.0040	0.0040	0.0040	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
19A	37185	MONONGAHELA RIVER	78.970	762.00	4538.00	0.00010	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.180	0.00	560.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/l)	Trib Conc (mg/l)	Stream Conc (mg/l)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

**Attachment C:  
WQM Hydrodynamics Outputs**

### WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
19A		37185				MONONGAHELA RIVER						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
<b>Q7-10 Flow</b>												
81.200	560.00	0.00	560.00	.0062	0.00010	1.214	486.05	400.37	0.95	0.144	20.00	7.00
<b>Q1-10 Flow</b>												
81.200	358.40	0.00	358.40	.0062	0.00010	NA	NA	NA	0.74	0.184	20.00	7.00
<b>Q30-10 Flow</b>												
81.200	761.60	0.00	761.60	.0062	0.00010	NA	NA	NA	1.13	0.121	20.00	7.00

**Attachment D:  
WQM 7.0 Modeling Specifications**



### WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

**Attachment E:  
WQM 7.0 Waste Load Allocations**

### WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
19A	37185	MONONGAHELA RIVER

**NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
81.200	Cumberland Harb	9.67	50	9.67	50	0	0

**NH3-N Chronic Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
81.200	Cumberland Harb	1.92	25	1.92	25	0	0

**Dissolved Oxygen Allocations**

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
81.20	Cumberland Harb	25	25	25	25	3	3	0	0

**Attachment F:  
WQM 7.0 D.O. Simulation**

### WQM 7.0 D.O. Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
19A	37185	MONONGAHELA RIVER		
<hr/>				
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
81.200	0.004	20.000	7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
486.048	1.214	400.372	0.949	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
2.00	0.000	0.00	0.700	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
8.243	0.443	Tsvoglou	6	
<u>Reach Travel Time (days)</u>	<u>Subreach Results</u>			
0.144	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.014	2.00	0.00	8.24
	0.029	2.00	0.00	8.24
	0.043	2.00	0.00	8.24
	0.057	2.00	0.00	8.24
	0.072	2.00	0.00	8.24
	0.086	2.00	0.00	8.24
	0.101	2.00	0.00	8.24
	0.115	2.00	0.00	8.24
	0.129	2.00	0.00	8.24
	0.144	2.00	0.00	8.24

**Attachment G:  
WQM 7.0 Effluent Limitations**

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
19A		37185		MONONGAHELA RIVER			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
81.200	Cumberland Harb	PA0253162	0.004	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			3

## **Attachment H: TRC Evaluation**



TRC EVALUATION

Facility Name

Cumberland Coal Mine Harbor- Outfa

560 = Q stream (cfs)	0.5 = CV Daily			
0.004 = Q discharge (MGD)	0.5 = CV Hourly			
4 = no. samples	0.5 = AFC_Partial Mix Factor			
0.3 = Chlorine Demand of Stream	0.5 = CFC_Partial Mix Factor			
0 = Chlorine Demand of Discharge	15 = AFC_Criteria Compliance Time (min)			
0.5 = BAT/BPJ Value	720 = CFC_Criteria Compliance Time (min)			
= % Factor of Safety (FOS)	= Decay Coefficient (K)			
Source	Reference	AFC Calculations	Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 14434.408	1.3.2.iii	WLA_cfc = 14072.409
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 5378.605	5.1d	LTA_cfc = 8181.039
Source	Effluent Limit Calculations			
PENTOXSD TRG	5.1f	AML_MULT = 1.720		
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500 BAT/BPJ		
		INST MAX LIMIT (mg/l) = 1.170		
WLA_afc	$(.019/e^{-k \cdot AFC\_tc}) + [(AFC\_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC\_tc}) \dots + Xd + (AFC\_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$			
LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$			
LTA_afc	wla_afc * LTAMULT_afc			
WLA_cfc	$(.011/e^{-k \cdot CFC\_tc}) + [(CFC\_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC\_tc}) \dots + Xd + (CFC\_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$			
LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no\_samples + 1)) - 2.326 \cdot LN(cvd^2 / no\_samples + 1)^{0.5})$			
LTA_cfc	wla_cfc * LTAMULT_cfc			
AML_MULT	$EXP(2.326 \cdot LN((cvd^2 / no\_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no\_samples + 1))$			
AVG MON LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)			
INST MAX LIMIT	$1.5 \cdot ((av\_mon\_limit / AML\_MULT) / LTAMULT\_afc)$			

**Attachment I:  
Site Map**

