

Application Type Renewal
Facility Type Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0254088
APS ID 841848
Authorization ID 1283019

Applicant and Facility Information

Applicant Name	<u>Derry Township Municipal Authority</u>	Facility Name	<u>New Alexandria STP</u>
Applicant Address	<u>PO Box 250</u> <u>New Derry, PA 15671-0250</u>	Facility Address	<u>Ray Ann Drive</u> <u>New Alexandria, PA 15670</u>
Applicant Contact	<u>Carol Henderson</u>	Facility Contact	<u>Same as Applicant</u>
Applicant Phone	<u>(724) 694-2513</u>	Facility Phone	<u>Same as Applicant</u>
Client ID	<u>43702</u>	Site ID	<u>720618</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Derry Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Westmoreland</u>
Date Application Received	<u>August 2, 2019</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>August 7, 2019</u>	If No, Reason	<u></u>
Purpose of Application	<u>Application for Renewal of NPDES Permit.</u>		

Summary of Review

The permittee has applied for a renewal of NPDES Permit No. PA0254088. NPDES Permit No. PA0254088 was previously issued by the PA Department of Environmental Protection (DEP) on February 1, 2015. That permit expired on January 31, 2020. The permit was submitted in a timely manner, and therefore was granted an administrative extension.



Sewage from this facility is treated with screens, sequencing batch reactors, and ultra-violet disinfections prior to discharge to Loyalhanna Creek through outfall 001.

The applicant is currently enrolled in and will continue to use eDMR.

Sewage Sludge is disposed of in the Dornick Point Wastewater Treatment Plant.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		 Stephanie Conrad / Environmental Engineering Specialist	May 3, 2021
X		 Christopher Kriley, P.E. / Program Manager	May 19, 2021

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.1</u>
Latitude	<u>40° 24' 24"</u>	Longitude	<u>-79° 25' 44.7"</u>
Quad Name	_____	Quad Code	_____
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Loyalhanna Creek (WWF)</u>	Stream Code	<u>43255</u>
NHD Com ID	<u>125292421</u>	RMI	<u>11.36</u>
Drainage Area	<u>208</u>	Yield (cfs/mi ²)	<u>0.032</u>
Q ₇₋₁₀ Flow (cfs)	<u>6.656</u>	Q ₇₋₁₀ Basis	<u>USGS Stream Stats and Low Flow Statistics for Pennsylvania</u>
Elevation (ft)	_____	Slope (ft/ft)	_____
Watershed No.	<u>18-C</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	_____	Existing Use Qualifier	_____
Exceptions to Use	_____	Exceptions to Criteria	_____
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>Metals, Total Suspended Solids (TSS)</u>		
Source(s) of Impairment	<u>Acid Mine Drainage, Acid Mine Drainage</u>		
TMDL Status	<u>Final</u>	Name	<u>Kiskiminetas-Conemaugh River Watersheds TMDL</u>
Background/Ambient Data	Data Source		
pH (SU)	_____	_____	
Temperature (°F)	_____	_____	
Hardness (mg/L)	_____	_____	
Other:	_____	_____	
Nearest Downstream Public Water Supply Intake	<u>Saltsburg Municipal Waterworks</u>		
PWS Waters	<u>Conemaugh River</u>	Flow at Intake (cfs)	_____
PWS RMI	_____	Distance from Outfall (mi)	<u>11.9</u>

Changes Since Last Permit Issuance: N/A

Other Comments: The discharge is to the Kiskiminetas-Conemaugh River Watershed that has a Final TMDL and is impaired by metals and pH. This sewage discharge is not expected to contribute to the stream impairment for which abandoned mine drainage is the source of such impairment. No WLAs have been developed for this sewage discharge and a 1/year reporting requirement for Iron, Manganese, and Aluminum is established in the permit to verify that the sewage discharge is not contributing to stream impairment.

Treatment Facility Summary				
Treatment Facility Name: New Alexandria STP				
WQM Permit No.		Issuance Date		
6510406		11/23/2021		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Tertiary	Activated Sludge With Solids Removal	Ultraviolet	0.1
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.1	170	Not Overloaded		

Changes Since Last Permit Issuance: None

Other Comments:

Compliance History

DMR Data for Outfall 001 (from April 1, 2020 to March 31, 2021)

Parameter	MAR-21	FEB-21	JAN-21	DEC-20	NOV-20	OCT-20	SEP-20	AUG-20	JUL-20	JUN-20	MAY-20	APR-20
Flow (MGD) Average Monthly	0.047	0.054	0.053	0.05	0.048	0.048	0.048	0.051	0.05	0.053	0.053	0.054
Flow (MGD) Daily Maximum	0.083	0.095	0.1	0.061	0.062	0.061	0.081	0.09	0.079	0.076	0.078	0.069
pH (S.U.) Minimum	6.76	6.91	7.08	6.88	6.81	6.97	6.9	6.53	6.72	6.8	6.47	6.86
pH (S.U.) Maximum	7.14	7.12	7.22	7.12	7.21	7.16	7.12	7.4	7.02	7.23	7.02	7.05
DO (mg/L) Minimum	4.06	4.03	4.19	4.13	4.11	4.02	4.02	4.01	4.01	5.0	4.01	4.01
CBOD5 (lbs/day) Average Monthly	3.98	3.8	2.024	1.25	1.2	1.2	1.2	1.32	1.25	1.98	1.8	3.87
CBOD5 (lbs/day) Weekly Average	12.46	9.0	5.254	1.53	1.6	1.53	2.03	2.56	1.98	4.7	10.1	5.47
CBOD5 (mg/L) Average Monthly	10.16	8.33	4.58	3	< 3	< 3	3	3.1	< 3	4.48	4	7.52
CBOD5 (mg/L) Weekly Average	18	11.4	6.3	3	< 3	< 3	< 3	3.4	< 3	9.4	15.5	9.5
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	97	72	101	103	104	101	85	134	98	108	85	78
BOD5 (lbs/day) Raw Sewage Influent Daily Maximum	144	83	127	145	112	128	109	149	138	135	98	118
BOD5 (mg/L) Raw Sewage Influent Average Monthly	317	195	264	245	275	271	242	303	275	260	217	201
TSS (lbs/day) Average Monthly	7.13	6.2	6.63	1.25	1.2	3.0	3.8	4.36	2.5	4.75	10.2	7.03
TSS (lbs/day) Raw Sewage Influent Average Monthly	60	48	87	86	72	66	53	103	91	75	60	80
TSS (lbs/day) Raw Sewage Influent Daily Maximum	121	70	113	130	84	91	71	161	170	95	75	137

**NPDES Permit Fact Sheet
New Alexandria STP**

NPDES Permit No. PA0254088

TSS (lbs/day) Weekly Average	20.1	15.0	21.68	6.11	1.6	8.14	14.9	15.01	7.91	14.01	40.3	14.9
TSS (mg/L) Average Monthly	18.2	13.75	15	3	< 3	7.5	9.4	10.25	6	10.75	23	15.6
TSS (mg/L) Raw Sewage Influent Average Monthly	264	128	227	202	192	183	151	241	259	178	152	210
TSS (mg/L) Weekly Average	29	19	26	12	< 3	16	22	20	12	28	62	26
Fecal Coliform (CFU/100 ml) Geometric Mean	5	5	12	6	17	49	16	17	13	7.0	44	48
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	10	18	29	36	45	218	727	727	79	38.0	2420	1300
Total Nitrogen (mg/L) Daily Maximum				46.1								
Ammonia (lbs/day) Average Monthly	1.53	3.7	0.09	0.07	0.07	0.064	0.09	0.17	0.113	0.075	0.09	0.08
Ammonia (lbs/day) Weekly Average	6.56	10.9	0.24	0.08	0.16	0.086	0.12	0.77	0.415	0.095	0.16	0.15
Ammonia (mg/L) Average Monthly	3.9	8.15	0.2	0.16	0.18	0.16	0.22	0.4	0.27	0.17	0.21	0.19
Ammonia (mg/L) Weekly Average	9.47	13.7	0.29	0.16	0.30	0.17	0.29	1.03	0.63	0.19	0.24	0.26
Total Phosphorus (mg/L) Daily Maximum				4.45								
Total Aluminum (mg/L) Daily Maximum				< 0.10								
Total Iron (mg/L) Daily Maximum				0.04								
Total Manganese (mg/L) Daily Maximum				< 0.02								

Compliance History

Compliance History	
Summary of DMRs:	Between April 2016 and April 2021, the facility has complied with submittal of Discharge Maintenance Reports. During the review period, no effluent limit violations were issued, however, eight exceedances did occur. The majority of the exceedances were for Fecal Coliform and Dissolved Oxygen between 2016 and 2019. Exceedances during 2020 are reported in the table below.
Summary of Inspections:	During the review period, once compliance evaluation was completed. This evaluation did not result in any violations.

Other Comments:

Effluent Violations for Outfall 001, from: May 1, 2020 To: March 31, 2021

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
TSS	05/31/20	Wkly Avg	40.3	lbs/day	37.5	lbs/day
TSS	05/31/20	Wkly Avg	62	mg/L	45	mg/L
Fecal Coliform	05/31/20	IMAX	2420	CFU/100 ml	1000	CFU/100 ml

Summary of Inspections:

Other Comments:

Development of Effluent Limitations

Outfall No. <u>001</u>	Design Flow (MGD) <u>0.1</u>
Latitude <u>40° 24' 24.00"</u>	Longitude <u>-79° 25' 44.70"</u>
Wastewater Description: <u>Sewage Effluent</u>	

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: The discharge was modeled using WQM 7.0 to evaluate the CBOD5, Ammonia Nitrogen and Dissolved Oxygen parameters. The modeling results confirm that technology based effluent limitations for CBOD5, Ammonia Nitrogen, and Dissolved Oxygen are appropriate.

For existing discharges, if an average monthly warm period limit of 25 mg/L is acceptable, a year-round monitoring requirement for ammonia-nitrogen at a minimum should be established. The previous permit required this parameter to be monitored and will be reapplied. The monitoring requirement for Ammonia Nitrogen are consistent with CBOD5, TSS and Fecal Coliform and Table 6-3 of the Permits Writers Manual.

Water Quality-Based Limitations

No limitations were determined through water quality modeling, using WQM 7.0, and no WQBELs will be imposed on this facility during this permit cycle.

Best Professional Judgment (BPJ) Limitations

Comments: A Dissolved Oxygen minimum limitation of 4.0 mg/L will be implemented based on the standard in 25 PA Code Chapter 93 and best professional judgment.

Anti-Backsliding

Section 402(o) of the Clean Water Act (CWA), enacted in the Water Quality Act of 1987, establishes anti-backsliding rules governing two situations. The first situation occurs when a permittee seeks to revise a Technology-Based effluent limitation based on BPJ to reflect a subsequently promulgated effluent guideline which is less stringent. The second situation addressed by Section 402(o) arises when a permittee seeks relaxation of an effluent limitation which is based upon a State treatment standard of water quality standard.

Previous limits can be used pursuant to EPA's anti-backsliding regulation 40 CFR 122.44 (I) Reissued permits. (1) Except as provided in paragraph (I)(2) of this section when a permit is renewed or reissued. Interim effluent limitations, standards or conditions must be at least as stringent as the final effluent limitations, standards, or conditions in the previous permit (unless the circumstances on which the previous permit was based have materially and substantially changed since the time the permit was issued and would constitute cause for permit modification or

revocation and reissuance under §122.62). (2) In the case of effluent limitations established on the basis of Section 402(a)(1)(B) of the CWA, a permit may not be renewed, reissued, or modified on the basis of effluent guidelines promulgated under section 304(b) subsequent to the original issuance of such permit, to contain effluent limitations which are less stringent than the comparable effluent limitations in the previous permit.

The facility is not seeking to revise the previously permitted effluent limits.

Additional Considerations:

Ultraviolet (UV) disinfection is used therefore Total Residual Chlorine (TRC) limits are not applicable. Routine monitoring of UV Transmittance will be at the same monitoring frequency that is used for TRC.

For pH, Dissolved Oxygen (DO) and UV Transmittance, a monitoring frequency 1/day has been imposed. In general, less frequent monitoring may be established only when the permittee demonstrates that there will be no discharge on days where monitoring is not required.

Nutrient monitoring is required to establish the nutrient load from the wastewater treatment facility and the impacts that load may have on the quality of the receiving stream(s). A 1/quarter monitor and report requirement for Total N & Total P has been added to the permit as per Chapter 92.a.61.

Sewage discharges will include monitoring, at a minimum, for *E. coli*, in new and reissued permits, with a monitoring frequency of 1/quarter for design flows ≥ 0.05 and < 1 MGD.

For POTWs with design flows greater than 2,000 GPD influent BOD₅ and TSS monitoring must be established in the permit, and the monitoring should be consistent with the same frequency and sample type as is used for other effluent parameters.

Monitoring frequency for the proposed effluent limits are based upon Table 6-3, Self-Monitoring Requirements for Sewage Dischargers, from the Departments Technical Guidance for the Development and Specification of Effluent Limitations. Please note that Monitoring Requirements were changed for Flow to 1/week Metered to be consistent with the guidance.

Mass Loading

Mass loading limits are applicable for publicly owned treatment works. Current policy requires average monthly mass loading limits be established for CBOD₅, TSS, and NH₃-N and average weekly mass loading limits be established for CBOD₅ and TSS. Average monthly mass loading limits (lbs/day) are based on the formula: design flow (MGD) x concentration limit (mg/L) x conversion factor (8.34).

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Instantaneous Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Metered
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	4.0	XXX	XXX	XXX	1/day	Grab
CBOD5	20	31	XXX	25.0	37.5	50	1/week	8-Hr Composite
BOD5 Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	8-Hr Composite
TSS	25	37	XXX	30.0	45.0	60	1/week	8-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
UV Transmittance (%)	XXX	XXX	Report	XXX	XXX	XXX	1/day	Measured
Total Nitrogen	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	8-Hr Composite
Ammonia-Nitrogen	Report	XXX	XXX	Report	XXX	XXX	1/week	8-Hr Composite

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Instantaneous Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Total Phosphorus	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	8-Hr Composite
Total Aluminum	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	8-Hr Composite
Total Iron	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	8-Hr Composite
Total Manganese	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	8-Hr Composite

Compliance Sampling Location: Outfall 001

Other Comments:

WARM PERIOD

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
18C	43255	LOYALHANNA CREEK	7,040	915.00	208.00	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
									Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.032	6.67	0.00	0.000	0.000	10.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
DTMA New Alex	PA0254088	0.0000	0.0000	0.1000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.38	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
18C	43255	LOYALHANNA CREEK	0.001	870.00	292.00	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.032	9.37	0.00	0.000	0.000	10.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Data				
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
18C		43255				LOYALHANNA CREEK						
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
Q7-10 Flow												
7.040	6.67	0.00	6.67	.1547	0.00121	.799	50.49	63.21	0.17	2.542	25.00	7.00
Q1-10 Flow												
7.040	4.27	0.00	4.27	.1547	0.00121	NA	NA	NA	0.13	3.241	25.00	7.00
Q30-10 Flow												
7.040	9.07	0.00	9.07	.1547	0.00121	NA	NA	NA	0.20	2.147	25.00	7.00

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.35	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

WQM 7.0 Wasteload Allocations

SWP Basin Stream Code Stream Name
18C 43255 LOYALHANNA CREEK

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
	7.040 DTMA New Alex	6.76	50	6.76	50	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
	7.040 DTMA New Alex	1.34	25	1.34	25	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
	7.04 DTMA New Alex	25	25	25	25	3	3	0	0

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
18C	43255	LOYALHANNA CREEK		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>
7.040	0.100	25.000		7.000
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>
50.493	0.799	63.211		0.169
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>
2.52	0.072	0.57		1.029
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>
8.258	2.192	Tsvoglou		5
<u>Reach Travel Time (days)</u>	<u>Subreach Results</u>			
2.542	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.254	2.46	0.44	7.54
	0.508	2.41	0.34	7.54
	0.763	2.35	0.26	7.54
	1.017	2.30	0.20	7.54
	1.271	2.25	0.15	7.54
	1.525	2.19	0.12	7.54
	1.780	2.14	0.09	7.54
	2.034	2.09	0.07	7.54
	2.288	2.05	0.05	7.54
	2.542	2.00	0.04	7.54

WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
18C		43255		LOYALHANNA CREEK			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
7.040	DTMA New Alex	PA0254088	0.100	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			3

COLD PERIOD

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
18C	43255	LOYALHANNA CREEK	7.040	915.00	208.00	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
									Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.032	13.34	0.00	0.000	0.000	10.0	0.00	0.00	5.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
DTMA New Alex	PA0254088	0.0000	0.0000	0.1000	0.000	15.00	7.00

Parameter Data				
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	12.80	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
18C	43255	LOYALHANNA CREEK	0.001	870.00	292.00	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.032	18.74	0.00	0.000	0.000	10.0	0.00	0.00	5.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q39-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Name	Parameter Data			
	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>			<u>Stream Name</u>							
18C		43255			LOYALHANNA CREEK							
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
Q7-10 Flow												
7.040	13.34	0.00	13.34	.1547	0.00121	.852	63.92	75.05	0.25	1.735	5.11	7.00
Q1-10 Flow												
7.040	8.54	0.00	8.54	.1547	0.00121	NA	NA	NA	0.19	2.220	5.18	7.00
Q30-10 Flow												
7.040	18.14	0.00	18.14	.1547	0.00121	NA	NA	NA	0.29	1.483	5.08	7.00

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

WQM 7.0 Wasteload Allocations

SWP Basin Stream Code Stream Name
18C 43255 LOYALHANNA CREEK

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
7.040	DTMA New Alex	20.59	50	20.59	50	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
7.040	DTMA New Alex	4.08	25	4.08	25	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>COD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
7.04	DTMA New Alex	25	25	25	25	3	3	0	0

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
18C	43255	LOYALHANNA CREEK		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>
7.040	0.100	5.115		7.000
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>
63.923	0.852	75.053		0.248
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>
2.26	0.111	0.29		0.223
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>
12.688	1.439	Tsilvoglou		5
<u>Reach Travel Time (days)</u>	<u>Subreach Results</u>			
1.735	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.174	2.24	0.28	11.42
	0.347	2.22	0.27	11.42
	0.521	2.20	0.26	11.42
	0.694	2.18	0.25	11.42
	0.868	2.16	0.24	11.42
	1.041	2.14	0.23	11.42
	1.215	2.11	0.22	11.42
	1.388	2.09	0.21	11.42
	1.562	2.07	0.20	11.42
	1.735	2.05	0.19	11.42

WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
18C		43255		LOYALHANNA CREEK			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
7.040	DTMA New Alex	PA0254088	0.100	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			3



Low-Flow Statistics for Pennsylvania Streams



Developed by the U.S. Geological Survey for the Pennsylvania Department of Environmental Protection

Pennsylvania Low-Flow Statistics - Query Results

LOW-FLOW STATISTICS

[All flow statistics in cubic feet per second (ft³/s)]

Mouse over or click on table headings to view definition of statistic

STREAM NAME: Loyalhanna Creek GAGE OR BRIDGE SITE: gage REFERENCE GAGE:¹ 03047000	COUNTY: Westmoreland USGS QUAD: Saltsburg STATION NAME: Loyalhanna Creek at Loyalhanna Dam, PA	LATITUDE: 402753 LONGITUDE: 792705 DRAINAGE AREA (sq. mi.): 292
---	---	--

Entire Period of Record ²	Q _{1,10}	Q _{7,10}	Q _{30,10}	MEAN	MEDIAN	HARMONIC MEAN
1944-91	2.29	9.37	28.6	496	257	**

P5	P10	P20	P30	P40	P50	P60	P70	P80	P90	P95
1790	1240	764	508	385	257	204	132	91.8	53.3	40.6

- ¹ Reference Gage indicates which USGS gage was used in the computation of lowflow statistics for the specified locations
- ² Period of Record for climatic year, April 1 through March 31
- ³ Period of record refers to pre-regulation conditions
- ⁴ Period of record refers to post-regulation conditions
- ** Statistic not computed due to insufficient data

[RETURN TO PREVIOUS PAGE](#)

[RETURN TO START PAGE](#)

This system designed and developed by the U.S. Geological Survey, Water Resources Division, New Cumberland, Pa. © 2002.