

Application Type Renewal  
 Facility Type Non-Municipal  
 Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0254169  
 APS ID 856343  
 Authorization ID 1299131

**Applicant and Facility Information**

Applicant Name	<u>Consol PA Coal Co. LLC</u>	Facility Name	<u>Enlow Fork Mine</u>
Applicant Address	<u>1000 Consol Energy Drive</u> <u>Canonsburg, PA 15317-6506</u>	Facility Address	<u>2041 Pleasant Grove Road</u> <u>Claysville, PA 15323-1037</u>
Applicant Contact	<u>Jaculyn Duke</u>	Facility Contact	<u>Brian Benson</u>
Applicant Phone	<u>(724) 416-8299</u>	Facility Phone	<u>(724) 416-8271</u>
Client ID	<u>259457</u>	Site ID	<u>261173</u>
Ch 94 Load Status	<u></u>	Municipality	<u>East Finley Township</u>
Connection Status	<u></u>	County	<u>Washington</u>
Date Application Received	<u>December 16, 2019</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>December 17, 2019</u>	If No, Reason	<u></u>
Purpose of Application	<u>Application for renewal of an NPDES Permit for treated sewage effluent</u>		

**Summary of Review**

The permittee has applied for a renewal of NPDES Permit No. PA0254169. NPDES Permit No. PA0254169 was previously issued by the PA Department of Environmental Protection (DEP) on June 23, 2015 and expired on June 30, 2020. The permit was submitted in a timely manner and therefore was granted an administrative extension.



Sewage from this facility is treated with flow equalization, extended aeration, final clarification, chlorination, and dichlorination.

The applicant is currently enrolled in and will continue to use eDMR.

The Act-14 PL 834 Municipal Notification was provided by the November 25, 2019 letters from Jaculyn Duke at Consol Energy and no comments were received.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania*

Approve	Deny	Signatures	Date
X		 Stephanie Conrad / Environmental Engineering Specialist	October 4, 2021
X		 Christopher Kriley, P.E. / Environmental Program Manager	October 18, 2021

**Summary of Review**

*Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

**Discharge, Receiving Waters and Water Supply Information**

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.0024</u>
Latitude	<u>40° 4' 27"</u>	Longitude	<u>-80° 21' 11"</u>
Quad Name	<u></u>	Quad Code	<u></u>
Wastewater Description: <u>Sewage Effluent</u>			

Receiving Waters	<u>Unnamed Tributary to Templeton Fork (TSF)</u>	Stream Code	<u>32708</u>
NHD Com ID	<u>73867894</u>	RMI	<u>0.44</u>
Drainage Area	<u>0.21</u>	Yield (cfs/mi <sup>2</sup> )	<u>0.00609</u>
Q <sub>7-10</sub> Flow (cfs)	<u>0.00128</u>	Q <sub>7-10</sub> Basis	<u>USGS Stream Stats</u>
Elevation (ft)	<u>1220</u>	Slope (ft/ft)	<u></u>
Watershed No.	<u>20-E</u>	Chapter 93 Class.	<u>TSF</u>
Existing Use	<u></u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u></u>	Exceptions to Criteria	<u></u>

Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u></u>		
Source(s) of Impairment	<u></u>		
TMDL Status	<u></u>	Name	<u></u>

Background/Ambient Data	Data Source	
pH (SU)	<u></u>	<u></u>
Temperature (°F)	<u></u>	<u></u>
Hardness (mg/L)	<u></u>	<u></u>
Other:	<u></u>	<u></u>

Nearest Downstream Public Water Supply Intake	<u>None in PA</u>	
PWS Waters	Flow at Intake (cfs)	<u></u>
PWS RMI	Distance from Outfall (mi)	<u></u>

Changes Since Last Permit Issuance:

Other Comments:

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Enlow Fork Mine 3 N 5 Airshaft & Portal Facility				
<b>WQM Permit No.</b>		<b>Issuance Date</b>		
6309405		June 8, 2010		
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage		Extended Aeration	Chlorination	0.024
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>

Changes Since Last Permit Issuance:

Other Comments:

<b>Compliance History</b>	
<b>Summary of DMRs:</b>	<b>Between September 2016 and September 2021, the facility has generally complied with submittal of Discharge Monitoring Reports. During the review period, no violations were issued. Two effluent violations occurred in November 2016, both for Ammonia-Nitrogen.</b>
<b>Summary of Inspections:</b>	<b>No inspections of the facility were completed between September 2016 and September 2021.</b>

Other Comments: The client has numerous open violations with other programs. As these violations, however, are not with clean water and the individual programs do not oppose the permit, the department is proceeding with issuance.

Compliance History

DMR Data for Outfall 001 (from September 1, 2020 to August 31, 2021)

Parameter	AUG-21	JUL-21	JUN-21	MAY-21	APR-21	MAR-21	FEB-21	JAN-21	DEC-20	NOV-20	OCT-20	SEP-20
Flow (MGD) Average Monthly	0.002	0.002	0.003	0.002	0.004	0.0035	0.00133	0.00391	0.00065 2	0.00137	0.0036	0.00374
pH (S.U.) Minimum	7.0	7.0	7.0	7.0	7.0	6.5	7.0	7.0	7.0	7.0	7.0	7.0
pH (S.U.) Maximum	7.5	8.0	8.0	8.0	8.0	8.8	8.0	8.0	8.0	7.5	8.0	8.0
DO (mg/L) Minimum	8.0	8.2	8.1	8.1	8.3	8.2	7.7	7.5	7.9	7.3	7.1	7.7
TRC (mg/L) Average Monthly	0.1	0.2	0.2	< 0.1	0.1	0.1	0.1	0.2	0.1	0.1	0.2	0.1
TRC (mg/L) Instantaneous Maximum	0.5	0.5	0.5	0.1	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
CBOD5 (mg/L) Average Monthly	12	8	6	4	5	9	< 10	10	4	6	< 4	21
CBOD5 (mg/L) Instantaneous Maximum	18	11	6	5	6	10	< 12	15	5	8	4	33
TSS (mg/L) Average Monthly	< 5	< 5	< 5	< 5	< 5	< 5	< 5	< 7	< 5	< 5	< 5	< 5
TSS (mg/L) Instantaneous Maximum	< 5	< 5	< 5	< 5	< 5	< 5	< 5	9	< 5	< 5	< 5	< 5
Fecal Coliform (CFU/100 ml) Geometric Mean	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	2	< 1	1	< 1	1	< 1	< 1	< 1	< 1	< 1	< 1	< 1
Total Nitrogen (mg/L) Daily Maximum									11.6			
Ammonia (mg/L) Average Monthly	< 0.8	< 0.8	< 0.8	< 0.8	< 0.8	< 0.8	< 0.8	< 0.8	< 0.8	< 0.8	< 0.8	< 0.8
Ammonia (mg/L) Instantaneous Maximum	< 0.8	< 0.8	< 0.8	< 0.8	< 0.8	< 0.8	< 0.8	< 0.8	< 0.8	< 0.8	< 0.8	< 0.8

**NPDES Permit Fact Sheet  
Enlow Fork Mine**

**NPDES Permit No. PA0254169**

Total Phosphorus (mg/L) Daily Maximum										0.6			
---	--	--	--	--	--	--	--	--	--	-----	--	--	--

**Development of Effluent Limitations**

<b>Outfall No.</b> <u>001</u>	<b>Design Flow (MGD)</b> <u>.024</u>
<b>Latitude</b> <u>40° 4' 27.00"</u>	<b>Longitude</b> <u>-80° 21' 11.00"</u>
<b>Wastewater Description:</b> <u>Sewage Effluent</u>	

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments:

**Water Quality-Based Limitations**

The discharge for this facility was modeled using the TRC Spreadsheet, and it was determined that a stricter limit should be imposed. The modeling file is attached in Attachment B.

The discharge for this facility was modeled using WQM 7.0 to evaluate the CBOD<sub>5</sub>, Ammonia Nitrogen, and Dissolved Oxygen parameters. The modeling results show technology based effluent limits for CBOD 5 are appropriate. The modeling results also confirm that Ammonia-Nitrogen and Dissolved Oxygen limitations are necessary to meet in-stream water quality criterion. The modeling output files are attached in Attachment A.

Based on eDMR data, the facility as operating should be able to meet the new, more restrictive Dissolved Oxygen limit. The facility is not, however, able to meet the new, more restrictive TRC limit. A compliance period of one year for TRC will therefore be established. January 1, 2023 is a tentative effective date for the new limit and is subject to change pending final issuance date.

Parameter	Limit (mg/l)	SBC	Model
Ammonia-Nitrogen May-October	3.0	Average Monthly	WQM 7.0
Ammonia-Nitrogen November- April	2.0	Average Monthly	WQM 7.0
Dissolved Oxygen	6.0	Instantaneous Minimum	WQM 7.0
Total Residual Chlorine	0.06	Average Monthly	TRC Spreadsheet



### Anti-Backsliding

Section 402(o) of the Clean Water Act (CWA), enacted in the Water Quality Act of 1987, establishes anti-backsliding rules governing two situations. The first situation occurs when a permittee seeks to revise a Technology-Based effluent limitation based on BPJ to reflect a subsequently promulgated effluent guideline which is less stringent. The second situation addressed by Section 402(o) arises when a permittee seeks relaxation of an effluent limitation which is based upon a State treatment standard of water quality standard.

Previous limits can be used pursuant to EPA's anti-backsliding regulation 40 CFR 122.44 **(I) Reissued permits. (1) Except as provided in paragraph (I)(2) of this section when a permit is renewed or reissued. Interim effluent limitations, standards or conditions must be at least as stringent as the final effluent limitations, standards, or conditions in the previous permit (unless the circumstances on which the previous permit was based have materially and substantially changed since the time the permit was issued and would constitute cause for permit modification or revocation and reissuance under §122.62). (2) In the case of effluent limitations established on the basis of Section 402(a)(1)(B) of the CWA, a permit may not be renewed, reissued, or modified on the basis of effluent guidelines promulgated under section 304(b) subsequent to the original issuance of such permit, to contain effluent limitations which are less stringent than the comparable effluent limitations in the previous permit.**

**The facility is not seeking to revise the previously permitted effluent limits.**

### Additional Considerations

Sewage discharges will include monitoring, at a minimum, for E. coli, in new and reissued permits, with a monitoring frequency of 1/year for design flows of 0.002 - 0.05 MGD.

For pH, Dissolved Oxygen (DO) and TRC, a monitoring frequency of 1/day has been imposed. In general, less frequent monitoring may be established only when the permittee demonstrates that there will be no discharge on days were monitoring is not required.

The receiving stream is not impaired for nutrients, therefore, annual sampling for nitrogen and phosphorus will be imposed per 25 PA Code §92a.6.

Monitoring frequency for the proposed effluent limits are based on Table 6-3, Self-Monitoring Requirements for Sewage Dischargers, from the Department's Technical Guidance for the Development and specification of Effluent Limitations. Please note that the Monitoring Requirements were changed for Flow to 1/week to be consistent with the guidance.

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: January 1, 2023 through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
TRC	XXX	XXX	XXX	0.06	XXX	0.2	1/day	Grab

Compliance Sampling Location: Outfall #001

Other Comments:

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through December 31, 2022.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab

Compliance Sampling Location: Outfall #001

Other Comments:

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	0.024	XXX	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	6.0 Inst Min	XXX	XXX	XXX	1/day	Grab
CBOD5	XXX	XXX	XXX	25	XXX	50	2/month	Grab
TSS	XXX	XXX	XXX	30	XXX	60	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Total Nitrogen	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	3.0	XXX	6.0	2/month	Grab
Ammonia May 1 - Oct 31	XXX	XXX	XXX	2.0	XXX	4.0	2/month	Grab
Total Phosphorus	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab

Compliance Sampling Location: Outfall #001

Other Comments:

# ATTACHMENT A

## WQM 7.0 Modeling Results

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20E	32708	TEMPLETON FORK	0.440	1220.00	0.21	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.006	0.00	0.00	0.000	0.000	10.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Elow Mine 3N5	PA0254169	0.0240	0.0000	0.0000	0.000	20.00	7.00

Parameter Data				
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Permit No. PA0254169

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20E	32708	TEMPLETON FORK	0.010	1200.00	0.26	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.006	0.00	0.00	0.000	0.000	10.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00
Parameter Data							
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
CBOD5	25.00	2.00	0.00	1.50			
Dissolved Oxygen	3.00	8.24	0.00	0.00			
NH3-N	25.00	0.00	0.00	0.70			

Permit No. PA0254169

### WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
20E		32708				TEMPLETON FORK						
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
<b>Q7-10 Flow</b>												
0.440	0.00	0.00	0.00	.0371	0.00881	.311	2.47	7.94	0.05	0.525	20.17	7.00
<b>Q1-10 Flow</b>												
0.440	0.00	0.00	0.00	.0371	0.00881	NA	NA	NA	0.05	0.529	20.11	7.00
<b>Q30-10 Flow</b>												
0.440	0.00	0.00	0.00	.0371	0.00881	NA	NA	NA	0.05	0.522	20.22	7.00



Permit No. PA0254169

### WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

Permit No. PA0254169

### WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
20E	32708	TEMPLETON FORK

**NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.440	Elow Mine 3N5	9.6	9.81	9.6	9.81	1	0

**NH3-N Chronic Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.440	Elow Mine 3N5	1.89	1.97	1.89	1.97	0	0

**Dissolved Oxygen Allocations**

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
0.44	Elow Mine 3N5	25	25	1.97	1.97	6	6	0	0

Permit No. PA0254169

**WQM 7.0 D.O. Simulation**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
20E	32708	TEMPLETON FORK		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>
0.440	0.024	20.166		7.000
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>
2.489	0.311	7.940		0.050
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>
24.23	1.494	1.91		0.709
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>
6.075	25.420	Owens		6
<u>Reach Travel Time (days)</u>	<u>Subreach Results</u>			
0.525	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.053	22.39	1.84	6.64
	0.105	20.69	1.77	6.91
	0.158	19.12	1.71	7.09
	0.210	17.66	1.64	7.24
	0.263	16.32	1.58	7.38
	0.315	15.08	1.53	7.51
	0.368	13.93	1.47	7.62
	0.420	12.87	1.42	7.73
	0.473	11.90	1.37	7.83
	0.525	10.99	1.32	7.92

Permit No. PA0254169

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
20E		32708		TEMPLETON FORK			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
0.440	Elow Mine 3N5	PA0254169	0.024	CBOD5	25		
				NH3-N	1.97	3.94	
				Dissolved Oxygen			6

Permit No. PA0254169

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20E	32708	TEMPLETON FORK	0.440	1220.00	0.21	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.012	0.00	0.00	0.000	0.000	10.0	0.00	0.00	5.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Elow Mine 3N5	PA0254169	0.0240	0.0000	0.0000	0.000	15.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	12.51	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Permit No. PA0254169

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20E	32708	TEMPLETON FORK	0.010	1200.00	0.26	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
									Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.012	0.00	0.00	0.000	0.000	10.0	0.00	0.00	5.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00
Parameter Data							
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
CBOD5	25.00	2.00	0.00	1.50			
Dissolved Oxygen	3.00	8.24	0.00	0.00			
NH3-N	25.00	0.00	0.00	0.70			

Permit No. PA0254169

### WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
20E		32708				TEMPLETON FORK						
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
<b>Q7-10 Flow</b>												
0.440	0.00	0.00	0.00	.0371	0.00881	.313	2.49	7.96	0.05	0.516	14.35	7.00
<b>Q1-10 Flow</b>												
0.440	0.00	0.00	0.00	.0371	0.00881	NA	NA	NA	0.05	0.523	14.58	7.00
<b>Q30-10 Flow</b>												
0.440	0.00	0.00	0.00	.0371	0.00881	NA	NA	NA	0.05	0.509	14.14	7.00

Permit No. PA0254169

**WQM 7.0 Modeling Specifications**

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		



Permit No. PA0254169

### WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
20E	32708	TEMPLETON FORK

**NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.440	Elow Mine 3N5	14.47	15.11	14.47	15.11	0	0

**NH3-N Chronic Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.440	Elow Mine 3N5	2.96	3.24	2.96	3.24	0	0

**Dissolved Oxygen Allocations**

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
0.44	Elow Mine 3N5	25	25	3.24	3.24	6	6	0	0

Permit No. PA0254169

### WQM 7.0 D.O. Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
20E	32708	TEMPLETON FORK		
<hr/>				
<u>RMJ</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
0.440	0.024	14.355	7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
2.490	0.313	7.962	0.051	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
23.52	1.489	3.03	0.453	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
6.420	22.181	Owens	6	
<u>Reach Travel Time (days)</u>	<u>Subreach Results</u>			
0.516	<u>TravTime</u>	<u>CBOD5</u>	<u>NH3-N</u>	<u>D.O.</u>
	(days)	(mg/L)	(mg/L)	(mg/L)
	0.052	22.16	2.96	7.63
	0.103	20.89	2.89	8.09
	0.155	19.69	2.83	8.30
	0.206	18.55	2.76	8.44
	0.258	17.49	2.70	8.54
	0.309	16.48	2.64	8.64
	0.361	15.53	2.58	8.72
	0.413	14.64	2.52	8.80
	0.464	13.80	2.46	8.87
	0.516	13.00	2.40	8.94

Permit No. PA0254169

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
20E		32708		TEMPLETON FORK			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
0.440	Elow Mine 3N5	PA0254169	0.024	CBOD5	25		
				NH3-N	3.24	6.48	
				Dissolved Oxygen			6

# ATTACHMENT B

## TRC Modeling Results

Copy of TRC\_CALC


TRC EVALUATION					
Input appropriate values in A3:A9 and D3:D9					
0.00128	= Q stream (cfs)		0.5	= CV Daily	
0.0024	= Q discharge (MGD)		0.5	= CV Hourly	
30	= no. samples		1	= AFC_Partial Mix Factor	
0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor	
0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)	
0.5	= BAT/BJ Value		720	= CFC_Criteria Compliance Time (min)	
0	= % Factor of Safety (FOS)			= Decay Coefficient (K)	
Source	Reference	AFC Calculations		Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 0.129		1.3.2.iii	WLA_cfc = 0.118
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 0.048		5.1d	LTA_cfc = 0.069
Source	Effluent Limit Calculations				
PENTOXSD TRG	5.1f	AML_MULT = 1.231			
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.059		AFC	
		INST MAX LIMIT (mg/l) = 0.193			
WLA_afc	$(.019/e^{-k^*AFC\_tc}) + [(AFC\_Yc^*Qs^*.019/Qd^*e^{-k^*AFC\_tc})... + Xd + (AFC\_Yc^*Qs^*Xs/Qd)]^{(1-FOS/100)}$				
LTAMULT_afc	$EXP((0.5^*LN(cvh^2+1))-2.326^*LN(cvh^2+1)^0.5)$				
LTA_afc	$wla\_afc^*LTAMULT\_afc$				
WLA_cfc	$(.011/e^{-k^*CFC\_tc}) + [(CFC\_Yc^*Qs^*.011/Qd^*e^{-k^*CFC\_tc})... + Xd + (CFC\_Yc^*Qs^*Xs/Qd)]^{(1-FOS/100)}$				
LTAMULT_cfc	$EXP((0.5^*LN(cvd^2/no\_samples+1))-2.326^*LN(cvd^2/no\_samples+1)^0.5)$				
LTA_cfc	$wla\_cfc^*LTAMULT\_cfc$				
AML_MULT	$EXP(2.326^*LN((cvd^2/no\_samples+1)^0.5)-0.5^*LN(cvd^2/no\_samples+1))$				
AVG MON LIMIT	$MIN(BAT\_BPJ,MIN(LTA\_afc,LTA\_cfc)^*AML\_MULT)$				
INST MAX LIMIT	$1.5^*((av\_mon\_limit/AML\_MULT)/LTAMULT\_afc)$				

# ATTACHMENT C

## USGS Stream Stats Output

## StreamStats Report

Region ID: PA  
 Workspace ID: PA20210908174502287000  
 Clicked Point (Latitude, Longitude): 40.07032, -80.35276  
 Time: 2021-09-08 13:45:23 -0400



### Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	0.21	square miles
ELEV	Mean Basin Elevation	1341	feet

### Low-Flow Statistics Parameters [Low Flow Region 4]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	0.21	square miles	2.26	1400