



Application Type

Renewal

Facility Type

Non-Municipal

Major / Minor

Minor

Application No.

PA0254525

APS ID

1138242

Authorization ID

1528721

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Applicant and Facility Information

Applicant Name	UMH Properties Inc.	Facility Name	Hillcrest Crossing MHP
Applicant Address	150 Clay Street	Facility Address	100 Lorraine Drive
	Morgantown, WV 26501		New Kensington, PA 15068-9785
Applicant Contact	Jeffrey Yorick	Facility Contact	
Applicant Phone	(304) 291-3380	Facility Phone	
Client ID	79530	Site ID	244124
Ch 94 Load Status	Not Overloaded	Municipality	Lower Burrell City
Connection Status		County	Westmoreland
Date Application Received	May 20, 2025	EPA Waived?	Yes
Date Application Accepted		If No, Reason	
Purpose of Application	Renewal		

Summary of Review

The permittee is proposing to renew NPDES Permit PA0254525 which expired on 8/31/2022.

The treated effluent will discharge into Chartiers Run, which is classified as a Trout Stocking Fishery (TSF) and is located in State Watershed No. 18-A.



WQM Permit 6569435 was issued on January 9, 1970 and approved a design hydraulic capacity of 0.025 MGD. UV Disinfection was added with 6569435 A-1 on March 9, 2020.

Act 14 Notifications were provided on April 16, 2025.

The client has no open violations for the Clean Water program.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Return	Deny	Signatures	Date
x			 Sam Mahsoob, EIT / Environmental Engineering Trainee	Select Date
x			 Mahbuba Iasmin, Ph.D., P.E. / Environmental Engineer Manager	6/24/2025

Discharge, Receiving Waters and Water Supply Information

Outfall No.	001	Design Flow (MGD)	.025
Latitude	40° 36' 2"	Longitude	-79° 41' 42"
Quad Name	New Kensington East	Quad ID	40079E6
Wastewater Description: Sewage Effluent			
Receiving Waters	Chartiers Run (TSF)	Stream Code	42524
NHD Com ID	123972424	RMI	2.8
Drainage Area	7.96	Yield (cfs/mi ²)	0.0127
Q ₇₋₁₀ Flow (cfs)	0.101	Q ₇₋₁₀ Basis	USGS StreamStats
Elevation (ft)	875.66	Slope (ft/ft)	.0129
Watershed No.	18-A	Chapter 93 Class.	TSF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment			
Source(s) of Impairment			
TMDL Status		Name	
Background/Ambient Data		Data Source	
pH (SU)			
Temperature (°F)			
Hardness (mg/L)			
Other:			
Nearest Downstream Public Water Supply Intake			
PWS Waters	Allegheny	Flow at Intake (cfs)	2390
PWS RMI	26	Distance from Outfall (mi)	3.5

Treatment Facility Summary				
Treatment Facility Name: Hillcrest Crossings				
WQM Permit No.		Issuance Date		
6569435		1/9/1970		
6569435 A-1		3/9/2020		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Extended Aeration	Ultraviolet	0.025
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.025	42.0	Not Overloaded		Unity Twp Municipal Authority

Compliance History	
Summary of DMRs:	[REDACTED]
Summary of Inspections:	[REDACTED]

Other Comments: [REDACTED]

Compliance History

DMR Data for Outfall 001 (from May 1, 2024 to April 30, 2025)

Parameter	APR-25	MAR-25	FEB-25	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24
Flow (MGD) Average Monthly	0.018	0.019	0.018	0.017	0.019	0.016	0.016	0.016	0.018	0.019	0.016	0.017
pH (S.U.) Instantaneous Minimum	6.8	7.0	6.7	6.8	6.7	6.7	6.9	7.0	6.8	6.8	6.6	6.4
pH (S.U.) Instantaneous Maximum	7.4	7.6	7.3	7.4	7.3	7.2	7.4	7.6	7.4	7.6	7.3	7.3
DO (mg/L) Instantaneous Minimum	4.9	4.6	4.7	4.3	4.8	4.5	4.9	4.7	4.6	4.7	4.7	4.9
CBOD5 (mg/L) Average Monthly	1.5	3.5	2	2.7	3	4	< 3	5	3.6	< 3	< 3	< 3
CBOD5 (mg/L) Instantaneous Maximum	1.8	4	2	3.6	3.2	4	< 3	6	4.2	< 3	< 3	< 3
TSS (mg/L) Average Monthly	7	8	11	21	25	12	9	< 3	4.5	< 3	4	5
TSS (mg/L) Instantaneous Maximum	8	8	15	24	32	14	9	< 3	5	< 3	5	6
Fecal Coliform (No./100 ml) Geometric Mean	5	5	11	2	4	< 1	1	1	1.7	< 1	6	< 1
Fecal Coliform (No./100 ml) Instantaneous Maximum	22	21	12	4	9	< 1	2	1	2	< 1	6	1
UV Intensity (mW/cm ²) Instantaneous Minimum	4.1	3.9	3.7	4.2	3.6	3.1	3.2	4.2	3.7	4.2	4.2	6.0
Total Nitrogen (mg/L) Daily Maximum					10.6							
Ammonia (mg/L) Average Monthly	4.3	8.4	0.2	0.5	0.15	0.4	0.5	1.0	0.4	0.7	1.7	1.5

NPDES Permit Fact Sheet
Hillcrest Crossing MHP

NPDES Permit No. PA0254525

Ammonia (mg/L) Instantaneous Maximum	8.4	10.9	0.3	0.7	0.017	0.5	0.9	1.2	0.6	1.1	3.34	2.9
Total Phosphorus (mg/L) Daily Maximum					2.25							

Compliance History

Development of Effluent Limitations

Outfall No. 001
Latitude 40° 36' 2.00"
Wastewater Description: Sewage Effluent

Design Flow (MGD) .025
Longitude -79° 41' 42.00"

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/L)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Total Nitrogen	Report	Average Monthly	-	92a.61(7)
Total Phosphorus	Report	Average Monthly	-	92a.61(8)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
E. Coli (No./100 ml)	-	Report		93a.61(11)(12)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
Total Residual Chlorine	1.6	IMAX	-	92a.47-48(3)(4)
Ammonia-Nitrogen	25	Average Monthly	-	BPJ (5)
Ammonia-Nitrogen	50	IMAX	-	BPJ (5)
Dissolved Oxygen	4.0	IMIN	-	BPJ (6)

Water Quality-Based Limitations

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
NH3-N (May 1 – Oct 31)	6.0	Average Monthly	WQM 6.3 (Previous Permit)
NH3-N (Nov 1 – April 30)	18.0	Average Monthly	WQM 6.3 (Previous Permit)
NH3-N (May 1 – Oct 31)	6.49	Average Monthly	WQM 7.0
NH3-N (Nov 1 – April 30)	50	Average Monthly	WQM 7.0
CBOD ₅	25	Average Monthly	WQM 7.0
DO	4	IMIN	WQM 7.0

Comments: The limits for Ammonia-Nitrogen will be maintained from the previous permit renewal.

Additional Considerations

Anti-Backsliding

Section 402(o) of the Clean Water Act (CWA), enacted in the Water Quality Act of 1987, establishes anti-backsliding rules governing two situations. The first situation occurs when a permittee seeks to revise a Technology-Based effluent limitation based on BPJ to reflect a subsequently promulgated effluent guideline which is less stringent. The second situation addressed by Section 402(o) arises when a permittee seeks relaxation of an effluent limitation which is based upon a State treatment standard of water quality standard.

Previous limits can be used pursuant to EPA's anti-backsliding regulation. Reissued permits. (1) Except as provided in paragraph (l)(2) of this section when a permit is renewed or reissued. Interim effluent limitations, standards or conditions must be at least as stringent as the final effluent limitations, standards, or conditions in the previous permit (unless the circumstances on which the previous permit was based have materially and substantially changed since the time the permit was issued and would constitute cause for permit modification or revocation and reissuance under §122.62). (2) In the case of effluent limitations established on the basis of Section 402(a)(1)(B) of the CWA, a permit may not be renewed, reissued, or modified on the basis of effluent guidelines promulgated under section 304(b) subsequent to the original issuance of such permit, to contain effluent limitations which are less stringent than the comparable effluent limitations in the previous permit.

(40 CFR 122.44 (l)(2) Establishing limitations, standards, and other permit conditions., 40 CFR Ch. I (7-1-21 Edition))

No permits limits have been made less stringent in the renewal draft permit.

E. Coli

Sewage discharges will include monitoring, at a minimum, for E. Coli, in new and reissued permits, with a monitoring frequency of 1/month for design flows ≥ 1 MGD, 1/quarter for design flows ≥ 0.05 and < 1 MGD, 1/year for design flows of 0.002 – 0.05 MGD.

(Note 12 SOP-Establishing Effluent Limitations for Individual Sewage Permits Final November 9, 2012, Revised February 5, 2024, Version 2.0. and 25 PA Code 92a.61(b).)

Effluent Multipliers

Section 2.C of the Permit Writers Manual contains the procedure for converting average monthly effluent limitations to average weekly, maximum daily, and instantaneous maximum effluent limitations. The average monthly limit is multiplied according to the following chart:

Discharge Solution	Parameters	Average Weekly	Maximum Daily	Instantaneous Maximum Multiplier
Sewage	All	1.5		2.0
Industrial	All		2.0	2.5*

(Department Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits, Updated June 28, 2023 (Document No. 362-0400-001))

Rounding Off

Section 5 C.2. of the Permit Writers Manual contains general guidelines for rounding conventional and toxic pollutants, with instructions to round down to the nearest decimal place indicated.

General Magnitude	Conventional Pollutants	Toxic Pollutants
<0.01	to nearest 0.001	to nearest 0.001
0.01 - 0.1	to nearest 0.01	to nearest 0.01

0.1 - 1.0	to nearest 0.1	to nearest 0.01
1.0 - 10.0	to nearest 0.5	to nearest 0.01
10.0 - 60.0	to nearest 1.0	to nearest 0.01
60.0 or greater	to nearest 5.0	to nearest 0.10

(*Department Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits, Updated June 28, 2023 (Document No. 362-0400-001)*)

Ultraviolet Disinfection

Ultraviolet (UV) disinfection is used therefore Total Residual Chlorine (TRC) limits are not applicable. Routine monitoring of UV intensity is at the same monitoring frequency that is used for TRC.

(*Section I.A, Note 4, SOP for Clean Water Program, Establishing Effluent Limitations for Individual Sewage Permits, Final November 9, 2012, Revised March 24, 2021, Version 1.9 and 25 PA Code 92a.61(b).*)

Nutrient Monitoring

Nutrient monitoring is required by the SOP for Effluent Limitations for Individual Sewage Permits. Monitoring is included to establish the nutrient load from the wastewater treatment facility and the impacts that load may have on the quality of the receiving stream(s). The receiving stream is not listed as impaired for nutrients, therefore at the discretion of the application manager, a monitoring frequency less than the equivalent of conventional pollutants in Table 6-3 of the Permit Writer's Manual has been selected.

(*Section I.A, Note 7 & 8, SOP for Clean Water Program, Establishing Effluent Limitations for Individual Sewage Permits, Final November 9, 2012, Revised March 24, 2021, Version 1.9 and 25 PA Code 92a.61(b).*)

Table 6-3 – Self-Monitoring Requirements for SEWAGE Discharges

Plant Design Flow (MGD)	Flow Monitoring	C-BOD ₅ or BOD ₅	Suspended Solids	pH	Fecal Coliform	Chlorine Residual	NH ₃ -N	Phosphorus	DO	Toxics
Single Residence (Individual Permit)	2/year by estimate	2/year*	2/year*	1/month*	2/year*	1/month*	2/year*	2/year*	2/year*	N/A
.0005 to .002	weekly, using average pump rate or weir (a)	1/month*	1/month*	daily*	1/month*	daily*	1/month*	1/month*	daily*	N/A
.002 to .01	weekly, using average pump rate or weir (a)	2/month*	2/month*	daily*	2/month*	daily*	2/month*	2/month*	daily*	N/A
0.01 to 0.1	weekly, using average pump rate or weir (a)	2/month*	2/month*	daily*	2/month*	daily*	2/month*	2/month*	Daily*	1/week*
0.1 to 1.0	meter	1/week**	1/week**	daily*	1/week*	daily*	1/week**	1/week**	daily*	1/week****
1.0 to 5.0	meter	2/week***	2/week***	daily*	2/week*	daily*	2/week***	2/week***	daily*	1/week****
5.0 to 25.0	meter	daily***	daily***	daily*	daily*	1/shift*	daily***	daily***	daily*	1/week****
over 25.0	meter	daily***	daily***	1/shift*	daily*	1/shift*	1/shift***	1/shift***	1/shift*	1/week****

* Grab sample-these should be most representative of the effluent and are to be taken at a time when the normal daily maximum flow would reach the sampling point.

** 8-hour composite sample.

*** 24-hour composite sample.

**** Same sample type as for Industrial Process Wastewater (See Table 6-4).

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Instantaneous Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	0.025	XXX	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	4.0	XXX	XXX	XXX	1/day	Grab
CBOD5	XXX	XXX	XXX	25	XXX	50	2/month	Grab
TSS	XXX	XXX	XXX	30	XXX	60	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
UV Intensity (mW/cm ²)	XXX	XXX	Report	XXX	XXX	XXX	1/day	Measured
Total Nitrogen	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab
Ammonia-Nitrogen Nov 1 - Apr 30	XXX	XXX	XXX	18.0	XXX	36.0	2/month	Grab
Ammonia-Nitrogen May 1 - Oct 31	XXX	XXX	XXX	6.0	XXX	12.0	2/month	Grab
Total Phosphorus	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001

Tools and References Used to Develop Permit	
<input type="checkbox"/>	WQM for Windows Model (see Attachments 3&4)
<input type="checkbox"/>	SOP: Establishing Effluent Limits for Individual Sewage Permits
<input type="checkbox"/>	Other: USGS StreamStats (See Attachments 1&2), 1996 Pollution Report (Uploaded in OnBase)

Attachment 1

USGS StreamStats -

Upstream


StreamStats Report - Upstream

Region ID: PA

Workspace ID: PA20250612202708228000

Clicked Point (Latitude, Longitude): 40.59947, -79.69478

Time: 2025-06-12 16:27:40 -0400



[Collapse All](#)

➤ Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	7.96	square miles
ELEV	Mean Basin Elevation	1106	feet

➤ Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 4]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	7.96	square miles	2.26	1400
ELEV	Mean Basin Elevation	1106	feet	1050	2580

Low-Flow Statistics Flow Report [Low Flow Region 4]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR²: Pseudo R Squared (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	0.279	ft ³ /s	43	43
30 Day 2 Year Low Flow	0.486	ft ³ /s	38	38
7 Day 10 Year Low Flow	0.101	ft ³ /s	66	66
30 Day 10 Year Low Flow	0.184	ft ³ /s	54	54
90 Day 10 Year Low Flow	0.335	ft ³ /s	41	41

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.29.1

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1

Attachment 2

USGS StreamStats -

Downstream


StreamStats Report - Downstream

Region ID: PA

Workspace ID: PA20250612203012063000

Clicked Point (Latitude, Longitude): 40.59812, -79.70006

Time: 2025-06-12 16:30:39 -0400



[Collapse All](#)

➤ Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	8.6	square miles
ELEV	Mean Basin Elevation	1101	feet

➤ Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 4]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	8.6	square miles	2.26	1400
ELEV	Mean Basin Elevation	1101	feet	1050	2580

Low-Flow Statistics Flow Report [Low Flow Region 4]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR²: Pseudo R Squared (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	0.303	ft ³ /s	43	43
30 Day 2 Year Low Flow	0.526	ft ³ /s	38	38
7 Day 10 Year Low Flow	0.111	ft ³ /s	66	66
30 Day 10 Year Low Flow	0.201	ft ³ /s	54	54
90 Day 10 Year Low Flow	0.363	ft ³ /s	41	41

Low-Flow Statistics Citations

Stuckey, M.H.,2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.29.1

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1

Attachment 3

WQM 7.0 Model -

Summer

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
18A	42524	CHARTIERS RUN			2.800	875.66	7.96	0.00000	0.00	<input checked="" type="checkbox"/>
Stream Data										
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)
Q7-10 0.013 0.00 0.00 0.000 0.000 0.0 0.00 0.00 25.00 7.00 0.00 0.00 Q1-10 0.00 0.00 0.000 0.000 Q30-10 0.00 0.00 0.000 0.000										
Discharge Data										
		Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH	
		Oufall 001	PA0254525	0.0250	0.0250	0.0250	0.000	20.00	7.50	
Parameter Data										
				Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
				CBOD5	25.00	2.00	0.00	1.50		
				Dissolved Oxygen	4.00	8.24	0.00	0.00		
				NH3-N	25.00	0.00	0.00	0.70		

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
18A	42524	CHARTIERS RUN			2.420	849.96	8.60	0.00000	0.00	<input checked="" type="checkbox"/>
Stream Data										
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)
Q7-10 0.013 0.00 0.00 0.000 0.000 0.0 0.00 0.00 25.00 7.00 0.00 0.00 Q1-10 0.00 0.00 0.000 0.000 Q30-10 0.00 0.00 0.000 0.000										
Discharge Data										
		Name		Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
					0.0000	0.0000	0.0000	0.000	25.00	7.00
Parameter Data										
			Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)		
			CBOD5		25.00	2.00	0.00	1.50		
			Dissolved Oxygen		3.00	8.24	0.00	0.00		
			NH3-N		25.00	0.00	0.00	0.70		

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>			<u>Stream Code</u>			<u>Stream Name</u>						
18A			42524			CHARTIERS RUN						
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
Q7-10 Flow												
2.800	0.10	0.00	0.10	.0387	0.01281	.385	7.59	19.71	0.05	0.486	23.62	7.09
Q1-10 Flow												
2.800	0.06	0.00	0.06	.0387	0.01281	NA	NA	NA	0.04	0.575	23.13	7.13
Q30-10 Flow												
2.800	0.14	0.00	0.14	.0387	0.01281	NA	NA	NA	0.05	0.427	23.90	7.07

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>				
18A	42524	CHARTIERS RUN					
NH3-N Acute Allocations							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
2.800	Oufall 001	11.44	30.57	11.44	30.57	0	0
NH3-N Chronic Allocations							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
2.800	Oufall 001	1.43	6.49	1.43	6.49	0	0
Dissolved Oxygen Allocations							
RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>	
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)
2.80	Oufall 001	25	25	6.49	6.49	4	4
						0	0

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>	
18A	42524	CHARTIERS RUN	
<u>RMI</u> 2.800	<u>Total Discharge Flow (mgd)</u> 0.025	<u>Analysis Temperature (°C)</u> 23.616	<u>Analysis pH</u> 7.091
<u>Reach Width (ft)</u> 7.590	<u>Reach Depth (ft)</u> 0.385	<u>Reach WDRatio</u> 19.706	<u>Reach Velocity (fps)</u> 0.048
<u>Reach CBOD5 (mg/L)</u> 8.36	<u>Reach Kc (1/days)</u> 1.131	<u>Reach NH3-N (mg/L)</u> 1.80	<u>Reach Kn (1/days)</u> 0.925
<u>Reach DO (mg/L)</u> 7.069	<u>Reach Kr (1/days)</u> 18.013	<u>Kr Equation</u> Owens	<u>Reach DO Goal (mg/L)</u> 6
<u>Reach Travel Time (days)</u> 0.486	Subreach Results		
	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)
		0.049	7.84
		0.097	7.35
		0.146	6.89
		0.194	6.45
		0.243	6.05
		0.291	5.67
		0.340	5.31
		0.389	4.98
		0.437	4.67
		0.486	4.37
			1.72
			7.19
			1.64
			7.28
			1.57
			7.36
			1.50
			7.43
			1.44
			7.50
			1.37
			7.56
			1.31
			7.62
			1.25
			7.67
			1.20
			7.72
			1.15
			7.72

WQM 7.0 Effluent Limits

SWP Basin		Stream Code		Stream Name			
18A		42524		CHARTIERS RUN			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Efl. Limit 30-day Ave. (mg/L)	Efl. Limit Maximum (mg/L)	Efl. Limit Minimum (mg/L)
2.800	Oufall 001	PA0254525	0.025	CBOD5	25		
				NH3-N	6.49	12.98	
				Dissolved Oxygen			4

Attachment 4

WQM 7.0 Model -

Winter

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC		
18A	42524	CHARTIERS RUN			2.800	875.66	7.96	0.00000	0.00	<input checked="" type="checkbox"/>		
Stream Data												
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)		
Q7-10 0.025 0.00 0.00 0.000 0.000 0.0 0.00 0.00 5.00 7.00 0.00 0.00 Q1-10 0.00 0.00 0.000 0.000 Q30-10 0.00 0.00 0.000 0.000												
Discharge Data												
				Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)		
Oufall 001		PA0254525				0.0250	0.0250	0.0250	0.000	15.00		
Parameter Data												
				Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)				
				CBOD5	25.00	2.00	0.00	1.50				
				Dissolved Oxygen	4.00	12.51	0.00	0.00				
				NH3-N	25.00	0.00	0.00	0.70				

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
18A	42524	CHARTIERS RUN			2.420	849.96	8.60	0.00000	0.00	<input checked="" type="checkbox"/>
Stream Data										
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)
Q7-10 0.026 0.00 0.00 0.000 0.000 0.0 0.00 0.00 5.00 7.00 0.00 0.00 Q1-10 0.00 0.00 0.000 0.000 Q30-10 0.00 0.00 0.000 0.000										
Discharge Data										
		Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH	
0.0000 0.0000 0.0000 0.000 25.00 7.00										
Parameter Data										
				Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
CBOD5 Dissolved Oxygen NH3-N				25.00	2.00	0.00	1.50			
3.00 25.00				8.24	0.00	0.00				
				0.00	0.70					

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>			<u>Stream Code</u>			<u>Stream Name</u>						
18A			42524			CHARTIERS RUN						
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
Q7-10 Flow												
2.800	0.20	0.00	0.20	.0387	0.01281	.417	8.9	21.34	0.06	0.358	6.61	7.05
Q1-10 Flow												
2.800	0.13	0.00	0.13	.0387	0.01281	NA	NA	NA	0.05	0.438	7.30	7.07
Q30-10 Flow												
2.800	0.27	0.00	0.27	.0387	0.01281	NA	NA	NA	0.08	0.309	6.23	7.04

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>				
18A	42524	CHARTIERS RUN					
NH3-N Acute Allocations							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
2.800	Oufall 001	22.51	50	22.51	50	0	0
NH3-N Chronic Allocations							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
2.800	Oufall 001	4.3	25	4.3	25	0	0
Dissolved Oxygen Allocations							
RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>	
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)
2.80	Oufall 001	25	25	25	25	4	4
						0	0

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>	
18A	42524	CHARTIERS RUN	
<u>RMI</u> 2.800	<u>Total Discharge Flow (mgd)</u> 0.025	<u>Analysis Temperature (°C)</u> 6.606	<u>Analysis pH</u> 7.051
<u>Reach Width (ft)</u> 8.903	<u>Reach Depth (ft)</u> 0.417	<u>Reach WDRatio</u> 21.340	<u>Reach Velocity (fps)</u> 0.065
<u>Reach CBOD5 (mg/L)</u> 5.69	<u>Reach Kc (1/days)</u> 1.011	<u>Reach NH3-N (mg/L)</u> 4.01	<u>Reach Kn (1/days)</u> 0.250
<u>Reach DO (mg/L)</u> 11.144	<u>Reach Kr (1/days)</u> 12.731	<u>Kr Equation</u> Owens	<u>Reach DO Goal (mg/L)</u> 6
<u>Reach Travel Time (days)</u> 0.358	Subreach Results		
	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)
		0.036	5.58
		0.072	5.47
		0.107	5.37
		0.143	5.26
		0.179	5.16
		0.215	5.06
		0.251	4.96
		0.286	4.87
		0.322	4.77
		0.358	4.68
			D.O. (mg/L)
			11.00
			11.00
			11.00
			11.00
			11.00
			11.00
			11.00
			11.00
			11.00

WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>				
18A	42524	CHARTIERS RUN					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Efl. Limit 30-day Ave. (mg/L)	Efl. Limit Maximum (mg/L)	Efl. Limit Minimum (mg/L)
2.800	Oufall 001	PA0254525	0.025	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			4