

Application Type Renewal
Facility Type Non-Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0254819
APS ID 841063
Authorization ID 1291451

Applicant and Facility Information

Applicant Name	<u>AK Coal Resources Inc.</u>	Facility Name	<u>North Fork Mine STP</u>
Applicant Address	<u>1134 Stoystown Road</u> <u>Friedens, PA 15541</u>	Facility Address	<u>716 Hoffman Church Road</u> <u>Friedens, PA 15541</u>
Applicant Contact	<u>Kent Saylor</u>	Facility Contact	<u>Joseph Lloyd</u>
Applicant Phone	<u>(817) 443-2646</u>	Facility Phone	<u>814-443-3344</u>
Client ID	<u>6980</u>	Site ID	<u>782665</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Jenner Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Somerset</u>
Date Application Received	<u>October 8, 2019</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>November 13, 2019</u>	If No, Reason	<u></u>
Purpose of Application	<u>See below.</u>		

Summary of Review

The permittee has applied for a renewal of NPDES Permit No. PA0254819. NPDES Permit No. PA0254819 was previously issued by the PA Department of Environmental Protection (DEP) on September 9, 2014 and subsequently amended on June 15, 2016. That permit expired on September 30, 2019. The NPDES permit was amended to reflect a reduction in the proposed design flow of the treatment facility from 4,000 gpd to 2,100 gpd.

This draft permit is approved during the Coronavirus pandemic requiring DEP employees to telework. Electronic signatures are considered appropriate for the draft permit documents. An electronic copy of the communication that transmitted approval of the draft permit documents has been saved and is included with the file.

The draft cover letter asks the permittee's permission to send the final permit documents electronically in case the office is still closed when the final permit is ready to be issued. If this is not acceptable to the permittee, DEP will arrange to mail the final permit documents through the US Postal Service.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		<i>David R. Ponchione</i> David R. Ponchione / Project Manager	July 8, 2020
X		<i>Christopher Kriley</i> Christopher Kriley, P.E. / Program Manager for Donald J. Leone, P.E. / Environmental Engineer Manager	July 13, 2020

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	.0021
Latitude	40° 6' 47.54"	Longitude	-79° 2' 54.22"
Quad Name	Boswell		
Wastewater Description: Sewage Effluent			
Receiving Waters	Hoffman Run (CWF)	Stream Code	45546
NHD Com ID	123722771	RMI	1.6800
Drainage Area	0.05	Yield (cfs/mi ²)	0.0352
Q ₇₋₁₀ Flow (cfs)	0.0018	Q ₇₋₁₀ Basis	USGS Stream Stats
Elevation (ft)	2,040	Slope (ft/ft)	0.0342
Watershed No.	18-E	Chapter 93 Class.	CWF
Exceptions to Use	None	Exceptions to Criteria	None
Assessment Status	Impaired		
Cause(s) of Impairment	HABITAT ALTERATIONS, METALS, SILTATION		
Source(s) of Impairment	ACID MINE DRAINAGE, REMOVAL OF RIPARIAN VEGETATION		
TMDL Status	Final	Name	Kiskiminetas-Conemaugh River Watersheds TMDL

Changes Since Last Permit Issuance: None

Treatment Facility Summary				
Treatment Facility Name: North Fork Mine STP				
WQM Permit No.	Issuance Date			
5615406	June 15, 2016			
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Septic Tank Sand Filter	Chlorine With Dechlorination	0.0021
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.0021	16.8	Not Overloaded	None	Combination of methods

Changes Since Permit Amendment Issuance: None

Other Comments

The existing treatment facility serves a bathhouse from which the wastewater flows by gravity to two septic tanks in series each having a volume of 2,300-gallons. The wastewater flows from the septic tanks to a dosing tank with 1,000-gallon capacity and then to a subsurface sand filter. After filtration the wastewater flows through a chlorine feeder to a 1,250-gallon chlorine contact, then to a de-chlorination feeder and discharges through the outfall to Hoffman Run, which is classified as cold-water fishery.

The original NPDES permit assumed the STP would have a design flow of 4,000-gpd. However, after the NPDES permit was issued, the permittee conducted a study of similar underground mine facilities in the region and concluded the plant should be designed for a lower flow. The facilities included in the study were found to have an average flow of 8-10 gpd for each employee. The facility has a design flow based on: 210 employees although only 140 are expected to be employed, thus providing a reserve flow. The facilities studied are maintained by the CME's certified sewage plant operators.

The existing treatment plant is a septic tank / sand filter type and is only rated 100 gpd higher than a small flow treatment facility that is defined as a facility rated at or less than 2,000 gpd. The Solids Management for Non-Lagoon Systems requirement is typically placed in permits for Non-Municipal plants. This writer feels it is more appropriate to replace that requirement with the requirements chosen for Part C.I.F and Part C.I.G that are applicable to SFTF's. They address the need for the permittee to measure the depth and scum in the septic tanks annually and address septic tank pumping requirements.

Compliance History

Operations Compliance Check Summary Report

Compliance Review Period: 6/15 – 6/20

Inspection Summary:

INSP ID	INSPECTED DATE	INSP TYPE	AGENCY	INSPECTION RESULT DESC
2611621	04/11/2017	Administrative/File Review	PA Dept of Environmental Protection	Violation(s) Noted
2455080	02/24/2016	Compliance Evaluation	PA Dept of Environmental Protection	No Violations Noted

Violation Summary:

VIOL ID	VIOLATION DATE	VIOLATION TYPE	VIOLATION TYPE DESC	RESOLVED DATE
790589	04/11/2017	92A.61(G)	NPDES - Failure to use a format or process required by DEP for self-monitoring results	04/19/2017

Open Violations by Client ID:

No open violations for client ID 6980

Enforcement Summary:

ENF ID	ENF TYPE	ENF CREATION DATE	VIOLATIONS	ENF FINALSTATUS	ENF CLOSED DATE
355741	NOV	07/05/2017	92A.61(G)	Comply/Closed	04/19/2017

DMR Violation Summary: Using eDMR as of 1/2018 No DMR exceedances.

Compliance Status: Permittee incompliance. Permit issuance recommended.

Completed by: John Murphy

Completed date: 6/11/20

Development of Effluent Limitations

Outfall No. <u>001</u>	Design Flow (MGD) <u>.0021</u>
Latitude <u>40° 6' 47.54"</u>	Longitude <u>-79° 2' 54.22"</u>
Wastewater Description: <u>Sewage Effluent</u>	

The discharge was previously evaluated using WQM 7.0 to evaluate the CBOD₅, Ammonia Nitrogen and Dissolved Oxygen parameters. The modeling results show technology based effluent limitations for CBOD₅ are appropriate. The modeling results also confirm that Ammonia-Nitrogen and Dissolved Oxygen limitations are necessary to meet in-stream water quality criterion. Because there have been no changes to the discharge or the receiving stream, it was unnecessary to remodel these parameters.

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)

Comments: The above effluent limitations are consistent with the previous permit amendment.

Water Quality-Based Limitations

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
Dissolved Oxygen	6.0	Inst. Min	WQM 7.0
Ammonia Nitrogen	3.0	Average Monthly	WQM 7.0
Total Residual Chlorine	0.10	Average Monthly	TRC_CALC

Comments: The above effluent are consistent with the previous permit amendment.

Kiskiminetas River Basin

There is a TMDL for metals in the Kiskiminetas River watershed. The contribution for metals from a sewage plant of this nature is expected to be less than water quality criteria and therefore not contributing to stream impairment. 1/year monitoring is imposed on the Total Aluminum, Total Manganese, and Total Iron parameters for plants rated between 0.002 mgd up to 0.499 mgd. This is consistent with the previous permit amendment.

TN and TP MONITORING

Nutrient monitoring is required to establish the nutrient load from the waste water treatment facility and the impacts that load may have on the quality of the receiving stream(s). Sewage discharges with design flows > 2,000 gpd require monitoring, at a minimum, for Total Nitrogen and Total Phosphorus in new and reissued permits. This is consistent with the previous permit amendment.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	0.0021	XXX	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	6.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.10	XXX	0.30	1/day	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50.0	2/month	Grab
TSS	XXX	XXX	XXX	30.0	XXX	60.0	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Total Nitrogen	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/year	Grab
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	9.0	XXX	18.0	2/month	Grab
Ammonia May 1 - Oct 31	XXX	XXX	XXX	3.0	XXX	6.0	2/month	Grab
Total Phosphorus	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/year	Grab
Total Aluminum	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/year	Grab

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Total Iron	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/year	Grab
Total Manganese	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001

To be consistent with current DEP policy:

- Effluent limitations for pH and DO are to be reported as “Instantaneous Minimum” in lieu of “Minimum”.
- The units for Fecal Coliform are now “No./100 ml” in lieu of “CFU/100 ml”.
- Mass loading limits and influent monitoring are not applicable for non-publicly owned treatment works.
- The design flow of the sewage treatment plant is less than 0.1 mgd. For this reason, the permittee is not required to report influent and effluent concentrations for various parameters as listed in the NPDES application. Total Dissolved Solids and its major constituents are therefore not a concern at this time.

The previous permit writer did not include a PDF file of the pollution report with the fact sheet and this writer does not have access, due to office closure, to scanning equipment to do so for this pollution report. A hard copy of the pollution report, which includes the modeling results can be found in Central Files.