

Application Type Renewal
Facility Type Industrial
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL INDUSTRIAL WASTE (IW)
AND IW STORMWATER**

Application No. PA0254843
APS ID 1010534
Authorization ID 1303966

Applicant and Facility Information

| | | | |
|---------------------------|--|------------------|--|
| Applicant Name | <u>West View Water Authority</u> | Facility Name | <u>Beaver County WTP</u> |
| Applicant Address | <u>210 Perry Highway</u> <u>Pittsburgh, PA 15229-1862</u> | Facility Address | <u>210 Perry Highway</u> <u>Pittsburgh, PA 15229-1862</u> |
| Applicant Contact | <u>Robert Christian</u> | Facility Contact | <u>Mark Valenty</u> |
| Applicant Phone | <u>(412) 931-3292</u> | Facility Phone | <u>(412) 931-3292</u> |
| Client ID | <u>62410</u> | Site ID | <u>784002</u> |
| SIC Code | <u>4941</u> | Municipality | <u>Baden Borough</u> |
| SIC Description | <u>Trans. & Utilities - Water Supply</u> | County | <u>Beaver</u> |
| Date Application Received | <u>January 29, 2020</u> | EPA Waived? | <u>Yes</u> |
| Date Application Accepted | <u>February 14, 2020</u> | If No, Reason | <u></u> |
| Purpose of Application | <u>Renewal of NPDES Permit for the discharge of WTP treated wastewater</u> | | |



Summary of Review

The permittee submitted an NPDES permit renewal application to the Department on January 29, 2020. The application is for the discharges from the Beaver County Water Treatment Plant (BCWTP). The water plant has a rated capacity of 15 MGD and currently treats an average daily intake flow of 10 MGD, for processing and distribution of potable water. BCWTP's source of intake water is the Ohio River at the Baden River Water Intake Facility. The previous NPDES permit was issued by the Department's Safe Drinking Water program on June 25, 2015 and its term ran from July 1, 2015 to June 30, 2020. The permit has been administratively extended until this renewal is processed.

The West View Water Authority (WVWA) was created in 1942 and provides potable water service to a population of more than 175,000 in 27 municipalities in Allegheny, Beaver and Butler counties with the majority of this water produced at the Joseph A. Berkley WTP on Neville Island. This primary potable water supply has been recently supplemented with the use of the BCWTP which achieved full operation on January 7, 2020. BCWTP is a conventional type treatment plant, operating under PWS Permit No. 0414504-1A. BCWTP treatment consists of chemical feed, inline static mixer, flocculation, sedimentation, multimedia filtration, pH adjustment, fluoridation, chlorination and UV disinfection.

The multimedia filter backwash wastewater treatment equipment, permitted under WQM Part II permit **0414200**, issued June 5, 2015, consists of sludge lagoons, sludge thickeners, belt filter presses (BFPs) and a disk filter. The treated wastewater effluent then enters a newly installed drain line, travelling over a mile before discharge at Outfall 001. This treated wastewater discharge is the subject of this NPDES permit.

Most of the waste generated at BCWTP is produced during filter backwash and sludge withdrawal from the process sedimentation basins which flow to gravity thickening tanks. Sludge is collected from these tanks for processing in the BFP

| Approve | Deny | Signatures | Date |
|---------|------|--|----------------|
| X | |  John L. Duryea, Jr., P.E. / Environmental Engineer | March 14, 2022 |
| X | |  Michael E. Fifth, P.E. / Environmental Engineer Manager | March 15, 2022 |

Summary of Review

Holding Tank. Next it is processed by the BFPs. BFP filtrate is returned to the gravity thickener tanks. Solids are collected and removed offsite for landfill disposal.

The wastewater generated at this plant consists of filter backwash water and supernatant from the gravity thickening tanks. These wastewater streams are collected into two earthen lagoons to allow the solids to settle. The effluent from these lagoons is then conveyed to a disk filter for suspended solids removal. Disk filter backwash is returned to the gravity thickener tanks. The filtrate from the disk filter is conveyed through the drain line toward discharge into Tevebau Run at Outfall 001. From there it enters a 360-foot-long culvert under the railroad right-of-way at the southern end of Norfolk Southern's Conway Railyard. This culvert empties into the Ohio River. Therefore, the point of first use was established in the original issuance of this permit as the Ohio River; at River Mile Index of 20.27 from the state line (961.1 from the mouth of the Ohio River near Cairo, IL). Figure 1 below shows a satellite image (from eMapPA) of the relative positions of the BCWTP and Outfall 001 (marked with an "X").




Figure 1: Satellite Image of the Beaver County WTP and Outfall 001 (marked with an "X")

As can be seen in Figure 1 above the BCWTP and Outfall 001 are separated by more than a mile, were it in a direct line. The distance of the drain line is in fact considerably farther, as the line is generally run along Tevebau Run, although in some cases, it is run along Tevebaugh Hollow Road. Figure 2 below shows an extract from a permittee supplied drawing, detailing the locations of the Baden River Water Intake Facility, BCWTP Outfall 001, Tevebau Run, a portion of the plant's drain line, the 360-foot-culvert and the Ohio River.




Figure 2: Excerpt from WWA Drawing Showing the BCWTP Intake and Outfall 001

Summary of Review

As can be seen from Figure 2 above, Outfall 001 discharges to Tevebau Run in close proximity to the culvert entrance under the adjacent railyard. Immediately after passing through this culvert, Tevebau Run has its confluence with the Ohio River. Also shown is the Baden River Water Intake Facility which is just upstream of the Tevebau Run/Ohio River confluence point. Figure 3 below shows the Pennsylvania Water Quality Network, Station 902 and its proximity to the BCWTP site (on the Baden Borough/Economy Township line) and outfall.




Figure 3: Water Quality Network Station 902 in Relation to Baden and the BCWTP

The applicant complied with Act 14.

A compliance check revealed a number of WVWA Effluent Limitation exceedances and related open violations in the Department’s Clean Water Program at WVWA’s Neville Island Facility. However, WVWA is working with the Department to gain compliance on these violations.

The prior Fact Sheet for this permit included a requirement for the permittee to submit sample results for the pollutants included in Modules 4 and 5 with their renewal submittal. This was also included as a Part C Condition in their permit. Although this additional information was not submitted with the renewal application, upon Department request, this information was received on February 17, 2022. This information was reviewed and none of the pollutants were detected in the three effluent samples taken and analyzed. Engineering judgement was exercised to determine that the reasonable potential analysis and WQBEL Development for the BCWTP discharge at Outfall 001 should not require reanalysis based on this input.

It is recommended that this permit be published as a draft for public comment.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*,

Summary of Review

DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

| Discharge, Receiving Waters and Water Supply Information | | | |
|--|---------------------------------|------------------------------|----------------|
| Outfall No. | 001 | Design Flow (MGD) | 1.08 |
| Latitude | 40° 38' 34.1" | Longitude | -80° 13' 56.0" |
| Quad Name | Baden | Quad Code | 1304 |
| Wastewater Description: Filter backwash water and supernatant from sludge thickening tanks | | | |
| Receiving Waters | Tevebau Run | Stream Code | 36581 |
| NHD Com ID | 99679792 | RMI | 0.189 |
| Drainage Area | 2.5 square miles | Yield (cfs/mi ²) | 0.0092 |
| Q7-10 Flow (cfs) | 0.023 | Q7-10 Basis | USGS |
| Elevation (ft) | 710 | Slope (ft/ft) | 0.01 |
| Watershed No. | 20-G | Chapter 93 Class. | WWF |
| Existing Use | Aquatic Life | Existing Use Qualifier | None |
| Exceptions to Use | None | Exceptions to Criteria | None |
| Assessment Status | Attaining Use(s) WWF | | |
| Cause(s) of Impairment | | | |
| Source(s) of Impairment | | | |
| TMDL Status | N/A | Name | |
| Nearest Downstream Public Water Supply Intake | Center Township Water Authority | | |
| PWS Waters | Ohio River | Flow at Intake (cfs) | 5880 |
| PWS RMI | 954.0 | Distance from Outfall (mi) | 7.14 miles |

Changes Since Last Permit Issuance: The site reported its first discharge in December 2018 and completed the plant's initial startup in January 2020.

Other Comments: See graphic of watershed in Figure 4 below:




Figure 4: Tevebau Run Watershed from USGS StreamStats

| Discharge, Receiving Waters and Water Supply Information | | | |
|--|--|------------------------------|---|
| Outfall No. | 001 | Design Flow (MGD) | 1.08 |
| Latitude | 40° 38' 34.1" | Longitude | -80° 13' 56.0" |
| Quad Name | Baden | Quad Code | 1304 |
| Wastewater Description: Filter backwash water and supernatant from sludge thickening tanks | | | |
| Receiving Waters | Ohio River (WWF) | Stream Code | 32317 |
| NHD Com ID | 99680246 | RMI | 961.15 miles |
| Drainage Area | 19600 Sq. Miles | Yield (cfs/mi ²) | 0.241 |
| Q ₇₋₁₀ Flow (cfs) | 4730 | Q ₇₋₁₀ Basis | ACOE, 2017 |
| Elevation (ft) | 683 | Slope (ft/ft) | |
| Watershed No. | 20-G | Chapter 93 Class. | WWF |
| Existing Use | Aquatic Life | Existing Use Qualifier | None |
| Exceptions to Use | None | Exceptions to Criteria | None |
| Assessment Status | Impaired | | |
| Cause(s) of Impairment | DIOXIN, PATHOGENS, POLYCHLORINATED BIPHENYLS (PCBs), | | |
| Source(s) of Impairment | SOURCE UNKNOWN | | |
| TMDL Status | Final | Name | Ohio River TMDL |
| Background/Ambient Data | | Data Source | |
| pH (SU) | 7.5 | | Average of WQN 902 data from Oct. 1998 - June 2019 |
| Hardness (mg/L) | 100.465 | | Statistical Long Term Average (LTA) from WQN 902 |
| Aluminum (mg/L) | 0.3985 | | Statistical LTA from WQN 902, Dec. 2013 - June 2019 |
| Iron (mg/L) | 1.2808 | | Statistical LTA from WQN 902, Oct. 1998 - June 2019 |
| Manganese (mg/L) | 0.1795 | | Statistical LTA from WQN 902, Oct. 1998 - June 2019 |
| Nearest Downstream Public Water Supply Intake | Center Township Water Authority | | |
| PWS Waters | Ohio River | Flow at Intake (cfs) | 5880 |
| PWS RMI | 954.0 | Distance from Outfall (mi) | 7.14 |

Changes Since Last Permit Issuance: The site reported its first discharge in December 2018 and completed the plant's initial startup in January 2020.

Other Comments: Consistent with the initial assessment and issuance of this permit, the discharge at Outfall 001 is to Tevebau Run just before the culvert entrance that passes under the Norfolk Southern Conway railyard. It continues to be considered that the first natural stream and aquatic life use of these waters is after it exits the culvert and enters the Ohio River.



Figure 5: Ohio River Watershed at Its Confluence with Tevebau Run from USGS StreamStats

| Treatment Facility Summary | | | | |
|--|----------------------------|-------------------------|---------------------|------------------------|
| Treatment Facility Name: Beaver County WTP | | | | |
| WQM Permit No. | | Issuance Date | | |
| 0414200 | | June 5, 2015 | | |
| Waste Type | Degree of Treatment | Process Type | Disinfection | Avg Annual Flow (MGD) |
| Industrial | Basic | Settling and filtration | Chlorination and UV | 1.0008 |
| Hydraulic Capacity (MGD) | Organic Capacity (lbs/day) | Load Status | Biosolids Treatment | Biosolids Use/Disposal |
| | N/A | Not Overloaded | N/A | N/A |

Changes Since Last Permit Issuance: BCWTP started full operation on January 7, 2020.

Other Comments: The process is illustrated below in Figure 6:




Figure 6: Process Flow Diagram for the Water and Wastewater Treatment at BCWTP

Compliance History

Table 1: DMR Data for Outfall 001 (from July 1, 2020 to June 30, 2021)

| Parameter | JUN-21 | MAY-21 | APR-21 | MAR-21 | FEB-21 | JAN-21 | DEC-20 | NOV-20 | OCT-20 | SEP-20 | AUG-20 | JUL-20 |
|---|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| Flow (MGD) Average Monthly | 0.845 | 0.775 | 0.912 | 0.878 | 0.961 | 0.900 | 0.792 | 0.828 | 0.834 | 0.962 | 1.008 | 0.966 |
| Flow (MGD) Daily Maximum | 0.904 | 0.950 | 0.959 | 0.936 | 0.986 | 0.936 | 0.806 | 0.850 | 0.928 | 1.08 | 1.008 | 1.01 |
| pH (S.U.) Minimum | 7.5 | 7.4 | 7.4 | 7.2 | 7.3 | 7.1 | 7.3 | 7.4 | 7.4 | 7.3 | 7.3 | 7.3 |
| pH (S.U.) Maximum | 7.5 | 7.5 | 7.5 | 7.4 | 7.4 | 7.3 | 7.4 | 7.5 | 7.5 | 7.3 | 7.6 | 7.5 |
| TRC (mg/L) Average Monthly | < 0.1 | < 0.1 | < 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | < 0.1 | < 0.1 | < 0.1 | < 0.1 | < 0.1 |
| TRC (mg/L) Instantaneous Maximum | < 0.1 | < 0.1 | < 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | < 0.1 | < 0.1 | < 0.1 | < 0.1 | < 0.1 |
| TSS (mg/L) Average Monthly | < 5.0 | < 5.0 | < 5.0 | 9 | < 5.0 | < 5 | < 5.0 | < 5.0 | < 5.0 | < 5 | < 5 | < 5 |
| TSS (mg/L) Instantaneous Maximum | < 5.0 | < 5.0 | < 5.0 | 18 | < 5.0 | < 5 | < 5.0 | < 5.0 | < 5.0 | < 5 | < 5 | < 5 |
| Total Aluminum (mg/L) Average Monthly | 0.2 | 0.2 | 0.1 | 3.0 | 0.4 | < 0.1 | < 0.1 | < 0.1 | 0.1 | 0.1 | 0.1 | 0.2 |
| Total Aluminum (mg/L) Instantaneous Maximum | 0.2 | 0.2 | 0.2 | 5.8 | 0.5 | < 0.1 | < 0.1 | < 0.1 | 0.1 | 0.1 | 0.1 | 0.3 |
| Total Iron (mg/L) Average Monthly | < 0.1 | < 0.1 | < 0.1 | 0.3 | 0.1 | < 0.1 | < 0.1 | < 0.1 | < 0.1 | 0.1 | < 0.1 | < 0.1 |
| Total Iron (mg/L) Instantaneous Maximum | < 0.1 | < 0.1 | < 0.1 | 0.6 | 0.1 | < 0.1 | < 0.1 | < 0.1 | < 0.1 | 0.1 | < 0.1 | < 0.1 |
| Total Manganese (mg/L) Average Monthly | 0.5 | 0.5 | 0.4 | 0.3 | 0.1 | 0.2 | 0.1 | 0.1 | 0.2 | 0.4 | 0.9 | 1.4 |
| Total Manganese (mg/L) Instantaneous Maximum | 0.7 | 0.5 | 0.5 | 0.5 | 0.2 | 0.2 | 0.2 | 0.1 | 0.2 | 0.5 | 1.0 | 1.8 |

| Compliance History | |
|--------------------------------|---|
| Summary of DMRs: | The site reported its first discharge in December 2018. The site has had only one exceedance for manganese 2020, but no recorded violations. However, the trend is positive after the completion of the plant's initial startup in January 2020 |
| Summary of Inspections: | An inspection was conducted on January 29, 2019. This inspection report identified no violations. |

Other Comments:

Since the issuance of its renewed NPDES permit in May 2019, WVWA's Joseph A. Berkley WTP (PA0217689) has been challenged to meet some of its permit effluent limitations. A revision to an existing Consent Order and Agreement is being prepared to address these issues. In addition, the construction and operation of a permanent wastewater treatment plant was planned to be added to the Neville Island site. More recently, WVWA has communicated to the Department that it would prefer to modify the Davis Island lagoons and add an overflow discharge to ALCOSAN. The Department attorney involved in these discussions was consulted and based on the WVWA letter received on February 9, 2022 and the meeting held between the Department and WVWA on February 10, 2022, there were no objections to issuing the permit for the Beaver County WTP.

Development of Effluent Limitations

| | | | |
|---|-------------|--------------------------|--------------|
| Outfall No. | 001 | Design Flow (MGD) | 1.08 |
| Latitude | 40° 39' 23" | Longitude | -80° 13' 27" |
| Wastewater Description: Filter backwash water and supernatant from sludge thickening tanks | | | |

Technology-Based Limitations

The WVWA BCWTP facility is not subject to Federal Effluent Limitation Guidelines (ELGs) as the SIC code (4941) is not listed under 40 CFR parts 405 through 471.

Regulatory Effluent Standards and Monitoring Requirements

The pH effluent range for all Industrial waste process and non-process discharges pursuant of 25 Pa. Code § 92a.48(a)(2) and 25 Pa. Code § 95.2 is indicated in Table 2 below.

Flow monitoring is required pursuant to 25 Pa. Code § 92a.61(d)(1) as indicated in Table 2 below.

Pursuant to 25 Pa. Code § 95.2(4) effluent standards for industrial wastes may not contain more than 7 mg/L of dissolved iron as indicated in Table 2 below.

Pursuant to 25 Pa. Code § 92a.48(b) the imposition of technology-based Total Residual Chlorine (TRC) limits for facilities that use chlorination and that are not already subject to TRC limits based on applicable federal ELG's or a facility specific BPJ evaluation as indicated in Table 2 below.

Table 2. Regulatory Effluent Standards

| Parameter | Monthly Avg. | Daily Max | IMAX |
|-----------------|------------------|-----------|----------|
| Flow (MGD) | Monitor | Monitor | ---- |
| Iron, Dissolved | ---- | ---- | 7.0 mg/L |
| pH (S.U.) | 6-9 at all times | | |
| TRC | 0.5 mg/L | ---- | 1.6 mg/L |

Total Dissolved Solids (TDS)

Integral to the implementation of 25 Pa. Code § 95.10 is the principle that existing, authorized mass loadings of TDS are exempt from any treatment requirements under these provisions. Existing mass loadings of TDS up to and including the maximum daily discharge loading for any existing discharge, provided that the loading was authorized prior to August 21, 2010 are exempt. Discharge loadings of TDS authorized by the Department are typically exempt from the treatment requirements of Chapter 95.10 until the net TDS loading is increased, an existing discharge proposes a hydraulic expansion or a change in the waste stream. If there are existing mass or production-based TDS effluent limits, then these are used as the basis for the existing mass loading. However, this facility is new, therefore, the facility is subject to 25 Pa. Code § 95.10 treatment requirements.

Best Practicable Control Technology Currently Achievable (BPT)

The Department's reference document *Technology-Based Control Requirements for Water Treatment Plant Wastes* (DEP-ID 362-2183-003) established BPT for discharges of WTPs wastewater, which are illustrated in Table 3 below.

Table 3. BPT Limits for WTP Filter Backwash Wastewater

| Parameter | Monthly Avg. (mg/L) | Daily Max (mg/L) |
|------------------------------|---------------------|------------------|
| Total Suspended Solids (TSS) | 30.0 | 60.0 |
| Iron (total) | 2.0 | 4.0 |
| Aluminum (total) | 4.0 | 8.0 |
| Manganese (total) | 1.0 | 2.0 |
| Flow | Monitor | ---- |
| pH (S.U.) | 6-9 at all times | |
| TRC | 0.5 | 1.0 |

Water Quality-Based Limitations

Total Maximum Daily Load (TMDL)

Tevebau Run is not subject to a TMDL. However, as noted above, the point-of-first-use for aquatic life and for the other designated uses subsequent to this discharge at Outfall 001 is a segment of the Ohio River that is covered by a TMDL for PCBs, Chlordane and organics. However, there is no known history or documentation that indicates that BCWTP discharges any of these toxins or pathogenic pollutants. Therefore, a Part C condition will be added to prohibit discharge of these proscribed pollutants.

Toxics Screening Analysis – Procedures for Evaluating Reasonable Potential and Developing WQBELs

Pursuant to consideration of the Water Quality Based Effluent Limitations (WQBELs) at Outfall 001, water quality modeling was created following DEP's procedures for evaluating reasonable potential which are as follows:

1. For IW discharges, the design flow used in the modeling is the average flow during production or operation and may be taken from the permit application.
2. All toxic pollutants with discharge concentrations reported in the permit application or on DMRs, are modeled and compared to the most stringent applicable water quality criterion as potential pollutants of concern. [This includes pollutants reported as "Not Detectable" or as "<MDL" where the method detection limit for the analytical method used by the applicant is greater than the most stringent water quality criterion]. The highest reported concentration is entered into the most recent version of the Department's Toxics Management Spreadsheet (TMS) analysis (refer to Attachment A).
3. For any outfall with an applicable design flow, perform TMS modeling for all pollutants reported in the discharge. Use the maximum reported value from the application form or from DMRs as the input concentration for the TMS model.
4. Compare the actual WQBEL from TMS with the maximum concentration reported on DMRs or the permit application. Use WQN data or another source to establish the existing or background concentration for naturally occurring pollutants, but generally assume zero background concentration for non-naturally occurring pollutants
 - Establish limits in the draft permit where the maximum reported concentration equals or exceeds 50% of the WQBEL. Use the average monthly and maximum daily limits for the permit as recommended by TMS. In some cases, establish an IMAX limit at 2.5 times the average monthly limit.
 - For non-conservative pollutants, establish monitoring requirements where the maximum reported concentration is between 25% - 50% of the WQBEL.
 - For conservative pollutants, establish monitoring requirements where the maximum reported concentration is between 10% - 50% of the WQBEL.

The information described above including the maximum reported discharge concentrations, the most stringent water quality criteria, the pollutant-of-concern (reasonable potential) determinations, the calculated WQBELs, and the WQBEL/monitoring recommendations are displayed in the results presentation from TMS spreadsheet (refer to Attachment A).

Water Quality Modeling Programs

Toxics Management Spreadsheet Version 1.3 is a single discharge, mass-balance water quality modeling program that includes consideration for mixing, first-order decay and other factors to determine recommended WQBELs for toxic substances and several non-toxic substances. Required input data including stream code, river mile index, elevation, drainage area, discharge name, NPDES permit number and discharge flow rate are entered into TMS to establish site-specific discharge conditions. Other data such as low flow yield, reach dimensions and partial mix factors may also be entered to further characterize the conditions of the discharge and receiving water. The modeling approach outlined above is used to determine if any pollutants are present or likely to be present in a discharge at levels that may cause, have the reasonable potential to cause, or contribute to excursions above state water quality standards (i.e., a reasonable potential analysis). Discharge concentrations for the selected pollutants are chosen to represent the "worst case" quality of the discharge (i.e., maximum reported discharge concentrations). TMS evaluates each pollutant by computing a Waste Load Allocation (WLA) for each applicable criterion and associated WQ objective, determining a recommended maximum WQBEL and comparing that recommended WQBEL with the input discharge concentration to determine which is more stringent. Based on this evaluation, TMS recommends average monthly and maximum daily WQBELs.

Reasonable Potential Analysis and WQBEL Development for the BCWTP discharge at Outfall 001

Discharges from Outfall 001 were evaluated based on concentrations reported on the application. The TMS model was run for Outfall 001 using the modeled discharge and receiving stream characteristics shown in Table 4

Table 4: TMS Inputs

| Parameter | Value |
|----------------------|--------|
| River Mile Index | 961.15 |
| Discharge Flow (MGD) | 1.08 |

WQBELs are calculated by TMS by allocating the established Water Quality (WQ) criteria for the receiving surface water from 25 PA Code § 93. As Outfall 001 does not discharge directly to the Ohio River, ORSANCO criteria were not considered. The criteria are then converted to a WQ objective. For metals with criteria established for its dissolved form, a translator is used to determine the criteria for the total metal which is then used as the WQ objective.

| Basin/Stream Characteristics | |
|---------------------------------------|--------|
| Parameter | Value |
| Area (mi ²) | 19600 |
| Q ₇₋₁₀ (cfs) | 4,730 |
| Low-flow yield (cfs/mi ²) | 0.2413 |
| Elevation (ft.) | 683 |
| Slope | 0.0002 |

From this calculated objective for each pollutant concentration the discharge allocation is then reduced by available data of existing pollutant loads in the receiving waters using actual concentration data from instream monitoring. In this case, WQN 902 (located on the Sewickley Bridge) data was downloaded and used to calculate statistical LTAs and coefficients of variation (CVs) (where available) and were entered into the TMS to establish the existing or background concentration for naturally occurring pollutants. In contrast, the assumption of zero background concentration is used for non-naturally occurring pollutants or where background data is insufficient to determine the background concentration.

The TMS model calculates and applies partial mixing factors for CFC, THH and CRL. The most limiting criteria is selected and finally WLAs are calculated for the IW discharger and compared to its reported discharge concentrations.

Note that the downstream public water intake (Center Township Water Authority) was conservatively modeled as being at the downstream model node. The TMS model results did not recommend any additional effluent limits nor reporting requirements. These results are included as Attachment A.

WQM 7.0 Model

The computer model WQM 7.0 is run to determine wasteload allocations and effluent limitations for CBOD₅, NH₃-N and Dissolved Oxygen for single and multiple point source discharge scenarios. In general, WQM 7.0 is run if the maximum BOD₅/CBOD₅ concentrations exceeds 30/25 mg/L respectively in the permit application or the DMRs. The permit application reports a peak BOD₅ concentration as being undetectable with an MDL of 3 mg/L, and a peak COD concentration also undetectable at an MDL of 15 mg/L. As this industrial discharger does not approach the criteria requiring the use of the WQM 7.0 Model, no run was made and no related effluent limitations imposed.

Total Residual Chlorine

To determine if WQBELs are required for discharges containing TRC, a discharge evaluation is performed using a DEP program called TRC_CALC created with Microsoft Excel for Windows. TRC_CALC calculates TRC Waste Load Allocations (WLAs) through the application of a mass balance model which considers TRC losses due to stream and discharge chlorine demands and first-order chlorine decay. Input values for the program include flow rates and discharge chlorine demands for the receiving stream, the number of samples taken per month, coefficients of TRC variability, partial mix factors, and an optional factor of safety. The mass balance model calculates WLAs for acute and chronic criteria that are then converted to long term averages using calculated multipliers. The multipliers are functions of the number of samples taken per month and the TRC variability coefficients (normally kept at default values unless site specific information is available). The most stringent limitation between the acute and chronic long-term averages is converted to an average monthly limit for comparison to the BAT average monthly limit of **0.5 mg/L from 25 Pa. Code § 92a.48(b)(2)**. The more stringent of these average monthly TRC limitations is then proposed. The results of the modeling, included in Attachment B, indicate that the BAT and BPJ, independently calculate are equivalent. Based on this the average monthly TRC limitations is proposed. The results of the modeling, included in Attachment B, indicate that AFC limits are required for TRC including an average monthly concentration of 0.500 mg/L (which matches the BAT value) and also calculated an instantaneous maximum concentration (IMAX) of 1.170 mg/L.

Anti-Backsliding

Section 402(o) of the Clean Water Act (CWA), enacted in the Water Quality Act of 1987, establishes anti-backsliding rules governing two situations. The first situation occurs when a permittee seeks to revise a Technology-Based effluent limitation

based on BPJ to reflect a subsequently promulgated effluent guideline which is less stringent. The second situation addressed by Section 402(o) arises when a permittee seeks relaxation of an effluent limitation which is based upon a State treatment standard of water quality standard.

Previous limits can be used pursuant to EPA's anti-backsliding regulation 40 CFR 122.44 (l) Reissued permits. (1) Except as provided in paragraph (l)(2) of this section when a permit is renewed or reissued. Interim effluent limitations, standards or conditions must be at least as stringent as the final effluent limitations, standards, or conditions in the previous permit (unless the circumstances on which the previous permit was based have materially and substantially changed since the time the permit was issued and would constitute cause for permit modification or revocation and reissuance under §122.62). (2) In the case of effluent limitations established on the basis of Section 402(a)(1)(B) of the CWA, a permit may not be renewed, reissued, or modified on the basis of effluent guidelines promulgated under section 304(b) subsequent to the original issuance of such permit, to contain effluent limitations which are less stringent than the comparable effluent limitations in the previous permit.

The BCWTP facility is not seeking to revise the previously permitted effluent limits. Therefore, the prior permit values or those calculated in the previous sections whichever is more protective will be imposed.

Table 5: Effluent Limitations in Force for NPDES Permit PA0254843

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|-----------------|----------------------|---------------|-----------------------|-----------------|---------------|------------------|-------------------------------|----------------------|
| | Mass Units (lbs/day) | | Concentrations (mg/L) | | | | Minimum Measurement Frequency | Required Sample Type |
| | Average Monthly | Daily Maximum | Minimum | Average Monthly | Daily Maximum | Instant. Maximum | | |
| Flow (MGD) | Report | Report | XXX | XXX | XXX | XXX | 2/month | Measured |
| pH (S.U.) | XXX | XXX | 6.0 | XXX | XXX | 9.0 | 2/month | Grab |
| TRC | XXX | XXX | XXX | 0.5 | XXX | 1.0 | 2/month | Grab |
| TSS | XXX | XXX | XXX | 30.0 | XXX | 60.0 | 2/month | Grab |
| Total Aluminum | XXX | XXX | XXX | 4.0 | XXX | 8.0 | 2/month | Grab |
| Total Iron | XXX | XXX | XXX | 2.0 | XXX | 4.0 | 2/month | Grab |
| Total Manganese | XXX | XXX | XXX | 1.0 | XXX | 2.0 | 2/month | Grab |

Effluent Limitations and Monitoring Requirements for Outfall 001

Effluent limits applicable at Outfall 001 are the more stringent of TBELs, WQBELs, regulatory effluent standards, and monitoring requirements as summarized in Table 6 below. The applicable limits and monitoring requirements provided below are based on those listed in Tables 2, 3 and 5 of this Fact Sheet. The Instantaneous Maximum values have been converted to Daily Maximum values to be consistent with current practice and guidance. Note that some values were incorrectly labeled as IMAX values in the previous permit.

Table 6. Effluent limits and monitoring requirements for Outfall 001

| Parameter | Mass (pounds) | | Concentration (mg/L) | | | Basis |
|-------------------|--------------------------------|---------------|----------------------|---------------|-----------------|----------------------------|
| | Average Monthly | Daily Maximum | Average Monthly | Daily Maximum | Instant Maximum | |
| Flow (MGD) | Report | Report | — | — | — | 25 Pa. Code § 92a.61(d)(1) |
| TRC | — | — | 0.5 | 1.0 | — | 25 Pa. Code § 92a.48(b) |
| TSS | — | — | 30.0 | 60.0 | — | 40 CFR § 125.3 |
| Iron (total) | — | — | 2.0 | 4.0 | — | TBEL, 40 CFR 122.44 |
| Aluminum (total) | — | — | 4.0 | 8.0 | — | TBEL, 40 CFR 122.44 |
| Manganese (total) | — | — | 1.0 | 2.0 | — | TMDL |
| pH (S.U.) | Within the range of 6.0 to 9.0 | | | | | 25 Pa. Code § 95.2 |

Table 6 contains no new or more restrictive effluent limits or monitoring that differs from WVWA's previous permit for BCWFP. Monitoring requirements are based on the previous permit's monitoring requirements for the facility are displayed in Table 7 below.

Table 7. Monitoring Requirements for Outfall 001

| Parameter | Sample Type | Minimum Sample Frequency |
|-------------------|-------------|--------------------------|
| Flow (MGD) | Meter | 2/Month |
| TRC | Grab | 2/Month |
| TSS | Grab | 2/Month |
| Iron (total) | Grab | 2/Month |
| Aluminum (total) | Grab | 2/Month |
| Manganese (total) | Grab | 2/Month |
| pH (S.U.) | Grab | 2/Month |

Effluent Limitation Compliance Schedule

Whenever the Department proposes the imposition of water quality based effluent limitations on existing sources, the NPDES permit may include a schedule of compliance to achieve the WQBELs. Any compliance schedule contained in an NPDES permit must be an “enforceable sequence of actions or operations leading to compliance with the water quality-based effluent limitations (“WQBELs”). In accordance with 40 CFR 122.47(a)(3) and PA Code, Chapter 92a.51, compliance schedules that are longer than one year in duration must set forth interim requirements and dates for their achievement. In order to grant a compliance schedule in an NPDES permit, the permitting authority has to make a reasonable finding, adequately supported by the administrative record and described in the fact sheet, that a compliance schedule is “appropriate” and that compliance with the final WQBEL is required “as soon as possible”.

In this case, no new or more stringent Effluent Limitations have been proposed, so, the Department has not established a compliance schedule for WVWA's next permit term. Following the permit effective date, the final permit limits will take effect.

| Tools and References Used to Develop Permit | |
|---|--|
| <input type="checkbox"/> | WQM for Windows Model |
| <input checked="" type="checkbox"/> | Toxics Management Spreadsheet (see Attachment A) |
| <input checked="" type="checkbox"/> | TRC Model Spreadsheet (see Attachment B) |
| <input type="checkbox"/> | Temperature Model Spreadsheet |
| <input type="checkbox"/> | Water Quality Toxics Management Strategy, 361-0100-003, 4/06. |
| <input checked="" type="checkbox"/> | Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97. |
| <input type="checkbox"/> | Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98. |
| <input type="checkbox"/> | Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96. |
| <input type="checkbox"/> | Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97. |
| <input type="checkbox"/> | Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97. |
| <input type="checkbox"/> | Pennsylvania CSO Policy, 385-2000-011, 9/08. |
| <input type="checkbox"/> | Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03. |
| <input type="checkbox"/> | Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97. |
| <input checked="" type="checkbox"/> | Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97. |
| <input type="checkbox"/> | Implementation Guidance Design Conditions, 391-2000-006, 9/97. |
| <input type="checkbox"/> | Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004. |
| <input type="checkbox"/> | Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997. |
| <input type="checkbox"/> | Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99. |
| <input type="checkbox"/> | Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004. |
| <input type="checkbox"/> | Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97. |
| <input type="checkbox"/> | Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008. |
| <input checked="" type="checkbox"/> | Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994. |
| <input type="checkbox"/> | Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09. |
| <input type="checkbox"/> | Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97. |
| <input type="checkbox"/> | Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97. |
| <input type="checkbox"/> | Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99. |
| <input checked="" type="checkbox"/> | Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999. |
| <input type="checkbox"/> | Design Stream Flows, 391-2000-023, 9/98. |
| <input type="checkbox"/> | Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98. |
| <input type="checkbox"/> | Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97. |
| <input type="checkbox"/> | Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07. |
| <input type="checkbox"/> | SOP: |
| <input checked="" type="checkbox"/> | Other: Technology-Based Control Requirements for Water Treatment Plant Wastes (DEP-ID 362-2183-003) |

ATTACHMENTS

ATTACHMENT A: TOXICS MANAGEMENT SPREADSHEET

ATTACHMENT B: TRC MODELING SPREADSHEET

**ATTACHMENT A
TOXICS MANAGEMENT SPREADSHEET**



Model Results

WWWA Beaver County WTP, NPDES Permit No. PA0254843, Outfall 001

Instructions

Results

RETURN TO INPUTS

SAVE AS PDF

PRINT

All Inputs Results Limits

Recommended WQBELs & Monitoring Requirements

No. Samples/Month:

| Pollutants | Mass Limits | | Concentration Limits | | | | Governing WQBEL | WQBEL Basis | Comments |
|------------|---------------|---------------|----------------------|-----|------|-------|-----------------|-------------|----------|
| | AML (lbs/day) | MDL (lbs/day) | AML | MDL | IMAX | Units | | | |
| | | | | | | | | | |



Model Results

WVWA Beaver County WTP, NPDES Permit No. PA0254843, Outfall 001

Instructions

Results

RETURN TO INPUTS

SAVE AS PDF

PRINT

All

Inputs

Results

Limits

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

| Pollutants | Governing WQBEL | Units | Comments |
|---------------------------------|-----------------|-------|----------------------------|
| Total Dissolved Solids (PWS) | N/A | N/A | PWS Not Applicable |
| Chloride (PWS) | N/A | N/A | PWS Not Applicable |
| Bromide | N/A | N/A | No WQS |
| Sulfate (PWS) | N/A | N/A | PWS Not Applicable |
| Fluoride (PWS) | N/A | N/A | PWS Not Applicable |
| Total Aluminum | 47,927 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Antimony | N/A | N/A | Discharge Conc < TQL |
| Total Arsenic | 14,601 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Barium | 2,848,113 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Beryllium | N/A | N/A | No WQS |
| Total Boron | 1,098,558 | µg/L | Discharge Conc < TQL |
| Total Cadmium | 289 | µg/L | Discharge Conc < TQL |
| Total Chromium (III) | 125,827 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Hexavalent Chromium | 2,210 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Cobalt | 12,884 | µg/L | Discharge Conc < TQL |
| Total Copper | 1,899 | µg/L | Discharge Conc < TQL |
| Total Cyanide | N/A | N/A | No WQS |
| Dissolved Iron | 438,015 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Iron | 622,065 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Lead | 4,645 | µg/L | Discharge Conc < TQL |
| Total Manganese | 1,198,151 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Mercury | 73.0 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Nickel | 63,631 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Phenols (Phenolics) (PWS) | | µg/L | Discharge Conc < TQL |
| Total Selenium | 7,284 | µg/L | Discharge Conc < TQL |
| Total Silver | 513 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Thallium | 350 | µg/L | Discharge Conc < TQL |
| Total Zinc | 16,250 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Molybdenum | N/A | N/A | No WQS |



Model Results

WWA Beaver County WTP, NPDES Permit No. PA0254843, Outfall 001

Instructions

Results

RETURN TO INPUTS

SAVE AS PDF

PRINT

All

Inputs

Results

Limits

Hydrodynamics

Q₇₋₁₀

| RMI | Stream Flow (cfs) | PWS Withdrawal (cfs) | Net Stream Flow (cfs) | Discharge Analysis Flow (cfs) | Slope (ft/ft) | Depth (ft) | Width (ft) | W/D Ratio | Velocity (fps) | Travel Time (days) | Complete Mix Time (min) |
|--------|-------------------|----------------------|-----------------------|-------------------------------|---------------|------------|------------|-----------|----------------|--------------------|-------------------------|
| 961.03 | 4,730 | | 4,730 | 1.671 | 0.00005 | 25. | 1349. | 53.96 | 0.14 | 0.762 | 2710.727 |
| 959.28 | 4,731 | | 4,731 | | | | | | | | |

Q_h

| RMI | Stream Flow (cfs) | PWS Withdrawal (cfs) | Net Stream Flow (cfs) | Discharge Analysis Flow (cfs) | Slope (ft/ft) | Depth (ft) | Width (ft) | W/D Ratio | Velocity (fps) | Travel Time (days) | Complete Mix Time (min) |
|--------|-------------------|----------------------|-----------------------|-------------------------------|---------------|------------|------------|-----------|----------------|--------------------|-------------------------|
| 961.03 | 12100.89 | | 12100.89 | 1.671 | 0.00005 | 37.792 | 1349. | 35.695 | 0.237 | 0.45 | 1459.093 |
| 959.28 | 12103.13 | | 12103.13 | | | | | | | | |



Model Results

WVWA Beaver County WTP, NPDES Permit No. PA0254843, Outfall 001

Instructions

Results

RETURN TO INPUTS

SAVE AS PDF

PRINT

All

Inputs

Results

Limits

Wasteload Allocations

AFC

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

| Pollutants | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|---------------------------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------------------------------|
| Total Dissolved Solids (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Chloride (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Sulfate (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Fluoride (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Aluminum | 398.5 | 1.1993 | | 0 | 750 | 750 | 74,774 | |
| Total Antimony | 0 | 0 | | 0 | 1,100 | 1,100 | 232,755 | |
| Total Arsenic | 0 | 0 | | 0 | 340 | 340 | 71,943 | Chem Translator of 1 applied |
| Total Barium | 0 | 0 | | 0 | 21,000 | 21,000 | 4,443,513 | |
| Total Boron | 0 | 0 | | 0 | 8,100 | 8,100 | 1,713,927 | |
| Total Cadmium | 0 | 0 | | 0 | 2.014 | 2.13 | 451 | Chem Translator of 0.944 applied |
| Total Chromium (III) | 0 | 0 | | 0 | 569.763 | 1,803 | 381,518 | Chem Translator of 0.316 applied |
| Hexavalent Chromium | 0 | 0 | | 0 | 16 | 16.3 | 3,448 | Chem Translator of 0.982 applied |
| Total Cobalt | 0 | 0 | | 0 | 95 | 95.0 | 20,102 | |
| Total Copper | 0 | 0 | | 0 | 13.439 | 14.0 | 2,962 | Chem Translator of 0.96 applied |
| Dissolved Iron | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Iron | 1280.8 | 1.3907 | | 0 | N/A | N/A | N/A | |
| Total Lead | 0 | 0 | | 0 | 64.581 | 81.6 | 17,276 | Chem Translator of 0.791 applied |
| Total Manganese | 179.5 | 0.8644 | | 0 | N/A | N/A | N/A | |
| Total Mercury | 0 | 0 | | 0 | 1.400 | 1.65 | 349 | Chem Translator of 0.85 applied |
| Total Nickel | 0 | 0 | | 0 | 468.236 | 469 | 99,275 | Chem Translator of 0.998 applied |
| Total Phenols (Phenolics) (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Selenium | 0 | 0 | | 0 | N/A | N/A | N/A | Chem Translator of 0.922 applied |
| Total Silver | 0 | 0 | | 0 | 3.217 | 3.78 | 801 | Chem Translator of 0.85 applied |
| Total Thallium | 0 | 0 | | 0 | 65 | 65.0 | 13,754 | |
| Total Zinc | 0 | 0 | | 0 | 117.180 | 120 | 25,353 | Chem Translator of 0.978 applied |



Model Results

WVWA Beaver County WTP, NPDES Permit No. PA0254843, Outfall 001

Instructions

Results

RETURN TO INPUTS

SAVE AS PDF

PRINT

All Inputs Results Limits

CFC

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

| Pollutants | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|---------------------------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------------------------------|
| Total Dissolved Solids (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Chloride (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Sulfate (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Fluoride (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Aluminum | 398.5 | 1.1993 | | 0 | N/A | N/A | N/A | |
| Total Antimony | 0 | 0 | | 0 | 220 | 220 | 321,211 | |
| Total Arsenic | 0 | 0 | | 0 | 150 | 150 | 219,008 | Chem Translator of 1 applied |
| Total Barium | 0 | 0 | | 0 | 4,100 | 4,100 | 5,986,209 | |
| Total Boron | 0 | 0 | | 0 | 1,600 | 1,600 | 2,336,082 | |
| Total Cadmium | 0 | 0 | | 0 | 0.246 | 0.27 | 395 | Chem Translator of 0.909 applied |
| Total Chromium (III) | 0 | 0 | | 0 | 74.115 | 86.2 | 125,827 | Chem Translator of 0.86 applied |
| Hexavalent Chromium | 0 | 0 | | 0 | 10 | 10.4 | 15,177 | Chem Translator of 0.962 applied |
| Total Cobalt | 0 | 0 | | 0 | 19 | 19.0 | 27,741 | |
| Total Copper | 0 | 0 | | 0 | 8.956 | 9.33 | 13,621 | Chem Translator of 0.96 applied |
| Dissolved Iron | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Iron | 1280.8 | 1.3907 | | 0 | 1,500 | 1,500 | 622,065 | WQC = 30 day average; PMF = 1 |
| Total Lead | 0 | 0 | | 0 | 2.517 | 3.18 | 4,645 | Chem Translator of 0.791 applied |
| Total Manganese | 179.5 | 0.8644 | | 0 | N/A | N/A | N/A | |
| Total Mercury | 0 | 0 | | 0 | 0.770 | 0.91 | 1,323 | Chem Translator of 0.85 applied |
| Total Nickel | 0 | 0 | | 0 | 52.007 | 52.2 | 76,161 | Chem Translator of 0.997 applied |
| Total Phenols (Phenolics) (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Selenium | 0 | 0 | | 0 | 4.600 | 4.99 | 7,284 | Chem Translator of 0.922 applied |
| Total Silver | 0 | 0 | | 0 | N/A | N/A | N/A | Chem Translator of 1 applied |
| Total Thallium | 0 | 0 | | 0 | 13 | 13.0 | 18,981 | |
| Total Zinc | 0 | 0 | | 0 | 118.139 | 120 | 174,938 | Chem Translator of 0.986 applied |



Model Results

WVWA Beaver County WTP, NPDES Permit No. PA0254843, Outfall 001

Instructions

Results

RETURN TO INPUTS

SAVE AS PDF

PRINT

All Inputs Results Limits

THH

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

| Pollutants | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|---------------------------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------|
| Total Dissolved Solids (PWS) | 0 | 0 | | 0 | 500,000 | 500,000 | N/A | |
| Chloride (PWS) | 0 | 0 | | 0 | 250,000 | 250,000 | N/A | |
| Sulfate (PWS) | 0 | 0 | | 0 | 250,000 | 250,000 | N/A | |
| Fluoride (PWS) | 0 | 0 | | 0 | 2,000 | 2,000 | N/A | |
| Total Aluminum | 398.5 | 1.1993 | | 0 | N/A | N/A | N/A | |
| Total Antimony | 0 | 0 | | 0 | 5.6 | 5.6 | 8,176 | |
| Total Arsenic | 0 | 0 | | 0 | 10 | 10.0 | 14,601 | |
| Total Barium | 0 | 0 | | 0 | 2,400 | 2,400 | 3,504,122 | |
| Total Boron | 0 | 0 | | 0 | 3,100 | 3,100 | 4,526,158 | |
| Total Cadmium | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Chromium (III) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Hexavalent Chromium | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Cobalt | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Copper | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Dissolved Iron | 0 | 0 | | 0 | 300 | 300 | 438,015 | |
| Total Iron | 1280.8 | 1.3907 | | 0 | N/A | N/A | N/A | |
| Total Lead | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Manganese | 179.5 | 0.8644 | | 0 | 1,000 | 1,000 | 1,198,151 | |
| Total Mercury | 0 | 0 | | 0 | 0.050 | 0.05 | 73.0 | |
| Total Nickel | 0 | 0 | | 0 | 610 | 610 | 890,631 | |
| Total Phenols (Phenolics) (PWS) | 0 | 0 | | 0 | 5 | 5.0 | N/A | |
| Total Selenium | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Silver | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Thallium | 0 | 0 | | 0 | 0.24 | 0.24 | 350 | |
| Total Zinc | 0 | 0 | | 0 | N/A | N/A | N/A | |



Model Results

WVWA Beaver County WTP, NPDES Permit No. PA0254843, Outfall 001

Instructions

Results

RETURN TO INPUTS

SAVE AS PDF

PRINT

All Inputs Results Limits

CRL

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

| Pollutants | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|---------------------------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------|
| Total Dissolved Solids (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Chloride (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Sulfate (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Fluoride (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Aluminum | 398.5 | 1.1993 | | 0 | N/A | N/A | N/A | |
| Total Antimony | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Arsenic | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Barium | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Boron | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Cadmium | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Chromium (III) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Hexavalent Chromium | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Cobalt | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Copper | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Dissolved Iron | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Iron | 1280.8 | 1.3907 | | 0 | N/A | N/A | N/A | |
| Total Lead | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Manganese | 179.5 | 0.8644 | | 0 | N/A | N/A | N/A | |
| Total Mercury | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Nickel | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Phenols (Phenolics) (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Selenium | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Silver | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Thallium | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Zinc | 0 | 0 | | 0 | N/A | N/A | N/A | |

**ATTACHMENT B
TRC MODELING SPREADSHEET**

TRC_CALC_externa BCWTP PA0254843 Run Outfall 001

| TRC EVALUATION | | | | |
|---|---|-------------------------------|--------------------------------------|-----------|
| Input appropriate values in A3:A9 and D3:D9 | | | | |
| 4730 | = Q stream (cfs) | 0.5 | = CV Daily | |
| 1.08 | = Q discharge (MGD) | 0.5 | = CV Hourly | |
| 4 | = no. samples | 1 | = AFC_Partial Mix Factor | |
| 0.3 | = Chlorine Demand of Stream | 1 | = CFC_Partial Mix Factor | |
| 0 | = Chlorine Demand of Discharge | 15 | = AFC_Criteria Compliance Time (min) | |
| 0.5 | = BAT/BPJ Value | 720 | = CFC_Criteria Compliance Time (min) | |
| 0 | = % Factor of Safety (FOS) | | =Decay Coefficient (K) | |
| Source | Reference | AFC Calculations | | Reference |
| TRC | 1.3.2.iii | WLA_afc = 903.123 | | 1.3.2.iii |
| PENTOXSD TRG | 5.1a | LTAMULT_afc = 0.373 | | 5.1c |
| PENTOXSD TRG | 5.1b | LTA_afc = 336.525 | | 5.1d |
| | | WLA_cfc = 880.467 | | |
| | | LTAMULT_cfc = 0.581 | | |
| | | LTA_cfc = 511.862 | | |
| Source | Reference | Effluent Limit Calculations | | |
| PENTOXSD TRG | 5.1f | AML_MULT = 1.720 | | |
| PENTOXSD TRG | 5.1g | AVG_MON_LIMIT (mg/l) = 0.500 | | BAT/BPJ |
| | | INST_MAX_LIMIT (mg/l) = 1.170 | | |
| WLA_afc | $(.019/e^{-k \cdot AFC_tc}) + [(AFC_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC_tc}) \dots + Xd + (AFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$ | | | |
| LTAMULT_afc | $EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$ | | | |
| LTA_afc | wla_afc * LTAMULT_afc | | | |
| WLA_cfc | $(.011/e^{-k \cdot CFC_tc}) + [(CFC_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC_tc}) \dots + Xd + (CFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$ | | | |
| LTAMULT_cfc | $EXP((0.5 \cdot LN(cvd^2 / no_samples + 1)) - 2.326 \cdot LN(cvd^2 / no_samples + 1)^{0.5})$ | | | |
| LTA_cfc | wla_cfc * LTAMULT_cfc | | | |
| AML_MULT | $EXP(2.326 \cdot LN((cvd^2 / no_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no_samples + 1))$ | | | |
| AVG_MON_LIMIT | MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT) | | | |
| INST_MAX_LIMIT | 1.5 * ((av_mon_limit / AML_MULT) / LTAMULT_afc) | | | |