

Application Type New
Facility Type Industrial
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL INDUSTRIAL WASTE (IW)
AND IW STORMWATER**

Application No. PA0255335
APS ID 959109
Authorization ID 1213633

Applicant and Facility Information

| | | | |
|---------------------------|---|------------------|---|
| Applicant Name | <u>Allegheny Energy Supply Co. LLC</u> | Facility Name | <u>Mitchell FGD Landfill</u> |
| Applicant Address | <u>341 White Pond Drive</u> <u>Akron, OH 44320</u> | Facility Address | <u>Route 837</u> <u>Courtney, PA 15067</u> |
| Applicant Contact | <u>William Cannon</u> | Facility Contact | <u>Same as Applicant</u> |
| Applicant Phone | <u>(724) 838-6018</u> | Facility Phone | <u>Same as Applicant</u> |
| Client ID | <u>95418</u> | Site ID | <u>827420</u> |
| SIC Code | <u>4953</u> | Municipality | <u>Union Township</u> |
| SIC Description | <u>Trans. & Utilities - Refuse Systems</u> | County | <u>Washington</u> |
| Date Application Received | <u>December 8, 2017</u> | EPA Waived? | <u>No</u> |
| Date Application Accepted | <u>March 26, 2018</u> | If No, Reason | <u>Expressed Interest</u> |
| Purpose of Application | <u>Renewal of NPDES Permit Coverage</u> | | |



Summary of Review

The Department received an updated NPDES renewal application from Allegheny Energy Supply Co. LLC for its Mitchell FGD Landfill on December 8, 2017. The site is currently covered under NPDES permit PA0002895 with two other sites. PA0002895 is to be split to separate Mitchell FGD Landfill into a separate permit distinct from the Mitchell Power Station and the Mitchell Mingo Landfill. The site has an SIC Code of 4953, Refuse System, and is a coal ash landfill.

Mitchell FGD Landfill is a coal combustion residue landfill, currently under interim closure. The site received the coal combustion residue from the Mitchell Power Station. The Mitchell Power Station is a coal and oil-fired electric generating station which was decommissioned on October 9, 2013. The Mitchell FGD Landfill has been in a PADEP-approved "Temporary Reduction of Waste Disposal Activity" status since September of 1999. Following Mitchell's decommissioning, the site was covered with 12 inches of soil and fully vegetated, following which a modification application for the closure was submitted June 30, 2014. FirstEnergy currently awaits response from the Department's Waste Management Program to a groundwater assessment; following which, focus will return to the closure plan.

The site's wastewater consists of the inactive coal combustion residue landfill surface impoundment discharge. The site has one outfall, Outfall 007. Outfall 007 discharges leachate, seeps, springs and stormwater runoff from the inactivated, fully covered and vegetated landfill to an Unnamed Tributary to the Monongahela River. Prior to discharging through Outfall 007, the landfill leachate is treated by the use of a sedimentation pond. No water treatment chemicals are used in the treatment process. Any sediments removed from this pond will be properly disposed of in accordance with Department regulations. The average annual wastewater flow discharge through Outfall 007 is 0.0559 MGD, as displayed in the site's flow diagram in Attachment A.

The sedimentation pond collects and treats a combination of landfill underdrain, leachate and surface stormwater discharge. The discharge of this sedimentation pond is Outfall 007. Stormwater that falls onto the site goes to the pond and is not separated from the process discharge.

| Approve | Deny | Signatures | Date |
|---------|------|--|-----------|
| x | |  Adam Olesnanik / Environmental Engineering Specialist | 2-12-20 |
| ✓ | |  Michael E. Fifth, P.E. / Environmental Engineer Manager | 2/14/2020 |

Summary of Review

Public Participation:

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period, which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Changes Since Last Permit Issuance:

The site is being covered by its own permit and being separated from two other sites in its current permit.

Compliance History

| | |
|---------------------------------------|--|
| <p>Summary of DMRs:</p> | <p>This specific outfall of permit PA0002895 is in compliance with permit conditions, Outfall 006 of permit PA0002895 has shown to be out of compliance with the permit limitations.</p> |
| <p>Summary of Inspections:</p> | <p>The site has no open violations. The site was last inspected on November 9, 2018; one violations were noted, violation of effluent limits in Part A of permit. This violation is from exceedances of the limitations at Outfall 006 of PA0002895, which is going to be covered under a separate permit.</p> |

| Discharge, Receiving Waters and Water Supply Information | | | |
|---|---|--|-------------------------|
| Outfall No. | <u>007</u> | Design Flow (MGD) | <u>0.0795</u> |
| | | Long Term Average Discharge Flow (MGD) | <u>0.0559</u> |
| Latitude | <u>40° 13' 26"</u> | Longitude | <u>-79° 58' 37"</u> |
| Quad Name | <u>Monongahela</u> | Quad Code | <u>1706</u> |
| Wastewater Description: <u>Coal Ash Landfill Leachate, Seeps, Springs, and Stormwater</u> | | | |
| Receiving Waters | <u>Unnamed Tributary of Monongahela</u> | Stream Code | <u>39584</u> |
| NHD Com ID | <u>134839796</u> | RMI | <u>0.56</u> |
| Drainage Area | <u>0.0656</u> | Yield (cfs/mi ²) | <u>0.00415</u> |
| Q ₇₋₁₀ Flow (cfs) | <u>0.000272</u> | Q ₇₋₁₀ Basis | <u>USGS StreamStats</u> |
| Elevation (ft) | <u>980</u> | Slope (ft/ft) | <u>0.085</u> |
| Watershed No. | <u>19-C</u> | Chapter 93 Class. | <u>WWF</u> |
| Existing Use | <u></u> | Existing Use Qualifier | <u></u> |
| Exceptions to Use | <u></u> | Exceptions to Criteria | <u></u> |
| Assessment Status | <u>Impaired</u> | | |
| Cause(s) of Impairment | <u>Siltation</u> | | |
| Source(s) of Impairment | <u>Abandoned Mine Drainage</u> | | |
| TMDL Status | <u>Name</u> | | |
| Nearest Downstream Public Water Supply Intake | <u>PA American Water Co -Pittsburgh</u> | | |
| PWS Waters | <u>Monongahela River</u> | Flow at Intake (cfs) | <u>550</u> |
| PWS RMI | <u>25.55</u> | Distance from Outfall (mi) | <u>4.45</u> |

USGS StreamStates Drainage Area and Flow Report is include in Attachment D.

Development of Effluent Limitations

| | |
|--|---|
| Outfall No. <u>007</u> | Design Flow (MGD) <u>0.0795</u> |
| Latitude <u>40° 13' 26.00"</u> | Longitude <u>-79° 58' 37.00"</u> |
| Wastewater Description: <u>Coal Ash Landfill Leachate, Seeps, Springs, and Stormwater</u> | |

Technology-Based Limitations:

Federal Effluent Limitation Guidelines (ELGs)

The site is subject to Federal Effluent Limitation Guidelines (ELGs) pursuant to 40 CFR 423.12(b) (11) (Steam Electric Power Generating Point Source Category) and must achieve the limits in Table 1 below. Based on the type of discharge and 40 CFR 423.12(b) (12), the limitations will be expressed as concentration limitation instead of mass-based limitations

Table 1. Federal ELGs

| Parameter | Monthly Avg. (mg/L) | Maximum Daily (mg/L) |
|----------------|---------------------|----------------------|
| TSS | 30 | 100 |
| Oil and Grease | 15 | 20 |

Total Dissolved Solids Considerations

Outfall 007 is also subject to Chapter 95.10 Effluent Standards for total dissolved solids (TDS). The provisions of Chapter 95.10 were adopted on August 20, 2010 and became effective August 21, 2010. Chapter 95.10 of the Department's regulations establishes the effluent standards applicable to new and expanding discharges of TDS. Under the provisions of this regulation, dischargers that are subject to the requirements of 95.10 must be identified; discharges that are exempt from any treatment requirements under this chapter must be identified; the existing mass loadings of TDS that are exempt from the treatment requirements must be identified and quantified; and discharges of new and expanding mass loadings of TDS must be evaluated.

Integral to the implementation of Chapter 95.10 is the principle that existing, authorized mass loadings of TDS are exempt from any treatment requirements under these provisions. Existing mass loadings of TDS up to and including the maximum daily discharge loading for any existing discharge, provided that the loading was authorized prior to August 21, 2010 are exempt. Generally, no permit actions are required until an NPDES permit is issued, renewed, or amended. Discharge loadings of TDS authorized by the Department are typically exempt from the treatment requirements of Chapter 95.10 until the net TDS loading is increased, an existing discharge proposes a hydraulic expansion or there is a change in the waste stream. If there are existing mass or production based TDS effluent limits, then these are used as the basis for the existing mass loading.

The discharge from Outfall 007 was authorized, and existed prior to August 21, 2010. Therefore, the discharge is considered to be an existing, authorized mass loading of TDS and is exempt from any treatment requirements.

The TDS discharge reported in the application is 2,107 lb/day measured as an average daily discharge, over the course of a calendar year, otherwise known as an annual average daily load. With the load being greater than 2,000 lb/day, monitoring for TDS is imposed at Outfall 007.

Regulatory Effluent Standards and Monitoring Requirements

Flow monitoring is required pursuant to 25 Pa. Code § 92a.61(d)(1)

As oil-bearing wastewaters, discharges from Outfall 007 are subject to effluent standards for oil and grease from 25 Pa. Code § 95.2(2)

Waste may not contain more than 7 milligrams per liter of dissolved iron per 25 Pa. Code § 95.2(4).

Effluent standards for pH are also imposed on industrial wastes by 25 Pa. Code § 95.2(1) as indicated in Table 2

Table 2: Regulatory Effluent Standards and Monitoring Requirements for Outfall 007

| Parameter | Monthly Average | Daily Maximum | Units |
|-----------------|--|---------------|-------|
| Flow | Monitor and Report | | MGD |
| Iron, Dissolved | - | 7.0 | mg/L |
| Oil & Grease | 15 | 30 | mg/L |
| pH | Not less than 6.0 nor greater than 9.0 | | S.U. |

Water Quality-Based Limitations:

Toxics Screening Analysis – Procedures for Evaluating Reasonable Potential and Developing WQBELs

DEP’s procedures for evaluating reasonable potential are as follows:

1. For IW discharges, the design flow to use in modeling is the average flow during production or operation, and may be taken from the permit application.
2. Perform a Toxics Screening Analysis to identify toxic pollutants of concern. All toxic pollutants whose maximum concentrations, as reported in the permit application or on DMRs, are greater than the most stringent applicable water quality criterion are pollutants of concern. [This includes pollutants reported as "Not Detectable" or as "<MDL" where the method detection limit for the analytical method used by the applicant is greater than the most stringent water quality criterion]. List all toxic pollutants of concern in a Toxics Screening Analysis section of the fact sheet (see Attachment B).
3. For any outfall with an applicable design flow, perform PENTOXSD modeling for all pollutants of concern. Use the maximum reported value from the application form or from DMRs as the input concentration for the PENTOXSD model run.
4. Compare the actual WQBEL from PENTOXSD with the maximum concentration reported on DMRs or the permit application. Use WQN data or another source to establish the existing or background concentration for naturally occurring pollutants, but generally assume zero background concentration for non-naturally occurring pollutants.
 - Establish limits in the draft permit where the maximum reported concentration equals or exceeds 50% of the WQBEL. Use the average monthly and maximum daily limits for the permit as recommended by PENTOXSD. Establish an IMAX limit at 2.5 times the average monthly limit.
 - For non-conservative pollutants, establish monitoring requirements where the maximum reported concentration is between 25% - 50% of the WQBEL.
 - For conservative pollutants, establish monitoring requirements where the maximum reported concentration is between 10% - 50% of the WQBEL.

The information described above including the maximum reported discharge concentrations, the most stringent water quality criteria, the pollutant-of-concern (reasonable potential) determinations, the calculated WQBELs, and the WQBEL/monitoring recommendations are collected on a spreadsheet titled "Toxics Screening Analysis" and is displayed in Attachment B.

PENTOXSD Water Quality Modeling Program

PENTOXSD Version 2.0 for Windows is a single discharge, mass-balance water quality modeling program that includes consideration for mixing, first-order decay and other factors to determine recommended WQBELs for toxic substances and several non-toxic substances. Required input data including stream code, river mile index, elevation, drainage area, discharge name, NPDES permit number and discharge flow rate are entered into PENTOXSD to establish site-specific discharge conditions. Other data such as low flow yield, reach dimensions and partial mix factors may also be entered to further characterize the conditions of the discharge and receiving water. Pollutants are then selected for analysis based on those present or likely to be present in a discharge at levels that may cause, have the reasonable potential to cause, or contribute to excursions above state water quality standards (i.e., a reasonable potential analysis). Discharge concentrations for the selected pollutants are chosen to represent the "worst case" quality of the discharge (i.e., maximum reported discharge concentrations). PENTOXSD then evaluates each pollutant by computing a Waste Load Allocation for each applicable criterion, determining a recommended maximum WQBEL and comparing that recommended WQBEL with the input discharge concentration to determine which is more stringent. Based on this evaluation, PENTOXSD recommends average monthly and maximum daily WQBELs.

Reasonable Potential Analysis and WQBEL Development for Outfall 007

Table 3: PENTOXSD Inputs

| Parameter | Value |
|---------------------------------------|---------|
| River Mile Index | 0.56 |
| Discharge Flow (MGD) | 0.0559 |
| Basin/Stream Characteristics | |
| Parameter | Value |
| Area in Square Miles | 0.0656 |
| Q ₇₋₁₀ (cfs) | 0.00272 |
| Low-flow yield (cfs/mi ²) | 0.00415 |
| Elevation (ft) | 980 |
| Slope | 0.085 |

Discharges from Outfall 007 are evaluated based on concentrations reported on the application and on DMRs; data from those sources are used for toxics screening as described above. The PENTOXSD model is run with the discharge and receiving stream characteristics shown in Table 3. The pollutants selected for analysis include those identified as candidates for modeling by the Toxics Screening Analysis spreadsheet (in accordance with Step 2 of the Toxics Screening Analysis procedure discussed above). Pollutants for which water quality standards have not been promulgated (e.g., TSS, oil and grease) are excluded from the analysis.

The WQBELs calculated using PENTOXSD are compared to the maximum reported effluent concentrations as described in the Toxics Screening Analysis section above to evaluate the need to impose WQBELs or monitoring requirements in the permit. Based on the recommendations of the Toxics Screening Analysis, effluent limitations for Arsenic and Boron are proposed at Outfall 007. These limits are shown in Table 4 below. Output from the PENTOXSD model runs are included in Attachment C. The PWS parameters that were suggested from the toxics screening analysis were analyzed as if the discharge was directly to the Monongahela River. No water quality limits for these PWS parameters were determined at this location. Therefore, because

the discharge is further away from the PWS intake, no water quality limits will be imposed for the PWS parameters at Outfall 007.

Table 4. WQBELs from PENTOXSD and Toxics Screening Analysis for Outfall 007

| Parameter | Monthly average (µg/L) | Daily maximum (µg/L) |
|--------------|------------------------|----------------------|
| Arsenic | 10.031 | 15.651 |
| Boron (mg/L) | 1.605 | 2.504 |

Total Dissolved Solids, Chloride, Bromide, and Sulfate

The Toxics Screening Analysis' reporting recommendations for TDS, chloride, bromide and sulfate are the result of a new monitoring initiative. TDS and its major constituents including chloride, bromide and sulfate have emerged as pollutants of concern in several major watersheds in the Commonwealth. The conservative nature of these solids allows them to accumulate in surface waters and they may remain a concern even if the immediate downstream public water supply is not directly impacted. Bromide has been linked to the formation of disinfection byproducts at increased levels in public water systems. In addition, the Environmental Quality Board has directed DEP to collect additional data related to sulfate and chloride. Furthermore, EPA has expressed concern related to bromide and the importance of monitoring all point sources for bromide when it may be present.

Based on the concerns identified above and under the authority of 25 Pa. Code § 92a.61, DEP has determined that it should implement increased monitoring in NPDES permits for TDS, chloride, bromide and sulfate. The new/increased monitoring is prompted for discharges that exceed the following thresholds:

- Where the concentration of TDS in the discharge exceeds 1,000 mg/L, or the net TDS load from a discharge exceeds 20,000 lb/day, and the discharge flow exceeds 0.1 MGD, Part A of the permit should include monitor and report for TDS, chloride, bromide and sulfate. Allegheny Energy reported a TDS concentration of 4,580 mg/L however the discharge rate was reported to be 0.0559 MGD, therefore monitoring will not be imposed for these parameters.
- Where the concentration of bromide in a discharge exceeds 1 mg/L and the discharge flow exceeds 0.1 MGD, Part A of the permit should include monitor and report for bromide. Allegheny Energy reported a bromide concentration of 7.57 mg/L however the discharge rate was reported to be 0.0559 MGD, therefore monitoring will not be imposed for bromide.

Anti-Backsliding:

Previous limits can be used pursuant to EPA's anti-backsliding regulation, 40 CFR 122.44(l) and are displayed below in Table 5.

Table 5. Current Permit (PA0002895) Limits for Outfall 007

| Parameter | Average Monthly (mg/L) | Maximum Daily (mg/L) | IMAX (mg/L) | Monitoring Frequency |
|--------------|------------------------|----------------------|-------------|----------------------|
| Flow | Monitor | Monitor | | 2/Month |
| TSS | 30 | 100 | | 2/Month |
| Oil & Grease | 15 | 20 | 30 | 2/Month |
| Iron | 3.5 | 7.0 | | 2/Month |
| pH | Between 6.0 and 9.0 | | | 2/Month |

Final Effluent Limitations:

The final effluent limitations for Outfall 007 are displayed in Table 6 below, they are the most stringent values from the above effluent limitation development. Instantaneous maximum limitations are typically imposed to gauge compliance with composite sampling limits using grab samples or for Departmental sampling compliance purposes. Since the sampling type imposed at Mitchell FGD is grab sampling the instantaneous maximum limitation for oil & grease is not needed and has been removed.

Table 6. Proposed Permit Limits for Outfall 007

| Parameter | Average Monthly (mg/L) | Maximum Daily (mg/L) | IMAX (mg/L) | Sample Type | Monitoring Frequency |
|----------------|------------------------|----------------------|-------------|-------------|----------------------|
| Flow | Monitor | Monitor | | Measure | 2/Month |
| TSS | 30 | 100 | | Grab | 2/Month |
| TDS | Monitor | Monitor | | Grab | 2/Month |
| Oil & Grease | 15 | 20 | | Grab | 2/Month |
| Iron, Total | 3.5 | 7.0 | | Grab | 2/Month |
| Arsenic (µg/L) | 10.031 | 15.651 | | Grab | 2/Month |
| Boron | 1.605 | 2.504 | | Grab | 2/Month |
| pH | Between 6.0 and 9.0 | | | Grab | 2/Month |

Final WQBEL Compliance Report and Interim Monitoring

The WQBELs listed in Table 6 above for Arsenic and Boron are new to Outfall 007. Allegheny Energy does not have the necessary controls in place to ensure compliance with the WQBELs upon permit issuance. Therefore, in accordance with 25 Pa. Code § 92a.51(a) of DEP's regulations, Allegheny Energy will be granted three years to come into compliance with the WQBELs. Because the new WQBELs will not be effective upon permit issuance, the permit will be tiered to have interim and final effluent limitations. For the first three years, Arsenic and Boron will have monitor and report requirements, and after three years, the WQBELs will take effect. Additionally, because the WQBELs were developed using the default or model-derived estimates in PENTOXSD, the permittee shall collect site-specific data and conduct a Toxics Reduction Evaluation (TRE). The site-specific data and TRE will be submitted to DEP as part of a Final WQBEL Compliance Report.

| Tools and References Used to Develop Permit | |
|---|--|
| <input type="checkbox"/> | WQM for Windows Model (see Attachment [redacted]) |
| <input checked="" type="checkbox"/> | PENTOXSD for Windows Model (see Attachment C) |
| <input type="checkbox"/> | TRC Model Spreadsheet (see Attachment [redacted]) |
| <input type="checkbox"/> | Temperature Model Spreadsheet (see Attachment [redacted]) |
| <input checked="" type="checkbox"/> | Toxics Screening Analysis Spreadsheet (see Attachment B) |
| <input type="checkbox"/> | Water Quality Toxics Management Strategy, 361-0100-003, 4/06. |
| <input type="checkbox"/> | Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97. |
| <input type="checkbox"/> | Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98. |
| <input type="checkbox"/> | Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96. |
| <input type="checkbox"/> | Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97. |
| <input type="checkbox"/> | Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97. |
| <input type="checkbox"/> | Pennsylvania CSO Policy, 385-2000-011, 9/08. |
| <input type="checkbox"/> | Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03. |
| <input type="checkbox"/> | Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97. |
| <input type="checkbox"/> | Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97. |
| <input type="checkbox"/> | Implementation Guidance Design Conditions, 391-2000-006, 9/97. |
| <input type="checkbox"/> | Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004. |
| <input type="checkbox"/> | Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997. |
| <input type="checkbox"/> | Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99. |
| <input type="checkbox"/> | Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004. |
| <input type="checkbox"/> | Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97. |
| <input type="checkbox"/> | Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008. |
| <input type="checkbox"/> | Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994. |
| <input type="checkbox"/> | Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09. |
| <input type="checkbox"/> | Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97. |
| <input type="checkbox"/> | Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97. |
| <input type="checkbox"/> | Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99. |
| <input type="checkbox"/> | Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999. |
| <input type="checkbox"/> | Design Stream Flows, 391-2000-023, 9/98. |
| <input type="checkbox"/> | Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98. |
| <input type="checkbox"/> | Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97. |
| <input type="checkbox"/> | Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07. |
| <input type="checkbox"/> | SOP: [redacted] |
| <input checked="" type="checkbox"/> | Other: USGS StreamStats (see Attachment D) |

Attachments

Attachment A: Mitchell FDG Landfill Flow Diagram


Attachment B: Toxics Screening Analysis Results

Attachment C: PENTOXSD Analysis Results

Attachment D: USGS StreamStates Drainage Area and Flow Report

Attachment E: Federal Effluent Limitation Guidelines in 40 CFR § 423.12

**Attachment A:
Mitchell FDG Landfill Flow Diagram**



| | | | | | |
|----------|------|--------|------|----|----------------|
| REVISION | DATE | APPRO. | CHKD | DR | PROJECT NUMBER |
| | | | | | |

INITIAL PROJECT # _____ THIS IS AN AutoCAD DRAWING-DO NOT MANUALLY REVISE

| | | | | | |
|-------------|------|------------|--|--|-------------|
| ENGINEERING | | DATE | MITCHELL FGD LANDFILL NPDES PERMIT RENEWAL APPLICATION FLOW DIAGRAM - FIGURE 2 | | |
| DR | RDC | 11/10/2017 | | | |
| CHKD | WEC | 11/10/2017 | FACILITY MITCHELL | | UNIT COMMON |
| APPD | WEC | 11/10/2017 | DWG. NO. P86109266 | | REV. |
| SCALE | NONE | | | | |

**Attachment B:
Toxics Screening Analysis Results**

TOXICS SCREENING ANALYSIS
WATER QUALITY POLLUTANTS OF CONCERN
VERSION 2.4

Facility: **Mitchell FGD Landfill**
Analysis Hardness (mg/L): **100**

NPDES Permit No.: **PA0255335**
Discharge Flow (MGD): **0.0559**

Outfall: **007**
Analysis pH (SU): **7**

| | Parameter | Maximum Concentration in Application or DMRs (µg/L) | Most Stringent Criterion (µg/L) | Candidate for PENTOXSD Modeling? | Most Stringent WQBEL (µg/L) | Screening Recommendation |
|----------------|---------------------------|---|---------------------------------|----------------------------------|-----------------------------|--------------------------|
| Group 1 | Total Dissolved Solids | 4580000 | 500000 | Yes | 2236510000 | No Limits/Monitoring |
| | Chloride | 663000 | 250000 | Yes | 1118250000 | FALSE |
| | Bromide | 7570 | N/A | No | | |
| | Sulfate | 1530000 | 250000 | Yes | 1118250000 | FALSE |
| | Fluoride | 279 | 2000 | No | | |
| Group 2 | Total Aluminum | 149 | 750 | No | | |
| | Total Antimony | < 0.9 | 5.6 | No (Value < QL) | | |
| | Total Arsenic | 19.4 | 10 | Yes | 10.031 | Establish Limits |
| | Total Barium | 62.8 | 2400 | No | | |
| | Total Beryllium | < 1 | N/A | No (Value < QL) | | |
| | Total Boron | 2860 | 1600 | Yes | 1605.033 | Establish Limits |
| | Total Cadmium | < 0.2 | 0.271 | No (Value < QL) | | |
| | Total Chromium | < 4 | N/A | No (Value < QL) | | |
| | Hexavalent Chromium | < 1 | 10.4 | No (Value < QL) | | |
| | Total Cobalt | < 5 | 19 | No | | |
| | Total Copper | < 5 | 9.3 | No | | |
| | Total Cyanide | < 10 | N/A | No (Value < QL) | | |
| | Total Iron | 636 | 1500 | No | | |
| | Dissolved Iron | 67.5 | 300 | No | | |
| | Total Lead | < 1 | 3.2 | No (Value < QL) | | |
| | Total Manganese | 675 | 1000 | No | | |
| | Total Mercury | < 0.2 | 0.05 | No (Value < QL) | | |
| | Total Molybdenum | 43.4 | N/A | No | | |
| | Total Nickel | 12.2 | 52.2 | No | | |
| | Total Phenols (Phenolics) | < 10 | 5 | Yes | 22365.18 | No Limits/Monitoring |
| | Total Selenium | < 5 | 5.0 | No (Value < QL) | | |
| | Total Silver | < 0.4 | 3.8 | No (Value < QL) | | |
| | Total Thallium | < 0.9 | 0.24 | No (Value < QL) | | |
| Total Zinc | < 25 | 119.8 | No | | | |

**Attachment C:
PENTOXSD Analysis Results**

PENTOXSD

Modeling Input Data

| Stream Code | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope | PWS With (mgd) | Apply FC |
|-------------|------|----------------|-----------------------|---------|----------------|-------------------------------------|
| 39584 | 0.56 | 980.00 | 0.07 | 0.08500 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| LFY | Trib Flow (cfs) | Stream Flow (cfs) | WD Ratio | Rch Width (ft) | Rch Depth (ft) | Rch Velocity (fps) | Rch Trav Time (days) | Tributary Hard (mg/L) | pH | Stream Hard (mg/L) | pH | Analysis Hard (mg/L) | pH |
|-------|-----------------|-------------------|----------|----------------|----------------|--------------------|----------------------|-----------------------|----|--------------------|----|----------------------|----|
| Q7-10 | 0.1 | 0 | 0.00027 | 0 | 0 | 0 | 0 | 100 | 7 | 0 | 0 | 0 | 0 |
| Qh | | 0 | 0 | 0 | 0 | 0 | 0 | 100 | 7 | 0 | 0 | 0 | 0 |

Discharge Data

| Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | AFC PMF | CFC PMF | THH PMF | CRL PMF | Disc Hard (mg/L) | Disc pH |
|-------------|---------------|--------------------------|---------------------------|------------------------|----------------|---------|---------|---------|---------|------------------|---------|
| Outfall 007 | PA0255335 | 0.0569 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 1640 | 7.72 |

Parameter Data

| Parameter Name | Disc Conc (µg/L) | Trib Conc (µg/L) | Disc Daily CV | Disc Hourly CV | Stream Conc (µg/L) | Stream CV | Fate Coef | FOS | Crit Mod | Max Disc Conc (µg/L) |
|----------------|------------------|------------------|---------------|----------------|--------------------|-----------|-----------|-----|----------|----------------------|
| ARSENIC | 1000000 | 0 | 0.5 | 0.5 | 0 | 0 | 0 | 0 | 1 | 0 |
| BORON | 1000000 | 0 | 0.5 | 0.5 | 0 | 0 | 0 | 0 | 1 | 0 |

| Stream Code | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope | PWS With (mgd) | Apply FC |
|-------------|------|----------------|-----------------------|---------|----------------|-------------------------------------|
| 39584 | 0.05 | 730.00 | 0.14 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| LFY | Trib Flow (cfs) | Stream Flow (cfs) | WD Ratio | Rch Width (ft) | Rch Depth (ft) | Rch Velocity (fps) | Rch Trav Time (days) | Tributary Hard (mg/L) | pH | Stream Hard (mg/L) | pH | Analysis Hard (mg/L) | pH |
|-------|-----------------|-------------------|----------|----------------|----------------|--------------------|----------------------|-----------------------|----|--------------------|----|----------------------|----|
| Q7-10 | 0.1 | 0 | 0 | 0 | 0 | 0 | 0 | 100 | 7 | 0 | 0 | 0 | 0 |
| Qh | | 0 | 0 | 0 | 0 | 0 | 0 | 100 | 7 | 0 | 0 | 0 | 0 |

Discharge Data

| Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | AFC PMF | CFC PMF | THH PMF | CRL PMF | Disc Hard (mg/L) | Disc pH |
|------|---------------|--------------------------|---------------------------|------------------------|----------------|---------|---------|---------|---------|------------------|---------|
| | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 100 | 7 |

Parameter Data

| Parameter Name | Disc Conc (µg/L) | Trib Conc (µg/L) | Disc Daily CV | Disc Hourly CV | Stream Conc (µg/L) | Stream CV | Fate Coef | FOS | Crit Mod | Max Disc Conc (µg/L) |
|----------------|------------------|------------------|---------------|----------------|--------------------|-----------|-----------|-----|----------|----------------------|
| ARSENIC | 0 | 0 | 0.5 | 0.5 | 0 | 0 | 0 | 0 | 1 | 0 |
| BORON | 0 | 0 | 0.5 | 0.5 | 0 | 0 | 0 | 0 | 1 | 0 |

PENTOXSD Analysis Results

Hydrodynamics

| SWP Basin | | Stream Code: | | Stream Name: | | | | | | | |
|----------------------------|-------------------|----------------|-----------------------|---------------------------------|-------------|------------|------------|----------|----------------|------------------------|-----------|
| 19C | | 39584 | | Trib 39584 to Monongahela River | | | | | | | |
| RMI | Stream Flow (cfs) | PWS With (cfs) | Net Stream Flow (cfs) | Disc Analysis Flow (cfs) | Reach Slope | Depth (ft) | Width (ft) | WD Ratio | Velocity (fps) | Reach Trav Time (days) | CMT (min) |
| Q7-10 Hydrodynamics | | | | | | | | | | | |
| 0.560 | 0.0003 | 0 | 0.0003 | 0.08647 | 0.085 | 0.4124 | 1.7087 | 4.1433 | 0.1231 | 0.2532 | 0 |
| 0.050 | 0.0077 | 0 | 0.0077 | NA | 0 | 0 | 0 | 0 | 0 | 0 | NA |
| Qh Hydrodynamics | | | | | | | | | | | |
| 0.560 | 0.0057 | 0 | 0.0057 | 0.08647 | 0.085 | 0.4235 | 1.7087 | 4.0343 | 0.1273 | 0.2447 | 0 |
| 0.050 | 0.1058 | 0 | 0.1058 | NA | 0 | 0 | 0 | 0 | 0 | 0 | NA |

PENTOXSD Analysis Results

Wasteload Allocations

| RMI | Name | Permit Number | | | | | | |
|--|-------------|--------------------|-----------|------------------|-------------|------------|-------------------|------------|
| 0.56 | Outfall 007 | PA0255335 | | | | | | |
| AFC | | | | | | | | |
| Q7-10: | CCT (min) | 0 | PMF | 1 | Analysis pH | 7.714 | Analysis Hardness | 1635.17 |
| | Parameter | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) |
| | ARSENIC | 0 | 0 | 0 | 0 | 340 | 340 | 341.069 |
| | BORON | 0 | 0 | 0 | 0 | 8100 | 8100 | 8125.477 |
| Dissolved WQC. Chemical translator of 1 applied. | | | | | | | | |
| CFC | | | | | | | | |
| Q7-10: | CCT (min) | 0 | PMF | 1 | Analysis pH | 7.714 | Analysis Hardness | 1635.17 |
| | Parameter | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) |
| | ARSENIC | 0 | 0 | 0 | 0 | 150 | 150 | 150.472 |
| | BORON | 0 | 0 | 0 | 0 | 1600 | 1600 | 1605.033 |
| Dissolved WQC. Chemical translator of 1 applied. | | | | | | | | |
| THH | | | | | | | | |
| Q7-10: | CCT (min) | 0 | PMF | 1 | Analysis pH | NA | Analysis Hardness | NA |
| | Parameter | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) |
| | ARSENIC | 0 | 0 | 0 | 0 | 10 | 10 | 10.031 |
| | BORON | 0 | 0 | 0 | 0 | 3100 | 3100 | 3109.75 |
| CRL | | | | | | | | |
| Qh: | CCT (min) | 0 | PMF | 1 | Analysis pH | NA | Analysis Hardness | NA |
| | Parameter | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) |
| | ARSENIC | 0 | 0 | 0 | 0 | NA | NA | NA |
| | BORON | 0 | 0 | 0 | 0 | NA | NA | NA |

PENTOXSD Analysis Results

Recommended Effluent Limitations

| <u>SWP Basin</u> | <u>Stream Code:</u> | <u>Stream Name:</u> | | | |
|------------------|-----------------------|---------------------------------|-------------------------|----------------|-----------------|
| 19C | 39584 | Trib 39584 to Monongahela River | | | |
| RMI | Name | Permit Number | Disc Flow (mgd) | | |
| 0.56 | Outfall 007 | PA0255335 | 0.0559 | | |
| Parameter | Effluent Limit (µg/L) | Governing Criterion | Max. Daily Limit (µg/L) | Most Stringent | |
| | | | | WQBEL (µg/L) | WQBEL Criterion |
| ARSENIC | 10.031 | THH | 15.651 | 10.031 | THH |
| BORON | 1605.033 | CFC | 2504.109 | 1605.033 | CFC |

PENTOXSD

Modeling Input Data

| Stream Code | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope | PWS With (mgd) | Apply FC |
|-------------|-------|----------------|-----------------------|---------|----------------|-------------------------------------|
| 37185 | 29.48 | 730.00 | 5320.00 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| LFY | Trib Flow (cfs) | Stream Flow (cfs) | WD Ratio | Rch Width (ft) | Rch Depth (ft) | Rch Velocity (fps) | Rch Trav Time (days) | Tributary | | Stream | | Analysis | | |
|-------|-----------------|-------------------|----------|----------------|----------------|--------------------|----------------------|-------------|-----|-------------|----|-------------|----|---|
| | | | | | | | | Hard (mg/L) | pH | Hard (mg/L) | pH | Hard (mg/L) | pH | |
| Q7-10 | 0.1 | 0 | 550 | 0 | 770 | 20 | 0 | 0 | 100 | 7 | 0 | 0 | 0 | 0 |
| Qh | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 100 | 7 | 0 | 0 | 0 | 0 |

Discharge Data

| Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | AFC PMF | CFC PMF | THH PMF | CRL PMF | Disc Hard (mg/L) | Disc pH |
|-----------|---------------|--------------------------|---------------------------|------------------------|----------------|---------|---------|---------|---------|------------------|---------|
| RMI 29.48 | PA0255335 | 0.0795 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 100 | 7 |

Parameter Data

| Parameter Name | Disc Conc (µg/L) | Trib Conc (µg/L) | Disc Daily CV | Disc Hourly CV | Steam Conc (µg/L) | Stream CV | Fate Coef | FOS | Crit Mod | Max Disc Conc (µg/L) |
|------------------------------|------------------|------------------|---------------|----------------|-------------------|-----------|-----------|-----|----------|----------------------|
| CHLORIDE (PWS) | 1000000 | 0 | 0.5 | 0.5 | 0 | 0 | 0 | 0 | 1 | 0 |
| PHENOLICS (PWS) | 1000000 | 0 | 0.5 | 0.5 | 0 | 0 | 0 | 0 | 1 | 0 |
| SULFATE (PWS) | 1000000 | 0 | 0.5 | 0.5 | 0 | 0 | 0 | 0 | 1 | 0 |
| TOTAL DISSOLVED SOLIDS (PWS) | 1000000 | 0 | 0.5 | 0.5 | 0 | 0 | 0 | 0 | 1 | 0 |

| Stream Code | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope | PWS With (mgd) | Apply FC |
|-------------|-------|----------------|-----------------------|---------|----------------|-------------------------------------|
| 37185 | 25.55 | 727.00 | 5330.00 | 0.00000 | 70.00 | <input checked="" type="checkbox"/> |

Stream Data

| LFY | Trib Flow (cfs) | Stream Flow (cfs) | WD Ratio | Rch Width (ft) | Rch Depth (ft) | Rch Velocity (fps) | Rch Trav Time (days) | Tributary | | Stream | | Analysis | | |
|-------|-----------------|-------------------|----------|----------------|----------------|--------------------|----------------------|-------------|-----|-------------|----|-------------|----|---|
| | | | | | | | | Hard (mg/L) | pH | Hard (mg/L) | pH | Hard (mg/L) | pH | |
| Q7-10 | 0.1 | 0 | 550 | 0 | 900 | 20 | 0 | 0 | 100 | 7 | 0 | 0 | 0 | 0 |
| Qh | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 100 | 7 | 0 | 0 | 0 | 0 |

Discharge Data

| Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | AFC PMF | CFC PMF | THH PMF | CRL PMF | Disc Hard (mg/L) | Disc pH |
|------|---------------|--------------------------|---------------------------|------------------------|----------------|---------|---------|---------|---------|------------------|---------|
| | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 100 | 7 |

Parameter Data

| Parameter Name | Disc Conc (µg/L) | Trib Conc (µg/L) | Disc Daily CV | Disc Hourly CV | Steam Conc (µg/L) | Stream CV | Fate Coef | FOS | Crit Mod | Max Disc Conc (µg/L) |
|------------------------------|------------------|------------------|---------------|----------------|-------------------|-----------|-----------|-----|----------|----------------------|
| CHLORIDE (PWS) | 0 | 0 | 0.5 | 0.5 | 0 | 0 | 0 | 0 | 1 | 0 |
| PHENOLICS (PWS) | 0 | 0 | 0.5 | 0.5 | 0 | 0 | 0 | 0 | 1 | 0 |
| SULFATE (PWS) | 0 | 0 | 0.5 | 0.5 | 0 | 0 | 0 | 0 | 1 | 0 |
| TOTAL DISSOLVED SOLIDS (PWS) | 0 | 0 | 0.5 | 0.5 | 0 | 0 | 0 | 0 | 1 | 0 |

PENTOXSD Analysis Results

Hydrodynamics

| <u>SWP Basin:</u> | | <u>Stream Code:</u> | | | <u>Stream Name:</u> | | | | | | |
|----------------------------|----------------------|---------------------|--------------------------|-----------------------------|---------------------|---------------|---------------|----------|-------------------|---------------------------|--------------|
| 19A | | 37185 | | | MONONGAHELA RIVER | | | | | | |
| RMI | Stream Flow (cfs) | PWS With (cfs) | Net Stream Flow (cfs) | Disc Analysis Flow (cfs) | Reach Slope | Depth (ft) | Width (ft) | WD Ratio | Velocity (fps) | Reach Trav Time (days) | CMT (min) |
| Q7-10 Hydrodynamics | | | | | | | | | | | |
| 29.480 | 550 | 0 | 550 | 0.12298 | 0.0001 | 20 | 770 | 38.5 | 0.0357 | 6.7232 | 755.305 |
| 25.550 | 550 | 108.29 | 441.71 | NA | 0 | 0 | 0 | 0 | 0 | 0 | NA |
| Qh Hydrodynamics | | | | | | | | | | | |
| 29.480 | 1845.3 | 0 | 1845.3 | 0.12298 | 0.0001 | 34.065 | 770 | 22.604 | 0.0704 | 3.4136 | 339.89 |
| 25.550 | 1845.3 | 108.29 | 1737.0 | NA | 0 | 0 | 0 | 0 | 0 | 0 | NA |

PENTOXSD Analysis Results

Wasteload Allocations

| RMI | Name | Permit Number | | | | | | | | | |
|--------|------------------------------|---------------|--------------------|-----------|------------------|-----------|-------------------|---------------|-------------|--|--|
| 29.48 | RMI 29.48 | PA0255335 | | | | | | | | | |
| AFC | | | | | | | | | | | |
| Q7-10: | CCT (min) | 15 | PMF | 0.14 | Analysis pH | 7 | Analysis Hardness | 100 | | | |
| | Parameter | | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | | |
| | TOTAL DISSOLVED SOLIDS (PWS) | | 0 | 0 | 0 | 0 | NA | NA | NA | | |
| | CHLORIDE (PWS) | | 0 | 0 | 0 | 0 | NA | NA | NA | | |
| | SULFATE (PWS) | | 0 | 0 | 0 | 0 | NA | NA | NA | | |
| | PHENOLICS (PWS) | | 0 | 0 | 0 | 0 | NA | NA | NA | | |
| CFC | | | | | | | | | | | |
| Q7-10: | CCT (min) | 720 | PMF | 0.976 | Analysis pH | 7 | Analysis Hardness | 100 | | | |
| | Parameter | | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | | |
| | TOTAL DISSOLVED SOLIDS (PWS) | | 0 | 0 | 0 | 0 | NA | NA | NA | | |
| | CHLORIDE (PWS) | | 0 | 0 | 0 | 0 | NA | NA | NA | | |
| | SULFATE (PWS) | | 0 | 0 | 0 | 0 | NA | NA | NA | | |
| | PHENOLICS (PWS) | | 0 | 0 | 0 | 0 | NA | NA | NA | | |
| THH | | | | | | | | | | | |
| Q7-10: | CCT (min) | 720 | PMF | 1 | Analysis pH | NA | Analysis Hardness | NA | | | |
| | Parameter | | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | | |
| | TOTAL DISSOLVED SOLIDS (PWS) | | 0 | 0 | 0 | 0 | 500000 | 500000 | 2.23651E+09 | | |
| | CHLORIDE (PWS) | | 0 | 0 | 0 | 0 | 250000 | 250000 | 1.11825E+09 | | |
| | SULFATE (PWS) | | 0 | 0 | 0 | 0 | 250000 | 250000 | 1.11825E+09 | | |
| | PHENOLICS (PWS) | | 0 | 0 | 0 | 0 | 5 | 5 | 22365.18 | | |
| CRL | | | | | | | | | | | |
| Qh: | CCT (min) | 339.89 | PMF | 1 | | | | | | | |

PENTOXSD Analysis Results

Wasteload Allocations

| RMI | Name | Permit Number | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) |
|-------|------------------------------|---------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|
| 29.48 | RMI 29.48 | PA0255335 | | | | | | | |
| | Parameter | | | | | | | | |
| | TOTAL DISSOLVED SOLIDS (PWS) | | 0 | 0 | 0 | 0 | NA | NA | NA |
| | CHLORIDE (PWS) | | 0 | 0 | 0 | 0 | NA | NA | NA |
| | SULFATE (PWS) | | 0 | 0 | 0 | 0 | NA | NA | NA |
| | PHENOLICS (PWS) | | 0 | 0 | 0 | 0 | NA | NA | NA |

PENTOXSD Analysis Results

Recommended Effluent Limitations

SWP Basin: 19A **Stream Code:** 37185 **Stream Name:** MONONGAHELA RIVER

| RMI | Name | Permit Number | Disc Flow (mgd) | Parameter | Effluent Limit (µg/L) | Governing Criterion | Max. Daily Limit (µg/L) | Most Stringent WQBEL (µg/L) | Most Stringent WQBEL Criterion |
|-------|-----------|---------------|-----------------|------------------------------|-----------------------|---------------------|-------------------------|-----------------------------|--------------------------------|
| 29.48 | RMI 29.48 | PA0255335 | 0.0795 | | | | | | |
| | | | | CHLORIDE (PWS) | 1000000 | INPUT | 1560000 | 1.11825E+09 | THH |
| | | | | PHENOLICS (PWS) | 22365.18 | THH | 34893.27 | 22365.18 | THH |
| | | | | SULFATE (PWS) | 1000000 | INPUT | 1560000 | 1.11825E+09 | THH |
| | | | | TOTAL DISSOLVED SOLIDS (PWS) | 1000000 | INPUT | 1560000 | 2.23651E+09 | THH |

**Attachment D:
USGS StreamStates Drainage Area and Flow Report**

Mitchell FGD Landfill Outfall 007 StreamStats Report

Region ID:
 Workspace ID:
 Clicked Point (Latitude, Longitude):
 Time:

PA
 PA20180412111950571000
 40.22386, -79.97637
 2018-04-12 07:20:06 -0400



Basin Characteristics

| Parameter Code | Parameter Description | Value | Unit |
|----------------|---|--------|--------------|
| DRNAREA | Area that drains to a point on a stream | 0.0656 | square miles |
| ELEV | Mean Basin Elevation | 1099 | feet |

Low-Flow Statistics Parameters (Low Flow Region 4)

| Parameter Code | Parameter Name | Value | Units | Min Limit | Max Limit |
|----------------|----------------------|--------|--------------|-----------|-----------|
| DRNAREA | Drainage Area | 0.0656 | square miles | 2.26 | 1400 |
| ELEV | Mean Basin Elevation | 1099 | feet | 1050 | 2580 |

Low-Flow Statistics Disclaimers (Low Flow Region 4)

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors

Low-Flow Statistics Flow Report (Low Flow Region 4)

| Statistic | Value | Unit |
|-------------------------|----------|--------------------|
| 7 Day 2 Year Low Flow | 0.00117 | ft ³ /s |
| 30 Day 2 Year Low Flow | 0.00255 | ft ³ /s |
| 7 Day 10 Year Low Flow | 0.000272 | ft ³ /s |
| 30 Day 10 Year Low Flow | 0.000708 | ft ³ /s |
| 90 Day 10 Year Low Flow | 0.00162 | ft ³ /s |

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

Attachment E:

Federal Effluent Limitation Guidelines in 40 CFR § 423.12

PART 423—STEAM ELECTRIC POWER GENERATING POINT SOURCE CATEGORY

§423.12 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT).

(a) In establishing the limitations set forth in this section, EPA took into account all information it was able to collect, develop and solicit with respect to factors (such as age and size of plant, utilization of facilities, raw materials, manufacturing processes, non-water quality environmental impacts, control and treatment technology available, energy requirements and costs) which can affect the industry subcategorization and effluent levels established. It is, however, possible that data which would affect these limitations have not been available and, as a result, these limitations should be adjusted for certain plants in this industry. An individual discharger or other interested person may submit evidence to the Regional Administrator (or to the State, if the State has the authority to issue NPDES permits) that factors relating to the equipment or facilities involved, the process applied, or other such factors related to such discharger are fundamentally different from the factors considered in the establishment of the guidelines. On the basis of such evidence or other available information, the Regional Administrator (or the State) will make a written finding that such factors are or are not fundamentally different for that facility compared to those specified in the Development Document. If such fundamentally different factors are found to exist, the Regional Administrator or the State shall establish for the discharger effluent limitations in the NPDES Permit either more or less stringent than the limitations established herein, to the extent dictated by such fundamentally different factors. Such limitations must be approved by the Administrator of the Environmental Protection Agency. The Administrator may approve or disapprove such limitations, specify other limitations, or initiate proceedings to revise these regulations. The phrase "other such factors" appearing above may include significant cost differentials. In no event may a discharger's impact on receiving water quality be considered as a factor under this paragraph.

(b) Any existing point source subject to this subpart must achieve the following effluent limitations representing the degree of effluent reduction by the application of the best practicable control technology currently available (BPT):

(11) The quantity of pollutants discharged in FGD wastewater, flue gas mercury control wastewater, combustion residual leachate, or gasification wastewater shall not exceed the quantity determined by multiplying the flow of the applicable wastewater times the concentration listed in the following table:

| Pollutant or pollutant property | BPT Effluent limitations | |
|---------------------------------|------------------------------|---|
| | Maximum for any 1 day (mg/l) | Average of daily values for 30 consecutive days shall not exceed (mg/l) |
| TSS | 100.0 | 30.0 |
| Oil and grease | 20.0 | 15.0 |

(12) At the permitting authority's discretion, the quantity of pollutant allowed to be discharged may be expressed as a concentration limitation instead of the mass-based limitations specified in paragraphs (b)(3) through (b)(7), and (b)(11), of this section. Concentration limitations shall be those concentrations specified in this section.