



Application Type  
Facility Type  
Major / Minor

Renewal  
Municipal  
Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. **PA0255726**  
APS ID **1134937**  
Authorization ID **1522834**

**Applicant and Facility Information**

Applicant Name	<b>Mt Pleasant Township Municipal Authority Washington County</b>	Facility Name	<b>MPTMA WWTP Washington County</b>
Applicant Address	PO Box 411	Facility Address	Sabo Road
	Hickory, PA 15340-0411		Mt Pleasant, PA 15340
Applicant Contact	Gary Farmer	Facility Contact	
Applicant Phone	(724) 356-7974	Facility Phone	
Client ID	357116	Site ID	843617
Ch 94 Load Status	Not Overloaded	Municipality	Mount Pleasant Township
Connection Status	No Limitations	County	Washington
Date Application Received	<u>April 2, 2025</u>	EPA Waived?	Yes
Date Application Accepted		If No, Reason	
Purpose of Application	<u>Renewal</u>		

**Summary of Review**

The permittee is proposing to renew NPDES Permit PA0255726 which is set to expire on 10/31/2025. The facility has not yet been constructed.

The treated effluent will discharge into Westland Run to Chartiers Creek, which is classified as a Warm Water Fishery (WWF) located in State Watershed No. 20-F.

WQM Permit No.6320401 is for the proposed sewage treatment plant rated at annual average design flow of 0.175 MGD, peak instantaneous capacity of 0.875 MGD, and organic design capacity of 349.4 lbs./day. The treatment process consists of two SBRs and UV disinfection. The sewage sludge will be treated with aerobic digestion and mechanical dewatering and then be hauled to the Arden Landfill.



WQM No.6320402 approved a sewer collection system, four pump stations, force mains, gravity sewer lines, and one grinder pump.

Act 14 Notifications were provided on March 24, 2025.

The permittee has no open violations by Client ID.

**Public Participation**

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*,

Approve	Return	Deny	Signatures	Date
x			 Sam Mahsoob, EIT / Environmental Engineering Trainee	6/25/2025
x			 Mahbuba Iasmin, Ph.D., P.E. / Environmental Engineer Manager	6/30/2025

### Summary of Review

DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	.175
Latitude	40° 16' 45"	Longitude	-80° 16' 39.84"
Quad Name	Midway	Quad ID	40080C3
Wastewater Description: Sewage Effluent			
Receiving Waters	Westland Run (WWF)	Stream Code	37052
NHD Com ID	99692734	RMI	0.5100
Drainage Area	3.2	Yield (cfs/mi <sup>2</sup> )	.01075
Q <sub>7-10</sub> Flow (cfs)	.0344	Q <sub>7-10</sub> Basis	USGS StreamStats
Elevation (ft)	1034.4	Slope (ft/ft)	.0007
Watershed No.	20-F	Chapter 93 Class.	WWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Impaired		
Cause(s) of Impairment	Aluminum, Iron, Manganese, PCBs, Chlordane, Pesticides, Organics		
Source(s) of Impairment	Acid Mine Drainage and Non-point sources		
TMDL Status	Final	Name	Chartiers Creek, Chartiers Creek Watershed
Background/Ambient Data	Data Source		
pH (SU)			
Temperature (°F)			
Hardness (mg/L)			
Other:			
Nearest Downstream Public Water Supply Intake	West View Water Authority PWS ID: 5020043		
PWS Waters	Ohio River	Flow at Intake (cfs)	4730
PWS RMI	35.3	Distance from Outfall (mi)	40.2

Other Comments:

The discharge is to Chartiers Creek, which has a Final TMDL and is impaired by PCB and Chlordane. Chartiers Creek is part of the Chartiers Creek Watershed that has a Final TMDL and is impaired by metals. This sewage discharge is not expected to contribute to the stream impairment for which abandoned mine drainage is a source of such impairment. 1/year monitoring frequency for Total Iron, Total Manganese and Total Aluminum will be carried over from the previous permit.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Mt Pleasant Municipal Authority WWTP				
<b>WQM Permit No.</b>	<b>Issuance Date</b>			
6320402	3/4/2021			
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary With Ammonia Reduction	Sequencing Batch Reactor	Ultraviolet	0.175
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.175	349.4	Not Overloaded	Aerobic Digestion	Landfill

**Development of Effluent Limitations**

**Outfall No.** 001  
**Latitude** 40° 16' 45.00"  
**Wastewater Description:** Sewage Effluent

**Design Flow (MGD)** .175  
**Longitude** -80° 16' 40.00"

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/L)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Total Nitrogen	Report	Average Monthly	-	92a.61(7)
Total Phosphorus	Report	Average Monthly	-	92a.61(8)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
E. Coli (No./100 ml)	-	Report		93a.61(11)(12)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
Total Residual Chlorine	1.6	IMAX	-	92a.47-48(3)(4)
Ammonia-Nitrogen	25	Average Monthly	-	BPJ (5)
Ammonia-Nitrogen	50	IMAX	-	BPJ (5)
Dissolved Oxygen	4.0	IMIN	-	BPJ (6)

**Water Quality-Based Limitations**

The following limitations were determined through water quality modeling (See Attachments 3&4):

Parameter	Limit (mg/l)	SBC	Model
Ammonia-Nitrogen (5/1 – 9/30)	4.14	Average Monthly	WQM 7.0
	8.28	IMAX	WQM 7.0
Ammonia-Nitrogen (10/1 – 4/30)	2.11	Average Monthly	WQM 7.0
	4.22	IMAX	WQM 7.0
Dissolved Oxygen (5/1 – 9/30)	6	IMIN	WQM 7.0
Dissolved Oxygen (10/1 – 4/30)	5	IMIN	WQM 7.0
CBOD5 (5/1 – 9/30)	23.23	Average Monthly	WQM 7.0
CBOD5 (10/1 – 4/30)	25	Average Monthly	WQM 7.0

Comments: The limits for Ammonia-Nitrogen will be carried over from the previous permit. WQM 7.0 recommended stricter limits for Dissolved Oxygen and CBOD5 in the summer.

### Additional Considerations

#### Ultraviolet Disinfection

Ultraviolet (UV) disinfection is approved therefore Total Residual Chlorine (TRC) limits are not applicable. Routine monitoring of UV intensity is applied at the same monitoring frequency that is used for TRC.

(Section I.A, Note 4, SOP for Clean Water Program, Establishing Effluent Limitations for Individual Sewage Permits, Final November 9, 2012, Revised March 24, 2021, Version 1.9 and 25 PA Code 92a.61(b).)

#### E. Coli

Sewage discharges will include monitoring, at a minimum, for E. Coli, in new and reissued permits, with a monitoring frequency of 1/month for design flows  $\geq 1$  MGD, 1/quarter for design flows  $\geq 0.05$  and  $< 1$  MGD, 1/year for design flows of 0.002 – 0.05 MGD.

(Note 12 SOP-Establishing Effluent Limitations for Individual Sewage Permits Final November 9, 2012, Revised February 5, 2024, Version 2.0. and 25 PA Code 92a.61(b).)

#### Effluent Multipliers

Section 2.C of the Permit Writers Manual contains the procedure for converting average monthly effluent limitations to average weekly, maximum daily, and instantaneous maximum effluent limitations. The average monthly limit is multiplied according to the following chart:

Discharge Solution	Parameters	Average Weekly	Maximum Daily	Instantaneous Maximum Multiplier
Sewage	All	1.5		2.0
Industrial	All		2.0	2.5*

(Department Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits, Updated June 28, 2023 (Document No. 362-0400-001))

#### Influent Monitoring

For POTWs with design flows greater than 2,000 GPD, influent BOD5 and TSS monitoring must be established in the permit, and the monitoring should be consistent with the same frequency and sample type as is used for other effluent parameters. BOD5 and TSS influent loads will once again be reported for monthly average and daily maximum values in lbs/day and monthly average concentrations in mg/L.

(Section IV.E.8. SOP – New and Reissuance Individual Sewage NPDES Permits Final November 9, 2012, Revised February 3, 2022, Version 2.0.)

#### Rounding Off

Section 5 C.2. of the Permit Writers Manual contains general guidelines for rounding conventional and toxic pollutants, with instructions to round down to the nearest decimal place indicated.

General Magnitude	Conventional Pollutants	Toxic Pollutants
<0.01	to nearest 0.001	to nearest 0.001
0.01 - 0.1	to nearest 0.01	to nearest 0.01
0.1 - 1.0	to nearest 0.1	to nearest 0.01
1.0 - 10.0	to nearest 0.5	to nearest 0.01
10.0 - 60.0	to nearest 1.0	to nearest 0.01
60.0 or greater	to nearest 5.0	to nearest 0.10

(Department Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits, Updated June 28, 2023 (Document No. 362-0400-001))

**Table 5-3: Methods of Expressing Effluent Limits for Sewage Discharges**

Discharge Situation	Mass Loadings (lbs/day)			Concentrations (mg/L)				Limit On Flow <sup>6</sup>
	Average Monthly	Average Weekly <sup>3</sup>	Maximum Daily	Average Monthly	Average Weekly	Maximum Daily	Instant Maximum <sup>4</sup>	
<b>A. POTW DISCHARGES:</b>								
1. Technology Based concentration limits	x	x <sup>3</sup>		x	x <sup>3</sup>		x	Yes
2. Water Quality Based limits	x	x <sup>3</sup>		x	x <sup>3</sup>		x	Yes
3. Water Quality Based limits (Toxics)	x		x	x		x		
<b>B. NON-POTW DISCHARGES:</b>								
1. Technology Based concentration limits	x <sup>5</sup>			x		x		Yes
2. Water Quality based limits	x <sup>5</sup>			x		x		Yes

1. This table is for all pollutants, conventional, non-conventional, toxic and all other pollutants that may be regulated by the permit. (Also refer to the toxics management strategy when specifying toxic WQBELs.)
2. X indicates need for an effluent limitation.
3. Only CBOD and TSS limitation.
4. Only include Instantaneous maximum limitations on the DMR forms if grab a sample is specified in the permit, otherwise do not include instantaneous maximum limitations on the DMR.

Also, the permit page could include the following language for when composite samples are required  
"Instantaneous maximum limitations are imposed to allow for a grab sample to be collected by the appropriate regulatory agency to determine compliance. The permittee does not have to monitor for the instantaneous maximum limitations, however, if grab samples are collected by the permittee, the results must be reported."

5. This is for all sewage permits with design flow greater than 100,000 gpd since 25 Pa. Code § 94.13 requires flow monitoring.
6. The maximum monthly average flow limitation is the permitted flow that is to be placed in the NPDES permit. Generally, the annual average flow (AAF) is to be used for water quality modeling and to be used to determine the allowable mass loading in NPDES permits (i.e., AAF x 8.34 x mg/l = #/day) (Refer to the Domestic Wastewater Facilities Manual).

**Anti-Backsliding**

Section 402(o) of the Clean Water Act (CWA), enacted in the Water Quality Act of 1987, establishes anti-backsliding rules governing two situations. The first situation occurs when a permittee seeks to revise a Technology-Based effluent limitation based on BPJ to reflect a subsequently promulgated effluent guideline which is less stringent. The second situation addressed by Section 402(o) arises when a permittee seeks relaxation of an effluent limitation which is based upon a State treatment standard of water quality standard.

Previous limits can be used pursuant to EPA's anti-backsliding regulation. Reissued permits. (1) Except as provided in paragraph (l)(2) of this section when a permit is renewed or reissued. Interim effluent limitations, standards or conditions must be at least as stringent as the final effluent limitations, standards, or conditions in the previous permit (unless the circumstances on which the previous permit was based have materially and substantially changed since the time the permit was issued and would constitute cause for permit modification or revocation and reissuance under §122.62). (2) In the case of effluent limitations established on the basis of Section 402(a)(1)(B) of the CWA, a permit may not be renewed, reissued, or modified on the basis of effluent guidelines promulgated under section 304(b) subsequent to the original issuance of such permit, to contain effluent limitations which are less stringent than the comparable effluent limitations in the previous permit.

*(40 CFR 122.44 (l)(2) Establishing limitations, standards, and other permit conditions., 40 CFR Ch. I (7-1-21 Edition))*

No permits limits have been made less stringent in the renewal draft permit.

Table 6-3 – Self-Monitoring Requirements for SEWAGE Discharges

Plant Design Flow (MGD)	Flow Monitoring	C-BOD <sub>5</sub> or BOD <sub>5</sub>	Suspended Solids	pH	Fecal Coliform	Chlorine Residual	NH <sub>3</sub> -N	Phosphorus	DO	Toxics
Single Residence (Individual Permit)	2/year by estimate	2/year*	2/year*	1/month*	2/year*	1/month*	2/year*	2/year*	2/year*	N/A
.0005 to .002	weekly, using average pump rate or weir (a)	1/month*	1/month*	daily*	1/month*	daily*	1/month*	1/month*	daily*	N/A
.002 to .01	weekly, using average pump rate or weir (a)	2/month*	2/month*	daily*	2/month*	daily*	2/month*	2/month*	daily*	N/A
0.01 to 0.1	weekly, using average pump rate or weir (a)	2/month*	2/month*	daily*	2/month*	daily*	2/month*	2/month*	Daily*	1/week*
<b>0.1 to 1.0</b>	<b>meter</b>	<b>1/week**</b>	<b>1/week**</b>	<b>daily*</b>	<b>1/week*</b>	<b>daily*</b>	<b>1/week**</b>	<b>1/week**</b>	<b>daily*</b>	<b>1/week****</b>
1.0 to 5.0	meter	2/week***	2/week***	daily*	2/week*	daily*	2/week***	2/week***	daily*	1/week****
5.0 to 25.0	meter	daily***	daily***	daily*	daily*	1/shift*	daily***	daily***	daily*	1/week****
over 25.0	meter	daily***	daily***	1/shift*	daily*	1/shift*	1/shift***	1/shift***	1/shift*	1/week****

\* Grab sample-these should be most representative of the effluent and are to be taken at a time when the normal daily maximum flow would reach the sampling point.

\*\* 8-hour composite sample.

\*\*\* 24-hour composite sample.

\*\*\*\* Same sample type as for Industrial Process Wastewater (See Table 6-4).

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Instantaneous Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Metered
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
DO Nov 1 - Apr 30	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
DO May 1 - Oct 31	XXX	XXX	6.0	XXX	XXX	XXX	1/day	Grab
CBOD5 Nov 1 - Apr 30	36.0	58.0	XXX	25.0	40.0	50	1/week	8-Hr Composite
CBOD5 May 1 - Oct 31	33.74	50.62	XXX	23.43	35.15	46.86	1/week	8-Hr Composite
BOD5 Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	8-Hr Composite
TSS	43.0	65.0	XXX	30.0	45.0	60	1/week	8-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab

Outfall 001, Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Instantaneous Minimum	Average Monthly	Weekly Average	Instant. Maximum		
UV Transmittance (%)	XXX	XXX	Report	XXX	XXX	XXX	1/day	Measured
Total Nitrogen	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	8-Hr Composite
Ammonia-Nitrogen Nov 1 - Apr 30	5.0	XXX	XXX	3.5	XXX	7	1/week	8-Hr Composite
Ammonia-Nitrogen May 1 - Oct 31	2.0	XXX	XXX	1.5	XXX	3	1/week	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	8-Hr Composite
Total Aluminum	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	8-Hr Composite
Total Iron	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	8-Hr Composite
Total Manganese	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	8-Hr Composite

Compliance Sampling Location: Outfall 001

<b>Tools and References Used to Develop Permit</b>	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachments 3&4)
<input checked="" type="checkbox"/>	SOP: Individual Sewage
<input checked="" type="checkbox"/>	Other: USGS StreamStats (see Attachments 1&2)

Attachment 1 – USGS StreamStats Upstream

13



Attachment 2 – USGS Streamstats Downstream

1



Attachment 3 – WQM 7.0 Model Summer

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name		RMI	Elevation	Drainage Area	Slope	PWS Withdrawal	Apply FC		
					(ft)	(sq mi)	(ft/ft)	(mgd)			
20F		37052 Trib 37052 to Charters Run		1.170	1033.00	3.43	0.00000	0.00	<input checked="" type="checkbox"/>		
<b>Stream Data</b>											
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio (ft)	Rch Width (ft)	Tributary Temp (°C)	Stream pH (°C)		
Q7-10	0.011	0.00	0.00	0.000	0.000	0.0	0.00	25.00	7.00		
Q1-10		0.00	0.00	0.000	0.000						
Q30-10		0.00	0.00	0.000	0.000						
<b>Discharge Data</b>											
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH				
		0.0000	0.0000	0.0000	0.000	25.00	7.00				
<b>Parameter Data</b>											
Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)						
CBOD5		25.00	2.00	0.00	1.50						
Dissolved Oxygen		3.00	8.24	0.00	0.00						
NH3-N		25.00	0.00	0.00	0.70						

**Input Data WQM 7.0**

Design Cond.	SWP Basin	Stream Code	Stream Name			RMI	Elevation	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC				
	20F	37052	Trib 37052 to Chartiers Run			1.550	1034.40	3.20	0.00000	0.00	<input checked="" type="checkbox"/>				
<b>Stream Data</b>															
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	pH	Stream Temp (°C)	Stream pH			
Q7-10	0.011	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00			
Q1-10		0.00	0.00	0.000	0.000										
Q30-10		0.00	0.00	0.000	0.000										
<b>Discharge Data</b>															
Name		Permit Number		Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor		Disc Temp (°C)	Disc pH					
Outfall 001		PA0255726		0.1750	0.1750	0.1750	0.000		20.00	7.00					
<b>Parameter Data</b>															
Parameter Name				Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)								
CBOD5				25.00	2.00	0.00	1.50								
Dissolved Oxygen				4.00	8.38	0.00	0.00								
NH3-N				25.00	0.00	0.00	0.70								











Attachment 4 – WQM 7.0 Model Winter

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC			
20F		37052	Trib 37052 to Chartiers Run		1.550	1034.40	3.20	0.00000	0.00	<input checked="" type="checkbox"/>			
<b>Stream Data</b>													
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream pH (°C)			
Q7-10	0.022	0.00	0.00	0.000	0.000	0.0	0.00	0.00	5.00	7.00			
Q1-10		0.00	0.00	0.000	0.000								
Q30-10		0.00	0.00	0.000	0.000								
<b>Discharge Data</b>													
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH						
Outfall 001	PA0255726	0.1750	0.1750	0.1750	0.000	15.00	7.00						
<b>Parameter Data</b>													
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)									
CBOD5	25.00	2.00	0.00	1.50									
Dissolved Oxygen	4.00	12.80	0.00	0.00									
NH3-N	25.00	0.00	0.00	0.70									

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name		RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC		
20F	37052	37052 to Chartiers Run		1.170	1033.00	3.43	0.00000	0.00	<input checked="" type="checkbox"/>		
<b>Stream Data</b>											
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio (ft)	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)	Stream pH
Q7-10	0.022	0.00	0.00	0.000	0.000	0.0	0.00	0.00	5.00	7.00	0.00
Q1-10		0.00	0.00	0.000	0.000						
Q30-10		0.00	0.00	0.000	0.000						
<b>Discharge Data</b>											
		Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH		
				0.0000	0.0000	0.0000	0.000	25.00	7.00		
<b>Parameter Data</b>											
				Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)				
				CBOD5	25.00	2.00	0.00	1.50			
				Dissolved Oxygen	3.00	8.24	0.00	0.00			
				NH3-N	25.00	0.00	0.00	0.70			









