

Application Type New
Facility Type Industrial
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL INDUSTRIAL WASTE (IW)
AND IW STORMWATER**

Application No. PA0256081
APS ID 1052606
Authorization ID 1377867

Applicant and Facility Information

Applicant Name	<u>Northern Cambria Municipal Authority</u>	Facility Name	<u>Miller Hollow Water Treatment Facility</u>
Applicant Address	<u>1202 Philadelphia Avenue</u> <u>Northern Cambria, PA 15714-1385</u>	Facility Address	<u>Old Miller Road</u> <u>Northern Cambria, PA 15714</u>
Applicant Contact	<u>Paul Weaver</u>	Facility Contact	<u>Ron Depto</u>
Applicant Phone	<u>(814) 948-5791</u>	Facility Phone	<u>(814) 948-5791</u>
Client ID	<u>213850</u>	Site ID	<u>848623</u>
SIC Code	<u>4941</u>	Municipality	<u>Susquehanna Township</u>
SIC Description	<u>Trans. & Utilities – Water Supply</u>	County	<u>Cambria</u>
Date Application Received	<u>November 24, 2021</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>December 10, 2021</u>	If No, Reason	<u></u>
Purpose of Application	<u>New NPDES permit for the new discharge of process wastewater from the water treatment plant.</u>		

Summary of Review



Background

The Department received a new NPDES permit application from Northern Cambria Borough Municipal Authority on November 24, 2021 for coverage of the new discharge from its Miller Hollow Water Treatment Facility in Susquehanna Township of Cambria County. The facility is a new municipal water treatment plant with an SIC Code 4941 (Water Supply).

The Miller Hollow Water Treatment Facility (WTP) was issued a PAG-02 NPDES Permit to cover the discharges of stormwater associated with construction activities on July 12, 2021. Construction of the facility is anticipated to start in May of 2022. The facility is also covered under Chapter 105 GP-4 and GP-5 Permits and a Public Water Supply Construction Permit.

Property and Operations

Miller Hollow WTP operates as a new municipal water treatment plant that treats raw water from the existing Miller Hollow Mine Source through membrane filtration. Construction of the Miller Hollow WTP is in response to a Consent Order and Agreement for violations of the Pennsylvania Safe Drinking Water Act and regulations from the Safe Drinking Water Program. Construction of the facility is anticipated to be complete by the end date of the Consent Order in July of 2024. Construction of the Miller Hollow WTP involved an earth disturbance of 5.13 acres and construction/ modification of a water treatment plant, source, pump stations, transmission main and storage facility. The Miller Hollow WTP will supply drinking water to serve 4813 people through 2270 connections.

Approve	Deny	Signatures	Date
X		 Lauren Nolfi, E.I.T. / Environmental Engineering Specialist	March 11, 2022
X		 Michael E. Fifth, P.E. / Environmental Engineer Manager	March 11, 2022

Summary of Review

The Miller Hollow WTP is a membrane filtration plant and utilizes microfiltration and reverse osmosis technologies in its water treatment system. The treatment system includes two microfiltration units, a 5000-gallon equalization tank, a 5000-gallon microfiltration break (filtrate) tank, two reverse osmosis (RO) units, a neutralization tank, and a backwash equalization tank. Chemical treatment includes orthophosphate for corrosion inhibition, sodium bisulphite for chlorine removal, anti-scalent to prevent RO membrane scaling and fouling, citric acid softener, sodium hypochlorite for disinfection, and sodium hydroxide to control acidity and remove metals. Flux maintenance is performed at scheduled intervals to loosen and remove foulant from the membrane fibers. Finished water is used in the flush and backwash water that is discharged to a 1350-gallon backwash equalization tank.

Outfalls

The facility has one outfall, Outfall 001, which discharges to the Unnamed Tributary to Walnut Run, designated in 25 PA Code Chapter 93 as a Cold Water Fishery (WWF) and Migratory Fishery (MF). Outfall 001 discharges filter backwash water from the equalization tank at a design, average and maximum flow of 0.02 MGD. Outfall 001 will not begin discharging until construction of the facility is complete.

Public Participation

Northern Cambria Municipal Authority provided evidence of Act 14 municipal and county notifications to Susquehanna Township and Cambria County on October 8, 2021.

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Conclusion

Draft permit issuance is recommended.

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.02</u>
Latitude	<u>40° 39' 57.89"</u>	Longitude	<u>-78° 45' 53.33"</u>
Quad Name	<u>Barnesboro</u>	Quad Code	<u>1315</u>
Wastewater Description: <u>Filter backwash water from equalization tank.</u>			
Receiving Waters	<u>Unnamed Tributary to Walnut Run (CWF, MF)</u>	Stream Code	<u>27255</u>
NHD Com ID	<u>61837293</u>	RMI	<u>0.36</u>
Drainage Area	<u>2.08 mi²</u>	Yield (cfs/mi ²)	<u>0.0468</u>
Q ₇₋₁₀ Flow (cfs)	<u>0.0974</u>	Q ₇₋₁₀ Basis	<u>USGS StreamStats</u>
Elevation (ft)	<u>1506</u>	Slope (ft/ft)	<u>0.012</u>
Watershed No.	<u>8-B</u>	Chapter 93 Class.	<u>CWF, MF</u>
Existing Use	<u></u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u>N/A</u>	Exceptions to Criteria	<u>N/A</u>
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>Habitat Alterations, Siltation</u>		
Source(s) of Impairment	<u>Channelization, Erosion from derelict land (barren land)</u>		
TMDL Status	<u>N/A</u>	Name	<u>N/A</u>
Nearest Downstream Public Water Supply Intake	<u>Indiana County Municipal Services Authority (ICMSA) Cherrytree</u>		
PWS Waters	<u>West Branch Susquehanna River</u>	Flow at Intake (cfs)	<u>0</u>
PWS RMI	<u>231</u>	Distance from Outfall (mi)	<u>6</u>

Other Comments:

Miller Hollow WTP has not been inspected since it is a proposed facility. The Miller Hollow Mine Source has a Consent Order and Agreement for violations of the Pennsylvania Safe Drinking Water Act and regulations from the Safe Drinking Water Program.

The client has no open violations.

The USGS Stream Stats Data for the drainage area is displayed in Attachment A.

Development of Effluent Limitations

Outfall No. 001 **Design Flow (MGD)** 0.02
Latitude 40° 39' 57.89" **Longitude** -78° 45' 53.33"
Wastewater Description: Filter backwash water from equalization tank.

Technology-Based Limitations (TBELs)

Miller Hollow Water WTP is not subject to Federal Effluent Limitation Guidelines (ELGs) as the SIC code is not listed under 40 CFR parts 405 through 471.

Regulatory Effluent Standards and Monitoring Requirements

Flow monitoring is required pursuant to 25 Pa. Code § 92a.61(d)(1) as indicated in Table 1.

Effluent standards for pH pursuant to 25 Pa. Code § 92a.48(a)(2) and 25 Pa. Code § 95.2(1), as indicated in Table 1, are also imposed on all industrial wastes.

Pennsylvania regulations at 25 Pa. Code § 92a.48(b) require the imposition of technology-based TRC limits for facilities that use chlorination and that are not already subject to TRC limits based on applicable federal ELGs or a facility-specific BPJ evaluation as indicated in Table 1.

Table 1: Regulatory Effluent Standards			
Parameter	Monthly Average	Daily Maximum	IMAX
Flow (MGD)	Monitor	Monitor	----
pH (S.U.)	Not less than 6.0 nor greater than 9.0 at all times		----
Total Residual Chlorine	0.5 mg/l	1.0 mg/l	1.6 mg/l

Best Practicable Control Technology Currently Achievable (BPT)

BPT for wastewater from treatment of water treatment plant (WTP) sludges and filter backwash is found in DEPs Technology-Based Control Requirements for Water Treatment Plant Wastes Document which recommends effluent limitations be imposed under Best Professional Judgement in accordance with 40 CFR § 125.3, and detailed in Table 2.

Table 2: BPT Limits for WTP sludge and filter backwash wastewater		
Parameter	Monthly Average (mg/L)	Daily Maximum (mg/L)
Total Suspended solids	30.0	60.0
Total Iron	2.0	4.0
Total Aluminum	4.0	8.0
Total Manganese	1.0	2.0
Flow (MGD)	Monitor and Report	
pH (S.U.)	Not less than 6.0 nor greater than 9.0 at all times	
Total Residual Chlorine	0.5 mg/l	1.0 mg/l

Water Quality-Based Effluent Limitations (WQBELs)

Toxics Management Analysis

The Department's Toxics Management Spreadsheet (TMS) was utilized to facilitate calculations necessary for completing a reasonable potential analysis and determine Water Quality-Based Effluent Limitations (WQBELs) for discharges containing toxic pollutant concentrations. TMS combines the functionality of two (2) of the Department's analysis tools, Toxics Screening Analysis Spreadsheet and PENTOXSD water quality model.

DEP's procedures for evaluating reasonable potential are as follows:

1. For IW discharges, the design flow to use in modeling is the average flow during production or operation and may be taken from the permit application.
2. Perform a Toxics Screening Analysis to identify toxic pollutants of concern. All toxic pollutants, as reported in the permit application or on DMRs, are modeled by the TMS to determine the parameters of concern. [This includes pollutants reported as "Not Detectable" or as "<MDL" where the method detection limit for the analytical method used by the applicant is greater than the most stringent water quality criterion].
 - Establish limits in the draft permit where the maximum reported concentration equals or exceeds 50% of the WQBEL. Use the average monthly and maximum daily limits for the permit as recommended by TMS. Establish an IMAX limit at 2.5 times the average monthly limit.
 - For non-conservative pollutants, establish monitoring requirements where the maximum reported concentration is between 25% - 50% of the WQBEL.
 - For conservative pollutants, establish monitoring requirements where the maximum reported concentration is between 10% - 50% of the WQBEL.

Discharges from Outfall 001 are evaluated based on concentrations reported on the application and contained in the DMRs; data from those sources are used as inputs into the TMS. A summary of TMS Inputs is contained in Tables 3 and 4 below.

Parameter	Value
Design Flow (MGD)	0.2
Hardness (mg/L)	575
pH (S.U.)	7.79
Partial Mix Factors (PMFs)	
AFC	calc.
CFC	calc.
THH	calc.
CRL	calc.
Complete Mix Times	
Q ₇₋₁₀ (min)	calc.
Q _h (min)	calc.

Parameter	Value
Stream Code	27255
RMI	0.36
Elevation	1506
Drainage Area (mi ²)	2.08
Slope (ft/ft)	0.12
PWS Withdrawal (MGD)	
Apply Fish Criteria	Yes
Low Flow Yield (cfs/mi ²)	0.0468
Stream Flow (cfs)	0.0974
Tributary Flow (cfs)	N/A
Width (ft)	
Stream Hardness (mg/L)	100
Stream pH (S.U.)	7

Based on the recommendations of the TMS, no WQBELs are recommended at Outfall 001. Analysis Report from the TMS run is included in Attachment B.

Total Residual Chlorine

To determine if WQBELs are required for discharges containing total residual chlorine (TRC), a discharge evaluation is performed using a DEP program called TRC_CALC created with Microsoft Excel for Windows. TRC_CALC calculates TRC Waste Load Allocations (WLAs) through the application of a mass balance model which considers TRC losses due to stream and discharge chlorine demands and first-order chlorine decay. Input values for the program include flow rates and discharge chlorine demands for the receiving stream, the number of samples taken per month, coefficients of TRC variability, partial mix factors, and an optional factor of safety. The mass balance model calculates WLAs for acute and chronic criteria that are then converted to long term averages using calculated multipliers. The multipliers are functions of the number of samples taken per month and the TRC variability coefficients (normally kept at default values unless site specific information is available). The most stringent limitation between the acute and chronic long-term averages is converted to an average monthly limit for comparison to the BAT average monthly limit of 0.5 mg/L from 25 Pa. Code § 92a.48(b)(2). The more stringent of these average monthly TRC limitations is then proposed. The results of the modeling, included in Attachment C, identify that BAT is the most stringent criteria for TRC at an average monthly limit of 0.5 mg/L. The maximum daily limit is 2 times the average monthly limit resulting in a 1.0 mg/L limit for maximum daily.

Anti-Backsliding

Miller Hollow WTP was not previously covered under an NPDES permit since the facility is a new discharge.

Effluent Limitations and Monitoring Requirements

Effluent limitations and monitoring requirements applicable at Outfall 001 are the most stringent of TBELs, WQBELs, and regulatory effluent standards and monitoring requirements, as summarized below in Table 5. The applicable limits and monitoring requirements provided below are based on those in Tables 1-4 of this Fact Sheet.

Table 5: Effluent Limits and Monitoring Requirements – Outfall 001						
Parameter	Mass		Concentration		Monitoring Requirements	
	Average Monthly	Daily Maximum	Average Monthly (mg/L)	Daily Maximum (mg/L)	Monitoring Frequency	Sample Type
Flow (MGD)	Monitor & Report				2/ month	Measured
Total Residual Chlorine	-	-	0.5	1.0	2/ month	Grab
Total Suspended Solids	-	-	30.0	60.0	2/ month	Grab
Aluminum, total	-	-	4.0	8.0	2/ month	Grab
Iron, total	-	-	2.0	4.0	2/ month	Grab
Manganese, total	-	-	1.0	2.0	2/ month	Grab
pH (S.U.)	-	-	Not less than 6.0 nor greater than		2/ month	Grab

Tools and References Used to Develop Permit	
<input type="checkbox"/>	WQM for Windows Model (see Attachment [redacted])
<input checked="" type="checkbox"/>	Toxics Management Spreadsheet (see Attachment B)
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment C)
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input checked="" type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [redacted]
<input type="checkbox"/>	Other: [redacted]

Attachments

Attachment A: USGS StreamStats Report

Attachment B: Toxics Management Spreadsheet Model Output

Attachment C: TRC Modeling Results

ATTACHMENT A:
USGS StreamStats Report


StreamStats Report

Region ID: PA

Workspace ID: PA20220223191743688000

Clicked Point (Latitude, Longitude): 40.66602, -78.76470

Time: 2022-02-23 14:18:12 -0500



Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	2.08	square miles

Parameter Code	Parameter Description	Value	Unit
ELEV	Mean Basin Elevation	1818	feet
PRECIP	Mean Annual Precipitation	43	inches

Low-Flow Statistics Parameters [Low Flow Region 3]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	2.08	square miles	2.33	1720
ELEV	Mean Basin Elevation	1818	feet	898	2700
PRECIP	Mean Annual Precipitation	43	inches	38.7	47.9

Low-Flow Statistics Disclaimers [Low Flow Region 3]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors

Low-Flow Statistics Flow Report [Low Flow Region 3]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.239	ft ³ /s
30 Day 2 Year Low Flow	0.346	ft ³ /s
7 Day 10 Year Low Flow	0.0974	ft ³ /s
30 Day 10 Year Low Flow	0.137	ft ³ /s
90 Day 10 Year Low Flow	0.205	ft ³ /s

Low-Flow Statistics Citations

**Stuckey, M.H.,2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p.
(<http://pubs.usgs.gov/sir/2006/5130/>)**

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.7.0

StreamStats Services Version: 1.2.22

NSS Services Version: 2.1.2

ATTACHMENT B:
Toxics Management Spreadsheet Model Output



Discharge Information

Instructions **Discharge** Stream

Facility: Miller Hollow Water Treatment Plant NPDES Permit No.: PA0256081 Outfall No.: 001

Evaluation Type: Major Sewage / Industrial Waste Wastewater Description: Filter backwash water

Discharge Characteristics								
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)				Complete Mix Times (min)	
			AFC	CFC	THH	CRL	Q ₇₋₁₀	Q _h
0.2	575	7.79						

Discharge Pollutant	Units	Max Discharge Conc	0 if left blank		0.5 if left blank		0 if left blank		1 if left blank		
			Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteria Mod	Chem Transl
Group 1	Total Dissolved Solids (PWS)	mg/L	676								
	Chloride (PWS)	mg/L	17.8								
	Bromide	mg/L	0.4								
	Sulfate (PWS)	mg/L	312								
	Fluoride (PWS)	mg/L	2								
Group 2	Total Aluminum	µg/L	0.0467								
	Total Antimony	µg/L	0.001								
	Total Arsenic	µg/L	0.0015								
	Total Barium	µg/L	0.0213								
	Total Beryllium	µg/L	0.0005								
	Total Boron	µg/L	0.0682								
	Total Cadmium	µg/L	0.0005								
	Total Chromium (III)	µg/L	0.00199								
	Hexavalent Chromium	µg/L	0.00025								
	Total Cobalt	µg/L	0.0004								
	Total Copper	µg/L	0.0025								
	Free Cyanide	µg/L									
	Total Cyanide	µg/L	0.01								
	Dissolved Iron	µg/L	0.02								
	Total Iron	µg/L	1.1								
	Total Lead	µg/L	0.0002								
	Total Manganese	µg/L	0.0097								
	Total Mercury	µg/L	0.0002								
	Total Nickel	µg/L	0.006								
	Total Phenols (Phenolics) (PWS)	µg/L	0.005								
	Total Selenium	µg/L	0.0125								
	Total Silver	µg/L	0.000274								
	Total Thallium	µg/L	0.0001								
Total Zinc	µg/L	0.0123									
Total Molybdenum	µg/L	0.0001									
Acrolein	µg/L	<									
Acrylamide	µg/L	<									
Acrylonitrile	µg/L	<									
Benzene	µg/L	<									
Bromoform	µg/L	<									

Group 3	Carbon Tetrachloride	µg/L	<																		
	Chlorobenzene	µg/L	<																		
	Chlorodibromomethane	µg/L	<																		
	Chloroethane	µg/L	<																		
	2-Chloroethyl Vinyl Ether	µg/L	<																		
	Chloroform	µg/L	<																		
	Dichlorobromomethane	µg/L	<																		
	1,1-Dichloroethane	µg/L	<																		
	1,2-Dichloroethane	µg/L	<																		
	1,1-Dichloroethylene	µg/L	<																		
	1,2-Dichloropropane	µg/L	<																		
	1,3-Dichloropropylene	µg/L	<																		
	1,4-Dioxane	µg/L	<																		
	Ethylbenzene	µg/L	<																		
	Methyl Bromide	µg/L	<																		
	Methyl Chloride	µg/L	<																		
	Methylene Chloride	µg/L	<																		
	1,1,2,2-Tetrachloroethane	µg/L	<																		
	Tetrachloroethylene	µg/L	<																		
	Toluene	µg/L	<																		
1,2-trans-Dichloroethylene	µg/L	<																			
1,1,1-Trichloroethane	µg/L	<																			
1,1,2-Trichloroethane	µg/L	<																			
Trichloroethylene	µg/L	<																			
Vinyl Chloride	µg/L	<																			
Group 4	2-Chlorophenol	µg/L	<																		
	2,4-Dichlorophenol	µg/L	<																		
	2,4-Dimethylphenol	µg/L	<																		
	4,6-Dinitro-o-Cresol	µg/L	<																		
	2,4-Dinitrophenol	µg/L	<																		
	2-Nitrophenol	µg/L	<																		
	4-Nitrophenol	µg/L	<																		
	p-Chloro-m-Cresol	µg/L	<																		
	Pentachlorophenol	µg/L	<																		
	Phenol	µg/L	<																		
Group 5	2,4,6-Trichlorophenol	µg/L	<																		
	Acenaphthene	µg/L	<																		
	Acenaphthylene	µg/L	<																		
	Anthracene	µg/L	<																		
	Benzidine	µg/L	<																		
	Benzo(a)Anthracene	µg/L	<																		
	Benzo(a)Pyrene	µg/L	<																		
	3,4-Benzofluoranthene	µg/L	<																		
	Benzo(ghi)Perylene	µg/L	<																		
	Benzo(k)Fluoranthene	µg/L	<																		
	Bis(2-Chloroethoxy)Methane	µg/L	<																		
	Bis(2-Chloroethyl)Ether	µg/L	<																		
	Bis(2-Chloroisopropyl)Ether	µg/L	<																		
	Bis(2-Ethylhexyl)Phthalate	µg/L	<																		
	4-Bromophenyl Phenyl Ether	µg/L	<																		
	Butyl Benzyl Phthalate	µg/L	<																		
	2-Chloronaphthalene	µg/L	<																		
	4-Chlorophenyl Phenyl Ether	µg/L	<																		
	Chrysene	µg/L	<																		
	Dibenzo(a,h)Anthracene	µg/L	<																		
	1,2-Dichlorobenzene	µg/L	<																		
	1,3-Dichlorobenzene	µg/L	<																		
	1,4-Dichlorobenzene	µg/L	<																		
	3,3-Dichlorobenzidine	µg/L	<																		
	Diethyl Phthalate	µg/L	<																		
	Dimethyl Phthalate	µg/L	<																		
	Di-n-Butyl Phthalate	µg/L	<																		
	2,4-Dinitrotoluene	µg/L	<																		



Stream / Surface Water Information

Miller Hollow Water Treatment Plant, NPDES Permit No. PA0256081, Outfall 001

Instructions Discharge **Stream**

Receiving Surface Water Name: Unnamed Tributary to Walnut Run

No. Reaches to Model: 1

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi ²)*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	027255	0.36	1506	2	0.12		Yes
End of Reach 1	027255	0	1483	2.19			Yes

Q₇₋₁₀

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	0.36	0.0468	0.0974									100	7		
End of Reach 1	0	0.0466	0.102									100	7		

Q_h

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness	pH	Hardness	pH
Point of Discharge	0.36														
End of Reach 1	0														



Model Results

Miller Hollow Water Treatment Plant, NPDES Permit No. PA0256081, Outfall 001

Instructions

Results

RETURN TO INPUTS

SAVE AS PDF

PRINT

All

Inputs

Results

Limits

Hydrodynamics

Wasteload Allocations

AFC

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Fluoride (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	750	750	986	
Total Antimony	0	0		0	1,100	1,100	1,446	
Total Arsenic	0	0		0	340	340	447	Chem Translator of 1 applied
Total Barium	0	0		0	21,000	21,000	27,611	
Total Boron	0	0		0	8,100	8,100	10,650	
Total Cadmium	0	0		0	8.882	10.1	13.3	Chem Translator of 0.88 applied
Total Chromium (III)	0	0		0	1992.850	6,306	8,292	Chem Translator of 0.316 applied
Hexavalent Chromium	0	0		0	16	16.3	21.4	Chem Translator of 0.982 applied
Total Cobalt	0	0		0	95	95.0	125	
Total Copper	0	0		0	56.748	59.1	77.7	Chem Translator of 0.96 applied
Dissolved Iron	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	324.843	572	752	Chem Translator of 0.568 applied
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Mercury	0	0		0	1.400	1.65	2.17	Chem Translator of 0.85 applied
Total Nickel	0	0		0	1706.756	1,710	2,249	Chem Translator of 0.998 applied
Total Phenols (Phenolics) (PWS)	0	0		0	N/A	N/A	N/A	
Total Selenium	0	0		0	N/A	N/A	N/A	Chem Translator of 0.922 applied
Total Silver	0	0		0	44.609	52.5	69.0	Chem Translator of 0.85 applied
Total Thallium	0	0		0	65	65.0	85.5	
Total Zinc	0	0		0	427.982	438	575	Chem Translator of 0.978 applied

CFC CCT (min): PMF: Analysis Hardness (mg/l): Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Fluoride (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Antimony	0	0		0	220	220	289	
Total Arsenic	0	0		0	150	150	197	Chem Translator of 1 applied
Total Barium	0	0		0	4,100	4,100	5,391	
Total Boron	0	0		0	1,600	1,600	2,104	
Total Cadmium	0	0		0	0.710	0.84	1.1	Chem Translator of 0.845 applied
Total Chromium (III)	0	0		0	259.229	301	396	Chem Translator of 0.86 applied
Hexavalent Chromium	0	0		0	10	10.4	13.7	Chem Translator of 0.962 applied
Total Cobalt	0	0		0	19	19.0	25.0	
Total Copper	0	0		0	33.071	34.4	45.3	Chem Translator of 0.96 applied
Dissolved Iron	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	1,500	1,500	1,972	WQC = 30 day average; PMF = 1
Total Lead	0	0		0	12.659	22.3	29.3	Chem Translator of 0.568 applied
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Mercury	0	0		0	0.770	0.91	1.19	Chem Translator of 0.85 applied
Total Nickel	0	0		0	189.568	190	250	Chem Translator of 0.997 applied
Total Phenols (Phenolics) (PWS)	0	0		0	N/A	N/A	N/A	
Total Selenium	0	0		0	4.600	4.99	6.56	Chem Translator of 0.922 applied
Total Silver	0	0		0	N/A	N/A	N/A	Chem Translator of 1 applied
Total Thallium	0	0		0	13	13.0	17.1	
Total Zinc	0	0		0	431.483	438	575	Chem Translator of 0.986 applied

THH CCT (min): PMF: Analysis Hardness (mg/l): Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	500,000	500,000	N/A	
Chloride (PWS)	0	0		0	250,000	250,000	N/A	
Sulfate (PWS)	0	0		0	250,000	250,000	N/A	
Fluoride (PWS)	0	0		0	2,000	2,000	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Antimony	0	0		0	5.6	5.6	7.36	
Total Arsenic	0	0		0	10	10.0	13.1	
Total Barium	0	0		0	2,400	2,400	3,156	
Total Boron	0	0		0	3,100	3,100	4,076	
Total Cadmium	0	0		0	N/A	N/A	N/A	
Total Chromium (III)	0	0		0	N/A	N/A	N/A	

Hexavalent Chromium	0	0		0	N/A	N/A	N/A	
Total Cobalt	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	N/A	N/A	N/A	
Dissolved Iron	0	0		0	300	300	394	
Total Iron	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Manganese	0	0		0	1,000	1,000	1,315	
Total Mercury	0	0		0	0.050	0.05	0.066	
Total Nickel	0	0		0	610	610	802	
Total Phenols (Phenolics) (PWS)	0	0		0	5	5.0	N/A	
Total Selenium	0	0		0	N/A	N/A	N/A	
Total Silver	0	0		0	N/A	N/A	N/A	
Total Thallium	0	0		0	0.24	0.24	0.32	
Total Zinc	0	0		0	N/A	N/A	N/A	

CRL

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Fluoride (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Antimony	0	0		0	N/A	N/A	N/A	
Total Arsenic	0	0		0	N/A	N/A	N/A	
Total Barium	0	0		0	N/A	N/A	N/A	
Total Boron	0	0		0	N/A	N/A	N/A	
Total Cadmium	0	0		0	N/A	N/A	N/A	
Total Chromium (III)	0	0		0	N/A	N/A	N/A	
Hexavalent Chromium	0	0		0	N/A	N/A	N/A	
Total Cobalt	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	N/A	N/A	N/A	
Dissolved Iron	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Mercury	0	0		0	N/A	N/A	N/A	
Total Nickel	0	0		0	N/A	N/A	N/A	
Total Phenols (Phenolics) (PWS)	0	0		0	N/A	N/A	N/A	
Total Selenium	0	0		0	N/A	N/A	N/A	
Total Silver	0	0		0	N/A	N/A	N/A	
Total Thallium	0	0		0	N/A	N/A	N/A	
Total Zinc	0	0		0	N/A	N/A	N/A	

Recommended WQBELs & Monitoring Requirements

No. Samples/Month: 4

Pollutants	Mass Limits		Concentration Limits			Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX			

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

Pollutants	Governing WQBEL	Units	Comments
Total Dissolved Solids (PWS)	N/A	N/A	PWS Not Applicable
Chloride (PWS)	N/A	N/A	PWS Not Applicable
Bromide	N/A	N/A	No WQS
Sulfate (PWS)	N/A	N/A	PWS Not Applicable
Fluoride (PWS)	N/A	N/A	PWS Not Applicable
Total Aluminum	750	µg/L	Discharge Conc ≤ 10% WQBEL
Total Antimony	7.36	µg/L	Discharge Conc ≤ 10% WQBEL
Total Arsenic	13.1	µg/L	Discharge Conc ≤ 10% WQBEL
Total Barium	3,156	µg/L	Discharge Conc ≤ 10% WQBEL
Total Beryllium	N/A	N/A	No WQS
Total Boron	2,104	µg/L	Discharge Conc ≤ 10% WQBEL
Total Cadmium	1.1	µg/L	Discharge Conc ≤ 10% WQBEL
Total Chromium (III)	396	µg/L	Discharge Conc ≤ 10% WQBEL
Hexavalent Chromium	13.7	µg/L	Discharge Conc ≤ 10% WQBEL
Total Cobalt	25.0	µg/L	Discharge Conc ≤ 10% WQBEL
Total Copper	45.3	µg/L	Discharge Conc ≤ 10% WQBEL
Total Cyanide	N/A	N/A	No WQS
Dissolved Iron	394	µg/L	Discharge Conc ≤ 10% WQBEL
Total Iron	1,972	µg/L	Discharge Conc ≤ 10% WQBEL
Total Lead	29.3	µg/L	Discharge Conc ≤ 10% WQBEL
Total Manganese	1,315	µg/L	Discharge Conc ≤ 10% WQBEL
Total Mercury	0.066	µg/L	Discharge Conc ≤ 10% WQBEL
Total Nickel	250	µg/L	Discharge Conc ≤ 10% WQBEL
Total Phenols (Phenolics) (PWS)		µg/L	PWS Not Applicable
Total Selenium	6.56	µg/L	Discharge Conc ≤ 10% WQBEL
Total Silver	52.5	µg/L	Discharge Conc ≤ 10% WQBEL
Total Thallium	0.32	µg/L	Discharge Conc ≤ 10% WQBEL
Total Zinc	438	µg/L	Discharge Conc ≤ 10% WQBEL
Total Molybdenum	N/A	N/A	No WQS

**ATTACHMENT C:
TRC Modeling Results**

TRC EVALUATION

0.0974	= Q stream (cfs)	0.5	= CV Daily	
0.02	= Q discharge (MGD)	0.5	= CV Hourly	
4	= no. samples	1	= AFC_Partial Mix Factor	
0.3	= Chlorine Demand of Stream	1	= CFC_Partial Mix Factor	
0	= Chlorine Demand of Discharge	0.012	= AFC_Criteria Compliance Time (min)	
0.5	= BAT/BPJ Value	0.012	= CFC_Criteria Compliance Time (min)	
0	= % Factor of Safety (FOS)	0	=Decay Coefficient (K)	
Source	Reference	AFC Calculations	Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 1.023	1.3.2.iii	WLA_cfc = 0.990
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 0.381	5.1d	LTA_cfc = 0.576
Source	Effluent Limit Calculations			
PENTOXSD TRG	5.1f	AML_MULT = 1.720		
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500	BAT/BPJ	
		INST MAX LIMIT (mg/l) = 1.170		
WLA_afc	$(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))... \\ ...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$			
LTAMULT_afc	$EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)$			
LTA_afc	$wla_afc*LTAMULT_afc$			
WLA_cfc	$(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))... \\ ...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$			
LTAMULT_cfc	$EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)$			
LTA_cfc	$wla_cfc*LTAMULT_cfc$			
AML_MULT	$EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))$			
AVG MON LIMIT	$MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)$			
INST MAX LIMIT	$1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)$			