

Application Type

Renewal

Facility Type

Non-Municipal

Major / Minor

Minor

Application No.

PA0261050

APS ID

631332

Authorization ID

1488206

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

**Applicant and Facility Information**

Applicant Name	<u>Quail Creek Homeowners Association</u>	Facility Name	<u>Quail Creek Wastewater Facility</u>
Applicant Address	<u>602 Quail Creek</u>	Facility Address	<u>Quail Creek Subdivision</u>
	<u>Manheim, PA 17545</u>		<u>Manheim, PA 17545</u>
Applicant Contact	<u>Nick Perrefort</u>	Facility Contact	<u>Justin LaTourette</u>
Applicant Phone	<u>(717) 629-0890</u>	Facility Phone	<u>(717) 903-5654</u>
Client ID	<u>260251</u>	Site ID	<u>698312</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Rapho Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Lancaster</u>
Date Application Received	<u>June 11, 2024</u>	EPA Waived?	<u>No</u>
Date Application Accepted	<u>June 11, 2024</u>	If No, Reason	<u>Chiques Creek Alternate TMDL</u>
Purpose of Application	<u>NPDES Renewal.</u>		

**Summary of Review**

Quail Creek Homeowners Association has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of its National Pollutant Discharge Elimination System (NPDES) permit. The existing permit was issued December 27, 2020, and became effective on January 1, 2020, authorizing discharge of treated sewage from the Quail Creek Wastewater Facility into UNT to Chiques Creek. The existing permit expiration date was December 31, 2024, and the permit has been administratively extended since that time.

Per the previous fact sheet, Quail Creek Homeowners Association is a 29-lot residential subdivision which is served by a small extended aeration plant. The Water Quality Management (WQM) Permit was issued on July 21, 2008 for construction/operation of the 0.0076 million gallons per day (mgd) WWTP (#3607403). The WWTP uses the Modified Ludzak-Ettinger (MLE) process for nutrient control. Before this facility was constructed, raw sewage generated from this property was pumped out by a licensed hauler and disposed at the nearest municipal treatment plant (Manheim WWTP, Derry Township WWTP, Springettsbury Township WWTP, or LASA WWTP). At the time, only approximately 8 EDUs were generating wastewater, which was not sufficient to provide a stable biological colony to allow conditions for effective treatment. By the end of April 2013, 10 homes had been built and the operator was able to initiate start-up of the WWTP on May 1, 2013.

Changes in this renewal: E. Coli monitoring has been added to the permit.

Sludge use and disposal description and location(s): Sludge holding tank with offsite disposal.

Supplemental information for this facility is provided at the end of this fact sheet.

Public Participation

Approve	Deny	Signatures	Date
X		Benjamin R. Lockwood Benjamin R. Lockwood / Environmental Engineering Specialist	February 21, 2025
X		Maria D. Bebeneck for Daniel W. Martin, P.E. / Environmental Engineer Manager	March 17, 2025

### Summary of Review

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

**Discharge, Receiving Waters and Water Supply Information**

Outfall No.	001	Design Flow (MGD)	.0076
Latitude	40° 13' 13"	Longitude	76° 27' 1"
Quad Name		Quad Code	
Wastewater Description:	Sewage Effluent		
Receiving Waters	Unnamed Tributary to Chiques Creek (WWF)	Stream Code	8015
NHD Com ID	57461965	RMI	0.95
Drainage Area	0.19 mi <sup>2</sup>	Yield (cfs/mi <sup>2</sup> )	0.12
Q <sub>7-10</sub> Flow (cfs)	0.023	Q <sub>7-10</sub> Basis	USGS Gage # 01576500
Elevation (ft)	528	Slope (ft/ft)	
Watershed No.	7-G	Chapter 93 Class.	WWF
Existing Use	N/A	Existing Use Qualifier	N/A
Exceptions to Use	N/A	Exceptions to Criteria	N/A
Assessment Status	Impaired		
Cause(s) of Impairment	Siltation, Pathogens		
Source(s) of Impairment	Agriculture, Source Unknown		
TMDL Status	Name Chiques Creek Alternate TMDL		
Nearest Downstream Public Water Supply Intake	Columbia Water Company		
PWS Waters	Susquehanna River	Flow at Intake (cfs)	
PWS RMI	27.5	Distance from Outfall (mi)	30

Changes Since Last Permit Issuance: A drainage area of 0.19 mi<sup>2</sup> and a Q<sub>7-10</sub> flow of 0.023 cubic feet per second (cfs) were determined by establishing a correlation to the yield of USGS Gage Station #01576500 on the Conestoga River. The Q<sub>7-10</sub> and drainage area at the gage are 38.6 cfs and 324 mi<sup>2</sup>, respectively. These values are taken from the USGS document "Selected Streamflow Statistics for Streamgage Locations in and near Pennsylvania". The Q<sub>7-10</sub> runoff rate at the gage station was calculated as follows:

$$\text{Yield} = (38.6 \text{ cfs}) / 324 \text{ mi}^2 = 0.12 \text{ cfs/mi}^2$$

The drainage area at the discharge point, taken from USGS PA StreamStats = 0.19 mi<sup>2</sup>

The Q<sub>7-10</sub> at the discharge point = 0.19 mi<sup>2</sup> x 0.12 cfs/mi<sup>2</sup> = 0.023 cfs

Other Comments: None

Treatment Facility Summary				
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Tertiary	Extended Aeration With Solids Removal	Hypochlorite	0.0076
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.0076	20	Not Overloaded	Aerobic Digestion	Other WWTP

Changes Since Last Permit Issuance: The treatment process consists of: Equalization, Anoxic Tank, Aeration Tank, Clarification, Tertiary Filtration, Chlorination, De-Chlorination, Post Aeration, Sludge Holding Tank, Outfall 001 to UNT 8015 to Chiques Creek

Other Comments: None

<b>Compliance History</b>	
<b>Summary of DMRs:</b>	A summary of past DMR effluent data is presented on the next page of this fact sheet.
<b>Summary of Inspections:</b>	1/14/2025: A routine inspection was conducted. The EQ tank appeared evenly aerated. The aeration tank appeared to be operating normally. The clarifier appeared clear with minimal floating scum. There was no ponding or solids accumulation at the tertiary filters. The chlorine contact tank appeared clear. Field sampling results were within permitted limits. A clear discharge was observed at Outfall 001.

Other Comments: There are currently no open violations associated with the Applicant.

**Existing Effluent Limitations and Monitoring Requirements**

**Outfall 001**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day)		Concentrations (mg/L)				Minimum Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	9.0	XXX	1/day	Grab
Dissolved Oxygen	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
Total Residual Chlorine (TRC)	XXX	XXX	XXX	0.2	XXX	0.66	1/day	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5)	XXX	XXX	XXX	25	XXX	50	2/month	8-Hr Composite
Total Suspended Solids	XXX	XXX	XXX	30	XXX	60	2/month	8-Hr Composite
Fecal Coliform (CFU/100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	2/month	Grab
Fecal Coliform (CFU/100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	2/month	Grab
Ammonia-Nitrogen Nov 1 - Apr 30	XXX	XXX	XXX	9.0	XXX	18	2/month	8-Hr Composite
Ammonia-Nitrogen May 1 - Oct 31	XXX	XXX	XXX	3.0	XXX	6.0	2/month	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	2.0	XXX	4.0	2/month	8-Hr Composite

Samples taken in compliance with the monitoring requirements specified above shall be taken at the following location(s):  
at Outfall 001

Outfall 001

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day)		Concentrations (mg/L)				Minimum Measurement Frequency	Required Sample Type
	Monthly	Annual	Monthly	Monthly Average	Maximum	Instant. Maximum		
Ammonia--N	Report	Report	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Kjeldahl--N	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Nitrate-Nitrite as N	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Total Nitrogen	Report	Report	XXX	Report	XXX	XXX	1/month	Calculation
Total Phosphorus	Report	Report	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Net Total Nitrogen	XXX	0	XXX	XXX	XXX	XXX	1/year	Calculation
Net Total Phosphorus	XXX	0	XXX	XXX	XXX	XXX	1/year	Calculation

Samples taken in compliance with the monitoring requirements specified above shall be taken at the following location(s):

at Outfall 001

Compliance History

DMR Data for Outfall 001 (from January 1, 2024 to December 31, 2024)

Parameter	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24	APR-24	MAR-24	FEB-24	JAN-24
Flow (MGD) Average Monthly	0.00236	0.00259	0.00286	0.00344	0.00463	0.00496	0.00407	0.00353	0.00412	0.00376	0.00255	0.00274
Flow (MGD) Daily Maximum	0.00398	0.00476	0.0045	0.00662	0.00687	0.01186	0.00584	0.00551	0.01196	0.00846	0.00404	0.00832
pH (S.U.) Minimum	6.75	7.09	7.14	7.29	7.53	7.59	7.54	7.67	7.68	7.48	7.64	7.44
pH (S.U.) Maximum	8.31	8.53	8.44	8.47	8.43	8.54	8.49	8.41	8.45	8.38	8.35	8.24
DO (mg/L) Minimum	9.27	8.91	8.11	6.84	8.01	7.94	8.2	7.91	9.42	9.68	10.14	10.14
TRC (mg/L) Average Monthly	< 0.04	< 0.04	< 0.04	< 0.06	< 0.06	< 0.03	< 0.04	< 0.05	< 0.04	< 0.04	< 0.05	< 0.04
TRC (mg/L) Instantaneous Maximum	0.09	0.15	0.10	0.20	0.24	0.13	0.12	0.42	0.12	0.13	0.12	0.15
CBOD5 (mg/L) Average Monthly	4.3	9.8	7.1	6.8	7.6	5.8	5.9	< 3.9	3.4	< 3.5	3.2	< 3.0
TSS (mg/L) Average Monthly	< 4.0	< 4.0	< 4.0	< 4.0	< 4.0	< 4.0	< 4.0	4.8	< 4.0	< 4.0	< 4.0	< 4.4
Fecal Coliform (CFU/100 ml) Geometric Mean	8	< 1	< 1	< 1	< 1	< 5	< 1	< 1	< 4	< 2	< 1	< 1
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	67	< 1	1	< 1	< 1	29	< 1	< 1	20	6	1	< 1
Nitrate-Nitrite (mg/L) Average Monthly	3.63	6.98	10.23	6.87	7.21	5.05	5.69	5.52	6.17	6.3	8.1	8.42
Nitrate-Nitrite (lbs) Total Monthly	3	6	10	8	99	7	8	6	10	6	6	7
Total Nitrogen (mg/L) Average Monthly	4.53	7.9	11.54	8	8.33	6.16	6.6	6.57	7.17	7.23	8.95	9.71
Total Nitrogen (lbs) Total Monthly	4	7	11	9	115	8	9	7	11	6	7	8
Total Nitrogen (lbs) Effluent Net   Total Annual				0.0								

NPDES Permit Fact Sheet  
Quail Creek Wastewater Facility

NPDES Permit No. PA0261050

Total Nitrogen (lbs)												
Total Annual												
Ammonia (mg/L)												
Average Monthly	< 0.11	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1
Ammonia (lbs)												
Total Monthly	< 0.09	< 0.08	< 0.1	< 0.1	< 1	< 0.1	< 0.1	< 0.1	< 0.2	< 0.09	< 0.07	< 0.09
Ammonia (lbs)												
Total Annual					< 1							
TKN (mg/L)												
Average Monthly	0.91	0.87	1.33	1.13	1.12	1.11	0.91	1.05	1	0.98	0.84	1.3
TKN (lbs)												
Total Monthly	0.7	0.7	1	1	15	2	1	1	2	0.9	0.6	1
Total Phosphorus (mg/L)												
Average Monthly	0.62	0.76	1.52	1.01	1.28	0.98	0.35	0.33	0.82	0.81	0.6	0.77
Total Phosphorus (lbs)												
Total Monthly	0.5	0.7	2	1	18	1	0.5	0.3	1	0.7	0.4	0.7
Total Phosphorus (lbs)												
Effluent Net   Total Annual					0.0							
Total Phosphorus (lbs)												
Total Annual					< 10							

Development of Effluent Limitations				
Outfall No.	001	Design Flow (MGD)	.0076	
Latitude	40° 13' 13"	Longitude	76° 27' 1"	
Wastewater Description:	Sewage Effluent			

### Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

### Water Quality-Based Limitations

#### CBOD<sub>5</sub>, NH<sub>3</sub>-N

Pursuant to 40 CFR § 122.44(d)(1)(i), more stringent requirements should be considered when pollutants are discharged at the levels which have the reasonable potential to cause or contribute to excursions above water quality standards.

WQM 7.0 ver. 1.1b is a water quality model designed to assist DEP in determining appropriate water quality based effluent limits (WQBELs) for carbonaceous biochemical oxygen demand (CBOD<sub>5</sub>), ammonia (NH<sub>3</sub>-N) and dissolved oxygen (D.O.). DEP's Technical Guidance No. 391-2000-007 provides the technical methods contained in WQM 7.0 for determining wasteload allocations and for determining recommended NPDES effluent limits for point source discharges. The model was utilized for this permit renewal. The model output indicated a CBOD<sub>5</sub> average monthly limit of 25 mg/l, an NH<sub>3</sub>-N average monthly limit of 6.33 mg/l, and a D.O. minimum limit of 5.0 mg/l were protective of water quality. The flow data used to run the model was acquired from USGS PA StreamStats and is included as an attachment. The CBOD<sub>5</sub> limit of 25 mg/l is the same as the existing permit limit, which will remain in the renewal. The existing NH<sub>3</sub>-N limit of 3.0 mg/l is more stringent, and will remain in the permit.

There are no industrial/commercial users contributing industrial wastewater to the system and Quail Creek Homeowners Association does not currently have an EPA-approved pretreatment program. Accordingly, evaluating reasonable potential of toxic pollutants is not necessary as effluent levels of toxic pollutants are expected to be insignificant.

### Additional Considerations

#### Chesapeake Bay Total Maximum Daily Load (TMDL)

DEP developed a strategy to comply with the EPA and Chesapeake Bay Foundation requirements by reducing point source loadings of Total Nitrogen (TN) and Total Phosphorus (TP). This strategy can be located in the *Pennsylvania Chesapeake Watershed Implementation Plan* (WIP), dated January 11, 2011. Subsequently, an update to the WIP was published as the Phase 2 WIP. As part of the Phase 2 WIP, a *Phase 2 Watershed Implementation Plan Wastewater Supplement* (Phase 2 Supplement) was developed, providing an update on TMDL implementation for point sources and DEP's current implementation strategy for wastewater. A new update to the WIP was published as the Phase 3 WIP in August 2019. As

part of the Phase 3 WIP, a *Phase 3 Watershed Implementation Plan Wastewater Supplement* (Phase 3 Supplement) was developed, and was most recently revised on December 17, 2019, and is the basis for the development of any Chesapeake Bay related permit parameters. Sewage discharges have been prioritized based on their design flow to the Bay. The highest priority (Phases 1, 2, and 3) dischargers will receive annual Cap Loads based on their design flow on August 29, 2005 and concentrations of 6 mg/l TN and 0.8 mg/l TP. These limits may be achieved through a combination of treatment technology, credits, or offsets. For Phase 4 and 5 facilities, Cap Loads are not currently being implemented for renewed or amended permits for facilities that do not increase design flow.

This facility is considered a Phase 5 non-significant discharger with a design flow less than 0.2 MGD but greater than 0.002 MGD, and is considered a new discharge to a tributary to the Chesapeake Bay. Therefore, Cap Loads of "0" will remain in the permit for TN and TP. A Nutrient Credit Purchase Agreement was signed on July 14, 2008 between Chesapeake Nutrient Management, LLC, and Quail Creek Homeowners' Association to purchase 538 lbs of nitrogen credits and 40 lbs of phosphorus credits each year for a period of twenty (20) years. DEP no longer offers any tools to calculate monthly loads for Net TN and Net TP, and it is no longer needed since offsets and credits are applied annually. Therefore, the reporting requirement for monthly net TN and TP load is no longer needed and will be removed from the permit.

#### Chiques Creek Alternate Restoration Plan

This facility discharges to Chiques Creek. Chiques Creek was included on Pennsylvania's 1996 303(d) List of Impaired Waters due to nutrient impairments. A TMDL for the Chiques Creek Watershed was approved by the United States Environmental Protection Agency (EPA) on April 9, 2001. Due to several deficiencies within the TMDL, it was withdrawn with approval from EPA on October 28, 2015. DEP, Susquehanna River Basin Commission (SRBC) and watershed stakeholders have been in the process of developing a large scale monitoring and restoration plan. The goal of this Alternate Restoration Plan (ARP) is to address impacts to the Chiques Creek Watershed due to suspended solids/siltation and nutrient pollution. During the ongoing ARP development, this discharge permit will be renewed to conform with existing guidance. This permit will include a Total Phosphorus (TP) limit of 2.0 mg/l. The TP limit of 2.0 mg/l is derived from 25 Pa. Code § 96.5(c). This section states that "when it is determined that the discharge of phosphorus, alone or in combination with the discharge of other pollutants, contributes or threatens to impair existing or designated uses in a free flowing surface water, phosphorus discharges from point source discharges shall be limited to an average monthly concentration of 2 mg/l." This is consistent with existing limits for other dischargers to the Chiques Creek Watershed. This limit is included in the existing permit, and will remain in the renewal. A continued evaluation of dischargers to Chiques Creek will be performed as described in the NPDES Part C Conditions.

#### Fecal Coliform

PA Code § 92a.47.(a)(4) requires a monthly average limit of 200/100 mL as a geometric mean and an instantaneous maximum limit not greater than 1,000/100 mL from May through September for fecal coliform. PA Code § 92a.47.(a)(5) requires a monthly average limit of 2,000/100 mL as a geometric mean and an instantaneous maximum limit not greater than 10,000/100 mL from October through April for fecal coliform. This is consistent with the existing permit limits.

#### E. Coli

PA Code § 92a.61 requires IMAX reporting of E. Coli. Per DEP's SOP No. BCW-PMT-033, sewage dischargers with a design flow of 0.002 – 0.05 mgd will include E. Coli monitoring with a frequency of 1/year. This parameter has been added to the renewal permit.

#### Dissolved Oxygen

A minimum D.O. limit of 5.0 mg/L is a D.O. water quality criterion found in 25 Pa. Code § 93.7(a). This is the existing permit limit, and it is recommended that it remain in the permit to ensure that the facility continues to achieve compliance with water quality standards.

#### Total Phosphorus

Historically, a Total Phosphorus (TP) effluent limit of 2.0 mg/l was established in the permit when it was determined that the facility was expected to contribute 0.25% or more of the total point source phosphorus loading at the point of discharge. This determination was based on the Department's *Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams* (Guidance No. 391-2000-018). DEP previously determined that the Millersville Borough WWTP met

this criteria, and phosphorus limitations were required in the permit. The TP average monthly limit of 2.0 mg/l and instantaneous maximum (IMAX) limit of 4.0 mg/l will remain in the permit to protect the local watershed.

**Total Residual Chlorine**

The attached computer printout utilizes the equations and calculations as presented in the Department's May 1, 2003 Implementation Guidance for Total Residual Chlorine (TRC) (ID No. 391-2000-015) for developing chlorine limitations. The Guidance references Chapter 92, Section 92.2d (3) which establishes a standard BAT limit of 0.5 mg/l unless a facility-specific BAT has been developed. The attached printout indicates that a water quality limit of 0.3 mg/l would be needed to prevent toxicity concerns. The existing average monthly limit of 0.2 mg/l and IMAX of 0.66 are more stringent and will remain in the renewal.

**Sampling Frequency & Sample Type**

The monitoring requirements were established based on BPJ and/or Table 6-3 of DEP's Technical Guidance No. 362-0400-001.

**Anti-Degradation**

The effluent limits for this discharge have been developed to ensure that existing instream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High Quality Waters are impacted by this discharge. No Exceptional Value Waters are impacted by this discharge.

**303(d) Listed Streams**

The discharge is located on a stream segment that is designated as impaired. There is an aquatic life impairment for siltation due to agriculture. There is also a recreational impairment for pathogens due to an unknown source.

**Class A Wild Trout Fisheries**

No Class A Wild Trout Fisheries are impacted by this discharge.

**Anti-Backsliding**

Pursuant to 40 CFR § 122.44(l)(1), all proposed permit requirements addressed in this fact sheet are at least as stringent as the requirements implemented in the existing NPDES permit unless any exceptions are addressed by DEP in this fact sheet.

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.2	XXX	0.66	1/day	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	30.0	XXX	60	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	9.0	XXX	18	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	XXX	XXX	XXX	3.0	XXX	6	2/month	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	2.0	XXX	4	2/month	8-Hr Composite

Compliance Sampling Location: Outfall 001

Other Comments: None

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, to comply with Pennsylvania's Chesapeake Bay Tributary Strategy.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Monthly	Annual	Monthly	Monthly Average	Maximum	Instant. Maximum		
Ammonia--N	Report	Report	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Kjeldahl--N	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Nitrate-Nitrite as N	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Total Nitrogen	Report	Report	XXX	Report	XXX	XXX	1/month	Calculation
Total Phosphorus	Report	Report	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Net Total Nitrogen	XXX	0	XXX	XXX	XXX	XXX	1/year	Calculation
Net Total Phosphorus	XXX	0	XXX	XXX	XXX	XXX	1/year	Calculation

Compliance Sampling Location: Outfall 001

Other Comments: None

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [REDACTED])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: BCW-PMT-033
<input type="checkbox"/>	Other: [REDACTED]


## Quail Creek Homeowners Association PA0261050 Outfall 001

**Region ID:** PA

**Workspace ID:** PA20250220190602298000

**Clicked Point (Latitude, Longitude):** 40.22011, -76.45002

**Time:** 2025-02-20 14:06:32 -0500



 [Collapse All](#)

### ➤ Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
BSLOPD	Mean basin slope measured in degrees	3.6211	degrees
DRNAREA	Area that drains to a point on a stream	0.19	square miles
ROCKDEP	Depth to rock	4	feet
URBAN	Percentage of basin with urban development	0.3753	percent

## ➤ Low-Flow Statistics

### Low-Flow Statistics Parameters [Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
BSLOPD	Mean Basin Slope degrees	3.6211	degrees	1.7	6.4
DRNAREA	Drainage Area	0.19	square miles	4.78	1150
ROCKDEP	Depth to Rock	4	feet	4.13	5.21
URBAN	Percent Urban	0.3753	percent	0	89

### Low-Flow Statistics Disclaimers [Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

### Low-Flow Statistics Flow Report [Low Flow Region 1]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.0129	ft^3/s
30 Day 2 Year Low Flow	0.0201	ft^3/s
7 Day 10 Year Low Flow	0.00388	ft^3/s
30 Day 10 Year Low Flow	0.00665	ft^3/s
90 Day 10 Year Low Flow	0.0141	ft^3/s

#### *Low-Flow Statistics Citations*

**Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)**

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government

as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

**USGS Product Names Disclaimer:** Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.27.0

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1


## Quail Creek Homeowners Association PA0261050 RMI = 0.0

**Region ID:** PA

**Workspace ID:** PA20250220191906194000

**Clicked Point (Latitude, Longitude):** 40.21647, -76.43452

**Time:** 2025-02-20 14:19:42 -0500



[Collapse All](#)

### ➤ Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
BSLOPD	Mean basin slope measured in degrees	3.6163	degrees
DRNAREA	Area that drains to a point on a stream	0.79	square miles
ROCKDEP	Depth to rock	4.2	feet
URBAN	Percentage of basin with urban development	0.6381	percent

➤ Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
BSLOPD	Mean Basin Slope degrees	3.6163	degrees	1.7	6.4
DRNAREA	Drainage Area	0.79	square miles	4.78	1150
ROCKDEP	Depth to Rock	4.2	feet	4.13	5.21
URBAN	Percent Urban	0.6381	percent	0	89

Low-Flow Statistics Disclaimers [Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 1]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.067	ft^3/s
30 Day 2 Year Low Flow	0.1	ft^3/s
7 Day 10 Year Low Flow	0.0225	ft^3/s
30 Day 10 Year Low Flow	0.0364	ft^3/s
90 Day 10 Year Low Flow	0.0727	ft^3/s

*Low-Flow Statistics Citations*

**Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)**

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government

as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.27.0

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1

TRC\_CALC

1A	B	C	D	E	F	G					
2	<b>TRC EVALUATION</b>										
3	Input appropriate values in B4:B8 and E4:E7										
4	0.023	= Q stream (cfs)		0.5	= CV Daily						
5	0.0076	= Q discharge (MGD)		0.5	= CV Hourly						
6	30	= no. samples		1	= AFC_Partial Mix Factor						
7	0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor						
8	0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)						
9	0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)						
	0	= % Factor of Safety (FOS)			= Decay Coefficient (K)						
10	Source	Reference	AFC Calculations	Reference	CFC Calculations						
11	TRC	1.3.2.iii	WLA_afc = 0.643	1.3.2.iii	WLA_cfc = 0.619						
12	PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581						
13	PENTOXSD TRG	5.1b	LTA_afc = 0.240	5.1d	LTA_cfc = 0.360						
14											
15	Source	Effluent Limit Calculations									
16	PENTOXSD TRG	5.1f	AML MULT = 1.231								
17	PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.295	AFC							
18			INST MAX LIMIT (mg/l) = 0.965								
19											
20	WLA_afc	$(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))... + Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$									
21	LTAMULT_afc	$EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)$									
22	LTA_afc	wla_afc*LTAMULT_afc									
23	WLA_cfc	$(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))... + Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$									
24	LTAMULT_cfc	$EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)$									
25	LTA_cfc	wla_cfc*LTAMULT_cfc									
26	AML MULT	$EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))$									
27	AVG MON LIMIT	MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)									
28	INST MAX LIMIT	$1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)$									

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
07G		8015 Trib 08015 to Chickies Creek			0.950	528.00	0.19	0.00000	0.00	<input checked="" type="checkbox"/>
<b>Stream Data</b>										
<b>Design Cond.</b>	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)
Q7-10	0.100	0.00	0.02	0.000	0.000	0.0	0.00	0.00	20.00	7.00
Q1-10		0.00	0.00	0.000	0.000					
Q30-10		0.00	0.00	0.000	0.000					
<b>Discharge Data</b>										
	Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor		Disc Temp (°C)	Disc pH	
	Quail Creek	PA0261050	0.0076	0.0076	0.0076	0.000	25.00	7.00		
<b>Parameter Data</b>										
	Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)				
	CBOD5		25.00	2.00	0.00	1.50				
	Dissolved Oxygen		5.00	8.24	0.00	0.00				
	NH3-N		25.00	0.00	0.00	0.70				

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
07G		8015 Trib 08015 to Chickies Creek			0.000	462.00	0.79	0.00000	0.00	<input checked="" type="checkbox"/>
<b>Stream Data</b>										
<b>Design Cond.</b>	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)
Q7-10	0.100	0.00	0.09	0.000	0.000	0.0	0.00	0.00	20.00	7.00
Q1-10		0.00	0.00	0.000	0.000					
Q30-10		0.00	0.00	0.000	0.000					
<b>Discharge Data</b>										
	Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH		
			0.0000	0.0000	0.0000	0.000	25.00	7.00		
<b>Parameter Data</b>										
	Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)				
	CBOD5		25.00	2.00	0.00	1.50				
	Dissolved Oxygen		3.00	8.24	0.00	0.00				
	NH3-N		25.00	0.00	0.00	0.70				

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>			<u>Stream Code</u>			<u>Stream Name</u>							
07G			8015			Trib 08015 to Chickies Creek							
RMI	Stream Flow	PWS Wth	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH	
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)		
<b>Q7-10 Flow</b>													
0.950	0.02	0.00	0.02	.0118	0.01316	.305	2.28	7.47	0.05	1.161	21.69	7.00	
<b>Q1-10 Flow</b>													
0.950	0.01	0.00	0.01	.0118	0.01316	NA	NA	NA	0.04	1.352	22.22	7.00	
<b>Q30-10 Flow</b>													
0.950	0.03	0.00	0.03	.0118	0.01316	NA	NA	NA	0.06	1.030	21.37	7.00	

## WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

### WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>				
07G	8015	Trib 08015 to Chickies Creek					
<b>NH3-N Acute Allocations</b>							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.950	Quail Creek	13.94	31.4	13.94	31.4	0	0
<b>NH3-N Chronic Allocations</b>							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.950	Quail Creek	1.73	6.33	1.73	6.33	0	0
<b>Dissolved Oxygen Allocations</b>							
RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>	
0.95	Quail Creek	25	25	6.33	6.33	5	5
						0	0

**WQM 7.0 D.O.Simulation**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
07G	8015	Trib 08015 to Chickies Creek		
<u>RMI</u>		<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>
0.950		0.008	21.691	7.000
<u>Reach Width (ft)</u>		<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>
2.279		0.305	7.471	0.050
<u>Reach CBOD5 (mg/L)</u>		<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>
9.78		1.052	2.14	0.797
<u>Reach DO (mg/L)</u>		<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>
7.146		27.297	Owens	5
<u>Reach Travel Time (days)</u>		<b>Subreach Results</b>		
1.161		TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)
				D.O. (mg/L)
		0.116	8.57	1.95
		0.232	7.51	1.78
		0.348	6.58	1.62
		0.464	5.77	1.48
		0.581	5.05	1.35
		0.697	4.43	1.23
		0.813	3.88	1.12
		0.929	3.40	1.02
		1.045	2.98	0.93
		1.161	2.61	0.85
				7.99

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>				
07G	8015	Trib 08015 to Chickies Creek					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
0.950	Quail Creek	PA0261050	0.008	CBOD5	25		
				NH3-N	6.33	12.66	
				Dissolved Oxygen			5