



Application Type New
Facility Type Sewage
GP Type PAG-04

**NPDES GENERAL PERMIT
CHECKLIST**

Application No. PAG044033
APS ID 873999
Authorization ID 1561451

Applicant and Facility Information			
Applicant Name	<u>Mark Wiczorkowski</u>	Facility Name	<u>3200 Catholic Valley Rd SRSTP</u>
Applicant Address	<u>3200 Catholic Valley Road</u> <u>Glen Rock, PA 17327-7658</u>	Facility Address	<u>3200 Catholic Valley Road</u> <u>Glen Rock, PA 17327-7658</u>
Municipality	<u>Codorus Township</u> <u>Unnamed Tributary to South Branch</u>	County	<u>York</u>
Receiving Water(s)	<u>Codorus Creek (WWF, MF)</u>	Ch. 93 Class.	<u>MF and WWF</u>
Date Application Received	<u>April 23, 2025</u>	WQM Required?	<u>Issued</u>

Checklist		
	<u>Completeness Item</u>	<u>Comments</u>
<input checked="" type="checkbox"/>	1. Three Copies of Complete NOI	_____
<input type="checkbox"/>	2. General Information Form (new coverage only)	_____
<input checked="" type="checkbox"/>	3. Act 14 notifications (new coverage only)	_____
<input checked="" type="checkbox"/>	4. Facility map or sketch with structure(s), facility and outfall(s)	_____
<input checked="" type="checkbox"/>	5. Topographic map with facility and outfall(s) identified	_____
<input type="checkbox"/>	6. WQM permit application (new facilities only)	_____
<input checked="" type="checkbox"/>	7. Evidence that the applicant is eligible for coverage under the PAG-04 General Permit	_____

Other Comments:

The Wiczorkowskis have submitted an application for a renewal permit for an NPDES permit for an existing small flow facility at 3200 Catholic Valley Road in Glen Rock, PA. This NPDES permit will serve to treat sewage at the residence.

Upon reviewing the renewal application, it was determined that the facility at 3200 Catholic Valley Road would qualify for a PAG-04 General Permit. The system currently installed at the Wiczorkowski residence is an Advantex AX20RTUV.

The effluent is discharged to a drainage channel that flows to an unnamed tributary to South Branch Codorus Creek (WWF), located in Watershed 7-H. This stream is not impaired. Due to the receiving stream not being HQ/EV and the installed system being part of the PAG-04 compatible list, the facility qualifies for the PAG-04 permit.

Approve	Deny	Signature	Date
X		<i>Jared Lescavage</i> Jared Lescavage / Project Manager	March 6, 2026
x		<i>Scott M Arwood</i> Scott M. Arwood, P.E. / Environmental Engineer Manager	03/06/2026

The PAG-04 permit will use the standard limits listed in the permit with the appropriate sampling frequencies.

WQ2TP (6715408) is suggested to remain in place as the respective WQM, as no changes are being made to the treatment plant at this time.