

Application Type

Renewal

Facility Type

Non-Municipal

Major / Minor

Minor

Application No.

**PA0261661**

APS ID

**750112**

Authorization ID

**1490878**

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

**Applicant and Facility Information**

Applicant Name	<b>Pravin M. and Mangla P. Patel</b>	Facility Name	<b>The Red Carpet Inn</b>
Applicant Address	2845 Lebanon Road	Facility Address	2845 Lebanon Road
	Manheim, PA 17545		Manheim, PA 17545
Applicant Contact	Pravin Patel	Facility Contact	Pravin Patel
Applicant Phone	(717) 665-3118	Facility Phone	(717) 665-3118
Client ID	287849	Site ID	725742
Ch 94 Load Status	Not Overloaded	Municipality	Rapho Township
Connection Status	No Limitations	County	Lancaster
Date Application Received	<u>July 2, 2024</u>	EPA Waived?	Yes
Date Application Accepted	<u>July 12, 2024</u>	If No, Reason	
Purpose of Application	NPDES Permit Renewal.		

**Summary of Review**

The Red Carpet Inn has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of its National Pollutant Discharge Elimination System (NPDES) permit. The existing permit was issued March 26, 2020, and became effective on April 1, 2020, authorizing discharge of treated sewage from the Red Carpet Inn WWTP into Shearers Creek. The existing permit expiration date was March 31, 2025, and the permit has been administratively extended since that time.

Per the previous fact sheet, this facility was originally an onlot treatment system. The facility was converted to a surface discharge when the original dwelling was demolished and rebuilt as a large motel. The Red Carpet Inn WWTP is a 0.0048 mgd treatment facility, with the design flow based upon 100 gall/day/room and 400 gpd for the residence. The facility discharges into Shearers Creek, which is a tributary of Chiques Creek. Chiques Creek is approximately 5.5 miles from this facility. The point of first use has been identified by DEP biologists as effluent dominated during dry periods. Biologists have recommended that the receiving stream will need the maximum protection available.

Changes in this renewal: Monthly Net Total Nitrogen and Net Total Phosphorus monitoring requirements have been removed from the permit. E. Coli monitoring has been added to the permit.

Sludge use and disposal description and location(s): Sludge holding tank with offsite disposal.

Supplemental information for this facility is provided at the end of this fact sheet.

**Public Participation**

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*,

Approve	Deny	Signatures	Date
X		Benjamin R. Lockwood Benjamin R. Lockwood / Environmental Engineering Specialist	April 15, 2025
X		Daniel W. Martin Daniel W. Martin, P.E. / Environmental Engineer Manager	June 6, 2025

### Summary of Review

DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

**Discharge, Receiving Waters and Water Supply Information**

Outfall No.	001	Design Flow (MGD)	.0048
Latitude	40° 13' 47.98"	Longitude	76° 25' 34.12"
Quad Name		Quad Code	
Wastewater Description:	Sewage Effluent		
Receiving Waters	Shearers Creek (HQ-CWF)	Stream Code	8012
NHD Com ID	57462079	RMI	1.95
Drainage Area	5.58 mi <sup>2</sup>	Yield (cfs/mi <sup>2</sup> )	0.12
Q <sub>7-10</sub> Flow (cfs)	0.67	Q <sub>7-10</sub> Basis	Stream Gage #01576500
Elevation (ft)	497	Slope (ft/ft)	
Watershed No.	7-G	Chapter 93 Class.	HQ-CWF
Existing Use	N/A	Existing Use Qualifier	N/A
Exceptions to Use	N/A	Exceptions to Criteria	N/A
Assessment Status	Impaired		
Cause(s) of Impairment	Habitat Alterations, Pathogens		
Source(s) of Impairment	Habitat Modification – Other Than Hydromodification, Source Unknown		
TMDL Status	Pending	Name	Chiques Creek Alternate TMDL
Background/Ambient Data			
pH (SU)	8.3	Data Source	WQN 206 – Chiques Creek
Temperature (°C)	21		WQN 206 – Chiques Creek
Hardness (mg/L)	250		WQN 206 – Chiques Creek
Other:			
Nearest Downstream Public Water Supply Intake			
PWS Waters	Wrightsville Borough Municipal Authority		
PWS RMI		Flow at Intake (cfs)	
		Distance from Outfall (mi)	29

Changes Since Last Permit Issuance: Stream flows were determined by establishing a correlation to the yield of USGS gage station No. 01576500 on Conestoga River. The Q<sub>7-10</sub> and drainage area at the gage station are 38.6 ft<sup>3</sup>/s and 324 mi<sup>2</sup>, respectively. The Q<sub>7-10</sub> runoff rate at the gage station was calculated as follows:

- Q<sub>7-10</sub> = (38.6 ft<sup>3</sup>/s)/324 mi<sup>2</sup> = 0.12 ft<sup>3</sup>/s/mi<sup>2</sup>

The drainage area at the discharge point = 5.58 mi<sup>2</sup>.

The Q<sub>7-10</sub> at the discharge point = 5.58 mi<sup>2</sup> x 0.12 ft<sup>3</sup>/s/mi<sup>2</sup> = 0.67 ft<sup>3</sup>/s.

Other Comments: None

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Comfort Inn Wastewater				
<b>WQM Permit No.</b>	<b>Issuance Date</b>			
3611401	10/31/2011			
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary With Ammonia And Phosphorus	Extended Aeration	Ultraviolet	0.0048
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.0048	9.6	Not Overloaded	Holding Tank	Other WWTP

Changes Since Last Permit Issuance: None

Other Comments: This facility utilizes the Purestream Biologically Engineered Single Sludge Treatment (BESST) process. The treatment facility consists of: Surge Tank, Anoxic Tank, Aeration Tank, Clarifier, UV Disinfection, Outfall 001 to Shearers Creek.

<b>Compliance History</b>	
<b>Summary of DMRs:</b>	A summary of the DMR data is presented on the next page of the fact sheet.
<b>Summary of Inspections:</b>	6/9/2020: An administrative inspection was conducted. All treatment units were operable and there were no outstanding issues at the time of inspection.  1/26/2021: A Notice of Violation (NOV) was issued for failure to purchase Total Phosphorus credits.

Other Comments: There are no open violations for this Applicant.

Compliance History

DMR Data for Outfall 001 (from March 1, 2024 to February 28, 2025)

Parameter	FEB-25	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24	APR-24	MAR-24
Flow (MGD) Average Monthly	0.00092 8	0.00106	0.00181 7	0.00179 7	0.00234	0.00194 8	0.00270 7	0.00215 8	0.00164 2	0.00117	0.00125 8	0.00168 2
Flow (MGD) Daily Maximum	0.00419 2	0.00235 7	0.00426 6	0.00366	0.00515 1	0.00429 9	0.00538 5	0.00460 6	0.00391	0.00304 7	0.00389 9	0.00507 7
pH (S.U.) Instantaneous Minimum	7.9	7.8	7.8	7.8	7.7	7.8	7.8	7.8	7.5	7.6	7.7	7.5
pH (S.U.) Instantaneous Maximum	8.2	8.2	8.1	8.1	8.2	8.2	8.2	8.3	8.1	8.1	8.2	8.2
DO (mg/L) Instantaneous Minimum	8.9	9.3	8.5	8.2	8.0	7.8	7.4	7.3	7.2	7.3	7.6	8.5
CBOD5 (mg/L) Average Monthly	< 2	< 2	< 2	< 2	< 3	< 3	< 3	< 2	< 2	< 2	< 2	< 2
CBOD5 (mg/L) Daily Maximum	< 2.4	< 2.4	< 2.4	< 2.4	3.2	3.7	3.1	< 2.4	< 2.4	< 2.4	< 2.4	< 2.4
TSS (mg/L) Average Monthly	12	4	2	3	3	3	3	4	2	2	2	2
TSS (mg/L) Daily Maximum	20	4	2	4	3	3	4	5	2	2	2	2
Fecal Coliform (No./100 ml) Geometric Mean	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 2	3	< 1	< 1	< 1
Fecal Coliform (No./100 ml) Instantaneous Maximum	< 1	< 1	< 1	< 1	< 1	< 1	< 1	4	8	< 1	< 1	< 1
Nitrate-Nitrite (mg/L) Average Monthly	< 27.4	< 37.4	< 15.4	< 16.4	< 22.4	< 20.9	< 17.9	< 27.4	< 28.9	< 35.4	< 35.11	< 31.4
Nitrate-Nitrite (mg/L) Daily Maximum	< 33.4	< 39.4	< 17.4	< 21.4	< 24.4	< 22.4	< 18.4	< 32.4	< 35.4	< 39.4	38.82	< 42.4
Nitrate-Nitrite (lbs) Total Monthly	< 18	< 15	< 10	< 10	< 21	< 8	< 14	< 18	< 17	< 13	< 10	< 27
Total Nitrogen (mg/L) Average Monthly	< 28.9	< 39.9	< 22.2	< 16.9	< 24.9	< 23.4	< 18.4	< 27.9	< 29.4	< 37.9	< 41.36	< 33.9
Total Nitrogen (mg/L) Daily Maximum	< 35.9	< 41.9	< 26.4	< 21.9	< 26.9	< 24.9	< 18.9	< 32.9	< 35.9	< 41.9	< 43.4	< 44.9

NPDES Permit Fact Sheet  
The Red Carpet Inn

NPDES Permit No. PA0261661

Total Nitrogen (lbs) Effluent Net   Total Monthly	4	1	00	-5	8	-6	00	4	2	NULL	-4	14
Total Nitrogen (lbs) Total Monthly	< 19	< 16	< 15	< 10	< 23	< 9	< 15	< 19	< 17	< 14	< 11	< 29
Total Nitrogen (lbs) Effluent Net   Total Annual						< 174						
Total Nitrogen (lbs) Total Annual						< 174						
Ammonia (mg/L) Average Monthly	< 0.1	0.8	3.7	< 0.1	< 0.1	< 0.3	< 0.7	< 0.1	< 0.1	< 0.1	< 0.1	0.6
Ammonia (mg/L) Daily Maximum	< 0.1	1.4	7.2	< 0.1	< 0.1	0.47	1.2	< 0.1	< 0.1	< 0.1	0.11	0.87
Ammonia (lbs) Average Monthly	< 0.002	0.4	0.09	< 0.002	< 0.003	< 0.005	< 0.02	< 0.002	< 0.002	< 0.001	< 0.0009	0.02
Ammonia (lbs) Total Annual						< 4						
TKN (mg/L) Average Monthly	< 1.5	< 2.5	< 6.8	< 0.5	< 2.5	< 2.5	< 0.5	< 0.5	< 0.5	< 2.5	< 6.3	< 2.5
TKN (lbs) Total Monthly	< 1	< 1	< 5	< 0.3	< 2	< 1	< 0.4	< 0.3	< 0.3	< 1	< 0.9	< 2
Total Phosphorus (mg/L) Average Monthly	< 0.1	0.2	< 0.2	0.1	< 0.2	0.5	0.4	< 0.2	0.1	0.2	< 0.2	0.2
Total Phosphorus (mg/L) Daily Maximum	0.14	0.16	0.23	0.12	0.31	0.72	0.36	0.39	0.16	0.2	0.28	0.25
Total Phosphorus (lbs) Effluent Net   Total Monthly	0.08	0.06	< 0.1	0.06	0.2	0.2	0.3	< 0.2	0.09	0.07	< 0.04	0.2
Total Phosphorus (lbs) Total Monthly	< 0.08	0.06	< 0.1	0.06	< 0.2	0.2	0.3	< 0.2	0.09	0.07	< 0.04	0.2
Total Phosphorus (lbs) Effluent Net   Total Annual							-9.0					
Total Phosphorus (lbs) Total Annual							< 2					
Total Copper (mg/L) Average Quarterly			0.023			0.018			0.021			0.022
Total Copper (mg/L) Daily Maximum			0.023			0.018			0.021			0.022
Total Lead (mg/L) Average Quarterly			< 0.001			< 0.001			< 0.001			< 0.001

Total Lead (mg/L)			< 0.001			< 0.001			< 0.001			< 0.001
Daily Maximum												
Total Zinc (mg/L)			0.0014			0.008			0.010			0.016
Average Quarterly												
Total Zinc (mg/L)			0.0014			0.008			0.010			0.016
Daily Maximum												

### Compliance History

#### Effluent Violations for Outfall 001, from: April 1, 2024 To: February 28, 2025

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
TSS	02/28/25	Avg Mo	12	mg/L	10	mg/L
Nitrate-Nitrite	09/30/24	Avg Mo	< 20.9	mg/L	10.0	mg/L
Nitrate-Nitrite	02/28/25	Avg Mo	< 27.4	mg/L	10.0	mg/L
Nitrate-Nitrite	04/30/24	Avg Mo	< 35.11	mg/L	10.0	mg/L
Nitrate-Nitrite	07/31/24	Avg Mo	< 27.4	mg/L	10.0	mg/L
Nitrate-Nitrite	06/30/24	Avg Mo	< 28.9	mg/L	10.0	mg/L
Nitrate-Nitrite	12/31/24	Avg Mo	< 15.4	mg/L	10.0	mg/L
Nitrate-Nitrite	05/31/24	Avg Mo	< 35.4	mg/L	10.0	mg/L
Nitrate-Nitrite	01/31/25	Avg Mo	< 37.4	mg/L	10.0	mg/L
Nitrate-Nitrite	11/30/24	Avg Mo	< 16.4	mg/L	10.0	mg/L
Nitrate-Nitrite	10/31/24	Avg Mo	< 22.4	mg/L	10.0	mg/L
Nitrate-Nitrite	08/31/24	Avg Mo	< 17.9	mg/L	10.0	mg/L
Nitrate-Nitrite	09/30/24	Daily Max	< 22.4	mg/L	20.0	mg/L
Nitrate-Nitrite	07/31/24	Daily Max	< 32.4	mg/L	20.0	mg/L
Nitrate-Nitrite	06/30/24	Daily Max	< 35.4	mg/L	20.0	mg/L

NPDES Permit Fact Sheet  
The Red Carpet Inn

NPDES Permit No. PA0261661

Nitrate-Nitrite	01/31/25	Daily Max	< 39.4	mg/L	20.0	mg/L
Nitrate-Nitrite	04/30/24	Daily Max	38.82	mg/L	20.0	mg/L
Nitrate-Nitrite	02/28/25	Daily Max	< 33.4	mg/L	20.0	mg/L
Nitrate-Nitrite	11/30/24	Daily Max	< 21.4	mg/L	20.0	mg/L
Nitrate-Nitrite	05/31/24	Daily Max	< 39.4	mg/L	20.0	mg/L
Nitrate-Nitrite	10/31/24	Daily Max	< 24.4	mg/L	20.0	mg/L
Total Nitrogen	08/31/24	Avg Mo	< 18.4	mg/L	5	mg/L
Total Nitrogen	06/30/24	Avg Mo	< 29.4	mg/L	5	mg/L
Total Nitrogen	05/31/24	Avg Mo	< 37.9	mg/L	5	mg/L
Total Nitrogen	12/31/24	Avg Mo	< 22.2	mg/L	5	mg/L
Total Nitrogen	10/31/24	Avg Mo	< 24.9	mg/L	5	mg/L
Total Nitrogen	04/30/24	Avg Mo	< 41.36	mg/L	5	mg/L
Total Nitrogen	11/30/24	Avg Mo	< 16.9	mg/L	5	mg/L
Total Nitrogen	02/28/25	Avg Mo	< 28.9	mg/L	5	mg/L
Total Nitrogen	07/31/24	Avg Mo	< 27.9	mg/L	5	mg/L
Total Nitrogen	09/30/24	Avg Mo	< 23.4	mg/L	5	mg/L
Total Nitrogen	01/31/25	Avg Mo	< 39.9	mg/L	5	mg/L
Total Nitrogen	11/30/24	Daily Max	< 21.9	mg/L	10	mg/L
Total Nitrogen	01/31/25	Daily Max	< 41.9	mg/L	10	mg/L
Total Nitrogen	12/31/24	Daily Max	< 26.4	mg/L	10	mg/L
Total Nitrogen	10/31/24	Daily Max	< 26.9	mg/L	10	mg/L
Total Nitrogen	09/30/24	Daily Max	< 24.9	mg/L	10	mg/L

NPDES Permit Fact Sheet  
The Red Carpet Inn

NPDES Permit No. PA0261661

Total Nitrogen	07/31/24	Daily Max	< 32.9	mg/L	10	mg/L
Total Nitrogen	06/30/24	Daily Max	< 35.9	mg/L	10	mg/L
Total Nitrogen	05/31/24	Daily Max	< 41.9	mg/L	10	mg/L
Total Nitrogen	04/30/24	Daily Max	< 43.4	mg/L	10	mg/L
Total Nitrogen	08/31/24	Daily Max	< 18.9	mg/L	10	mg/L
Total Nitrogen	02/28/25	Daily Max	< 35.9	mg/L	10	mg/L
Ammonia	12/31/24	Avg Mo	3.7	mg/L	1.0	mg/L
Ammonia	12/31/24	Daily Max	7.2	mg/L	2.0	mg/L

**Development of Effluent Limitations**

Outfall No. 001  
Latitude 40° 13' 47.98"  
Wastewater Description: Sewage Effluent

Design Flow (MGD) .0048  
Longitude 76° 25' 43.12"

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

**Water Quality-Based Limitations**

CBOD<sub>5</sub>, NH<sub>3</sub>-N

Pursuant to 40 CFR § 122.44(d)(1)(i), more stringent requirements should be considered when pollutants are discharged at the levels which have the reasonable potential to cause or contribute to excursions above water quality standards.

WQM 7.0 ver. 1.1b is a water quality model designed to assist DEP in determining appropriate water quality based effluent limits (WQBELs) for carbonaceous biochemical oxygen demand (CBOD<sub>5</sub>), ammonia (NH<sub>3</sub>-N) and dissolved oxygen (D.O.). DEP's Technical Guidance No. 391-2000-007 provides the technical methods contained in WQM 7.0 for determining wasteload allocations and for determining recommended NPDES effluent limits for point source discharges. The model was utilized for this permit renewal. The model output indicated a CBOD<sub>5</sub> average monthly limit of 25 mg/l, an NH<sub>3</sub>-N average monthly limit of 25 mg/l, and a D.O. minimum limit of 5.0 mg/l were protective of water quality. The flow data used to run the model was acquired from USGS PA StreamStats and is included as an attachment. The existing CBOD<sub>5</sub> limit and NH<sub>3</sub>-N limit are more stringent, and will remain in the permit renewal.

Toxics

Effluent sample results for toxic pollutants reported on the renewal application were entered into DEP's Toxics Management Spreadsheet Version 1.4 to develop appropriate permit requirements for toxic pollutants of concern. The Toxics Management Spreadsheet combines the functions of PENTOXSD and DEP's Toxics Screening Analysis. Stream pH and hardness inputs were determined using data from WQN Station 206 on Chiques Creek. The 90<sup>th</sup> percentile of data from Oct 1998 – Aug 2022 resulted in a pH of 8.3 and a stream hardness of 250 mg/l. Based on effluent sample results reported on the application, the Toxics Management Spreadsheet did not recommend new limits or monitoring requirements.

This data was analyzed based on the guidelines found in DEP's Water Quality Toxics Management Strategy (Document No. 361-0100-003) and DEP's SOP No. BPNPSM-PMT-033. The results are attached to this fact sheet. The Toxics Management Spreadsheet uses the following logic:

- Establish average monthly and instantaneous maximum (IMAX) limits in the draft permit where the maximum reported concentration exceeds 50% of the WQBEL.
- For non-conservative pollutants, establish monitoring requirements where the maximum reported concentration is between 25% - 50% of the WQBEL.
- For conservative pollutants, establish monitoring requirements where the maximum reported concentration is between 10%-50% of the WQBEL.

The Toxics Management Spreadsheet did not require any toxics monitoring requirements or limitations. The existing permit has limitations for Total Copper, Total Lead, and Total Zinc, which will remain in the renewal due to anti-backsliding requirements.

### **Additional Considerations**

#### **Chesapeake Bay Total Maximum Daily Load (TMDL)**

DEP developed a strategy to comply with the EPA and Chesapeake Bay Foundation requirements by reducing point source loadings of Total Nitrogen (TN) and Total Phosphorus (TP). This strategy can be located in the *Pennsylvania Chesapeake Watershed Implementation Plan* (WIP), dated January 11, 2011. Subsequently, an update to the WIP was published as the Phase 2 WIP. As part of the Phase 2 WIP, a *Phase 2 Watershed Implementation Plan Wastewater Supplement* (Phase 2 Supplement) was developed, providing an update on TMDL implementation for point sources and DEP's current implementation strategy for wastewater. A new update to the WIP was published as the Phase 3 WIP in August 2019. As part of the Phase 3 WIP, a *Phase 3 Watershed Implementation Plan Wastewater Supplement* (Phase 3 Supplement) was developed, and was most recently revised on December 17, 2019, and is the basis for the development of any Chesapeake Bay related permit parameters. Sewage discharges have been prioritized based on their design flow to the Bay. The highest priority (Phases 1, 2, and 3) dischargers will receive annual Cap Loads based on their design flow on August 29, 2005 and concentrations of 6 mg/l TN and 0.8 mg/l TP. These limits may be achieved through a combination of treatment technology, credits, or offsets. For Phase 4 and 5 facilities, Cap Loads are not currently being implemented for renewed or amended permits for facilities that do not increase design flow.

This facility is considered a Phase 5 non-significant facility with a design flow less than 0.2 MGD but greater than 0.002 MGD. According to the Phase 3 WIP, TN and TP monitoring is recommended for this facility, which is consistent with the existing permit. A TN limit and a TP limit are already included in the existing permit and will remain in the permit. DEP no longer offers any tools to calculate monthly loads for Net TN and Net TP. Therefore, this reporting requirement is no longer needed and will be removed from the permit.

#### **Chiques Creek Alternate Restoration Plan**

This facility discharges to Chiques Creek. Chiques Creek was included on Pennsylvania's 1996 303(d) List of Impaired Waters due to nutrient impairments. A Total Maximum Daily Load (TMDL) for the Chiques Creek Watershed was approved by the United States Environmental Protection Agency (EPA) on April 9, 2001. Due to several deficiencies within the TMDL, it was withdrawn with approval from EPA on October 28, 2015. DEP, Susquehanna River Basin Commission (SRBC) and watershed stakeholders have been in the process of developing a large scale monitoring and restoration plan. The goal of this Alternate Restoration Plan (ARP) is to address impacts to the Chiques Creek Watershed due to suspended solids/siltation and nutrient pollution. During the ongoing ARP development, this discharge permit will be renewed to conform with existing guidance. This permit will include a Total Phosphorus (TP) limit of 2.0 mg/l. The TP limit of 2.0 mg/l is derived from 25 Pa. Code § 96.5(c). This section states that "when it is determined that the discharge of phosphorus, alone or in combination with the discharge of other pollutants, contributes or threatens to impair existing or designated uses in a free flowing surface water, phosphorus discharges from point source discharges shall be limited to an average monthly concentration of 2 mg/l." The existing TP limit of 0.5 mg/l is more stringent and will remain in the renewal. A continued evaluation of dischargers to Chiques Creek will be performed as described in the NPDES Part C Conditions.

#### **Fecal Coliform**

PA Code § 92a.47.(a)(4) requires a monthly average limit of 200/100 mL as a geometric mean and an instantaneous maximum limit not greater than 1,000/100 mL from May through September for fecal coliform. PA Code § 92a.47.(a)(5) requires a monthly average limit of 2,000/100 mL as a geometric mean and an instantaneous maximum limit not greater than 10,000/100 mL from October through April for fecal coliform. The existing permit requires a year-round limit of 200/100 mL as a geometric mean. This year-round limit will remain in the renewal permit.

#### **E. Coli**

PA Code § 92a.61 requires IMAX reporting of E. Coli. Per DEP's SOP No. BCW-PMT-033, sewage dischargers with a design flow of 0.002 – 0.05 mgd will include E. Coli monitoring with a frequency of 1/year. This parameter has been added to the renewal permit.

Sampling Frequency & Sample Type

The monitoring requirements were established based on BPJ and/or Table 6-3 of DEP's Technical Guidance No. 362-0400-001.

Anti-Degradation

The effluent limits for this discharge have been developed to ensure that existing instream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. No Exceptional Value Waters are impacted by this discharge. This facility discharges to Shearers Creek, which is a High Quality water.

A Point of First Use (POFU) survey was completed on an Unnamed Tributary (UNT) to Shearers Creek on August 23, 2010. The findings for the survey included that Shearers Creek and its tributaries are classified as HQ under Chapter 93(b), and the stream is small. This facility discharging 6,000 gpd makes the UNT effluent dominated. DEP's Guidance "Water Quality Antidegradation Implementation Guidance" has been followed due to these classifications. An antidegradation analysis was performed in the May 26, 2011 Fact Sheet, and provided as an attachment to this fact sheet.

Intermittent Streams

DEP's Guidance "Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales and Storm Sewers" was utilized for the development of effluent limitations for this permit. The CBOD<sub>5</sub> limit of 10 mg/l average monthly, TSS limit of 10 mg/l average monthly, TN limit of 5 mg/l average monthly, and the TP limit of 0.5 mg/l average monthly were all derived from this guidance. These effluent limitations will remain in the renewal permit.

303(d) Listed Streams

The discharge is located on a stream segment that is designated as impaired. There is an aquatic life impairment for habitat alterations from habitat modification – other than hydromodification. There is a recreational impairment for pathogens from an unknown source.

Class A Wild Trout Fisheries

No Class A Wild Trout Fisheries are impacted by this discharge.

Anti-Backsliding

Pursuant to 40 CFR § 122.44(l)(1), all proposed permit requirements addressed in this fact sheet are at least as stringent as the requirements implemented in the existing NPDES permit unless any exceptions are addressed by DEP in this fact sheet.

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	7.0 Inst Min	XXX	XXX	XXX	1/day	Grab
CBOD5	XXX	XXX	XXX	10	20	25	2/month	24-Hr Composite
TSS	XXX	XXX	XXX	10	20	25	2/month	24-Hr Composite
Fecal Coliform (No./100 ml)	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Nitrate-Nitrite as N	XXX	XXX	XXX	10	20	25	2/month	24-Hr Composite
Total Nitrogen	XXX	XXX	XXX	5	10	12.5	2/month	Calculation
Ammonia	XXX	XXX	XXX	1.0	2.0	2.5	2/month	24-Hr Composite
Total Phosphorus	XXX	XXX	XXX	0.5	1	1.25	2/month	24-Hr Composite
Total Copper	XXX	XXX	XXX	0.053 Avg Qrtly	0.106	0.13	1/quarter	24-Hr Composite
Total Lead	XXX	XXX	XXX	0.094 Avg Qrtly	0.188	0.235	1/quarter	24-Hr Composite

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date )

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Total Zinc	XXX	XXX	XXX	0.244 Avg Qrtly	0.488	0.61	1/quarter	24-Hr Composite

Compliance Sampling Location: Outfall 001

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, to comply with Pennsylvania's Chesapeake Bay Tributary Strategy.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)					
	Monthly	Annual	Monthly	Monthly Average	Maximum	Instant. Maximum	Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
Ammonia--N	Report	Report	XXX	1.0	2.0	2.5	2/month	24-Hr Composite
Kjeldahl--N	Report	XXX	XXX	Report	XXX	XXX	2/month	24-Hr Composite
Nitrate-Nitrite as N	Report	XXX	XXX	10	20	25	2/month	24-Hr Composite
Total Nitrogen	Report	Report	XXX	5	10	12.5	2/month	Calculation
Total Phosphorus	Report	Report	XXX	0.5	1	1.25	2/month	24-Hr Composite
Net Total Nitrogen	XXX	181	XXX	XXX	XXX	XXX	1/month	Calculation
Net Total Phosphorus	XXX	0	XXX	XXX	XXX	XXX	1/month	Calculation

Compliance Sampling Location: Outfall 001

Other Comments: None

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [REDACTED])
<input checked="" type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input checked="" type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input checked="" type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input checked="" type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: BCW-PMT-033
<input type="checkbox"/>	Other: [REDACTED]


## The Red Carpet Inn PA0261661 Outfall 001

Region ID: PA

Workspace ID: PA20250409201343474000

Clicked Point (Latitude, Longitude): 40.22979, -76.42616

Time: 2025-04-09 16:14:24 -0400



[Collapse All](#)

### Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
BSLOPD	Mean basin slope measured in degrees	6.3234	degrees
DRNAREA	Area that drains to a point on a stream	5.58	square miles
ROCKDEP	Depth to rock	4	feet
URBAN	Percentage of basin with urban development	0.9931	percent

### Low-Flow Statistics

#### Low-Flow Statistics Parameters [Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
BSLOPD	Mean Basin Slope degrees	6.3234	degrees	1.7	6.4
DRNAREA	Drainage Area	5.58	square miles	4.78	1150
ROCKDEP	Depth to Rock	4	feet	4.13	5.21
URBAN	Percent Urban	0.9931	percent	0	89

Low-Flow Statistics Disclaimers [Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 1]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.795	ft^3/s
30 Day 2 Year Low Flow	1.07	ft^3/s
7 Day 10 Year Low Flow	0.342	ft^3/s
30 Day 10 Year Low Flow	0.484	ft^3/s
90 Day 10 Year Low Flow	0.737	ft^3/s

*Low-Flow Statistics Citations*

**Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)**

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.28.1

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1


## The Red Carpet Inn PA0261661 RMI = 0.0

Region ID: PA

Workspace ID: PA20250409201652017000

Clicked Point (Latitude, Longitude): 40.20766, -76.42950

Time: 2025-04-09 16:17:34 -0400



+/- [Collapse All](#)

### ► Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
BSLOPD	Mean basin slope measured in degrees	5.908	degrees
DRNAREA	Area that drains to a point on a stream	6.63	square miles
ROCKDEP	Depth to rock	4.1	feet
URBAN	Percentage of basin with urban development	1.5327	percent

### ► Low-Flow Statistics

#### Low-Flow Statistics Parameters [Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
BSLOPD	Mean Basin Slope degrees	5.908	degrees	1.7	6.4
DRNAREA	Drainage Area	6.63	square miles	4.78	1150
ROCKDEP	Depth to Rock	4.1	feet	4.13	5.21

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
URBAN	Percent Urban	1.5327	percent	0	89

Low-Flow Statistics Disclaimers [Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 1]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.975	ft^3/s
30 Day 2 Year Low Flow	1.31	ft^3/s
7 Day 10 Year Low Flow	0.423	ft^3/s
30 Day 10 Year Low Flow	0.596	ft^3/s
90 Day 10 Year Low Flow	0.918	ft^3/s

*Low-Flow Statistics Citations*

**Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)**

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.28.1

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
07G	8012 SHEARERS CREEK				1.950	497.00	5.58	0.00000	0.00	<input checked="" type="checkbox"/>
<b>Stream Data</b>										
<b>Design Cond.</b>	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)
Q7-10 0.100 0.00 0.67 0.000 0.000 0.0 0.00 0.00 20.00 7.00 0.00 0.00 Q1-10 0.00 0.00 0.000 0.000 Q30-10 0.00 0.00 0.000 0.000										
<b>Discharge Data</b>										
		Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH	
		Red Carpet Inn	PA0261661	0.0048	0.0048	0.0048	0.000	25.00	7.00	
<b>Parameter Data</b>										
				Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
				CBOD5	25.00	2.00	0.00	1.50		
				Dissolved Oxygen	5.00	8.24	0.00	0.00		
				NH3-N	25.00	0.00	0.00	0.70		

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC																																	
07G	8012 SHEARERS CREEK				1.950	497.00	5.58	0.00000	0.00	<input checked="" type="checkbox"/>																																	
<b>Stream Data</b>																																											
<b>Design Cond.</b>	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)																																	
<table> <tr> <td>Q7-10</td><td>0.100</td><td>0.00</td><td>0.67</td><td>0.000</td><td>0.000</td><td>0.0</td><td>0.00</td><td>0.00</td><td>20.00</td><td>7.00</td></tr> <tr> <td>Q1-10</td><td></td><td></td><td>0.00</td><td>0.000</td><td></td><td>0.000</td><td></td><td></td><td></td><td></td></tr> <tr> <td>Q30-10</td><td></td><td></td><td>0.00</td><td>0.000</td><td></td><td>0.000</td><td></td><td></td><td></td><td></td></tr> </table>											Q7-10	0.100	0.00	0.67	0.000	0.000	0.0	0.00	0.00	20.00	7.00	Q1-10			0.00	0.000		0.000					Q30-10			0.00	0.000		0.000				
Q7-10	0.100	0.00	0.67	0.000	0.000	0.0	0.00	0.00	20.00	7.00																																	
Q1-10			0.00	0.000		0.000																																					
Q30-10			0.00	0.000		0.000																																					
<b>Discharge Data</b>																																											
		Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH																																		
		Red Carpet Inn	PA0261661	0.0048	0.0048	0.0048	0.000	25.00	7.00																																		
<b>Parameter Data</b>																																											
				Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)																																				
				CBOD5	25.00	2.00	0.00	1.50																																			
				Dissolved Oxygen	5.00	8.24	0.00	0.00																																			
				NH3-N	25.00	0.00	0.00	0.70																																			

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>			<u>Stream Code</u>			<u>Stream Name</u>							
07G			8012			SHEARERS CREEK							
RMI	Stream Flow	PWS Wth	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH	
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)		
<b>Q7-10 Flow</b>													
1.950	0.67	0.00	0.67	.0074 0.00505	.479	12.22	25.52	0.12	1.029	20.05	7.00		
<b>Q1-10 Flow</b>													
1.950	0.43	0.00	0.43	.0074 0.00505	NA	NA	NA	0.09	1.316	20.09	7.00		
<b>Q30-10 Flow</b>													
1.950	0.91	0.00	0.91	.0074 0.00505	NA	NA	NA	0.14	0.868	20.04	7.00		

## WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

### WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>				
07G	8012	SHEARERS CREEK					
<b>NH3-N Acute Allocations</b>							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
1.950	Red Carpet Inn	16.64	50	16.64	50	0	0
<b>NH3-N Chronic Allocations</b>							
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
1.950	Red Carpet Inn	1.88	25	1.88	25	0	0
<b>Dissolved Oxygen Allocations</b>							
RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>	
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)
1.95	Red Carpet Inn	25	25	25	25	5	5
						0	0

### WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
07G	8012	SHEARERS CREEK		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
1.950	0.005	20.055	7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
12.218	0.479	25.522	0.116	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
2.25	0.098	0.27	0.703	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
8.207	20.028	Owens	5	
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>			
1.029	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.103	2.23	0.25	8.23
	0.206	2.21	0.24	8.23
	0.309	2.19	0.22	8.23
	0.412	2.16	0.21	8.23
	0.514	2.14	0.19	8.23
	0.617	2.12	0.18	8.23
	0.720	2.10	0.17	8.23
	0.823	2.08	0.15	8.23
	0.926	2.06	0.14	8.23
	1.029	2.04	0.13	8.23

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
07G	8012	SHEARERS CREEK					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
1.950	Red Carpet Inn	PA0261661	0.005	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			5



## Discharge Information

Instructions **Discharge** Stream

Facility: **The Red Carpet Inn** NPDES Permit No.: **PA0261661** Outfall No.: **001**

Evaluation Type: **Major Sewage / Industrial Waste** Wastewater Description: **Sewage Effluent**

Discharge Characteristics									
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)				Complete Mix Times (min)		
			AFC	CFC	THH	CRL	Q <sub>7-10</sub>	Q <sub>h</sub>	
0.0048	100	7							

		Discharge Pollutant	Units	Max Discharge Conc	Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteria Mod	Chem Transl
Group 1	Total Dissolved Solids (PWS)	mg/L											
	Chloride (PWS)	mg/L											
	Bromide	mg/L	<										
	Sulfate (PWS)	mg/L											
	Fluoride (PWS)	mg/L	<										
Group 2	Total Aluminum	µg/L											
	Total Antimony	µg/L	<										
	Total Arsenic	µg/L	<										
	Total Barium	µg/L											
	Total Beryllium	µg/L	<										
	Total Boron	µg/L	<										
	Total Cadmium	µg/L	<										
	Total Chromium (III)	µg/L											
	Hexavalent Chromium	µg/L											
	Total Cobalt	µg/L											
	Total Copper	mg/L	0.025										
	Free Cyanide	µg/L											
	Total Cyanide	µg/L	<										
	Dissolved Iron	µg/L											
	Total Iron	µg/L											
	Total Lead	µg/L	0.001										
	Total Manganese	µg/L											
	Total Mercury	µg/L	<										
	Total Nickel	µg/L											
	Total Phenols (Phenolics) (PWS)	µg/L											
	Total Selenium	µg/L	<										
	Total Silver	µg/L	<										
	Total Thallium	µg/L	<										
	Total Zinc	mg/L	0.015										
	Total Molybdenum	µg/L											
Group 3	Acrolein	µg/L	<										
	Acrylamide	µg/L	<										
	Acrylonitrile	µg/L	<										
	Benzene	µg/L	<										
	Bromoform	µg/L	<										







## Stream / Surface Water Information

Toxics Management Spreadsheet  
Version 1.4, May 2023

Instructions   **Discharge**   Stream

The Red Carpet Inn, NPDES Permit No. PA0261661, Outfall 001

Receiving Surface Water Name: **Susquehanna River**

No. Reaches to Model: 1

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi <sup>2</sup> )*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	008012	1.95	497	5.58			Yes
End of Reach 1	008012	0	445	6.63			Yes

**Q<sub>7-10</sub>**

Location	RMI	LFY (cfs/mi <sup>2</sup> )*	Flow (cfs)	W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary	Stream
	Stream	Tributary							Hardness	pH
Point of Discharge	1.95	0.1	0.67							
End of Reach 1	0	0.1	0.8						250	8.3

**Q<sub>h</sub>**

Location	RMI	LFY (cfs/mi <sup>2</sup> )*	Flow (cfs)	W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary	Stream
	Stream	Tributary							Hardness	pH
Point of Discharge	1.95									
End of Reach 1	0								250	8.3



## Model Results

Toxics Management Spreadsheet  
Version 1.4, May 2023

The Red Carpet Inn, NPDES Permit No. PA0261661, Outfall 001

<input type="button" value="Instructions"/>	<input checked="" type="button" value="Results"/>	<input type="button" value="RETURN TO INPUTS"/>	<input type="button" value="SAVE AS PDF"/>	<input type="button" value="PRINT"/>	<input checked="" type="radio"/> All	<input type="radio"/> Inputs	<input type="radio"/> Results	<input type="radio"/> Limits
---	---	---	--	--------------------------------------	--------------------------------------	------------------------------	-------------------------------	------------------------------

Hydrodynamics

Wasteload Allocations

AFC      CCT (min):       PMF:       Analysis Hardness (mg/l):       Analysis pH:

Pollutants	Stream Conc ( $\mu\text{g/L}$ )	Stream CV	Trib Conc ( $\mu\text{g/L}$ )	Fate Coef	WQC ( $\mu\text{g/L}$ )	WLA ( $\mu\text{g/L}$ )	Comments
Total Copper	0	0	0	0	31.667	33.0	Chem Translator of 0.96 applied
Total Lead	0	0	0	0	171.152	260	Chem Translator of 0.658 applied
Total Zinc	0	0	0	0	253.280	259	Chem Translator of 0.978 applied

**CFC** CCT (min): 8.503 PMF: 1 Analysis Hardness (mg/l): 248.36 Analysis pH: 8.22

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Copper	0	0	0	0	19.485	20.3	1,852	Chem Translator of 0.96 applied
Total Lead	0	0	0	0	6.670	10.1	924	Chem Translator of 0.658 applied
Total Zinc	0	0	0	0	255.352	259	23,626	Chem Translator of 0.986 applied

**THH** CCT (min): 8.503 PMF: 1 Analysis Hardness (mg/l): N/A Analysis pH: N/A

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Copper	0	0	0	0	N/A	N/A	N/A	
Total Lead	0	0	0	0	N/A	N/A	N/A	
Total Zinc	0	0	0	0	N/A	N/A	N/A	



## Recommended WQBELs & Monitoring Requirements

No. Samples/Month:

### **Other Pollutants without Limits or Monitoring**

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., < Target QL).

Comfort Inn  
PA0261661  
Spreadsheet to evaluate Non-Degradation of Water Quality

Parameter	Discharge Flow	WQ Objective	Stream Flow	Mean Concentration	Combined Flow	Concentration	Units	Multiplier	CAML	Non degrad Units
	Q discharge	C total	Q upstream	C upstream	Q total	C LTa				
CBOD5	0.0074	0.91	1.9782	0.88	1.9856	8.90	mg/L	1.72	15.31	mg/L CBOD5
TSS	0.0074	9	1.9782	8	1.9856	275.40	mg/L	1.72	473.69	mg/L TSS
NH3-N	0.0074	0.029	1.9782	0.027	1.9856	0.56	mg/L	1.72	0.97	mg/L NH3-N
NO2/NO3-N	0.0074	0.51	1.9782	0.49	1.9856	5.84	mg/L	1.72	10.04	mg/L NO2/NO3-N
Phosphorus	0.0074	0.024	1.9782	0.023	1.9856	0.29	mg/L	1.72	0.50	mg/L Phosphorus
TRC	0.0074	0	1.9782	0	1.9856	0.00	mg/L	1.72	0.00	mg/L TRC
Lead Total	0.0074	1.4	1.9782	1.2	1.9856	54.68	ug/L	1.72	94.05	ug/L Lead Total
Copper Total	0.0074	4.6	1.9782	4.5	1.9856	31.24	ug/L	1.72	53.73	ug/L Copper Total
Iron Total	0.0074	230	1.9782	199	1.9856	8488.41	ug/L	1.72	14600.06	ug/L Iron Total
Sulfate	0.0074	25	1.9782	22	1.9856	824.20	mg/L	1.72	1417.63	mg/L Sulfate
Aluminum Total	0.0074	115	1.9782	107	1.9856	2246.20	ug/L	1.72	3863.47	ug/L Aluminum Total
TDS	0.0074	96	1.9782	91	1.9856	1428.00	mg/L	1.72	2456.16	mg/L TDS
Zinc Total	0.0074	8.7	1.9782	8.2	1.9856	141.90	ug/L	1.72	244.07	ug/L Zinc Total
		CFS	Qhm-CFS		CFS					

ABACT Tech Limits-Sewage cases

	Q Discharge	0.0048 mgd	Q Upstream Q <sub>7-10</sub>	0.22 cfs	0.0074 cfs
					1.9782 Q <sub>hm</sub> cfs
Parameter					
	<2000 gpd	50,000 gpd	>50,000 gpd		
	Limit	Limit	Limit		
CBOD5	5/1 to 10/31	10	10	10	
CBOD5	11/1 to 4/30	20	20	10	
TSS		20	10	10	
NH3-N	5/1 to 10/31	5	3	1.5	
NH3-N	11/1 to 4/30	15	9	4.5	
Disinfection		UV/ND	UV/ND	UV/ND	

Notes

- Preliminary Limitations are the more stringent of ABACT, Non-degradation or WQBEI for each parameter of concern.
- WQ Objective C total and Mean Concentration C upstream abstracted from Table 3 of the Water Quality Antidegradation Implementation Guidance
- Average Monthly Limit has a default value of 1.72 (Water Quality Antidegradation Implementation Guidance, page 64)