

Application Type Renewal
 Facility Type Non-Municipal
 Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0262137
 APS ID 820007
 Authorization ID 1308381

Applicant and Facility Information

| | | | |
|---------------------------|--|------------------|---|
| Applicant Name | <u>Log Cabin Court Mobile Home Park</u> | Facility Name | <u>Log Cabin Court MHP</u> |
| Applicant Address | <u>123 Gilpin Drive</u> <u>West Chester, PA 19382</u> | Facility Address | <u>Lobin Road</u> <u>Earl Township, PA 17519</u> |
| Applicant Contact | <u>P.C.S. Chadaga</u> | Facility Contact | <u>P.C.S Chadaga</u> |
| Applicant Phone | <u>(484) 887-8247</u> | Facility Phone | <u>(484) 887-8247</u> |
| Client ID | <u>306529</u> | Site ID | <u>2332</u> |
| Ch 94 Load Status | <u>Not Overloaded</u> | Municipality | <u>Earl Township</u> |
| Connection Status | <u>No Limitations</u> | County | <u>Lancaster</u> |
| Date Application Received | <u>March 4, 2020</u> | EPA Waived? | <u>Yes</u> |
| Date Application Accepted | <u>March 13, 2020</u> | If No, Reason | <u></u> |
| Purpose of Application | <u>NPDES Renewal.</u> | | |

Summary of Review

Log Cabin Court MHP has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of its National Pollutant Discharge Elimination System (NPDES) permit. The permit was issued September 15, 2015 and became effective on October 1, 2015, authorizing discharge of treated sewage from the existing wastewater treatment plant (WWTP) located in Earl Township, Lancaster County into UNT to Conestoga River. The existing permit expiration date was September 30, 2020, and the permit has been administratively extended since that time.

Per the previous fact sheet, the WWTP has been designed to serve an existing 16.5 acre mobile home park, which contains 82 mobile home sites. A point of first use survey was performed by a DEP biologist on December 22, 2011. Three different potential discharge points were examined for the proposed facility. It was determined that the point of first use for all three sites was at the proposed discharge points. On January 25, 2012, DEP sent a letter to the Applicant which included preliminary effluent limitations for the three proposed outfall locations. The application received on August 2, 2013 indicated the intent to use proposed "Discharge Point C." The previous permit limitations were developed for this discharge point.

Changes in this renewal: Monthly calculation of Net TN and Net TP has been removed from the permit. E.Coli monitoring has been added to the permit.

Sludge use and disposal description and location(s): Offsite WWTP

Supplemental information for this report is provided at the end of the fact sheet.

Public Participation

| Approve | Deny | Signatures | Date |
|---------|------|---|---------------|
| X | | <i>Benjamin R. Lockwood</i> Benjamin R. Lockwood / Environmental Engineering Specialist | June 7, 2021 |
| X | | <i>Maria D. Bebenek for Daniel W. Martin</i> Daniel W. Martin, P.E. / Environmental Engineer Manager | June 15, 2021 |
| X | | <i>Maria D. Bebenek</i> Maria D. Bebenek, P.E. / Program Manager | June 15, 2021 |

Summary of Review

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

| Discharge, Receiving Waters and Water Supply Information | | | |
|--|--|------------------------------|----------------------------|
| Outfall No. | <u>001</u> | Design Flow (MGD) | <u>.014</u> |
| Latitude | <u>40° 7' 45"</u> | Longitude | <u>76° 4' 44"</u> |
| Quad Name | <u>Terre Hill</u> | Quad Code | <u>1737</u> |
| Wastewater Description: <u>Sewage Effluent</u> | | | |
| Receiving Waters | <u>Unnamed Tributary to Conestoga River (CWF, MF)</u> | Stream Code | <u>07792</u> |
| NHD Com ID | <u>57462453</u> | RMI | <u>1.6</u> |
| Drainage Area | <u>1.49 mi²</u> | Yield (cfs/mi ²) | <u>0.039</u> |
| Q ₇₋₁₀ Flow (cfs) | <u>0.0585</u> | Q ₇₋₁₀ Basis | <u>USGS PA StreamStats</u> |
| Elevation (ft) | <u>369</u> | Slope (ft/ft) | <u></u> |
| Watershed No. | <u>7-J</u> | Chapter 93 Class. | <u>CWF, MF</u> |
| Existing Use | <u>N/A</u> | Existing Use Qualifier | <u>N/A</u> |
| Exceptions to Use | <u>N/A</u> | Exceptions to Criteria | <u>N/A</u> |
| Assessment Status | <u>Impaired</u> | | |
| Cause(s) of Impairment | <u>Pathogens, Pathogens, Nutrients</u> | | |
| Source(s) of Impairment | <u>Agriculture, Urban Runoff/Storm Sewers, Agriculture</u> | | |
| TMDL Status | <u>N/A</u> | Name | <u>N/A</u> |
| Nearest Downstream Public Water Supply Intake | <u>Lancaster City Water Bureau</u> | | |
| PWS Waters | <u>Conestoga River</u> | Flow at Intake (cfs) | <u></u> |
| PWS RMI | <u></u> | Distance from Outfall (mi) | <u>22.5</u> |

Changes Since Last Permit Issuance: USGS PA StreamStats provided a drainage area of 1.49 mi² and a Q₇₋₁₀ of 0.0585 cfs at the point of discharge.

Other Comments: None

| Treatment Facility Summary | | | | |
|----------------------------|----------------------------|-------------------|---------------------|------------------------|
| Waste Type | Degree of Treatment | Process Type | Disinfection | Avg Annual Flow (MGD) |
| Sewage | Secondary | Extended Aeration | Hypochlorite | 0.014 |
| | | | | |
| Hydraulic Capacity (MGD) | Organic Capacity (lbs/day) | Load Status | Biosolids Treatment | Biosolids Use/Disposal |
| 0.014 | 28 | Not Overloaded | Sludge Holding | Other WWTP |

Changes Since Last Permit Issuance: None

Other Comments: The WWTP process consists of the following:

Equalization Tank – 2 Aeration Tanks – Clarifier – Chlorine Contact Tank (with tablet feed) – Post Aeration Tank – Outfall 001 to UNT to Conestoga River.

| Compliance History | |
|--------------------------------|--|
| Summary of DMRs: | A summary of the past 12-month DMR effluent data is presented on the next page of this fact sheet. |
| Summary of Inspections: | 12/6/2017: A routine inspection was conducted. The treatment units appeared to be operating normally. No other issues were noted. 6/23/2020: An administrative inspection was conducted. The WWTP was operating normally, and all units were online. At the time of inspection there were no outstanding issues or needs at the facility. |

Other Comments: There are currently no open violations associated with the permittee or facility.

Compliance History

DMR Data for Outfall 001 (from April 1, 2020 to March 31, 2021)

| Parameter | MAR-21 | FEB-21 | JAN-21 | DEC-20 | NOV-20 | OCT-20 | SEP-20 | AUG-20 | JUL-20 | JUN-20 | MAY-20 | APR-20 |
|--|---------|---------|---------|---------|---------|---------|---------|--------------|---------|---------|--------------|---------|
| Flow (MGD) Average Monthly | 0.0063 | 0.00612 | 0.00586 | 0.00693 | 0.00674 | 0.00611 | 0.00606 | 0.00659 7 | 0.00676 | 0.00627 | 0.00675 2 | 0.00686 |
| Flow (MGD) Daily Maximum | 0.00973 | 0.01346 | 0.0085 | 0.01369 | 0.01008 | 0.00976 | 0.01005 | 0.01312 | 0.0117 | 0.00817 | 0.01119 7 | 0.01118 |
| pH (S.U.) Minimum | 7.26 | 7.19 | 7.39 | 7.39 | 7.41 | 7.32 | 7.42 | 7.37 | 7.33 | 7.26 | 7.19 | 7.11 |
| pH (S.U.) Maximum | 7.57 | 7.68 | 7.74 | 7.66 | 7.65 | 7.67 | 7.71 | 7.74 | 7.84 | 7.65 | 7.8 | 7.82 |
| DO (mg/L) Minimum | 7.2 | 8.18 | 8.75 | 8.16 | 7.2 | 7.85 | 6.67 | 6.09 | 5.46 | 7.3 | 6.83 | 7.01 |
| CBOD5 (mg/L) Average Monthly | 5.1 | 2.6 | < 2.1 | < 2 | < 2 | < 2 | < 2 | < 2 | < 2 | < 2 | < 2.1 | < 2.2 |
| TSS (mg/L) Average Monthly | < 12 | < 4 | < 4 | < 4 | < 4 | < 4 | < 4 | < 4 | < 4 | < 4 | < 4 | < 4 |
| Fecal Coliform (CFU/100 ml) Geometric Mean | 552 | 2 | < 1 | < 50 | < 1 | < 1 | < 1 | < 6 | < 1 | < 1 | < 1 | < 1 |
| Fecal Coliform (CFU/100 ml) Instantaneous Maximum | 1200 | 3 | < 1 | 2500 | 2 | 1 | < 1 | 31 | 1 | 2 | < 1 | 1 |
| UV Intensity (mW/cm ²) Minimum | 19.47 | 11.27 | 18.48 | 20.79 | 20.79 | 22.88 | 24.9 | 20.79 | 22.11 | 24.09 | 24.41 | 22.11 |
| UV Intensity (mW/cm ²) Average Monthly | 24.53 | 21.03 | 23.02 | 24.47 | 24.53 | 26.09 | 26.75 | 26.71 | 26.16 | 27.09 | 27.27 | 26.68 |
| Nitrate-Nitrite (mg/L) Average Monthly | 7.01 | 18.87 | 17.5 | 28.2 | 43.8 | 35 | 31.8 | 15.99 | 15.1 | 17.7 | 28.9 | 12.69 |
| Nitrate-Nitrite (lbs) Total Monthly | 11 | 24 | 22 | 49 | 66 | 50 | 44 | 21 | 28 | 27 | 32 | 18 |
| Total Nitrogen (mg/L) Average Monthly | 9.61 | 26.3 | 18.3 | < 28.7 | < 44.3 | < 35.6 | 32.9 | < 16.49 | 16.1 | 18.8 | < 30.3 | 17.4 |
| Total Nitrogen (lbs) Effluent Net Total Monthly | 15 | 32 | 23 | < 50 | < 67 | < 51 | 46 | < 22 | 30 | 29 | < 34 | 25 |
| Total Nitrogen (lbs) Total Monthly | 15 | 32 | 23 | < 50 | < 67 | < 51 | 46 | < 22 | 30 | 29 | < 34 | 25 |

NPDES Permit Fact Sheet
Log Cabin Court MHP

NPDES Permit No. PA0262137

| | | | | | | | | | | | | | |
|---|------|------|--------|-------|-------|-------|------------------|-------|-------|-------|--------|-------|-------|
| Total Nitrogen (lbs) Effluent Net Total Annual | | | | | | | < NULL59 2 | | | | | | |
| Total Nitrogen (lbs) Total Annual | | | | | | | < 483 | | | | | | |
| Ammonia (mg/L) Average Monthly | 0.79 | 4.72 | < 0.11 | < 0.1 | < 0.1 | < 0.1 | < 0.1 | < 0.1 | < 0.1 | < 0.1 | < 0.1 | < 0.5 | < 3.4 |
| Ammonia (lbs) Total Monthly | 1 | 5 | < 0.1 | < 0.2 | < 0.2 | < 0.1 | < 0.1 | < 0.1 | < 0.1 | < 0.2 | < 0.2 | < 0.6 | < 5 |
| Ammonia (lbs) Total Annual | | | | | | | < 22 | | | | | | |
| TKN (mg/L) Average Monthly | 2.61 | 7.4 | 0.81 | < 0.5 | < 0.5 | < 0.6 | 1.15 | < 0.5 | 0.96 | 1.12 | < 1.44 | 4.7 | |
| TKN (lbs) Total Monthly | 5 | 8 | 1 | < 0.9 | < 0.8 | < 0.8 | 2 | < 0.7 | 2 | 2 | < 2.0 | 7 | |
| Total Phosphorus (mg/L) Average Monthly | 0.56 | 0.23 | 0.23 | 0.14 | 0.14 | 0.21 | 0.32 | 0.68 | 0.8 | 0.64 | 0.57 | 0.69 | |
| Total Phosphorus (lbs) Effluent Net Total Monthly | 1 | 0.2 | 0.3 | 0.2 | 0.2 | 0.3 | 0.4 | 1 | 1 | 1 | 0.6 | 1 | |
| Total Phosphorus (lbs) Total Monthly | 1 | 0.2 | 0.3 | 0.2 | 0.2 | 0.3 | 0.4 | 1 | 1 | 1 | 0.6 | 1 | |
| Total Phosphorus (lbs) Effluent Net Total Annual | | | | | | | < NULL | | | | | | |
| Total Phosphorus (lbs) Total Annual | | | | | | | < 8 | | | | | | |

Existing Effluent Limitations and Monitoring Requirements

The tables below summarize the effluent limits and monitoring requirements implemented in the existing NPDES permit.

Outfall 001

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|---|-------------------------------------|---------------------|--------------------------|--------------------|---------|---------------------|--|----------------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Average Weekly | Instantaneous Minimum | Average Monthly | Maximum | Instant. Maximum | | |
| Flow (MGD) | Report | Report Daily Max | XXX | XXX | XXX | XXX | Continuous | Measured |
| pH (S.U.) | XXX | XXX | 6.0 | XXX | XXX | 9.0 | 1/day | Grab |
| DO | XXX | XXX | 5.0 | XXX | XXX | XXX | 1/day | Grab |
| UV Intensity (mW/cm ²) | XXX | XXX | Report | Report | XXX | XXX | 1/day | Recorded |
| CBOD5 | XXX | XXX | XXX | 25 | XXX | 50 | 2/month | 8-Hr Composite |
| TSS | XXX | XXX | XXX | 30 | XXX | 60 | 2/month | 8-Hr Composite |
| Fecal Coliform (No./100 ml) Oct 1 - Apr 30 | XXX | XXX | XXX | 2,000 Geo Mean | XXX | 10,000 | 2/month | Grab |
| Fecal Coliform (No./100 ml) May 1 - Sep 30 | XXX | XXX | XXX | 200 Geo Mean | XXX | 1,000 | 2/month | Grab |
| Ammonia Nov 1 - Apr 30 | XXX | XXX | XXX | 12 | XXX | 24 | 2/month | 8-Hr Composite |
| Ammonia May 1 - Oct 31 | XXX | XXX | XXX | 4.0 | XXX | 8.0 | 2/month | 8-Hr Composite |
| Total Phosphorus | XXX | XXX | XXX | 0.8 | XXX | 1.6 | 2/month | 8-Hr Composite |

Compliance Sampling Location: At discharge from facility

Outfall 001

| Parameter | Effluent Limitations | | | | | Monitoring Requirements | |
|----------------------|-------------------------------------|--------|-----------------------|--------------------|---------|--|----------------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Monthly | Annual | Monthly | Monthly Average | Maximum | | |
| Ammonia---N | Report | Report | XXX | Report | XXX | 2/month | 8-Hr Composite |
| Kjeldahl---N | Report | XXX | XXX | Report | XXX | 2/month | 8-Hr Composite |
| Nitrate-Nitrite as N | Report | XXX | XXX | Report | XXX | 2/month | 8-Hr Composite |
| Total Nitrogen | Report | Report | XXX | Report | XXX | 2/month | Calculation |
| Total Phosphorus | Report | Report | XXX | Report | XXX | 2/month | 8-Hr Composite |
| Net Total Nitrogen | Report | 0 | XXX | XXX | XXX | 1/month | Calculation |
| Net Total Phosphorus | Report | 0 | XXX | XXX | XXX | 1/month | Calculation |

Compliance Sampling Location: At discharge from facility

- The existing NPDES Permit authorizes the permittee to use 2,075 lbs/year as Total Nitrogen (TN) Offsets toward compliance with the Annual Net TN mass load limitations.

Development of Effluent Limitations

Outfall No. 001
 Latitude 40° 7' 45"
 Wastewater Description: Sewage Effluent

Design Flow (MGD) .014
 Longitude 76° 4' 44"

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

| Pollutant | Limit (mg/l) | SBC | Federal Regulation | State Regulation |
|------------------------------|-----------------|-----------------|--------------------|------------------|
| CBOD ₅ | 25 | Average Monthly | 133.102(a)(4)(i) | 92a.47(a)(1) |
| | 40 | Average Weekly | 133.102(a)(4)(ii) | 92a.47(a)(2) |
| Total Suspended Solids | 30 | Average Monthly | 133.102(b)(1) | 92a.47(a)(1) |
| | 45 | Average Weekly | 133.102(b)(2) | 92a.47(a)(2) |
| pH | 6.0 – 9.0 S.U. | Min – Max | 133.102(c) | 95.2(1) |
| Fecal Coliform (5/1 – 9/30) | 200 / 100 ml | Geo Mean | - | 92a.47(a)(4) |
| Fecal Coliform (5/1 – 9/30) | 1,000 / 100 ml | IMAX | - | 92a.47(a)(4) |
| Fecal Coliform (10/1 – 4/30) | 2,000 / 100 ml | Geo Mean | - | 92a.47(a)(5) |
| Fecal Coliform (10/1 – 4/30) | 10,000 / 100 ml | IMAX | - | 92a.47(a)(5) |
| Total Residual Chlorine | 0.5 | Average Monthly | - | 92a.48(b)(2) |

Water Quality-Based Limitations

Pursuant to 40 CFR § 122.44(d)(1)(i), more stringent requirements should be considered when pollutants are discharged at the levels which have the reasonable potential to cause or contribute to excursions above water quality standards.

WQM 7.0 ver. 1.1b is a water quality model designed to assist DEP in determining appropriate water quality based effluent limits (WQBELs) for carbonaceous biochemical oxygen demand (CBOD₅), ammonia (NH₃-N) and dissolved oxygen (D.O.). DEP's Technical Guidance No. 391-2000-007 provides the technical methods contained in WQM 7.0 for determining wasteload allocations and for determining recommended NPDES effluent limits for point source discharges. The model was utilized for this permit renewal. An existing discharge (Nexans Inc PA0084247) was included in the modeling, as it is located less than 0.01 miles away. The model output indicated a CBOD₅ average monthly limit of 25 mg/l, an NH₃-N average monthly limit of 4.82 mg/l, and a D.O. minimum limit of 5.0 mg/l were protective of water quality. The flow data used to run the model was acquired from USGS PA StreamStats, and is included as an attachment. Rounded in accordance with DEP's Technical Guidance No. 362-0400-001, an NH₃-N average monthly limit of 4.8 mg/l would be required. The CBOD₅ limit is the same as the limit in the existing permit, which will remain. The existing NH₃-N permit limit of 4.0 mg/l is more stringent and will remain in the permit.

There are no industrial/commercial users contributing industrial wastewater to the system and Log Cabin Court MHP does not currently have an EPA-approved pretreatment program. Accordingly, evaluating reasonable potential of toxic pollutants is not necessary as effluent levels of toxic pollutants are expected to be insignificant.

Best Professional Judgement (BPJ) Limitations

Dissolved Oxygen

A minimum D.O. limit of 5.0 mg/L is a D.O. water quality criterion found in 25 Pa. Code § 93.7(a). This limit is included in the existing NPDES permit. This limit will remain in the permit to ensure that the facility will achieve compliance with DEP water quality standards.

Total Phosphorus

For Total Phosphorus (TP), the current NPDES permit requires the permittee to comply with average monthly and IMAX limits of 0.8 mg/l and 1.6 mg/l, respectively. Due to the nutrient-based impairment for the receiving stream, these limits were put into place with coordination from the permittee. The TP limit of 0.8 mg/l was used for operational reasons, as the small facility would be able to meet this limit more easily than a limit of 0.5 mg/l. These limits will remain in the renewal permit.

Additional Considerations

Chesapeake Bay Total Maximum Daily Load (TMDL)

DEP developed a strategy to comply with the EPA and Chesapeake Bay Foundation requirements by reducing point source loadings of Total Nitrogen (TN) and Total Phosphorus (TP). This strategy can be located in the *Pennsylvania Chesapeake Watershed Implementation Plan* (WIP), dated January 11, 2011. Subsequently, an update to the WIP was published as the Phase 2 WIP. As part of the Phase 2 WIP, a *Phase 2 Watershed Implementation Plan Wastewater Supplement* (Phase 2 Supplement) was developed, providing an update on TMDL implementation for point sources and DEP's current implementation strategy for wastewater. A new update to the WIP was published as the Phase 3 WIP in August 2019. As part of the Phase 3 WIP, a *Phase 3 Watershed Implementation Plan Wastewater Supplement* (Phase 3 Supplement) was developed, and was most recently revised on December 17, 2019, and is the basis for the development of any Chesapeake Bay related permit parameters. Sewage discharges have been prioritized based on their design flow to the Bay. The highest priority (Phases 1, 2, and 3) dischargers will receive annual Cap Loads based on their design flow on August 29, 2005 and concentrations of 6 mg/l TN and 0.8 mg/l TP. These limits may be achieved through a combination of treatment technology, credits, or offsets. For Phase 4 and 5 facilities, Cap Loads are not currently being implemented for renewed or amended permits for facilities that do not increase design flow. For new Phase 4 and 5 sewage dischargers, in general DEP will issue new permits containing Cap Loads of "0" and new facilities will be expected to purchase credits and/or apply offsets to achieve compliance.

This facility is considered a Phase 5 non-significant discharger with a design flow less than 0.2 MGD but greater than 0.002 MGD. As this was a new facility, per the Phase 3 Supplement, a Cap Load of "0" was placed in the permit for TN and TP. For TN, the use of offsets was allowed. The permit authorizes the use of 2,075 lbs/year as TN Offsets for the connection of on-lot sewage disposal systems to the WWTP serving 83 EDUs. These Cap Loads will remain in the renewal permit. DEP no longer offers any tools to calculate the monthly loads for Net TN and Net TP, and these calculations are no longer needed since offsets and credits are applied annually. Therefore, this reporting requirement is no longer needed and will be removed from the permit.

Fecal Coliform

PA Code § 92a.47.(a)(4) requires a monthly average limit of 200/100 mL as a geometric mean and an instantaneous maximum limit not greater than 1,000/100 mL from May through September for fecal coliform. PA Code § 92a.47.(a)(5) requires a monthly average limit of 2,000/100 mL as a geometric mean and an instantaneous maximum limit not greater than 10,000/100 mL from October through April for fecal coliform. These limits are included in the existing permit, and will remain in the permit.

E. Coli

PA Code § 92a.61 requires IMAX reporting of E. Coli. Per DEP's SOP No. BCW-PMT-033, sewage dischargers with a design flow of 0.002 – 0.05 mgd will include E. Coli monitoring with a frequency of 1/year. This parameter has been added to the renewal permit.

UV Monitoring

DEP's SOP No. BPNPSM-PMT-033 recommends at a minimum, routine monitoring of UV transmittance, dosage, or intensity when the facility is utilizing a UV disinfection system. The monitoring should occur at the same frequency as would be used for TRC. This recommendation was implemented as a part of the proper operation and maintenance requirement specified in Part B of the NPDES permit, requesting permittees to demonstrate the effectiveness of UV disinfection system. This approach has been assigned to other facilities equipped with similar technology. The existing permit has a monitoring requirement for UV intensity, which will remain in the permit.

Sampling Frequency & Sample Type

The monitoring requirements were established based on the BPJ and/or Table 6-3 of DEP's technical guidance No. 362-0400-001.

Flow Monitoring

Flow monitoring is recommended by DEP's technical guidance and is also required by 25 PA Code §§ 92a.27 and 92a.61.

Anti-Degradation

The effluent limits for this discharge have been developed to ensure that existing instream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High Quality Waters are impacted by this discharge. No Exceptional Value Waters are impacted by this discharge.

303(d) Listed Streams

The discharge is located on a stream segment that is designated on the 303(d) list as impaired. There is a recreational impairment for pathogens due to agriculture and urban/runoff storm sewers. There is an aquatic life impairment for nutrients due to agriculture.

Class A Wild Trout Fisheries

No Class A Wild Trout Fisheries are impacted by this discharge.

Anti-Backsliding

Pursuant to 40 CFR § 122.44(l)(1), all proposed permit requirements addressed in this fact sheet are at least as stringent as the requirements implemented in the existing NPDES permit unless any exceptions addressed by DEP in this fact sheet.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|---|-------------------------------------|------------------|-----------------------|-------------------|---------|------------------|--|----------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Average Weekly | Instantaneous Minimum | Average Monthly | Maximum | Instant. Maximum | | |
| Flow (MGD) | Report | Report Daily Max | XXX | XXX | XXX | XXX | Continuous | Measured |
| pH (S.U.) | XXX | XXX | 6.0 | XXX | XXX | 9.0 | 1/day | Grab |
| DO | XXX | XXX | 5.0 | XXX | XXX | XXX | 1/day | Grab |
| CBOD5 | XXX | XXX | XXX | 25 | XXX | 50 | 2/month | 8-Hr Composite |
| TSS | XXX | XXX | XXX | 30 | XXX | 60 | 2/month | 8-Hr Composite |
| Fecal Coliform (No./100 ml) Oct 1 - Apr 30 | XXX | XXX | XXX | 2,000 Geo Mean | XXX | 10,000 | 2/month | Grab |
| Fecal Coliform (No./100 ml) May 1 - Sep 30 | XXX | XXX | XXX | 200 Geo Mean | XXX | 1,000 | 2/month | Grab |
| E. Coli (No./100 ml) | XXX | XXX | XXX | XXX | XXX | Report | 1/year | Grab |
| UV Intensity (mW/cm ²) | XXX | XXX | Report | Report | XXX | XXX | 1/day | Recorded |
| Ammonia Nov 1 - Apr 30 | XXX | XXX | XXX | 12 | XXX | 24 | 2/month | 8-Hr Composite |
| Ammonia May 1 - Oct 31 | XXX | XXX | XXX | 4.0 | XXX | 8.0 | 2/month | 8-Hr Composite |
| Total Phosphorus | XXX | XXX | XXX | 0.8 | XXX | 1.6 | 2/month | 8-Hr Composite |

Compliance Sampling Location: At discharge from facility

Other Comments: None

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, to comply with Pennsylvania's Chesapeake Bay Tributary Strategy.


Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|----------------------|---------------------------------|--------|-----------------------|-----------------|---------|------------------|--|----------------------|
| | Mass Units (lbs) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Monthly | Annual | Monthly | Monthly Average | Maximum | Instant. Maximum | | |
| Ammonia-N | Report | Report | XXX | Report | XXX | XXX | 2/month | 8-Hr Composite |
| Kjeldahl-N | Report | XXX | XXX | Report | XXX | XXX | 2/month | 8-Hr Composite |
| Nitrate-Nitrite as N | Report | XXX | XXX | Report | XXX | XXX | 2/month | 8-Hr Composite |
| Total Nitrogen | Report | Report | XXX | Report | XXX | XXX | 1/month | Calculation |
| Total Phosphorus | Report | Report | XXX | Report | XXX | XXX | 2/month | 8-Hr Composite |
| Net Total Nitrogen | XXX | 0 | XXX | XXX | XXX | XXX | 1/year | Calculation |
| Net Total Phosphorus | XXX | 0 | XXX | XXX | XXX | XXX | 1/year | Calculation |

Compliance Sampling Location: At discharge from facility

Other Comments: 2,075 lbs/year of TN Offsets are approved to be used for compliance with the TN Cap Load of 0 lbs/year.

| Tools and References Used to Develop Permit | |
|---|--|
| <input checked="" type="checkbox"/> | WQM for Windows Model (see Attachment [redacted]) |
| <input type="checkbox"/> | Toxics Management Spreadsheet (see Attachment [redacted]) |
| <input type="checkbox"/> | TRC Model Spreadsheet (see Attachment [redacted]) |
| <input type="checkbox"/> | Temperature Model Spreadsheet (see Attachment [redacted]) |
| <input type="checkbox"/> | Water Quality Toxics Management Strategy, 361-0100-003, 4/06. |
| <input checked="" type="checkbox"/> | Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97. |
| <input type="checkbox"/> | Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98. |
| <input type="checkbox"/> | Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96. |
| <input type="checkbox"/> | Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97. |
| <input type="checkbox"/> | Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97. |
| <input type="checkbox"/> | Pennsylvania CSO Policy, 385-2000-011, 9/08. |
| <input checked="" type="checkbox"/> | Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03. |
| <input type="checkbox"/> | Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97. |
| <input checked="" type="checkbox"/> | Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97. |
| <input type="checkbox"/> | Implementation Guidance Design Conditions, 391-2000-006, 9/97. |
| <input checked="" type="checkbox"/> | Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004. |
| <input type="checkbox"/> | Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997. |
| <input type="checkbox"/> | Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99. |
| <input type="checkbox"/> | Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004. |
| <input type="checkbox"/> | Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97. |
| <input type="checkbox"/> | Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008. |
| <input type="checkbox"/> | Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994. |
| <input type="checkbox"/> | Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09. |
| <input type="checkbox"/> | Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97. |
| <input type="checkbox"/> | Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97. |
| <input type="checkbox"/> | Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99. |
| <input type="checkbox"/> | Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999. |
| <input type="checkbox"/> | Design Stream Flows, 391-2000-023, 9/98. |
| <input type="checkbox"/> | Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98. |
| <input type="checkbox"/> | Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97. |
| <input type="checkbox"/> | Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07. |
| <input type="checkbox"/> | SOP: [redacted] |
| <input type="checkbox"/> | Other: [redacted] |



Copyright: © 2013 National Geographic Society. i-cubed

Enter report title:

Log Cabin Court MHP PA0262137 Outfall 001

Enter comments:

Some comments here

Log Cabin Court MHP PA0262137 Outfall 001

Region ID:

PA

Workspace ID:


PA20210506111945333000

Clicked Point (Latitude, Longitude):

40.12898, -76.07882

Time:

2021-05-06 07:19:57 -0400



Basin Characteristics

| Parameter Code | Parameter Description | Value | Unit |
|----------------|--|---------|--------------|
| DRNAREA | Area that drains to a point on a stream | 1.49 | square miles |
| BSLOPD | Mean basin slope measured in degrees | 2.0273 | degrees |
| ROCKDEP | Depth to rock | 5 | feet |
| URBAN | Percentage of basin with urban development | 14.0822 | percent |

Low-Flow Statistics Parameters [Low Flow Region 1]

| Parameter Code | Parameter Name | Value | Units | Min Limit | Max Limit |
|----------------|--------------------------|---------|--------------|-----------|-----------|
| DRNAREA | Drainage Area | 1.49 | square miles | 4.78 | 1150 |
| BSLOPD | Mean Basin Slope degrees | 2.0273 | degrees | 1.7 | 6.4 |
| ROCKDEP | Depth to Rock | 5 | feet | 4.13 | 5.21 |
| URBAN | Percent Urban | 14.0822 | percent | 0 | 89 |

Low-Flow Statistics Disclaimers [Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors

Low-Flow Statistics Flow Report [Low Flow Region 1]

| Statistic | Value | Unit |
|-------------------------|--------|--------------------|
| 7 Day 2 Year Low Flow | 0.165 | ft ³ /s |
| 30 Day 2 Year Low Flow | 0.253 | ft ³ /s |
| 7 Day 10 Year Low Flow | 0.0585 | ft ³ /s |
| 30 Day 10 Year Low Flow | 0.0937 | ft ³ /s |
| 90 Day 10 Year Low Flow | 0.213 | ft ³ /s |

Low-Flow Statistics Citations

[Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p.](#)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.5.2

StreamStats Services Version: 1.2.22

NSS Services Version: 2.1.1

Enter report title:


Log Cabin Court MHP PA0262137 Downstream Point RMI = 0.0

Enter comments:

Some comments here

Log Cabin Court MHP PA0262137 Downstream Point RMI = 0.0

| | |
|--------------------------------------|---------------------------|
| Region ID: | PA |
| Workspace ID: | PA20210506113305835000 |
| Clicked Point (Latitude, Longitude): | 40.14905, -76.09028 |
| Time: | 2021-05-06 07:33:17 -0400 |



Basin Characteristics

| Parameter Code | Parameter Description | Value | Unit |
|----------------|--|--------|--------------|
| DRNAREA | Area that drains to a point on a stream | 2.74 | square miles |
| BSLOPD | Mean basin slope measured in degrees | 1.8089 | degrees |
| ROCKDEP | Depth to rock | 5 | feet |
| URBAN | Percentage of basin with urban development | 8.0522 | percent |

Low-Flow Statistics Parameters [Low Flow Region 1]

| Parameter Code | Parameter Name | Value | Units | Min Limit | Max Limit |
|----------------|--------------------------|--------|--------------|-----------|-----------|
| DRNAREA | Drainage Area | 2.74 | square miles | 4.78 | 1150 |
| BSLOPD | Mean Basin Slope degrees | 1.8089 | degrees | 1.7 | 6.4 |
| ROCKDEP | Depth to Rock | 5 | feet | 4.13 | 5.21 |
| URBAN | Percent Urban | 8.0522 | percent | 0 | 89 |

Low-Flow Statistics Disclaimers [Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors

Low-Flow Statistics Flow Report [Low Flow Region 1]

| Statistic | Value | Unit |
|-------------------------|--------|--------------------|
| 7 Day 2 Year Low Flow | 0.237 | ft ³ /s |
| 30 Day 2 Year Low Flow | 0.37 | ft ³ /s |
| 7 Day 10 Year Low Flow | 0.0805 | ft ³ /s |
| 30 Day 10 Year Low Flow | 0.132 | ft ³ /s |
| 90 Day 10 Year Low Flow | 0.315 | ft ³ /s |

Low-Flow Statistics Citations

[Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p.](#)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.5.2

StreamState Services Version: 1.2.22

NSS Services Version: 2.1.1

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|-----------|-------------|-------------------------------|-------|----------------|-----------------------|---------------|----------------------|-------------------------------------|
| 07J | 7792 | Trib 07792 to Conestoga River | 1.600 | 369.00 | 1.49 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY | Trib Flow | Stream Flow | Rch Trav Time | Rch Velocity | WD Ratio | Rch Width | Rch Depth | Tributary Temp | Tributary pH | Stream Temp | Stream pH |
|--------------|--------|-----------|-------------|---------------|--------------|----------|-----------|-----------|----------------|--------------|-------------|-----------|
| | (cfsm) | (cfs) | (cfs) | (days) | (fps) | | (ft) | (ft) | (°C) | | (°C) | |
| Q7-10 | 0.100 | 0.00 | 0.06 | 0.000 | 0.000 | 0.0 | 0.00 | 0.00 | 20.00 | 7.00 | 0.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |

Discharge Data

| Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
|-----------|---------------|--------------------------|---------------------------|------------------------|----------------|----------------|---------|
| Log Cabin | PA0262137 | 0.0140 | 0.0140 | 0.0140 | 0.000 | 25.00 | 7.00 |

Parameter Data

| Parameter Name | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) |
|------------------|------------------|------------------|--------------------|--------------------|
| CBOD5 | 25.00 | 2.00 | 0.00 | 1.50 |
| Dissolved Oxygen | 5.00 | 8.24 | 0.00 | 0.00 |
| NH3-N | 25.00 | 0.00 | 0.00 | 0.70 |

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|-----------|------------------------------------|-------------|-------|----------------|-----------------------|---------------|----------------------|-------------------------------------|
| 07J | 7792 Trib 07792 to Conestoga River | | 1.590 | 368.00 | 1.50 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY (cfsm) | Trib Flow (cfs) | Stream Flow (cfs) | Rch Trav Time (days) | Rch Velocity (fps) | WD Ratio | Rch Width (ft) | Rch Depth (ft) | Tributary | | Stream | |
|--------------|------------|-----------------|-------------------|----------------------|--------------------|----------|----------------|----------------|-----------|------|-----------|------|
| | | | | | | | | | Temp (°C) | pH | Temp (°C) | pH |
| Q7-10 | 0.100 | 0.00 | 0.06 | 0.000 | 0.000 | 0.0 | 0.00 | 0.00 | 20.00 | 7.00 | 0.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |

Discharge Data

| Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
|-------------|---------------|--------------------------|---------------------------|------------------------|----------------|----------------|---------|
| Nexans Inc. | PA0084247 | 0.0075 | 0.0075 | 0.0075 | 0.000 | 25.00 | 7.00 |

Parameter Data

| Parameter Name | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) |
|------------------|------------------|------------------|--------------------|--------------------|
| CBOD5 | 25.00 | 2.00 | 0.00 | 1.50 |
| Dissolved Oxygen | 5.00 | 8.24 | 0.00 | 0.00 |
| NH3-N | 25.00 | 0.00 | 0.00 | 0.70 |

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|-----------|-------------|-------------------------------|-------|----------------|-----------------------|---------------|----------------------|-------------------------------------|
| 07J | 7792 | Trib 07792 to Conestoga River | 0.000 | 338.00 | 2.74 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY (cfsm) | Trib Flow (cfs) | Stream Flow (cfs) | Rch Trav Time (days) | Rch Velocity (fps) | WD Ratio | Rch Width (ft) | Rch Depth (ft) | Tributary Temp (°C) | pH | Stream Temp (°C) | pH |
|--------------|------------|-----------------|-------------------|----------------------|--------------------|----------|----------------|----------------|---------------------|------|------------------|------|
| Q7-10 | 0.100 | 0.00 | 0.08 | 0.000 | 0.000 | 0.0 | 0.00 | 0.00 | 20.00 | 7.00 | 0.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |

Discharge Data

| Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
|------|---------------|--------------------------|---------------------------|------------------------|----------------|----------------|---------|
| | | 0.0000 | 0.0000 | 0.0000 | 0.000 | 0.00 | 7.00 |

Parameter Data

| Parameter Name | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) |
|------------------|------------------|------------------|--------------------|--------------------|
| CBOD5 | 25.00 | 2.00 | 0.00 | 1.50 |
| Dissolved Oxygen | 5.00 | 8.24 | 0.00 | 0.00 |
| NH3-N | 25.00 | 0.00 | 0.00 | 0.70 |

WQM 7.0 Hydrodynamic Outputs

| <u>SWP Basin</u> | | <u>Stream Code</u> | | | | <u>Stream Name</u> | | | | | | |
|--------------------|-------------|--------------------|-----------------|--------------------|-------------|-------------------------------|-------|-----------|----------|-----------------|---------------|-------------|
| 07J | | 7792 | | | | Trib 07792 to Conestoga River | | | | | | |
| RMI | Stream Flow | PWS With | Net Stream Flow | Disc Analysis Flow | Reach Slope | Depth | Width | W/D Ratio | Velocity | Reach Trav Time | Analysis Temp | Analysis pH |
| | (cfs) | (cfs) | (cfs) | (cfs) | (ft/ft) | (ft) | (ft) | | (fps) | (days) | (°C) | |
| Q7-10 Flow | | | | | | | | | | | | |
| 1.600 | 0.06 | 0.00 | 0.06 | .0217 | 0.01894 | .338 | 4.53 | 13.4 | 0.05 | 0.012 | 21.35 | 7.00 |
| 1.590 | 0.06 | 0.00 | 0.06 | .0333 | 0.00357 | .355 | 5.44 | 15.33 | 0.05 | 1.906 | 21.69 | 7.00 |
| Q1-10 Flow | | | | | | | | | | | | |
| 1.600 | 0.04 | 0.00 | 0.04 | .0217 | 0.01894 | NA | NA | NA | 0.04 | 0.014 | 21.83 | 7.00 |
| 1.590 | 0.04 | 0.00 | 0.04 | .0333 | 0.00357 | NA | NA | NA | 0.04 | 2.220 | 22.22 | 7.00 |
| Q30-10 Flow | | | | | | | | | | | | |
| 1.600 | 0.08 | 0.00 | 0.08 | .0217 | 0.01894 | NA | NA | NA | 0.08 | 0.010 | 21.07 | 7.00 |
| 1.590 | 0.09 | 0.00 | 0.09 | .0333 | 0.00357 | NA | NA | NA | 0.08 | 1.691 | 21.37 | 7.00 |

WQM 7.0 Modeling Specifications

| | | | |
|--------------------|--------|-------------------------------------|-------------------------------------|
| Parameters | Both | Use Inputted Q1-10 and Q30-10 Flows | <input checked="" type="checkbox"/> |
| WLA Method | EMPR | Use Inputted W/D Ratio | <input type="checkbox"/> |
| Q1-10/Q7-10 Ratio | 0.64 | Use Inputted Reach Travel Times | <input type="checkbox"/> |
| Q30-10/Q7-10 Ratio | 1.36 | Temperature Adjust Kr | <input checked="" type="checkbox"/> |
| D.O. Saturation | 90.00% | Use Balanced Technology | <input checked="" type="checkbox"/> |
| D.O. Goal | 6 | | |

WQM 7.0 Wasteload Allocations

| | | |
|------------------|--------------------|-------------------------------|
| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> |
| 07J | 7792 | Trib 07792 to Conestoga River |

NH3-N Acute Allocations

| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|-------|----------------|---------------------------------|---------------------------|---------------------------------|---------------------------|-------------------|----------------------|
| 1.600 | Log Cabin | 14.4 | 39.29 | 14.4 | 28.84 | 2 | 27 |
| 1.590 | Nexans Inc. | 15.31 | 50 | 13.94 | 36.71 | 2 | 27 |

NH3-N Chronic Allocations

| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|-------|----------------|---------------------------------|---------------------------|---------------------------------|---------------------------|-------------------|----------------------|
| 1.600 | Log Cabin | 1.76 | 8.23 | 1.76 | 4.82 | 2 | 41 |
| 1.590 | Nexans Inc. | 1.82 | 15.67 | 1.73 | 9.18 | 2 | 41 |

Dissolved Oxygen Allocations

| RMI | Discharge Name | <u>CBOD5</u> | | <u>NH3-N</u> | | <u>Dissolved Oxygen</u> | | Critical Reach | Percent Reduction |
|------|----------------|--------------------|--------------------|--------------------|--------------------|-------------------------|--------------------|-------------------|----------------------|
| | | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | | |
| 1.60 | Log Cabin | 25 | 25 | 4.82 | 4.82 | 5 | 5 | 0 | 0 |
| 1.59 | Nexans Inc. | 25 | 25 | 9.18 | 9.18 | 5 | 5 | 0 | 0 |

WQM 7.0 D.O. Simulation

| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> | | | |
|---------------------------------|-----------------------------------|----------------------------------|---------------------|-----------------------------|--|
| 07J | 7792 | Trib 07792 to Conestoga River | | | |
| <u>RMI</u> | <u>Total Discharge Flow (mgd)</u> | <u>Analysis Temperature (°C)</u> | | <u>Analysis pH</u> | |
| 1.600 | 0.014 | 21.351 | | 7.000 | |
| <u>Reach Width (ft)</u> | <u>Reach Depth (ft)</u> | <u>Reach WDRatio</u> | | <u>Reach Velocity (fps)</u> | |
| 4.532 | 0.338 | 13.405 | | 0.052 | |
| <u>Reach CBOD5 (mg/L)</u> | <u>Reach Kc (1/days)</u> | <u>Reach NH3-N (mg/L)</u> | | <u>Reach Kn (1/days)</u> | |
| 8.21 | 1.231 | 1.30 | | 0.777 | |
| <u>Reach DO (mg/L)</u> | <u>Reach Kr (1/days)</u> | <u>Kr Equation</u> | | <u>Reach DO Goal (mg/L)</u> | |
| 7.367 | 23.067 | Owens | | 6 | |
| <u>Reach Travel Time (days)</u> | | | | | |
| 0.012 | | | | | |
| | <u>Subreach Results</u> | | | | |
| | <u>TravTime (days)</u> | <u>CBOD5 (mg/L)</u> | <u>NH3-N (mg/L)</u> | <u>D.O. (mg/L)</u> | |
| | 0.001 | 8.20 | 1.30 | 7.38 | |
| | 0.002 | 8.19 | 1.30 | 7.40 | |
| | 0.004 | 8.18 | 1.30 | 7.42 | |
| | 0.005 | 8.16 | 1.30 | 7.44 | |
| | 0.006 | 8.15 | 1.30 | 7.45 | |
| | 0.007 | 8.14 | 1.30 | 7.47 | |
| | 0.008 | 8.13 | 1.30 | 7.48 | |
| | 0.009 | 8.11 | 1.29 | 7.50 | |
| | 0.011 | 8.10 | 1.29 | 7.51 | |
| | 0.012 | 8.09 | 1.29 | 7.53 | |
| <u>RMI</u> | <u>Total Discharge Flow (mgd)</u> | <u>Analysis Temperature (°C)</u> | | <u>Analysis pH</u> | |
| 1.590 | 0.022 | 21.692 | | 7.000 | |
| <u>Reach Width (ft)</u> | <u>Reach Depth (ft)</u> | <u>Reach WDRatio</u> | | <u>Reach Velocity (fps)</u> | |
| 5.437 | 0.355 | 15.332 | | 0.051 | |
| <u>Reach CBOD5 (mg/L)</u> | <u>Reach Kc (1/days)</u> | <u>Reach NH3-N (mg/L)</u> | | <u>Reach Kn (1/days)</u> | |
| 9.68 | 0.765 | 2.14 | | 0.797 | |
| <u>Reach DO (mg/L)</u> | <u>Reach Kr (1/days)</u> | <u>Kr Equation</u> | | <u>Reach DO Goal (mg/L)</u> | |
| 7.275 | 20.929 | Owens | | 6 | |
| <u>Reach Travel Time (days)</u> | | | | | |
| 1.906 | | | | | |
| | <u>Subreach Results</u> | | | | |
| | <u>TravTime (days)</u> | <u>CBOD5 (mg/L)</u> | <u>NH3-N (mg/L)</u> | <u>D.O. (mg/L)</u> | |
| | 0.191 | 8.27 | 1.84 | 7.99 | |
| | 0.381 | 7.06 | 1.58 | 7.99 | |
| | 0.572 | 6.03 | 1.36 | 7.99 | |
| | 0.763 | 5.15 | 1.16 | 7.99 | |
| | 0.953 | 4.40 | 1.00 | 7.99 | |
| | 1.144 | 3.76 | 0.86 | 7.99 | |
| | 1.334 | 3.21 | 0.74 | 7.99 | |
| | 1.525 | 2.74 | 0.63 | 7.99 | |
| | 1.716 | 2.34 | 0.54 | 7.99 | |
| | 1.906 | 2.00 | 0.47 | 7.99 | |

WQM 7.0 Effluent Limits

| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> | | | | | |
|------------------|--------------------|-------------------------------|-----------------|------------------|--------------------------------|----------------------------|----------------------------|
| 07J | 7792 | Trib 07792 to Conestoga River | | | | | |
| RMI | Name | Permit Number | Disc Flow (mgd) | Parameter | Effl. Limit 30-day Ave. (mg/L) | Effl. Limit Maximum (mg/L) | Effl. Limit Minimum (mg/L) |
| 1.600 | Log Cabin | PA0262137 | 0.014 | CBOD5 | 25 | | |
| | | | | NH3-N | 4.82 | 9.64 | |
| | | | | Dissolved Oxygen | | | 5 |
| RMI | Name | Permit Number | Disc Flow (mgd) | Parameter | Effl. Limit 30-day Ave. (mg/L) | Effl. Limit Maximum (mg/L) | Effl. Limit Minimum (mg/L) |
| 1.590 | Nexans Inc. | PA0084247 | 0.007 | CBOD5 | 25 | | |
| | | | | NH3-N | 9.18 | 18.36 | |
| | | | | Dissolved Oxygen | | | 5 |