



Application Type
Facility Type
Major / Minor

Renewal
Municipal
Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. **PA0263711**
APS ID **1074871**
Authorization ID **1416157**

Applicant and Facility Information

Applicant Name	Benezette Township Elk County	Facility Name	Benezette WWTP
Applicant Address	PO Box 45 16 Trout Run Road	Facility Address	105 Schoolhouse Road
	Benezette, PA 15821-0045		Benezette, PA 15821
Applicant Contact	Pamela Mong	Facility Contact	Pamela Mong
Applicant Phone	(814) 787-8811	Facility Phone	(814) 787-8811
Client ID	140919	Site ID	715653
Ch 94 Load Status	Not Overloaded	Municipality	Benezette Township
Connection Status	No Limitations	County	Elk
Date Application Received	October 31, 2022	EPA Waived?	Yes
Date Application Accepted	March 21, 2025	If No, Reason	
Purpose of Application	This is an application for NPDES renewal		

Summary of Review

The application submitted by the applicant requests a NPDES renewal permit for the Benezette WWTP located at 105 Schoolhouse Road, Benezette, PA 15821 in Elk County, municipality of Benezette Township. The existing permit became effective on May 1, 2018 and expired on April 30, 2023. The application for renewal was received by DEP Southcentral Regional Office (SCRO) on October 31, 2022.

The purpose of this Fact Sheet is to present the basis of information used for establishing the proposed NPDES effluent limitations. The Fact Sheet includes a description of the facility, a description of the facility's receiving waters, a description of the facility's receiving waters attainment/non-attainment assessment status, and a description of any changes to the proposed monitoring/sampling frequency. Section 6 provides the justification for the proposed NPDES effluent limits derived from technology based effluent limits (TBEL), water quality based effluent limits (WQBEL), total maximum daily loading (TMDL), antidegradation, anti-backsliding, and/or whole effluent toxicity (WET). A brief summary of the outlined descriptions has been included in the Summary of Review section.

The subject facility is a 0.04 MGD treatment facility. The applicant anticipates proposed upgrades to the treatment facility in the next five years. The facility proposes an effluent pump station to address outfall backwater effects on the treatment process. The NPDES application has been processed as a Minor Sewage Facility (Level 1) due to the type of sewage and the design flow rate for the facility. The applicant disclosed the Act 14 requirement to Elk County Commissioners and Benezette Township Supervisors. A planning approval letter was not necessary as the facility is neither new or expanding.

Utilizing the DEP's web-based Emap-PA information system, the receiving waters has been determined to be Trout Run. The sequence of receiving streams that the Trout Run discharges into are Bennett Branch Sinnemahoning Creek, West Branch

Approve	Deny	Signatures	Date
X		Nicholas Hong, P.E. / Environmental Engineer Nick Hong (via electronic signature)	April 2, 2025
		Adam Olesnanik, P.E. / Environmental Engineer Manager	Okay to Draft JCD 4/4/2025

Summary of Review

Susquehanna River, Susquehanna River which eventually drains into the Chesapeake Bay. The subject site is subject to the Chesapeake Bay implementation requirements. The receiving water has protected water usage for cold water fishes (CWF) and migratory fishes (MF). No Class A Wild Trout fisheries are impacted by this discharge. The absence of high quality and/or exceptional value surface waters removes the need for an additional evaluation of anti-degradation requirements.

The Trout Run is a Category 2 stream listed in the 2024 Integrated List of All Waters (formerly 303d Listed Streams). This stream is an attaining stream that supports aquatic life and recreational uses. The secondary receiving waters has total maximum daily load (TMDL) effluent limits to improve water quality in the subject facility's watershed.

The existing permit and proposed permit differ as follows:

- **Dissolved oxygen limit increased to 5 mg/l.**
- **Due to the EPA triennial review, monitoring shall be required for E. Coli.**

Sludge use and disposal description and location(s): Sewage sludge disposed at Benezette WWTP on reed beds

The proposed permit will expire five (5) years from the effective date.

Based on the review in this report, it is recommended that the permit be drafted. DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Any additional information or public review of documents associated with the discharge or facility may be available at PA DEP Southcentral Regional Office (SCRO), 909 Elmerton Avenue, Harrisburg, PA 17110. To make an appointment for file review, contact the SCRO File Review Coordinator at 717.705.4700.

1.0 Applicant

1.1 General Information

This fact sheet summarizes PA Department of Environmental Protection's review for the NPDES renewal for the following subject facility.

Facility Name: Benezette WWTP

NPDES Permit #: PA0263711

Physical Address: 105 Schoolhouse Road
Benezette, PA 15821

Mailing Address: 16 Trout Run Road
Benezette, PA 15821

Contact: Pamela Mong
Secretary/Treasurer
bentwp@yahoo.com

Consultant: Brock Bowers
Water/Wastewater Designer
420 Allegheny Street
Hollidaysburg, PA 16648
(814) 696-7460
bbowers@keller-engineers.com

1.2 Permit History

Description of Facility

Due to frequent effluent violations, the Township entered into a Consent Order and Agreement on December 18, 2017.

Permit submittal included the following information.

- NPDES Application
- Flow Diagrams
- Influent Sample Data
- Effluent Sample Data

2.0 Treatment Facility Summary

2.1.1 Site location

The physical address for the facility is 105 Schoolhouse Road, Benezette, PA 15821. A topographical and an aerial photograph of the facility are depicted as Figure 1 and Figure 2.

Figure 1: Topographical map of the subject facility





Figure 2: Aerial Photograph of the subject facility



2.1.2 Sources of Wastewater/Stormwater

The wastewater treatment plant receives 100% of the wastewater from Benezette Township.


2.2 Description of Wastewater Treatment Process

The subject facility is a 0.04 MGD design flow facility. The subject facility treats wastewater using a Purestream / ES Biologically Engineered Single Sludge Technology (BESST) system. The treatment consists of anoxic tanks, aeration tanks, clarifiers, and chlorine disinfection prior to discharge through the outfall. Solids are treated using an aerated sludge holding tank and reed beds. The facility is being evaluated for flow, pH, dissolved oxygen, TRC, CBOD5, TSS, fecal coliform, nitrogen species, and phosphorus. The existing permits limits for the facility is summarized in Section 2.4.

The treatment process is summarized in the table.

Treatment Facility Summary				
Treatment Facility Name: Benezette WWTP				
WQM Permit No.		Issuance Date		
2410402		01/12/2012		
2410402 A-1		03/28/2013		
2410402 A-2		08/28/2018		
2410402 A-3		08/14/2023		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary With Total Nitrogen Reduction	Activated Sludge	Hypochlorite	0.04
<hr/>				
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.04	63	Not Overloaded	Drying	Landfill

The treatment process is depicted as shown. The schematic did not include a disinfection unit. The project narrative submitted with the NPDES application detailed the disinfection as chlorine. Subsequent renewal applications should include an updated flow diagram.



2.3 Facility Outfall Information

The facility has the following outfall information for wastewater.

Outfall No. 001
Latitude 41° 18' 56.48"
Wastewater Description: Sewage Effluent

Design Flow (MGD) .04
Longitude -78° 23' 10.00"

2.3.1 Operational Considerations- Chemical Additives

Chemical additives are chemical products introduced into a waste stream that is used for cleaning, disinfecting, or maintenance and which may be detected in effluent discharged to waters of the Commonwealth. Chemicals excluded are those used for neutralization of waste streams, the production of goods, and treatment of wastewater.

The subject facility utilizes the following chemicals as part of their treatment process.

- Chlorine for disinfection

2.4 Existing NPDES Permits Limits

The existing NPDES permit limits are summarized in the table.

PART A - EFFLUENT LIMITATIONS, MONITORING, RECORDKEEPING AND REPORTING REQUIREMENTS

I. A. For Outfall 001, Latitude 41° 18' 56.5", Longitude 78° 23' 11", River Mile Index 0.13, Stream Code 24674

Type of Effluent: Treated domestic sewage

1. The permittee is authorized to discharge during the period from Permit Effective Date through Permit Expiration Date.
2. Based on the anticipated wastewater characteristics and flows described in the permit application and its supporting documents and/or amendments, the following effluent limitations and monitoring requirements apply (see also Additional Requirements and Footnotes).

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report	XXX 6.0	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	Inst Min Report	XXX	XXX	9.0	1/day	Grab
Dissolved Oxygen (Interim)*	XXX	XXX	Inst Min 4.0	XXX	XXX	XXX	1/day	Grab
Dissolved Oxygen (Final)**	XXX	XXX	Inst Min	XXX	XXX	XXX	1/day	Grab
Total Residual Chlorine (TRC)	XXX	XXX	XXX 0.5	XXX	XXX	1.6	1/day	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5)	8.0	13	XXX Biochemical Oxygen Demand (BOD5) Influent	25.0 Report	40.0 XXX	50 XXX	1/week 1/week	8-Hr Composite 8-Hr Composite
Total Suspended Solids Influent	Report	XXX	XXX 10	Report 15	Report 30.0	XXX 45.0	1/week 1/week	8-Hr Composite 8-Hr Composite
Total Suspended Solids Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX 2000	Geo Mean 200	XXX Geo Mean	10000 1000	1/week 1/week	Grab Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX Ammonia-Nitrogen May 1 - Oct 31	Geo Mean Report	XXX XXX	1000 XXX	1/week 2/month	Grab 8-Hr Composite 8-Hr Composite
Total Phosphorus	XXX	XXX	XXX Total Phosphorus	Report	XXX	XXX	2/month	8-Hr Composite

* - Interim limits apply from the permit effective date (PED) to PED + 2 years

** - Final limits apply from the PED + 2 years to the permit expiration date.

PART A - EFFLUENT LIMITATIONS, MONITORING, RECORDKEEPING AND REPORTING REQUIREMENTS

I. B. For Outfall 001 (cont'd), Latitude 41° 18' 56.5", Longitude 78° 23' 11", River Mile Index 0.13, Stream Code 24674

Type of Effluent: Treated domestic sewage

1. The permittee is authorized to discharge during the period from Permit Effective Date through Permit Expiration Date.
2. Based on the anticipated wastewater characteristics and flows described in the permit application and its supporting documents and/or amendments, the following effluent limitations and monitoring requirements apply (see also Additional Requirements and Footnotes).

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Monthly	Annual	Monthly	Monthly Average	Maximum	Instant. Maximum		
Ammonia-N	Report	Report	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Kieldahl-N	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Nitrate-Nitrite as N	Report	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Total Nitrogen	Report	Report	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Total Phosphorus	Report	Report	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Net Total Nitrogen	XXX	0	XXX	XXX	XXX	XXX	1/year	Calculation
Net Total Phosphorus	XXX	0	XXX	XXX	XXX	XXX	1/year	Calculation

Samples taken in compliance with the monitoring requirements specified above shall be taken at the following location: Outfall 001 – after disinfection, except for the influent sampling.

Footnotes:

- (1) See Part C for Chesapeake Bay Requirements.
- (2) This is the minimum number of sampling events required. Permittees are encouraged, and it may be advantageous in demonstrating compliance, to perform more than the minimum number of sampling events required.
- (3) The permittee is authorized to use Total Nitrogen offsets in the amount of 3,500 lbs/year for compliance purposes, due to the retirement of 140 on-lot systems. These offsets may be reported on monthly and/or annual Chesapeake Bay supplemental reporting forms.

3.0 Facility NPDES Compliance History

3.1 Summary of Inspections

A summary of the most recent inspections during the existing permit review cycle is as follows.

The DEP inspector noted the following during the inspection.

09/23/2022:

- The new flow-proportioned chlorine system was not operable due to a sag in the effluent discharge line affecting its operation.
- The reed beds have been replanted and small reeds were visible.

12/01/2022:

- The low-pressure collection system owned by the Township is comprised of approximately 170 camps/residences with grinder pumps and a single pump station located at the Benezette store campground.
- Sewage Treatment Plant (STP) has two trains with only Plant B in operation due to low flows
- DEP observed a layer of solids/scum on top of the clarifier to the left of the anoxic tank which was inhibiting any flow into the trough. Ms. Martinchek explained the floating solids were due to balking sludge and a scum skimmer that was set to low to be effective. The scum/solids appeared to be carrying over to the contact tank where the floating solids and cloudy effluent entered the dechlorination tank. The solids were also observed in the manhole at the effluent composite sampling location which eventually discharges to Trout Run. The solids leaving the STP was

attributed to the scum skimmer not being operable and inadequate sludge wasting. This is a violation of 92A.41(A)5: 25 Pa. Code 92a.41(a)(5) for failure to keep permitted treatment units in operable condition and failure to operate and maintain all facilities which are installed or used by the Permittee to achieve compliance. DEP requested the Township provide a detailed written corrective action plan in the next 14 days to address the violation.

- DEP observed the outfall at the stream which was partially submerged. No solids were present most likely due to increased stream flow/levels due to heavy rainfall in the area the previous day.
- There were 6 effluent violations for Fecal Coliform and two permit exceedances for Total Suspended Solids(TSS) during the period reviewed. Noncompliance forms submitted for the Fecal Coliform violations attribute them to insufficient Chlorine feed or equipment malfunction and TSS violations for need of increased wasting of sludge due to higher than normal organic loads.
- Mr. Ruffo stated the Township's engineer (Keller engineers of Hollidaysburg) is contracted to design a pump station to push flow proportioned chlorinated effluent to the Trout Run outfall to deal with Hypochlorite feed issues and better meet Fecal Coliform limits set forth on NPDES permit. He advised he is seeking funding sources for the project and hopes to have work completed by spring of 2023.
- DEP recommended Standard Operating Procedures (SOPs are outdated from 2018) be updated and establish a written checklist to be completed by the daily operations staff which details plant process controls, daily cleaning/maintenance of plant/equipment, observations, and sludge wasting.

01/05/2023:

- The Township continues to experiment with manually adding the polymer, Pollu-Treat CL 835 to the aeration basins for coagulation.
- DEP recommended the Township develop a high flow management plan and conduct some type of inflow/infiltration investigation to deal with excessive flows which appear to be upsetting STP performance.
- DEP observed a layer of solids/sludge in the baffle area next to the effluent trough by the clarifier to the left of the anoxic tank. Solids/sludge was observed on the top lip of the trough entering the flow which discharges to the chlorine contact tank . The solids were also observed in the manhole at the effluent composite sampling location which eventually discharges to Outfall # 001 at Trout Run which was submerged and not visible today. These solids leaving the STP may be attributed to inadequate sludge cleaning /wasting and plant maintenance. This is a violation of 92A.41(A)5 NPDES-failure to operate and maintain all facilities which are installed or used by the Permittee to achieve compliance.
- Operator should complete a circuit rider general work plan.

02/03/2023:

- The Township continues to experiment with manually adding the polymer, Pollu-Treat CL 835 to the aeration basins for coagulation.
- A high flow management plan was added to the SOP.
- Due to low temperatures/freezing conditions, the de-chlorination tank appeared foamy.
- TRC samples appear to vary greatly when the plant is discharging as compared to idle mode

09/04/2024:

- The manhole with parshall flume was the prior location of an ultrasonic flow meter. The meter has been relocated to the chlorine contact tank and a 4" weir installed. A composite sampling line is located in the flume and pulls samples on a flow basis when the plant is discharging.
- A different manhole on the discharge line appeared to have solids accumulation.
- A different manhole had no issues observed. The slope of the line from this manhole to the outfall was increased to eliminate backflow and an elbow added at the discharge. After observation of the chlorine tank, manholes, and outfall, a general overview plant tour was conducted.
- Sludge is wasted as needed to three reed beds. Two of the three beds were replanted this year and do not yet have full coverage.
- A non-compliance report was submitted on 8/12/24 for overflow from the EQ tank during a high rainfall event on 8/9/24. The affected area was limed.

3.2 Summary of DMR Data

A review of approximately 1-year of DMR data shows that the monthly average flow data for the facility below the design capacity of the treatment system. The maximum average flow data for the DMR reviewed was 0.015053 MGD in September 2024. The design capacity of the treatment system is 0.04 MGD.

The off-site laboratory used for the analysis of the parameters was Fairway Laboratories located at 2019 Ninth Avenue, Altoona, PA 16603.

DMR Data for Outfall 001 (from February 1, 2024 to January 31, 2025)

Parameter	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24	APR-24	MAR-24	FEB-24
Flow (MGD) Average Monthly	0.00640 6	0.00863 3	0.00999 8	0.01310 1	0.01505 3	0.0124 0.0124	0.01144 9	0.00842 7	0.00899 4	0.01450 8	0.00872 1	0.00923 5
Flow (MGD) Weekly Average	0.00775 1	0.01074 8	0.01098 5	0.01526 5	0.01859 0.0196	0.01389 4	0.00852 4	0.01049 6	0.02272 8	0.01239 6	0.01241	
pH (S.U.) Instantaneous Minimum	6.5	6.58	6.12	7.02	7.14	7.19	7.06	7.02	6.84	6.84	6.6	6.64
pH (S.U.) Instantaneous Maximum	7.91	8.04	7.68	8.16	8.29	8.32	8.34	8.3	8.3	7.57	8.0	8.11
DO (mg/L) Instantaneous Minimum	8.56	7.75	7.59	6.57	5.85	4.88	5.39	5.74	4.21	10.09	5.04	4.39
TRC (mg/L) Average Monthly	< 0.02	< 0.15	< 0.1	0.02	0.20	0.17	< 0.06	< 0.17	< 0.25	< 0.18	< 0.09	< 0.18
TRC (mg/L) Instantaneous Maximum	0.13	1.27	0.98	0.2	0.72	1.37	0.4	1.46	1.53	1.57	0.84	0.96
CBOD5 (lbs/day) Average Monthly	0.8	1.1	0.7	< 1.2	1.2	1.8	2.0	1.4	1.2	2.7	0.6	0.5
CBOD5 (lbs/day) Weekly Average	2.0	2.0	0.8	2	2.0	3.0	3.0	2.0	2.0	8	0.6	0.8
CBOD5 (mg/L) Average Monthly	14.8	13.3	12.0	< 11.4	16.6	24.6	22.9	21.1	22.3	16.9	13.2	8.8
CBOD5 (mg/L) Weekly Average	24.0	20.0	13.0	16.0	42.0	33.0	29.0	27.0	34.0	30.0	16.0	15.0
BOD5 (lbs/day) Influent Average Monthly	19.0	19.0	16.0	40	33	17.0	33.0	21	19.0	15	11	301
BOD5 (mg/L) Influent Average Monthly	391.0	251.0	266.0	399	339	229.5	385.0	332	331.0	160.9	232	14
TSS (lbs/day) Average Monthly	1.0	1.0	1.0	1.0	0.6	0.8	0.7	0.6	1.0	4	0.8	< 0.6
TSS (lbs/day) Influent Average Monthly	21.0	23.0	18.0	37.0	39.0	27.0	38.0	25	22.0	20	15	284

NPDES Permit Fact Sheet
Benezette WWTP

NPDES Permit No. PA0263711

TSS (lbs/day) Weekly Average	2.0	2.0	1.0	2.0	0.9	1.0	1.0	0.8	1.0	13	1.0	1
TSS (mg/L) Average Monthly	22.6	15.5	15.9	12.0	6.8	9.6	7.4	8.6	18.1	23.0	16.3	< 11.4
TSS (mg/L) Influent Average Monthly	421.0	298.0	291.0	366	400	356.0	438.0	386	387	206	303	13
TSS (mg/L) Weekly Average	37.0	23.0	23.0	17.0	8.0	12.0	11.0	11.0	27.0	47.0	23.0	30.0
Fecal Coliform (No./100 ml) Geometric Mean	10.0	< 2.0	2.0	63	11	13.0	12.0	19	20.0	18	< 134	< 2
Fecal Coliform (No./100 ml) Instantaneous Maximum	31.5	4.1	4.0	1986.3	65	32.3	63.7	44.3	50.8	579.4	2420	4.1
Nitrate-Nitrite (mg/L) Average Monthly	30.05	< 18.19	< 35.56	< 23.44	< 10.953	< 12.052	< 2.4	< 9.54	< 7.37	< 2.952	< 10.226	< 6.009
Nitrate-Nitrite (lbs) Total Monthly	40.0	< 44.0	< 71	< 68	< 28	< 34.0	< 5	< 17	< 13	< 7	< 15	< 11
Total Nitrogen (mg/L) Average Monthly	33.003	< 39.07	< 40.04	< 25.582	< 20.876	< 12.931	< 4.878	< 11.68	< 10.746	< 31.422	< 24.81	< 19.744
Total Nitrogen (lbs) Total Monthly	44.0	< 95	< 80	< 74	< 63	< 37.0	< 11	< 21	< 19.0	< 70	< 37	< 31
Total Nitrogen (lbs) Effluent Net Total Annual					-2989							
Total Nitrogen (lbs) Total Annual					< 511							
Ammonia (mg/L) Average Monthly	< 1.058	22.97	4.334	0.3988	8.9984	< 0.1	< 0.4254	< 0.1	< 0.714	6.418	12.0	13.152
Ammonia (lbs) Total Monthly	< 2.0	56	9.0	1.0	34	< 0.3	< 0.9	< 0.2	< 1.0	14	18	18
Ammonia (lbs) Total Annual					< 142							
TKN (mg/L) Average Monthly	2.958	20.88	4.48	2.142	9.923	0.879	2.478	2.15	3.381	28.47	14.59	13.74
TKN (lbs) Total Monthly	4.0	51	9.0	6.0	35	3.0	6.0	4	7.0	63	21	20

NPDES Permit Fact Sheet
Benezette WWTP

NPDES Permit No. PA0263711

Total Phosphorus (mg/L)											
Average Monthly	4.85	5.77	9.8	9.92	9.71	6.88	8.35	9.48	7.53	2.35	2.63
Total Phosphorus (lbs)											
Total Monthly	6.0	14	20	28	29	21.0	19.0	17	14	5	4
Total Phosphorus (lbs)											
Effluent Net Total Annual					0.0						
Total Phosphorus (lbs)											
Total Annual					212						

3.2.1 Chesapeake Bay Truing

The table summarizes the facility's compliance/noncompliance with Chesapeake Bay cap loads.

For the truing period ending in 2023, the supplemental report indicates that the facility was in violation with phosphorus cap loads. DEP suspects that there could be a data entry error on the supplemental report. This violation should be reviewed by the township and DEP operations staff.

Chesapeake Bay Annual Nutrient Summary										
Benezette WWTP										
PA0263711										
Year for Truing Period (Oct 1 - Sept 30)	Nitrogen (lbs)				Phosphorus (lbs)				Compliant with Permit Limits (Yes/No)	
	Annual Total Mass Load	Lbs Credit Purchased	Lbs Offsets Generated	Annual Net Mass Load	Annual Total Mass Load	Lbs Credit Purchased	Lbs Offsets Generated	Annual Net Mass Load	Nitrogen	Phosphorus
2017	1070	0	3500	-2430	158	158		0	Yes	Yes
2018	988		3500	-2512	187	188		-1	Yes	Yes
2019	927	0	3500	-2573	138	138		0	Yes	Yes
2020	298	0	3500	-3202	117	119		-2	Yes	Yes
2021	627	0	3500	-2873	181	183		-2	Yes	Yes
2022	381	0	3500	-3119	183	183		0	Yes	Yes
2023	511	0	3500	-2989	212	0		212	Yes	No

Notes:

Nitrogen Annual Net Mass CAP Load =	0	lbs
Phosphorus Annual Net Mass CAP Load =	0	lbs

3.3 Non-Compliance

3.3.1 Non-Compliance- NPDES Effluent

A summary of the non-compliance to the permit limits for the existing permit cycle is as follows.

From the DMR data beginning on May 1, 2018 to March 25, 2025, the following table summarizes effluent non-compliances.

Summary of Non-Compliance with NPDES Effluent Limits Beginning May 1, 2018 and Ending March 23, 2025										
NON_COMPLIANCE_DATE	NON_COMPL_TYPE_DESC	NON_COMPL_CATEGORY_DESC	PARAMETER	SAMPLE_VALUE	VIOLATION_CONDITION	PERMIT_VALUE	UNIT_OF_MEASURE	STAT_BASE_CODE	DISCHARGE_COMMENTS	FACILITY_COMMENTS
6/19/2018	Violation of permit condition	Effluent	Fecal Coliform	> 2420	>	1000	No./100 ml	Instantaneous Maximum		Cause: foam in MLSS basin spilled over causing excessive solids in chlorine contact basin. Action: transfer solids from chlorine contact basin to digester, increase chlorine dose
6/19/2018	Violation of permit condition	Effluent	Total Residual Chlorine (TRC)	1.8	>	1.6	mg/L	Instantaneous Maximum		
7/15/2018	Violation of permit condition	Effluent	Fecal Coliform	> 2420	>	1000	No./100 ml	Instantaneous Maximum		employee training
7/15/2018	Violation of permit condition	Effluent	Total Residual Chlorine (TRC)	2.2	>	1.6	mg/L	Instantaneous Maximum		employee training
8/23/2018	Violation of permit condition	Effluent	Carbonaceous Biochemical Oxygen	42.0	>	40.0	mg/L	Weekly Average		Cause: Equipment malfunction caused plant septicity Correction: equipment repaired, waste, increase air, add lime, reseed
8/23/2018	Violation of permit condition	Effluent	Fecal Coliform	> 2420	>	1000	No./100 ml	Instantaneous Maximum		Cause: Equipment malfunction caused plant septicity Correction: Equ
8/23/2018	Violation of permit condition	Effluent	Total Suspended Solids	51.0	>	45.0	mg/L	Weekly Average		Cause: equipment malfunction caused plant septicity Correction: equipment repaired, waste, increase air, add lime, reseed
9/27/2018	Violation of permit condition	Effluent	Fecal Coliform	> 2420	>	1000	No./100 ml	Instantaneous Maximum		clean chlorine contact tank, monitor free chlorine
10/18/2018	Violation of permit condition	Effluent	Total Residual Chlorine (TRC)	< 0.6	>	.5	mg/L	Average Monthly		increased dechlorination tablets
11/26/2018	Violation of permit condition	Effluent	Total Residual Chlorine (TRC)	0.7	>	.5	mg/L	Average Monthly		increase dechlorination tablets
11/26/2018	Violation of permit condition	Effluent	Total Residual Chlorine (TRC)	2.2	>	1.6	mg/L	Instantaneous Maximum		increase dechlorination tablets
12/16/2018	Violation of permit condition	Effluent	Total Residual Chlorine (TRC)	1.9	>	1.6	mg/L	Instantaneous Maximum		tablet feeder broke and pieces of chlorine tablets entered contact basin
1/19/2019	Violation of permit condition	Effluent	Total Residual Chlorine (TRC)	2.0	>	1.6	mg/L	Instantaneous Maximum		Insufficient dechlorination tablets. Employee training on how to determine quantity of dechlorination tablet feeders needed.
4/21/2019	Violation of permit condition	Effluent	Total Residual Chlorine (TRC)	1.7	>	1.6	mg/L	Instantaneous Maximum		
3/16/2019	Other	Other								
6/20/2019	Violation of permit condition	Effluent	Fecal Coliform	> 2420	>	1000	No./100 ml	Instantaneous Maximum		Cause: High TSS prevented sufficient disinfection. Action: Addressed TSS non-compliance and cleaned out chlorine contact tank
6/20/2019	Violation of permit condition	Effluent	Total Suspended Solids	38.0	>	30.0	mg/L	Average Monthly		Cause: Septic waste from local campground and high flows Action: Increased air, added lime, increased plant hydraulic capacity

6/20/2019	Violation of permit condition	Effluent	Total Suspended	80.0	>	45.0	mg/L	Weekly Average		Cause: Septic waste from local campground and high flows Action: Increased air, added lime, increased plant hydraulic capacity
9/15/2019	Violation of permit condition	Effluent	Fecal Coliform	2420	>	1000	No./100 ml	Instantaneous Maximum		A flow based chlorine injector is to be installed with current improvement project to address low chlorine levels during high flow events
9/2/2019	Violation of permit condition	Other Violations								
10/15/2019	Violation of permit condition	Effluent	Fecal Coliform	>2420	>	1000	No./100 ml	Instantaneous Maximum		New chlorine equipment installed and started up October 14th
10/15/2019	Violation of permit condition	Effluent	Fecal Coliform	>504	>	200	No./100 ml	Geometric Mean		New chlorine equipment installed and started up October 14th
10/15/2019	Violation of permit condition	Effluent	Total Suspended	53.0	>	45.0	mg/L	Weekly Average		Influent surge pushed solids up in clarifier. Reset influent floats to step feed high flows.
9/15/2019	Violation of permit condition	Other Violations								
10/15/2019	Violation of permit condition	Other Violations								
11/25/2019	Violation of permit condition	Effluent	Carbonaceous Biochemical Oxygen	105.0	>	40.0	mg/L	Weekly Average		High instantaneous waste load on plant due to tourist season. Low DO decreased bug population to efficiently process waste
11/25/2019	Violation of permit condition	Effluent	Carbonaceous Biochemical Oxygen	45.0	>	25.0	mg/L	Average Monthly		High instantaneous waste load on plant due to tourist season. Low DO decreased bug population to efficiently process waste
11/25/2019	Violation of permit condition	Effluent	Total Suspended	34.0	>	30.0	mg/L	Average Monthly		High instantaneous waste load on plant due to tourist season. Low DO decreased bug population to efficiently process waste
11/25/2019	Violation of permit condition	Effluent	Total Suspended Solids	80.0	>	45.0	mg/L	Weekly Average		High instantaneous waste load on plant due to tourist season. Low DO decreased bug population to efficiently process waste
12/21/2019	Violation of permit condition	Effluent	Carbonaceous Biochemical Oxygen	42.0	>	25.0	mg/L	Average Monthly		
12/21/2019	Violation of permit condition	Effluent	Carbonaceous Biochemical Oxygen	79.0	>	40.0	mg/L	Weekly Average		
12/21/2019	Violation of permit condition	Effluent	Total Suspended	39.0	>	30.0	mg/L	Average Monthly		
12/21/2019	Violation of permit condition	Effluent	Total Suspended	62.0	>	45.0	mg/L	Weekly Average		
1/25/2020	Violation of permit condition	Effluent	Carbonaceous Biochemical Oxygen	27.0	>	25.0	mg/L	Average Monthly		Digester supernatant pumped to headworks during low flows causing temporary plant upset.

1/25/2020	Violation of permit condition	Effluent	Carbonaceous Biochemical Oxygen	57.0	>	40.0	mg/L	Weekly Average		Digester supernatant pumped to headworks during low flows causing temporary plant upset.
1/25/2020	Violation of permit condition	Effluent	Total Suspended	65.0	>	45.0	mg/L	Weekly Average		Digester supernatant pumped to headworks during low flows causing temporary plant upset.
4/27/2021	Violation of permit condition	Effluent	Total Suspended	< 40.0	>	30.0	mg/L	Average Monthly		Caused by a frozen wasting line that was quickly cleared and wasting increased.
4/27/2021	Violation of permit condition	Effluent	Total Suspended	170.0	>	45.0	mg/L	Weekly Average		Caused by a frozen wasting line that was quickly cleared and wasting increased.
3/12/2021	Violation of permit condition	Other Violations								
5/24/2021	Sample collection less frequent than required	Other Violations	Total Kjeldahl Nitrogen							
5/24/2021	Sample collection less frequent than required	Other Violations	Total Nitrogen							
5/24/2021	Violation of permit schedule	Other Violations								
6/23/2021	Sample collection less frequent than required	Other Violations	Ammonia-Nitrogen							
6/23/2021	Sample collection less frequent than required	Other Violations	Nitrate-Nitrite as N							
6/23/2021	Sample collection less frequent than required	Other Violations	Total Kjeldahl Nitrogen							
6/23/2021	Sample collection less frequent than required	Other Violations	Total Nitrogen							
6/23/2021	Sample collection less frequent than required	Other Violations	Total Phosphorus							
5/10/2021	Violation of permit condition	Other Violations								
7/19/2021	Violation of permit condition	Effluent	Fecal Coliform	>2420	>	1000	No./100 ml	Instantaneous Maximum		On 6/10/21 lid to sample bottle was dropped in sink causing sample contamination.
7/19/2021	Violation of permit condition	Effluent	Fecal Coliform	>65	>	200	No./100 ml	Geometric Mean		On 6/10/21 lid to sample bottle was dropped in sink causing sample contamination.
6/30/2021	Violation of permit condition	Other Violations								
9/18/2021	Violation of permit condition	Effluent	Fecal Coliform	>2420	>	1000	No./100 ml	Instantaneous Maximum		Effluent flow meter not communicating with chlorine feed pumps and is in manual operation. High flows resulted in low chlorine residual. Manufacturer is evaluating problem.
9/18/2021	Violation of permit condition	Effluent	Fecal Coliform	>246	>	200	No./100 ml	Geometric Mean		Effluent flow meter not communicating with chlorine feed pumps and is in manual operation. Variable flows resulted in low chlorine residual and higher than normal fecal results. Manufacturer is evaluating problem.
9/6/2021	Violation of permit condition	Other Violations								

10/23/2021	Violation of permit condition	Effluent	Fecal Coliform	> 101	>	200	No./100 ml	Geometric Mean		Chlorine application rate is being manually controlled. Unanticipated high flows exceeded manual settings and resulted in a high fecal reading on 9/16/21. Flow meter that controls chlorine dosing is still out for service.
10/23/2021	Violation of permit condition	Effluent	Fecal Coliform	> 2420	>	1000	No./100 ml	Instantaneous Maximum		Chlorine application rate is being manually controlled. Unanticipated high flows exceeded manual settings and resulted in a high fecal reading on 9/16/21. Flow meter that controls chlorine dosing is still out for service.
10/23/2021	Violation of permit condition	Other Violations								
11/29/2022	Late DMR Submission	Other								
6/27/2022	Violation of permit condition	Effluent	Total Suspended	33.3	>	30.0	mg/L	Average Monthly		Increase in organic load caused a slight upset to plant. Solids wasting increased and put additional section of plant into service.
7/21/2022	Violation of permit condition	Effluent	Total Suspended Solids	46.7	>	45.0	mg/L	Weekly Average		Plant A got upset when put into service to accommodate higher organic flows. Plant needed time to adjust. Recommended increased wasting and to slowly introduce influent when putting a new portion of plant in service.
10/25/2022	Sample collection less frequent than required	Other Violations	Ammonia-Nitrogen							
10/25/2022	Sample collection less frequent than required	Other Violations	Nitrate-Nitrite as N							
10/25/2022	Sample collection less frequent than required	Other Violations	Total Kjeldahl Nitrogen							
10/25/2022	Sample collection less frequent than required	Other Violations	Total Nitrogen							
10/25/2022	Sample collection less frequent than required	Other Violations	Total Phosphorus							

2/24/2023	Violation of permit condition	Effluent	Carbonaceous Biochemical Oxygen	47.6	>	40.0	mg/L	Weekly Average	High flows caused an increased CBOD concentration in effluent. Wasting was increased and SOP was updated to include a plan for high flow events
1/27/2023	Violation of permit condition	Other Violations							
9/26/2023	Violation of permit condition	Effluent	Fecal Coliform	>2420	>	1000	No./100 ml	Instantaneous Maximum	
8/30/2023	Violation of permit condition	Other Violations							
1/29/2024		Unauthorized Discharges							due to snowmelt and rain we had a hydraulic overload at the plant resulting in a solids washout into the receiving waters: Trout Run Immediate action took place to resolve the issue and prevent further washout. Immediate actions taken: 1 waste the plant 2 turn air off to let sludge settle
5/22/2024	Violation of permit condition	Effluent	Total Suspended	47.0	>	45.0	mg/L	Weekly Average	
8/12/2024		Unauthorized Discharges							As noted, the area experienced 3 inches of rain in the matter of 2 hours, which caused the plant to handle higher than normal peak flows. This caused the 2 pumps in the EQ tank to not keep up with incoming flow for a short period of time causing a small overflow outside of the tank on the ground surface.
10/23/2024	Violation of permit condition	Effluent	Carbonaceous Biochemical Oxygen Demand	42.0	>	40.0	mg/L	Weekly Average	For the first two weeks of September, Tourist activity was very high and more solids needed wasted from the Clarifier. After this was completed and flow reduced, CBODs came back down to underneath 7 mg/l on the following 3 weeks lab samples.

3.3.2 Non-Compliance- Enforcement Actions

A summary of the non-compliance enforcement actions for the current permit cycle is as follows:

Beginning in May 1, 2018 to March 25, 2025, there were no observed enforcement actions.

3.4 Summary of Biosolids Disposal

A summary of the biosolids disposed of from the facility is as follows.

2024			
Sewage Sludge / Biosolids Production Information			
Hauled Off-Site			
2024	Gallons	% Solids	Dry Tons
January	11,600	0.037	0.18
February	1,200	0.520	0.026
March	0	0.000	0
April	2,300	0.760	0.073
May	5,800	0.610	0.091
June	20,529	0.370	0.315
July	25,640	0.370	0.392
August	25,640	0.370	0.392
September	15,450	0.388	0.243
October	14,775	0.452	0.274
November	0	0.000	0
December	3,700	1.100	0.17
Notes:			
Sewage sludge disposed at Benezette WWTP on reed beds			

3.5 Open Violations

No open violations existed as of March 2025.

4.0 Receiving Waters and Water Supply Information Detail Summary

4.1 Receiving Waters

The receiving waters has been determined to be Trout Run. The sequence of receiving streams that the Trout Run discharges into are Bennett Branch Sinnemahoning Creek, West Branch Susquehanna River, Susquehanna River which eventually drains into the Chesapeake Bay.

4.2 Public Water Supply (PWS) Intake

The closest PWS to the subject facility is Shawville Power Plant (PWS ID #6170333) located approximately 88 miles downstream of the subject facility on the West Branch Susquehanna. Based upon the distance and the flow rate of the facility, the PWS should not be impacted.

4.3 Class A Wild Trout Streams

Class A Wild Trout Streams are waters that support a population of naturally produced trout of sufficient size and abundance to support long-term and rewarding sport fishery. DEP classifies these waters as high-quality coldwater fisheries.

The information obtained from EMAP suggests that no Class A Wild Trout Fishery will be impacted by this discharge.

4.4 2024 Integrated List of All Waters (303d Listed Streams)

Section 303(d) of the Clean Water Act requires States to list all impaired surface waters not supporting uses even after appropriate and required water pollution control technologies have been applied. The 303(d) list includes the reason for impairment which may be one or more point sources (i.e. industrial or sewage discharges) or non-point sources (i.e. abandoned mine lands or agricultural runoff and the pollutant causing the impairment such as metals, pH, mercury or siltation).

States or the U.S. Environmental Protection Agency (EPA) must determine the conditions that would return the water to a condition that meets water quality standards. As a follow-up to listing, the state or EPA must develop a Total Maximum Daily Load (TMDL) for each waterbody on the list. A TMDL identifies allowable pollutant loads to a waterbody from both point and non-point sources that will prevent a violation of water quality standards. A TMDL also includes a margin of safety to ensure protection of the water.

The water quality status of Pennsylvania's waters uses a five-part categorization (lists) of waters per their attainment use status. The categories represent varying levels of attainment, ranging from Category 1, where all designated water uses are met to Category 5 where impairment by pollutants requires a TMDL for water quality protection.

The receiving waters is listed in the 2024 Pennsylvania Integrated Water Quality Monitoring and Assessment Report as a Category 2 waterbody. The surface waters is an attaining stream that supports aquatic life and recreational uses. The designated use has been classified as protected waters for cold water fishes (CWF) and migratory fishes (MF). The receiving waters contains trout natural reproduction. However, eMAP does not indicate the stream as Class A stream.

4.5 Low Flow Stream Conditions

Water quality modeling estimates are based upon conservative data inputs. The data are typically estimated using either a stream gauge or through USGS web based StreamStats program. The NPDES effluent limits are based upon the combined flows from both the stream and the facility discharge.

A conservative approach to estimate the impact of the facility discharge using values which minimize the total combined volume of the stream and the facility discharge. The volumetric flow rate for the stream is based upon the seven-day, 10-year low flow (Q710) which is the lowest estimated flow rate of the stream during a 7 consecutive day period that occurs once in 10 -year time period. The facility discharge is based upon a known design capacity of the subject facility.

The closest WQN station to the subject facility is the West Branch Susquehanna River Karthaus (WQN404). This WQN station is located approximately 56 miles downstream of the subject facility.

The closest gauge station to the subject facility is the Sinnemahoning Creek at Sinnemahoning, PA (USGS station number 1543500). This gauge station is located approximately 21 miles downstream of the subject facility.

For WQM modeling, default values for pH and stream water temperature data from the water quality network station were used. pH was estimated to be 7.0 and the stream water temperature was estimated to be 20 C.

The hardness of the stream was estimated from the water quality network to be 100 mg/l CaCO₃.

The low flow yield and the Q710 for the subject facility was estimated as shown below.

Gauge Station Data		
USGS Station Number	1543500	
Station Name	Sinnemahoning Creek at Sinnemahoning, PA	
Q710	14.5 ft ³ /sec	
Drainage Area (DA)	685	mi ²

Calculations

The low flow yield of the gauge station is:

Low Flow Yield (LFY) = Q710 / DA

$$LFY = (14.5 \text{ ft}^3/\text{sec} / 685 \text{ mi}^2)$$

LFY =	0.0212	ft ³ /sec/mi ²
-------	--------	--------------------------------------

The low flow at the subject site is based upon the DA of 55.7 mi²

Q710 = (LFY@gauge station)(DA@Subject Site)

$$Q710 = (0.0212 \text{ ft}^3/\text{sec}/\text{mi}^2)(55.7 \text{ mi}^2)$$

Q710 =	1.179	ft ³ /sec
--------	-------	----------------------

4.6 Summary of Discharge, Receiving Waters and Water Supply Information

Outfall No.	001	Design Flow (MGD)	0.12
Latitude	41° 18' 56.91"	Longitude	-78° 23' 9.97"
Quad Name		Quad Code	
Wastewater Description:	Sewage Effluent		
Receiving Waters	Trout Run (CWF, MF)	Stream Code	24674
NHD Com ID	61431142	RMI	0.12
Drainage Area	55.7	Yield (cfs/mi ²)	0.0212
Q ₇₋₁₀ Flow (cfs)	1.179	Q ₇₋₁₀ Basis	Streamstats/Streamgauge
Elevation (ft)	300	Slope (ft/ft)	
Watershed No.	8-A	Chapter 93 Class.	CWF, MF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Attaining Use(s) supports aquatic life and recreational uses.		
Cause(s) of Impairment	Not appl.		
Source(s) of Impairment	Not appl.		
TMDL Status	February 27, 2009	Name	Bennett Branch Sinnemahoning Creek Watershed TMDL. Target is drainage from abandoned coal mines
Background/Ambient Data		Data Source	
pH (SU)	7.0	Default	
Temperature (°C)	20	Default	
Hardness (mg/L)	100	Default	
Other:			
Nearest Downstream Public Water Supply Intake	Shawville Power Plant		
PWS Waters	West Branch Susquehanna	Flow at Intake (cfs)	
PWS RMI		Distance from Outfall (mi)	88

5.0: Overview of Presiding Water Quality Standards

5.1 General

There are at least six (6) different policies which determines the effluent performance limits for the NPDES permit. The policies are technology based effluent limits (TBEL), water quality based effluent limits (WQBEL), antidegradation, total maximum daily loading (TMDL), anti-backsliding, and whole effluent toxicity (WET). The effluent performance limitations enforced are the selected permit limits that is most protective to the designated use of the receiving waters. An overview of each of the policies that are applicable to the subject facility has been presented in Section 6.

5.2.1 Technology-Based Limitations

TBEL treatment requirements under section 301(b) of the Act represent the minimum level of control that must be imposed in a permit issued under section 402 of the Act (40 CFR 125.3). Available TBEL requirements for the state of Pennsylvania are itemized in PA Code 25, Chapter 92a.47.

The presiding sources for the basis for the effluent limitations are governed by either federal or state regulation. The reference sources for each of the parameters is itemized in the tables. The following technology-based limitations apply, subject to water quality analysis and best professional judgement (BPJ) where applicable:

Parameter	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

5.2.2 Mass Based Limits

For publicly owned treatment works (POTW), mass loadings are calculated based upon design flow rate of the facility and the permit limit concentration. The generalized calculation for mass loadings is shown below:

$$\text{Quantity } \left(\frac{\text{lb}}{\text{day}} \right) = (\text{MGD})(\text{Concentration})(8.34)$$

5.3 Water Quality-Based Limitations

WQBEL are based on the need to attain or maintain the water quality criteria and to assure protection of designated and existing uses (PA Code 25, Chapter 92a.2). The subject facility that is typically enforced is the more stringent limit of either the TBEL or the WQBEL.

Determination of WQBEL is calculated by spreadsheet analysis or by a computer modeling program developed by DEP. DEP permit engineers utilize the following computing programs for WQBEL permit limitations: (1) MS Excel worksheet for Total Residual Chlorine (TRC); (2) WQM 7.0 for Windows Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen Version 1.1 (WQM Model) and (3) Toxics using DEP Toxics Management Spreadsheet for Toxics pollutants.

The modeling point nodes utilized for this facility are summarized below.

General Data 1	(Modeling Point #1)	(Modeling Point #2)	Units
Stream Code	24674	24508	
River Mile Index	2.69	0	miles
Elevation	300	288	feet
Latitude	41.315436	41.32432	
Longitude	-78.386008	-78.343972	
Drainage Area	55.7	236	sq miles
Low Flow Yield	0.021167883	0.0212	cfs/sq mile

Note: RMI in table are RMI used for modeling. Actual RMI are different

5.3.1 Water Quality Modeling 7.0

The WQM Model is a computer model that is used to determine NPDES discharge effluent limitations for Carbonaceous BOD (CBOD5), Ammonia Nitrogen (NH₃-N), and Dissolved Oxygen (DO) for single and multiple point source discharges scenarios. WQM Model is a complete-mix model which means that the discharge flow and the stream flow are assumed to instantly and completely mixed at the discharge node.

WQM recommends effluent limits for DO, CBOD5, and NH₃-N in mg/l for the discharge(s) in the simulation.

Four types of limits may be recommended. The limits are

- (a) a minimum concentration for DO in the discharge as 30-day average;
- (b) a 30-day average concentration for CBOD5 in the discharge;
- (c) a 30-day average concentration for the NH₃-N in the discharge;
- (d) 24-hour average concentration for NH₃-N in the discharge.

The WQM Model requires several input values for calculating output values. The source of data originates from either EMAP, the National Map, or Stream Stats. Data for stream gauge information, if any, was abstracted from USGS Low-Flow, Base-Flow, and Mean-Flow Regression Equations for Pennsylvania Streams authored by Marla H. Stuckey (Scientific Investigations Report 2006-5130).

The applicable WQM Effluent Limit Type are discussed in Section 6 under the corresponding parameter which is either DO, CBOD, or ammonia-nitrogen.

5.3.2 Toxics Modeling

Toxics modeling is required if the facility receives industrial/commercial contributions. The facility reported the facility does not receive industrial/commercial wastewater.

The facility flow rate does not exceed 0.1 MGD and the facility does not receive industrial/commercial contributions. Thus, the facility is not subject to toxics modeling.

5.3.3 Whole Effluent Toxicity (WET)

The facility is not subject to WET.

5.4 Total Maximum Daily Loading (TMDL)

5.4.1 TMDL

The goal of the Clean Water Act (CWA), which governs water pollution, is to ensure that all of the Nation's waters are clean and healthy enough to support aquatic life and recreation. To achieve this goal, the CWA created programs designed to regulate and reduce the amount of pollution entering United States waters. Section 303(d) of the CWA requires states to assess their waterbodies to identify those not meeting water quality standards. If a waterbody is not meeting standards, it is listed as impaired and reported to the U.S. Environmental Protection Agency. The state then develops a plan to clean up the impaired waterbody. This plan includes the development of a Total Maximum Daily Load (TMDL) for the pollutant(s) that were found to be the cause of the water quality violations. A Total Maximum Daily Load (TMDL) calculates the maximum amount of a specific pollutant that a waterbody can receive and still meet water quality standards.

A TMDL for a given pollutant and waterbody is composed of the sum of individual wasteload allocations (WLAs) for point sources and load allocations (LAs) for nonpoint sources and natural background levels. In addition, the TMDL must include an implicit or explicit margin of safety (MOS) to account for the uncertainty in the relationship between pollutant loads and the quality of the receiving waterbody. The TMDL components are illustrated using the following equation:

$$\text{TMDL} = \sum \text{WLAs} + \sum \text{LAs} + \text{MOS}$$

Pennsylvania has committed to restoring all impaired waters by developing TMDLs and TMDL alternatives for all impaired waterbodies. The TMDL serves as the starting point or planning tool for restoring water quality.

5.4.1.1 Local TMDL

The subject facility discharge into Trout Run. Trout Run then discharges into Bennett Branch Sinnemahoning Creek which has a local TMDL. Bennett Branch Sinnemahoning Creek Watershed TMDL was developed for impaired segments in the Bennett Branch Sinnemahoning Creek Watershed. These were done to address the impairments noted on the 1996 Pennsylvania (PA) Section 303(d) list of impaired waters, required under the Clean Water Act.

Bennett Branch is listed as impaired for metals and pH. All impairments resulted from drainage from abandoned coal mines. The TMDL addresses the three primary metals associated with abandoned mine drainage (AMD) (iron, aluminum, and manganese) and pH.

The subject facility is a sewage discharger. This the facility will not be subject to the TMDL.

5.4.1.2 Chesapeake Bay TMDL Requirement

The Chesapeake Bay Watershed is a large ecosystem that encompasses approximately 64,000 square miles in Maryland, Delaware, Virginia, West Virginia, Pennsylvania, New York and the District of Columbia. An ecosystem is composed of interrelated parts that interact with each other to form a whole. All of the plants and animals in an ecosystem depend on each other in some way. Every living thing needs a healthy ecosystem to survive. Human activities affect the Chesapeake Bay ecosystem by adding pollution, using resources and changing the character of the land.

Most of the Chesapeake Bay and many of its tidal tributaries have been listed as impaired under Section 303(d) of the federal Water Pollution Control Act ("Clean Water Act"), 33 U.S.C. § 1313(d). While the Chesapeake Bay is outside the boundaries of Pennsylvania, more than half of the State lies within the watershed. Two major rivers in Pennsylvania are part of the Chesapeake Bay Watershed. They are (a) the Susquehanna River and (b) the Potomac River. These two rivers total 40 percent of the entire Chesapeake Bay watershed.

The overall management approach needed for reducing nitrogen, phosphorus and sediment are provided in the Bay TMDL document and the Phase I, II, and III WIPs which is described in the Bay TMDL document and Executive Order 13508.

The Bay TMDL is a comprehensive pollution reduction effort in the Chesapeake Bay watershed identifying the necessary pollution reductions of nitrogen, phosphorus and sediment across the seven Bay watershed jurisdictions of Delaware, Maryland, New York, Pennsylvania, Virginia, West Virginia and the District of Columbia to meet applicable water quality standards in the Bay and its tidal waters.

The Watershed Implementation Plans (WIPs) provides objectives for how the jurisdictions in partnership with federal and local governments will achieve the Bay TMDL's nutrient and sediment allocations.

Phase 3 WIP provides an update on Chesapeake Bay TMDL implementation activities for point sources and DEP's current implementation strategy for wastewater. The latest revision of the supplement was September 13, 2021.

The Chesapeake Bay TMDL (Appendix Q) categorizes point sources into four sectors:

- Sector A- significant sewage dischargers;
- Sector B- significant industrial waste (IW) dischargers;
- Sector C- non-significant dischargers (both sewage and IW facilities); and
- Sector D- combined sewer overflows (CSOs).

All sectors contain a listing of individual facilities with NPDES permits that were believed to be discharging at the time the TMDL was published (2010). All sectors with the exception of the non-significant dischargers have individual wasteload allocations (WLAs) for TN and TP assigned to specific facilities. Non-significant dischargers have a bulk or aggregate allocation for TN and TP based on the facilities in that sector that were believed to be discharging at that time and their estimated nutrient loads.

Cap Loads will be established in permits as Net Annual TN and TP loads (lbs/yr) that apply during the period of October 1 – September 30. For facilities that have received Cap Loads in any other form, the Cap Loads will be modified accordingly when the permits are renewed.

Offsets have been incorporated into Cap Loads in several permits issued to date. From this point forward, permits will be issued with the WLAs as Cap Loads and will identify Offsets separately to facilitate nutrient trading activities and compliance with the TMDL.

Based upon the supplement the subject facility has been categorized as a Sector C discharger. The supplement defines Sector C as a non-significant dischargers include sewage facilities (Phase 4 facilities: ≥ 0.2 MGD and < 0.4 MGD and Phase 5 facilities: > 0.002 MGD and < 0.2 MGD), small flow/single residence sewage treatment facilities (≤ 0.002 MGD), and non-significant IW facilities, all of which may be covered by statewide General Permits or may have individual NPDES permits.

At this time, there are approximately 850 Phase 4 and 5 sewage facilities, approximately 715 small flow sewage treatment facilities covered by a statewide General Permit, and approximately 300 non-significant IW facilities.

For Phase 5 sewage facilities with individual permits (average annual design flow on August 29, 2005 > 0.002 MGD and < 0.2 MGD), DEP will issue individual permits with monitoring and reporting for TN and TP throughout the permit term at a frequency no less than annually, unless 1) the facility has already conducted at least two years of nutrient monitoring and 2) a summary of the monitoring results are included in the next permit's fact sheet. If, however, Phase 5 facilities choose to expand, the renewed or amended permits will contain Cap Loads based on the lesser of a) existing TN/TP concentrations at current design average annual flow or b) 7,306 lbs/yr TN and 974 lbs/yr TP.

If no data are available to determine existing concentrations for expanding Phase 4 or 5 facilities, default concentrations of 25 mg/l TN and 4 mg/l TP may be used (these are the average estimated concentrations of all non-significant sewage facilities).

DEP will not issue permits to existing Phase 4 and 5 facilities containing Cap Loads unless it is done on a broad scale or unless the facilities are expanding.

For new Phase 4 and 5 sewage discharges, in general DEP will issue new permits containing Cap Loads of "0" and new facilities will be expected to purchase credits and/or apply offsets to achieve compliance, with the exception of small flow and single residence facilities.

The total nitrogen (TN) and total phosphorus (TP) cap loads itemized by for the subject facility are as follows:

TN Cap Load (lbs/yr)	0
TN Delivery Ratio	0.644
TP Cap Load (lbs/yr)	0
TP Delivery Ratio	0.241

This facility subject to Sector C monitoring requirements. Monitoring for nitrogen and phosphorus shall continue at least 2x/month.

Reporting

Cap Loads will be established in permits as Net Annual TN and TP loads (lbs/yr) that apply during the period of October 1 – September 30.

Facilities with NPDES permits must use DEP's eDMR system for reporting, except small flow treatment facilities. An Annual DMR must be submitted by the end of the Truing Period, November 28. As attachments to the Annual DMR a facility must submit a completed Annual Chesapeake Bay Spreadsheet, available through DEP's Supplemental Reports website, which contains an Annual Nutrient Monitoring worksheet and an Annual Nutrient Budget worksheet. This Spreadsheet will be submitted once per Compliance Year only, and reflect all nutrient sample results (for the period October 1 – September 30), Credit transactions (including the Truing Period) and Offsets applied during the Compliance Year.

5.5 Anti-Degradation Requirement

Chapter 93.4a of the PA regulations requires that surface water of the Commonwealth of Pennsylvania may not be degraded below levels that protect the existing uses. The regulations specifically state that *Existing instream water uses and the level of water quality necessary to protect the existing uses shall be maintained and protected*. Antidegradation requirements are implemented through DEP's guidance manual entitled Water Quality Antidegradation Implementation Guidance (Document #391-0300-02).

The policy requires DEP to protect the existing uses of all surface waters and the existing quality of High Quality (HQ) and Exceptional Value (EV) Waters. Existing uses are protected when DEP makes a final decision on any permit or approval for an activity that may affect a protected use. Existing uses are protected based upon DEP's evaluation of the best available information (which satisfies DEP protocols and Quality Assurance/Quality Control (QA/QC) procedures) that indicates the protected use of the waterbody.

For a new, additional, or increased point source discharge to an HQ or EV water, the person proposing the discharge is required to utilize a nondischarge alternative that is cost-effective and environmentally sound when compared with the cost of the proposed discharge. If a nondischarge alternative is not cost-effective and environmentally sound, the person must use the best available combination of treatment, pollution prevention, and wastewater reuse technologies and assure that any discharge is nondegrading. In the case of HQ waters, DEP may find that after satisfaction of intergovernmental coordination and public participation requirements lower water quality is necessary to accommodate important economic or social development in the area in which the waters are located. In addition, DEP will assure that cost-effective and reasonable best management practices for nonpoint source control in HQ and EV waters are achieved.

The subject facility's discharge will be to a non-special protection waters and the permit conditions are imposed to protect existing instream water quality and uses. Neither HQ waters or EV waters is impacted by this discharge.

5.6 Anti-Backsliding

Anti-backsliding is a federal regulation which prohibits a permit from being renewed, reissued, or modified containing effluent limitations which are less stringent than the comparable effluent limitations in the previous permit (40 CFR 122.1.1 and 40 CFR 122.1.2). A review of the existing permit limitations with the proposed permit limitations confirm that the facility is consistent with anti-backsliding requirements. The facility has proposed effluent limitations that are as stringent as the existing permit.

6.0 NPDES Parameter Details

The basis for the proposed sampling and their monitoring frequency that will appear in the permit for each individual parameter are itemized in this Section. The final limits are the more stringent of technology based effluent treatment (TBEL) requirements, water quality based (WQBEL) limits, TMDL, antidegradation, anti-degradation, or WET.

The reader will find in this section:

- a) a justification of recommended permit monitoring requirements and limitations for each parameter in the proposed NPDES permit;
- b) a summary of changes from the existing NPDES permit to the proposed permit; and
- c) a summary of the proposed NPDES effluent limits.

6.1 Recommended Monitoring Requirements and Effluent Limitations

A summary of the recommended monitoring requirements and effluent limitations are itemized in the tables. The tables are categorized by (a) Conventional Pollutants and Disinfection, (b) Nitrogen Species and Phosphorus, and (c) Chapter 92a.61 targeted parameters

6.1.1 Conventional Pollutants and Disinfection

Summary of Proposed NPDES Parameter Details for Conventional Pollutants and Disinfection Benezette WWTP; PA0263711

Parameter	Permit Limitation Required by ¹ :	Recommendation	
pH (S.U.)	TBEL	Monitoring: The monitoring frequency shall be daily as a grab sample (Table 6-3).	
		Effluent Limit: Effluent limits may range from pH = 6.0 to 9.0	
		Rationale: The monitoring frequency has been assigned in accordance with Table 6-3 and the effluent limits assigned by Chapter 95.2(1).	
Dissolved Oxygen	BPJ	Monitoring: The monitoring frequency shall be daily as a grab sample (Table 6-3).	
		Effluent Limit: Effluent limits shall be greater than 5.0 mg/l.	
		Rationale: The monitoring frequency has been assigned in accordance with Table 6-3 and the effluent limits assigned by best professional judgement.	
CBOD	TBEL	Monitoring: The monitoring frequency shall be 1x/wk as an 8-hr composite sample (Table 6-3).	
		Effluent Limit: Effluent limits shall not exceed 8 lbs/day and 25 mg/l as an average monthly.	
		Rationale: The monitoring frequency has been assigned in accordance with Table 6-3 and the effluent limits assigned by Chapter 92a.47(a)(1). WQM modeling indicates that the TBEL is more stringent than the WQBEL. Thus, the permit limit is confined to TBEL.	
TSS	TBEL	Monitoring: The monitoring frequency shall be 1x/wk as an 8-hr composite sample (Table 6-3).	
		Effluent Limit: Effluent limits shall not exceed 10 lbs/day and 30 mg/l as an average monthly.	
		Rationale: The monitoring frequency has been assigned in accordance with Table 6-3 and the effluent limits assigned by Chapter 92a.47(a)(1). While there is no WQM modeling for this parameter, the permit limit for TSS is generally assigned similar effluent limits as CBOD or BOD.	
TRC	TBEL	Monitoring: The monitoring frequency shall be on a daily basis as a grab sample (Table 6-3).	
		Effluent Limit: The average monthly limit should not exceed 0.5 mg/l and/or 1.6 mg/l as an instantaneous maximum.	
		Rationale: Chlorine in both combined (chloramine) and free form is extremely toxic to freshwater fish and other forms of aquatic life (Implementation Guidance Total Residual Chlorine 1). The TRC effluent limitations to be imposed on a discharger shall be the more stringent of either the WQBEL or TBEL requirements and shall be expressed in the NPDES permit as an average monthly and instantaneous maximum effluent concentration (Implementation Guidance Total Residual Chlorine 4). Based on the stream flow rate (lowest 7-day flow rate in 10 years) and the design flow rate of the subject facility calculated by the TRC Evaluation worksheet, the TBEL is more stringent than the WQBEL. The monitoring frequency has been assigned in accordance with Table 6-3 and the effluent limits assigned by Chapter 92a.48(b)(2)	
Fecal Coliform	TBEL	Monitoring: The monitoring frequency shall be 1x/wk as a grab sample (Table 6-3).	
		Effluent Limit: Summer effluent limits shall not exceed 200 No./100 mL as a geometric mean. Winter effluent limits shall not exceed 2000 No./100 mL as a geometric mean.	
		Rationale: The monitoring frequency has been assigned in accordance with Table 6-3 and the effluent limits assigned by Chapter 92a.47(a)(4) and 92a.47(a)(5).	
E. Coli	SOP; Chapter 92a.61	Monitoring: The monitoring frequency shall be 1x/yr as a grab sample (SOP).	
		Effluent Limit: No effluent requirements.	
		Rationale: Consistent with the SOP- Establishing Effluent Limitations for Individual Sewage Permits (Revised March 22, 2019) and under the authority of Chapter 92a.61, the facility will be required to monitor for E.Coli.	
Notes:			
1 The NPDES permit was limited by (a) anti-Backsliding, (b) Anti-Degradation, (c) SOP, (d) TBEL, (e) TMDL, (f) WQBEL, (g) WET, or (h) Other			
2 Monitoring frequency based on flow rate of 0.04 MGD.			
3 Table 6-3 (Self Monitoring Requirements for Sewage Discharges) in Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits (Document # 362-0400-001) Revised 10/97			
4 Water Quality Antidegradation Implementation Guidance (Document # 391-0300-002)			
5 Chesapeake Bay Phase 3 Watershed Implementation Plan Wastewater Supplement, Revised September 13, 2021			

6.1.2 Nitrogen Species and Phosphorus

Summary of Proposed NPDES Parameter Details for Nitrogen Species and Phosphorus

Benezette WWTP; PA0263711

Parameter	Permit Limitation Required by ¹ :	Recommendation	
Ammonia-Nitrogen	Impl. Guidance of Section 93.7 Ammonia Criteria	Monitoring:	The monitoring frequency shall be 2x/month as an 8-hr composite sample (Table 6-3).
		Effluent Limit:	No effluent requirements.
		Rationale:	The monitoring frequency has been assigned in accordance with Table 6-3
Nitrate-Nitrite as N	Chesapeake Bay TMDL	Monitoring:	The monitoring frequency shall be 2x/mo as an 8-hr composite sample
		Effluent Limit:	No effluent requirements.
		Rationale:	Due to the Chesapeake Bay Implementation Plan, the facility is required to be monitored on a frequency at least 2x/mo.
Total Nitrogen	Chesapeake Bay TMDL	Monitoring:	The monitoring frequency shall be 1x/mo as a calculation
		Effluent Limit:	No effluent requirements.
		Rationale:	Due to the Chesapeake Bay Implementation Plan, the facility is required to be monitored on a frequency at least 1x/mo.
TKN	Chesapeake Bay TMDL	Monitoring:	The monitoring frequency shall be 2x/mo as an 8-hr composite sample
		Effluent Limit:	No effluent requirements.
		Rationale:	Due to the Chesapeake Bay Implementation Plan, the facility is required to be monitored on a frequency at least 2x/mo.
Total Phosphorus	Chesapeake Bay TMDL	Monitoring:	The monitoring frequency shall be 2x/mo as an 8-hr composite sample
		Effluent Limit:	No effluent requirements.
		Rationale:	Due to the Chesapeake Bay Implementation Plan, the facility is required to be monitored on a frequency at least 2x/mo.
Net Total Nitrogen	Chesapeake Bay TMDL	Monitoring:	The monitoring frequency shall be 1x/yr as a calculation
		Effluent Limit:	Effluent limits shall not exceed 0 lbs/yr.
		Rationale:	Due to the Chesapeake Bay Implementation Plan, the facility is required to be monitored on a frequency at least 1x/yr.
Net Total Phosphorus	Chesapeake Bay TMDL	Monitoring:	The monitoring frequency shall be 1x/yr as a calculation
		Effluent Limit:	Effluent limits shall not exceed 0 lbs/yr.
		Rationale:	Due to the Chesapeake Bay Implementation Plan, the facility is required to be monitored on a frequency at least 1x/yr.

Notes:

1 The NPDES permit was limited by (a) anti-Backsliding, (b) Anti-Degradation, (c) SOP, (d) TBEL, (e) TMDL, (f) WQBEL, (g) WET, or (h) Other
2 Monitoring frequency based on flow rate of 0.04 MGD.

3 Table 6-3 (Self Monitoring Requirements for Sewage Discharges) in Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits (Document # 362-0400-001) Revised 10/97

4 Water Quality Antidegradation Implementation Guidance (Document # 391-0300-002)

5 Chesapeake Bay Phase 3 Watershed Implementation Plan Wastewater Supplement, Revised September 13, 2021

6.1.3 Toxics

Summary of Proposed NPDES Parameter Details for pollutants monitored under Chapter 92a.61
Benezette WWTP; PA0263711

Parameter	Permit Limitation Required by ¹ :	Recommendation
E. Coli	SOP; Chapter 92a.61	<p>Monitoring: The monitoring frequency shall be 1x/yr as a grab sample (SOP).</p> <p>Effluent Limit: No effluent requirements.</p> <p>Rationale: Consistent with the SOP- Establishing Effluent Limitations for Individual Sewage Permits (Revised March 22, 2019) and under the authority of Chapter 92a.61, the facility will be required to monitor for E.Coli.</p>

Notes:

- 1 The NPDES permit was limited by (a) anti-Backsliding, (b) Anti-Degradation, (c) SOP, (d) TBEL, (e) TMDL, (f) WQBEL, (g) WET, or (h) Other
- 2 Monitoring frequency based on flow rate of 0.04 MGD.
- 3 Table 6-3 (Self Monitoring Requirements for Sewage Discharges) in Technical Guidance for the Development and Specification of Effluent
- 4 Water Quality Antidegradation Implementaton Guidance (Document # 391-0300-002)
- 5 Chesapeake Bay Phase 3 Watershed Implementation Plan Wastewater Supplement, Revised September 13, 2021

6.1.3.1 Implementation of Regulation- Chapter 92a.61

Chapter 92a.61 provides provisions to DEP to monitor for pollutants that may have an impact on the quality of waters of the Commonwealth.

Based upon DEP policy directives the following pollutants shall be monitored:

- Consistent with DEP Management directives issued on March 22, 2021 and in conjunction with EPA's 2017 Triennial Review, monitoring for E. Coli shall be required. The monitoring frequency is based upon flow rate.

6.2 Summary of Changes From Existing Permit to Proposed Permit

A summary of how the proposed NPDES permit differs from the existing NPDES permit is summarized as follows.

- **Dissolved oxygen limit increased to 5 mg/l.**
- **Due to the EPA triennial review, monitoring shall be required for E. Coli.**

6.3.1 Summary of Proposed NPDES Effluent Limits

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

The proposed NPDES effluent limitations are summarized in the table below.

PART A - EFFLUENT LIMITATIONS, MONITORING, RECORDKEEPING AND REPORTING REQUIREMENTS

I. A. For Outfall <u>001</u> , Latitude <u>41° 18' 56.48"</u> , Longitude <u>78° 23' 10.00"</u> , River Mile Index <u>0.12</u> , Stream Code <u>24674</u>
Receiving Waters: <u>Trout Run (CWF, MF)</u>
Type of Effluent: <u>Sewage Effluent</u>
1. The permittee is authorized to discharge during the period from <u>Permit Effective Date</u> through <u>Permit Expiration Date</u> .)
2. Based on the anticipated wastewater characteristics and flows described in the permit application and its supporting documents and/or amendments, the following effluent limitations and monitoring requirements apply (see also Additional Requirements and Footnotes).

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
Dissolved Oxygen	XXX	XXX	5.0 Inst Min	XXX	XXX	XXX	1/day	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5)	8	13	XXX	25.0	40.0	XXX	1/week	8-Hr Composite
Biochemical Oxygen Demand (BOD5)		Report Daily Max	XXX	Report	XXX	XXX		24-Hr Composite
Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Total Suspended Solids			XXX	30.0	45.0	XXX	1/week	8-Hr Composite
Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Total Suspended Solids	10	15	XXX	30.0	45.0	XXX	1/week	8-Hr Composite
Fecal Coliform (No./100 ml)				2000				
Oct 1 - Apr 30	XXX	XXX	XXX	Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml)				200				
May 1 - Sep 30	XXX	XXX	XXX	Geo Mean	XXX	1000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab

Outfall 001, Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Ammonia-Nitrogen Nov 1 - Apr 30	Report	XXX	XXX	Report	XXX	XXX	2/week	8-Hr Composite
Ammonia-Nitrogen May 1 - Oct 31	Report	XXX	XXX	Report	XXX	XXX	2/week	8-Hr Composite
Total Phosphorus	Report	XXX	XXX	Report	XXX	XXX	2/week	8-Hr Composite

Samples taken in compliance with the monitoring requirements specified above shall be taken at the following location(s):

at Outfall 001

PART A - EFFLUENT LIMITATIONS, MONITORING, RECORDKEEPING AND REPORTING REQUIREMENTS

I. B. For Outfall 001, Latitude 41° 18' 56.48", Longitude 78° 23' 10.00", River Mile Index 0.12, Stream Code 24674

Receiving Waters: Trout Run (CWF, MF)

Type of Effluent: Sewage Effluent

1. The permittee is authorized to discharge during the period from Permit Effective Date through Permit Expiration Date.
2. Based on the anticipated wastewater characteristics and flows described in the permit application and its supporting documents and/or amendments, the following effluent limitations and monitoring requirements apply (see also Additional Requirements and Footnotes).

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Monthly	Annual	Monthly	Monthly Average	Maximum	Instant. Maximum		
Ammonia--N	Report	Report	XXX	Report	XXX	XXX	2/week	8-Hr Composite
Kjeldahl--N	Report	XXX	XXX	Report	XXX	XXX	2/week	8-Hr Composite
Nitrate-Nitrite as N	Report	XXX	XXX	Report	XXX	XXX	2/week	8-Hr Composite
Total Nitrogen	Report	Report	XXX	Report	XXX	XXX	1/month	Calculation
Total Phosphorus	Report	Report	XXX	Report	XXX	XXX	2/week	8-Hr Composite
Net Total Nitrogen	Report	0	XXX	XXX	XXX	XXX	1/month	Calculation
Net Total Phosphorus	Report	0	XXX	XXX	XXX	XXX	1/month	Calculation

Samples taken in compliance with the monitoring requirements specified above shall be taken at the following location(s):

at Outfall 001

Footnotes:

- (1) See Part C for Chesapeake Bay Requirements.
- (2) This is the minimum number of sampling events required. Permittees are encouraged, and it may be advantageous in demonstrating compliance, to perform more than the minimum number of sampling events required.

6.3.2 Summary of Proposed Permit Part C Conditions

The subject facility has the following Part C conditions.

- Chlorine Minimization
- Hauled-in Waste Restrictions
- Chesapeake Bay Nutrient Definitions
- Solids Management for Non-Lagoon Treatment Systems
- Onlot Nitrogen Offsets
- High Flow Management

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [REDACTED])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: [REDACTED]
<input type="checkbox"/>	Other: [REDACTED]

Attachment A

Stream Stats/Gauge Data

Table 1. List of U.S. Geological Survey streamgage locations in and near Pennsylvania with updated streamflow statistics.—Continued
[Latitude and Longitude in decimal degrees; mi², square miles]

Streamgage number	Streamgage name	Latitude	Longitude	Drainage area (mi ²)	Regulated ¹
01541303	West Branch Susquehanna River at Hyde, Pa.	41.005	-78.457	474	Y
01541308	Bradley Run near Ashville, Pa.	40.509	-78.584	6.77	N
01541500	Clearfield Creek at Dimeling, Pa.	40.972	-78.406	371	Y
01542000	Moshannon Creek at Osceola Mills, Pa.	40.850	-78.268	68.8	N
01542500	WB Susquehanna River at Karthaus, Pa.	41.118	-78.109	1,462	Y
01542810	Waldy Run near Emporium, Pa.	41.579	-78.293	5.24	N
01543000	Driftwood Branch Sinnemahoning Creek at Sterling Run, Pa.	41.413	-78.197	272	N
01543500	Sinnemahoning Creek at Sinnemahoning, Pa.	41.317	-78.103	685	N
01544000	First Fork Sinnemahoning Creek near Sinnemahoning, Pa.	41.402	-78.024	245	Y
01544500	Kettle Creek at Cross Fork, Pa.	41.476	-77.826	136	N
01545000	Kettle Creek near Westport, Pa.	41.320	-77.874	233	Y
01545500	West Branch Susquehanna River at Renovo, Pa.	41.325	-77.751	2,975	Y
01545600	Young Womans Creek near Renovo, Pa.	41.390	-77.691	46.2	N
01546000	North Bald Eagle Creek at Milesburg, Pa.	40.942	-77.794	119	N
01546400	Spring Creek at Houserville, Pa.	40.834	-77.828	58.5	N
01546500	Spring Creek near Axemann, Pa.	40.890	-77.794	87.2	N
01547100	Spring Creek at Milesburg, Pa.	40.932	-77.786	142	N
01547200	Bald Eagle Creek below Spring Creek at Milesburg, Pa.	40.943	-77.786	265	N
01547500	Bald Eagle Creek at Blanchard, Pa.	41.052	-77.604	339	Y
01547700	Marsh Creek at Blanchard, Pa.	41.060	-77.606	44.1	N
01547800	South Fork Beech Creek near Snow Shoe, Pa.	41.024	-77.904	12.2	N
01547950	Beech Creek at Monument, Pa.	41.112	-77.702	152	N
01548005	Bald Eagle Creek near Beech Creek Station, Pa.	41.081	-77.549	562	Y
01548500	Pine Creek at Cedar Run, Pa.	41.522	-77.447	604	N
01549000	Pine Creek near Waterville, Pa.	41.313	-77.379	750	N
01549500	Blockhouse Creek near English Center, Pa.	41.474	-77.231	37.7	N
01549700	Pine Creek below Little Pine Creek near Waterville, Pa.	41.274	-77.324	944	Y
01550000	Lycoming Creek near Trout Run, Pa.	41.418	-77.033	173	N
01551500	WB Susquehanna River at Williamsport, Pa.	41.236	-76.997	5,682	Y
01552000	Loyalsock Creek at Loyalsockville, Pa.	41.325	-76.912	435	N
01552500	Muncy Creek near Sonestown, Pa.	41.357	-76.535	23.8	N
01553130	Sand Spring Run near White Deer, Pa.	41.059	-77.077	4.93	N
01553500	West Branch Susquehanna River at Lewisburg, Pa.	40.968	-76.876	6,847	Y
01553700	Chillisquaque Creek at Washingtonville, Pa.	41.062	-76.680	51.3	N
01554000	Susquehanna River at Sunbury, Pa.	40.835	-76.827	18,300	Y
01554500	Shamokin Creek near Shamokin, Pa.	40.810	-76.584	54.2	N
01555000	Penns Creek at Penns Creek, Pa.	40.867	-77.048	301	N
01555500	East Mahantango Creek near Dalmatia, Pa.	40.611	-76.912	162	N
01556000	Frankstown Branch Juniata River at Williamsburg, Pa.	40.463	-78.200	291	N
01557500	Bald Eagle Creek at Tyrone, Pa.	40.684	-78.234	44.1	N
01558000	Little Juniata River at Spruce Creek, Pa.	40.613	-78.141	220	N
01559000	Juniata River at Huntingdon, Pa.	40.485	-78.019	816	LF
01559500	Standing Stone Creek near Huntingdon, Pa.	40.524	-77.971	128	N
01559700	Sulphur Springs Creek near Manns Choice, Pa.	39.978	-78.619	5.28	N
01560000	Dunning Creek at Belden, Pa.	40.072	-78.493	172	N

Table 2 25


Table 2. Selected low-flow statistics for streamgage locations in and near Pennsylvania.—Continued

[ft³/s; cubic feet per second; —, statistic not computed; <, less than]

Streamgage number	Period of record used in analysis ¹	Number of years used in analysis	1-day, 10-year (ft ³ /s)	7-day, 10-year (ft ³ /s)	7-day, 2-year (ft ³ /s)	30-day, 10-year (ft ³ /s)	30-day, 2-year (ft ³ /s)	90-day, 10-year (ft ³ /s)
01530500	1940–2008	69	5.0	6.1	11.0	7.6	13	9.0
01531000	² 1981–2008	28	138	147	237	169	296	203
01531000	³ 1905–1979	68	86.3	97.0	175	116	219	161
01531500	² 1981–2008	28	550	592	1,030	733	1,340	952
01531500	³ 1915–1979	65	539	571	990	675	1,230	928
01532000	1915–2008	94	2.2	2.8	9.7	4.6	14.4	9.4
01532850	1967–1979	13	.1	.2	.4	.3	.8	.7
01533400	² 1981–2008	28	602	648	1,110	790	1,430	1,060
01533500	1942–1958	17	.4	.6	1.5	.8	2.0	1.7
01533950	1962–1978	17	.2	.3	1.0	.6	1.4	1.0
01534000	1915–2008	94	15.2	17.3	35.9	24.2	51.0	38.7
01534300	1960–2008	49	1.1	1.7	5.1	2.8	7.6	4.8
01534500	² 1961–2008	48	16.7	18.8	29.2	21.9	35.8	27.6
01534500	³ 1941–1959	19	18.8	23.0	33.3	25.6	39.2	34.9
01536000	² 1961–2008	48	28.7	32.7	51.7	40.8	68.1	54.3
01536000	³ 1940–1959	20	77.8	93.9	119	105	138	124
01536500	² 1981–2008	28	828	872	1,450	1,030	1,830	1,350
01536500	³ 1901–1979	79	778	811	1,350	927	1,640	1,260
01537000	1943–1993	51	1.3	2.0	4.9	3.1	6.4	4.7
01537500	1941–1990	50	.2	.3	1.9	.5	3.1	1.6
01538000	1921–2008	88	3.1	3.6	7.1	5.0	9.3	7.5
01539000	1940–2008	69	15.4	16.8	36.8	21.1	51.1	36.8
01539500	1942–1958	17	.1	.3	1.4	1.0	3.3	2.3
01540200	1965–1981	17	0	0	.3	.1	.3	.1
01540500	² 1981–2008	28	1,080	1,120	1,870	1,320	2,330	1,690
01540500	³ 1906–1979	74	927	978	1,660	1,160	2,050	1,590
01541000	1915–2008	94	25.3	27.9	50.7	35.3	66.6	49.6
01541200	² 1967–2008	40	34.6	45.2	66.0	63.1	100	92.4
01541200	³ 1957–1965	9	22.9	24.7	44.7	27.7	58.2	36.4
01541303	1980–2008	29	53.4	58.5	94.0	74.4	123	102
01541308	1969–1979	11	1.3	1.3	1.9	1.6	2.4	2.1
01541500	² 1962–2008	47	39.0	41.9	66.5	51.9	86.3	70.6
01541500	³ 1915–1960	46	14.9	21.3	41.9	28.5	55.0	42.9
01542000	1942–1993	52	8.1	9.1	14.8	11.3	17.8	14.6
01542500	² 1967–2008	33	216	235	326	285	435	402
01542500	³ 1941–1965	20	—	131	189	152	243	221
01542810	1966–2008	43	.1	.1	.3	.2	.5	.3
01543000	1915–2008	94	2.9	4.2	16.0	9.6	27.4	19.2
01543500	1940–2008	69	10.7	14.5	44.9	26.6	74.9	50.5
01544000	² 1957–2008	52	3.3	6.9	19.0	11.2	31.1	19.0
01544500	1942–2008	67	4.2	4.9	12.5	7.5	17.4	11.7
01545000	² 1964–2008	45	6.8	8.2	21.2	12.0	32.7	20.7
01545500	² 1963–2008	46	217	238	446	306	629	428
01545500	³ 1909–1961	53	125	141	278	190	387	296
01545600	1966–2008	43	1.2	1.5	4.4	2.4	6.7	4.2

StreamStats Report

Region ID: PA
Workspace ID: PA20250401093756945000
Clicked Point (Latitude, Longitude): 41.31545, -78.38599
Time: 2025-04-01 05:38:21 -0400



Benezette WWTP PA0263711 Modeling Point #1 April 2025

[Collapse All](#)

► Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	55.7	square miles
FOREST	Percentage of area covered by forest	95.1072	percent
GLACIATED	Percentage of basin area that was historically covered by glaciers	0	percent
PRECIP	Mean Annual Precipitation	44	inches

► Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 5]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	55.7	square miles	4.84	982
FOREST	Percent Forest	95.1072	percent	41	100
GLACIATED	Percent of Glaciation	0	percent	0	100
PRECIP	Mean Annual Precipitation	44	inches	33.1	47.1

Low-Flow Statistics Flow Report [Low Flow Region 5]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR²: Pseudo R Squared (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	4.35	ft ³ /s	38	38
30 Day 2 Year Low Flow	6.8	ft ³ /s	33	33

Statistic	Value	Unit	SE	ASEP
7 Day 10 Year Low Flow	1.39	ft^3/s	57	57
30 Day 10 Year Low Flow	2.63	ft^3/s	51	51
90 Day 10 Year Low Flow	4.51	ft^3/s	41	41

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.


Application Version: 4.28.0

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1

StreamStats Report

Region ID: PA
Workspace ID: PA20250401094201302000
Clicked Point (Latitude, Longitude): 41.32415, -78.34391
Time: 2025-04-01 05:42:25 -0400



Benezette WWTP PA0263711 Modeling Point #2 PA0263711

[Collapse All](#)

Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	236	square miles
FOREST	Percentage of area covered by forest	95.5272	percent
GLACIATED	Percentage of basin area that was historically covered by glaciers	0	percent
PRECIP	Mean Annual Precipitation	44	inches

Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 5]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	236	square miles	4.84	982
FOREST	Percent Forest	95.5272	percent	41	100
GLACIATED	Percent of Glaciation	0	percent	0	100
PRECIP	Mean Annual Precipitation	44	inches	33.1	47.1

Low-Flow Statistics Flow Report [Low Flow Region 5]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR²: Pseudo R Squared (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	23.5	ft ³ /s	38	38
30 Day 2 Year Low Flow	35.2	ft ³ /s	33	33

Statistic	Value	Unit	SE	ASEp
7 Day 10 Year Low Flow	8.88	ft^3/s	57	57
30 Day 10 Year Low Flow	15.6	ft^3/s	51	51
90 Day 10 Year Low Flow	24.9	ft^3/s	41	41

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.28.0

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1

Attachment B

WQM 7.0 Modeling Output Values

WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
08A	24674	TROUT RUN					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
2.690	Benezette	PA0263711	0.040	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			5

WQM 7.0 Wasteload Allocations

SWP Basin	Stream Code	Stream Name
08A	24674	TROUT RUN

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
2.690	Benezette	16.04	50	16.04	50	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
2.690	Benezette	1.86	25	1.86	25	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	CBOD5		NH3-N		Dissolved Oxygen		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
2.69	Benezette	25	25	25	25	5	5	0	0

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
08A	24674 TROUT RUN		2.690	300.00	55.70	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	pH	Stream Temp (°C)	pH
	(cfsm)	(cfs)	(cfs)									
Q7-10	0.021	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Benezette	PA0263711	0.0400	0.0400	0.0400	0.000	25.00	7.44
Parameter Data							
Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)		
CBOD5		25.00	2.00	0.00	1.50		
Dissolved Oxygen		5.00	8.24	0.00	0.00		
NH3-N		25.00	0.00	0.00	0.70		

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation	Drainage Area	Slope	PWS Withdrawal	Apply FC
				(ft)	(sq mi)	(ft/ft)	(mgd)	
08A	24674	TROUT RUN	0.000	288.00	236.00	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Stream pH	Temp	pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.021	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow	Permitted Disc Flow	Design Disc Flow	Reserve Factor	Disc Temp	Disc pH
		(mgd)	(mgd)	(mgd)			
		0.0000	0.0000	0.0000	0.000	25.00	7.00
Parameter Data							
Parameter Name		Disc Conc	Trib Conc	Stream Conc	Fate Coef		
		(mg/L)	(mg/L)	(mg/L)	(1/days)		
CBOD5		25.00	2.00	0.00	1.50		
Dissolved Oxygen		3.00	8.24	0.00	0.00		
NH3-N		25.00	0.00	0.00	0.70		

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>			
08A	24674	TROUT RUN			
<u>RMI</u>		<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
2.690		0.040	20.250	7.014	
<u>Reach Width (ft)</u>		<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
24.094		0.609	39.572	0.084	
<u>Reach CBOD5 (mg/L)</u>		<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
3.15		0.230	1.25	0.714	
<u>Reach DO (mg/L)</u>		<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
8.081		0.681	Tsivoglou	5	
<u>Reach Travel Time (days)</u>		<u>Subreach Results</u>			
1.949		TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
		0.195	3.01	1.09	7.32
		0.390	2.88	0.95	6.75
		0.585	2.75	0.82	6.34
		0.780	2.63	0.72	6.06
		0.975	2.51	0.62	5.88
		1.170	2.40	0.54	5.78
		1.365	2.29	0.47	5.74
		1.559	2.19	0.41	5.75
		1.754	2.09	0.36	5.81
		1.949	2.00	0.31	5.89

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>			<u>Stream Code</u>			<u>Stream Name</u>						
08A			24674			TROUT RUN						
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
Q7-10 Flow												
2.690	1.18	0.00	1.18	.0619	0.00084	.609	24.09	39.57	0.08	1.949	20.25	7.01
Q1-10 Flow												
2.690	0.87	0.00	0.87	.0619	0.00084	NA	NA	NA	0.07	2.285	20.33	7.02
Q30-10 Flow												
2.690	2.15	0.00	2.15	.0619	0.00084	NA	NA	NA	0.12	1.408	20.14	7.01

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.74	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.83	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

Attachment C

TRC Evaluation

Benezett WWTP
PA0263711

April 2025

1A	B	C	D	E	F	G
2 TRC EVALUATION						
3 Input appropriate values in B4:B8 and E4:E7						
4 1.179051095	= Q stream (cfs)		0.5	= CV Daily		
5 0.04	= Q discharge (MGD)		0.5	= CV Hourly		
6 30	= no. samples		1	= AFC_Partial Mix Factor		
7 0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor		
8 0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)		
9 0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)		
	0 = % Factor of Safety (FOS)		0	= Decay Coefficient (K)		
#	Source	Reference	AFC Calculations	Reference	CFC Calculations	
#	TRC	1.3.2.iii	WLA_afc = 6.097	1.3.2.iii	WLA_cfc = 5.937	
#	PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581	
#	PENTOXSD TRG	5.1b	LTA_afc= 2.272	5.1d	LTA_cfc = 3.451	
#	Source		Effluent Limit Calculations			
#	PENTOXSD TRG	5.1f	AML MULT = 1.231			
#	PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500	BAT/BPJ		
#			INST MAX LIMIT (mg/l) = 1.635			
WLA_afc			(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))... ...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)			
LTAMULT_afc			EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)			
LTA_afc			wla_afc*LTAMULT_afc			
WLA_cfc			(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))... ...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)			
LTAMULT_cfc			EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)			
LTA_cfc			wla_cfc*LTAMULT_cfc			
AML MULT			EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))			
AVG MON LIMIT			MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)			
INST MAX LIMIT			1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)			