

Application Type Renewal  
Facility Type Non-Municipal  
Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0263834  
APS ID 1066509  
Authorization ID 1405279

**Applicant and Facility Information**

Applicant Name	<u>Lake Lucy Sewage Authority</u>	Facility Name	<u>Lake Lucy STP</u>
Applicant Address	<u>1560 Lake Lucy Road</u> <u>Tionesta, PA 16353</u>	Facility Address	<u>Behind 1543 Lake Lucy Road</u> <u>Tionesta, PA 16353</u>
Applicant Contact	<u>Richard Harriett, Chairman</u> <u><a href="mailto:lakelucysewageauthority@gmail.com">lakelucysewageauthority@gmail.com</a></u>	Facility Contact	<u>Richard Harriett, Chairman</u> <u><a href="mailto:lakelucysewageauthority@gmail.com">lakelucysewageauthority@gmail.com</a></u>
Applicant Phone	<u>(814) 354-2648</u>	Facility Phone	<u>(814) 354-2648</u>
Client ID	<u>370898</u>	Site ID	<u>545577</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Washington Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Clarion County</u>
Date Application Received	<u>June 6, 2022</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>June 30, 2022</u>	If No, Reason	<u>-</u>

Purpose of Application Renewal of an NPDES Permit for an existing discharge of treated sanitary wastewater. This application also transfers ownership from the Lake Lucy Sewage Association to the Lake Lucy Sewer Authority.

**Summary of Review**

Act 14 - Proof of Notification was submitted and received.  
A Part II Water Quality Management permit is not required at this time.  
The applicant should be able to meet the limits of this permit, which will protect the uses of the receiving stream.

I. OTHER REQUIREMENTS:

- A. Stormwater into Sewers
- B. Right of Way
- C. Solids Handling
- D. Public Sewerage Availability
- E. Effluent Chlorine Optimization and Minimization
- F. Little or No Assimilative Capacity

SPECIAL CONDITIONS:

- II. Solids Management

There are no open violations in EFACTS associated with the subject Client ID (370898) as of 9/13/2022.

Approve	Deny	Signatures	Date
X		Stephen A. McCauley Stephen A. McCauley, E.I.T. / Environmental Engineering Specialist	9/13/2022
X		Adam J. Pesek (Lead Reviewer) for Vacant / Environmental Engineer Manager	9/23/2022

**Discharge, Receiving Waters and Water Supply Information**

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.014</u>
Latitude	<u>41° 23' 53.00"</u>	Longitude	<u>-79° 23' 29.00"</u>
Quad Name	<u>-</u>	Quad Code	<u>-</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>East Branch Hemlock Creek (EV)</u>	Stream Code	<u>54853</u>
NHD Com ID	<u>100476245</u>	RMI	<u>4.60</u>
Drainage Area	<u>0.54</u>	Yield (cfs/mi <sup>2</sup> )	<u>0.11</u>
Q <sub>7-10</sub> Flow (cfs)	<u>0.059</u>	Q <sub>7-10</sub> Basis	<u>calculated</u>
Elevation (ft)	<u>1559</u>	Slope (ft/ft)	<u>0.005997</u>
Watershed No.	<u>16-E</u>	Chapter 93 Class.	<u>EV*</u>
Existing Use	<u>-</u>	Existing Use Qualifier	<u>-</u>
Exceptions to Use	<u>-</u>	Exceptions to Criteria	<u>-</u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u>-</u>		
Source(s) of Impairment	<u>-</u>		
TMDL Status	<u>-</u>	Name	<u>-</u>
Background/Ambient Data		Data Source	
pH (SU)	<u>-</u>		<u>-</u>
Temperature (°F)	<u>-</u>		<u>-</u>
Hardness (mg/L)	<u>-</u>		<u>-</u>
Other:	<u>-</u>		<u>-</u>
Nearest Downstream Public Water Supply Intake	<u>Aqua Pennsylvania, Inc. - Emlenton</u>		
PWS Waters	<u>Allegheny River</u>	Flow at Intake (cfs)	<u>1,376</u>
PWS RMI	<u>90.0</u>	Distance from Outfall (mi)	<u>54</u>

\* This facility has been permitted to discharge to the East Branch Hemlock Creek since 1979. The receiving stream was re-designated in 1995 as an Exceptional Value (EV) stream. This discharge is considered "grandfathered" at its previous NPDES Permit limits, which were set to prevent nuisance conditions due to dry stream conditions.

Sludge use and disposal description and location(s): All sludge is disposed of at an approved landfill.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the Pennsylvania Bulletin in accordance with 25 Pa. Code § 92a.82. Upon publication in the Pennsylvania Bulletin, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the Pennsylvania Bulletin at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Narrative: This Fact Sheet details the determination of draft NPDES permit limits for an existing discharge of 0.014 MGD of treated sewage from a non-municipal STP in Washington Township, Clarion County.

Treatment permitted under Water Quality Management (WQM) Permit number 1679401 consists of: A bar screen, a 303,700 gallon waste stabilization lagoon, a second 350,800 gallon waste stabilization lagoon, one intermittent sand filter, and tablet chlorination with a 489 gallon contact tank.

**1. Streamflow:**

Patchel Run near Franklin, PA - USGS Reference Gage Number 03025200

Q <sub>7-10</sub> :	<u>0.63</u>	cfs	(USGS StreamStats)
Drainage Area:	<u>5.69</u>	sq. mi.	(USGS StreamStats)
Yieldrate:	<u>0.11</u>	cfsm	(calculated)

East Branch Hemlock Creek at Outfall 001:

Yieldrate:	<u>0.11</u>	cfsm	(calculated above)
Drainage Area:	<u>0.54</u>	sq. mi.	(USGS StreamStats)
% of stream allocated:	<u>100%</u>	Basis:	No nearby discharges
Q <sub>7-10</sub> :	<u>0.059</u>	cfs	(calculated)

**2. Wasteflow:**

Maximum discharge: 0.014 MGD = 0.021 cfs

Runoff flow period: 24 hours Basis: Runoff flow for lagoon systems

The calculated stream flow (Q<sub>7-10</sub>) is greater than 3 times the permitted discharge flow. Therefore, the standards in DEP guidance (391-2000-014) will not be applied.

Flow will be required to be monitored as authorized under Chapter 92a.61, and as recommended in the SOP.

**3. Parameters:**

The following parameters were evaluated: pH, Total Suspended Solids, Fecal Coliform, E. Coli, Total Phosphorus, Total Nitrogen, NH<sub>3</sub>-N, CBOD<sub>5</sub>, Dissolved Oxygen, and Total Residual Chlorine.

a. pH

Between 6.0 and 9.0 at all times

Basis: Application of Chapter 93.7 technology-based limits.

The measurement frequency will remain as 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001).

b. Total Suspended Solids

Limits are 30.0 mg/l as a monthly average and 60.0 as an instantaneous maximum.

Basis: Application of Chapter 92a47 technology-based limits. Since the previous limits are more restrictive and are being attained, the previous limits that were based on the old dry streams guidance will be retained. Per DEP policy, the CBOD5 limits were changed from seasonal to year round.

c. Fecal Coliform

05/01 - 09/30: 200/100ml (monthly average geometric mean)  
1,000/100ml (instantaneous maximum)

10/01 - 04/30: 2,000/100ml (monthly average geometric mean)  
10,000/100ml (instantaneous maximum)

Basis: Application of Chapter 92a47 technology-based limits

d. E. Coli

Monitoring was added for E. Coli at a frequency of 1/year.

Basis: Application of Chapter 92a.61 as recommended by the SOP for flows greater than 0.002 MGD and less than 0.05 MGD.

e. Phosphorus

- Limit necessary due to:
- Discharge to lake, pond, or impoundment
  - Discharge to stream

Basis: N/A

- Limit not necessary

Basis: Chapter 96.5 does not apply. However, the previous monitoring for Total Phosphorus will be retained in accordance with the SOP, based on Chapter 92a.61.

f. Total Nitrogen

The previous monitoring for Total Nitrogen will be retained in accordance with the SOP, based on Chapter 92a.61.

g. Ammonia-Nitrogen (NH<sub>3</sub>-N)

Median discharge pH to be used: 6.7 Standard Units (S.U.)

Basis: eDMR data from previous 12 months

Discharge temperature: 25°C (default value used in the absence of data)

Median stream pH to be used: 7.0 Standard Units (S.U.)

Basis: default value used in the absence of data

Stream Temperature: 20°C (default value used for EV [CWF] modeling)

Background NH<sub>3</sub>-N concentration: 0.0 mg/l

Basis: Default value

Calculated NH<sub>3</sub>-N Summer limits: 25.0 mg/l (monthly average)

50.0 mg/l (instantaneous maximum)

Calculated NH<sub>3</sub>-N Winter limits: 25.0 mg/l (monthly average)  
50.0 mg/l (instantaneous maximum)

Result: WQ modeling resulted in the calculated NH<sub>3</sub>-N limits above (see Attachment 1). The winter limits are calculated as three times the summer limits, but since the technology-based limits are more protective, they will be used. Since the previous limits are more restrictive and are being attained, the previous limits that were based on the old dry streams guidance will be retained.

h. CBOD<sub>5</sub>

Median discharge pH to be used: 6.7 Standard Units (S.U.)

Basis: eDMR data from previous 12 months

Discharge temperature: 25°C (default value used in the absence of data)

Median stream pH to be used: 7.0 Standard Units (S.U.)

Basis: default value used in the absence of data

Stream Temperature: 20°C (default value used for EV [CWF] modeling)

Background CBOD<sub>5</sub> concentration: 2.0 mg/l

Basis: Default value

Calculated CBOD<sub>5</sub> limits: 25.0 mg/l (monthly average)  
50.0 mg/l (instantaneous maximum)

Result: WQ modeling resulted in the calculated limits above (see Attachment 1). Since the previous limits are more restrictive and are being attained, the previous limits that were based on the old dry streams guidance will be retained. Per DEP policy, the CBOD<sub>5</sub> limits were changed from seasonal to year round.

i. Dissolved Oxygen (DO)

The technology-based minimum of 4.0 mg/l is recommended by the WQ Model (see Attachment 1) and the SOP based on Chapter 93.7, under the authority of Chapter 92a.61.

The measurement frequency will remain as 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001).

j. Total Residual Chlorine (TRC)

TRC limits: 0.5 mg/l (monthly average)  
1.6 mg/l (instantaneous maximum)

Basis: The TRC limits above were calculated using the Department's TRC Calculation Spreadsheet (see Attachment 2). The limits are based on the first point of use, per the SOP. Since the calculated limits are the same as in the previous permit, and are attainable, they will be retained.

The measurement frequency will remain as 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001).

**4. Reasonable Potential Analysis for Receiving Stream:**

A Reasonable Potential Analysis was not performed in accordance with State practices using the Department's Toxics Management Spreadsheet since no sampling other than sewage-related parameters was performed for this facility with the renewal application.

**5. Reasonable Potential for Downstream Public Water Supply (PWS):**

The Department's Toxics Management Spreadsheet does not calculate limits for parameters that are based on PWS criteria (TDS, Chloride, Bromide, and Sulfate). However, since no sample data was provided, mass-balance calculations were not performed.

Nearest Downstream potable water supply (PWS): Aqua Pennsylvania, Inc. - Emlenton

Distance downstream from the point of discharge: 54.0 miles (approximate)

- No limits necessary  
 Limits needed

Basis: Significant dilution available

**6. Anti-Backsliding:**

Since all the permit limits in this renewal are the same or more restrictive than the previous NPDES Permit, anti-backsliding is not applicable.

**7. Attachment List:**

- Attachment 1 - WQ Modeling Printouts - Perennial Reach
- Attachment 2 - WQ Modeling Printouts - Dry Reach
- Attachment 3 - TRC\_Calc Spreadsheet

(The Attachments above can be found at the end of this document)

Compliance History

DMR Data for Outfall 001 (from August 1, 2021 to July 31, 2022)

Parameter	JUL-22	JUN-22	MAY-22	APR-22	MAR-22	FEB-22	JAN-22	DEC-21	NOV-21	OCT-21	SEP-21	AUG-21
Flow (MGD) Average Monthly	0.006	0.006	0.0098	0.013	0.018	0.014	0.013	0.0125	0.0012	0.0013	0.0012	0.0058
Flow (MGD) Daily Maximum	0.020	0.011	0.014	0.014	0.021	0.014	0.014	0.014	0.0014	0.0019	0.0014	0.013
pH (S.U.) Minimum	6.9	6.6	6.4	6.2	6.4	6.4	6.5	6.6	6.3	6.6	6.4	6.2
pH (S.U.) Maximum	7.9	7.6	7.3	6.9	7.1	7.1	7.1	7.1	7.1	7.1	7.1	7.1
DO (mg/L) Minimum	4.01	4.09	4.11	4.18	4.10	4.00	4.07	4.00	4.01	4.09	4.14	4.06
TRC (mg/L) Average Monthly	0.47	0.47	0.47	0.457	0.46	0.41	0.41	0.48	0.473	0.47	0.485	0.45
TRC (mg/L) Instantaneous Maximum	1.3	1.2	1.0	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.6	0.12
CBOD5 (mg/L) Average Monthly	< 2.0	< 2.0	2.05	2.65	6.35	11.0	4.25	3.3	< 2.0	< 2.0	2.0	< 2.0
TSS (mg/L) Average Monthly	5.0	7.0	8.5	8.5	20.5	23	14.5	9.5	6.0	5.5	6.5	13.5
Fecal Coliform (No./100 ml) Geometric Mean	< 10	< 10	< 10	< 10	< 10	728.0	501.9	34.9	20.15	< 10	34.9	< 10
Fecal Coliform (No./100 ml) Instantaneous Maximum	< 10	< 10	< 10	< 10	< 10	53000	7000	122	29	< 10	122	< 10
Total Nitrogen (mg/L) Average Monthly	2.025	1.92	2.09	1.805	3.533	3.255	3.125	5.09	6.08	2.315	4.26	4.045
Ammonia (mg/L) Average Monthly	0.226	1.23	1.21	2.086	2.65	< 0.10	6.51	3.44	3.87	1.915	1.655	3.63
Total Phosphorus (mg/L) Average Monthly	< 0.10	0.14	0.22	0.455	1.13	1.17	0.665	1.14	0.205	0.135	0.22	0.34

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	4.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	XXX	XXX	XXX	10.0	XXX	20	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	10.0	XXX	20	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	Grab
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	9.0	XXX	18	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	XXX	XXX	XXX	3.0	XXX	6	2/month	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite

Compliance Sampling Location: at Outfall 001, after disinfection.

Flow is monitor only based on Chapter 92a.61. The limits for pH and Dissolved Oxygen are technology-based on Chapter 93.7. The Total Residual Chlorine (TRC) limits are technology-based on Chapter 92a.48. The limits for CBOD<sub>5</sub>, Total Suspended Solids (TSS), and Ammonia-Nitrogen are technology-based on the old Dry Streams Guidance. The limits for Fecal Coliforms are technology-based on Chapter 92a.47. Monitoring for E. Coli, Total Nitrogen, and Total Phosphorus is based on Chapter 92a.61.



Attachment 1

**WQM 7.0 Effluent Limits** (Perennial Reach)

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
16E	54853	EAST BRANCH HEMLOCK CREEK					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
3.400	perennial reach	PA0263834	0.014	CBOD5	3.33		
				NH3-N	8.34	16.68	
				Dissolved Oxygen			6.24

Since the perennial reach outputs equal the dry reach inputs, the dry reach inputs are protective of the receiving stream.

**WQM 7.0 D.O.Simulation**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
16E	54853	EAST BRANCH HEMLOCK CREEK		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
3.400	0.014	20.371	6.969	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
7.676	0.414	18.544	0.092	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
2.10	0.051	0.62	0.720	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
8.094	22.602	Owens	6	
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>			
0.932	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.093	2.09	0.58	8.19
	0.186	2.08	0.54	8.19
	0.279	2.07	0.51	8.19
	0.373	2.06	0.47	8.19
	0.466	2.05	0.44	8.19
	0.559	2.04	0.41	8.19
	0.652	2.03	0.39	8.19
	0.745	2.02	0.36	8.19
	0.838	2.01	0.34	8.19
	0.932	2.00	0.32	8.19

### WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
16E	54853	EAST BRANCH HEMLOCK CREEK	3.400	1521.00	2.46	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.110	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
perennial reach	PA0263834	0.0140	0.0000	0.0000	0.000	25.00	6.70

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	3.33	2.00	0.00	1.50
Dissolved Oxygen	6.24	8.24	0.00	0.00
NH3-N	8.34	0.00	0.00	0.70

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
16E	54853	EAST BRANCH HEMLOCK CREEK	2.000	1445.00	4.58	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.110	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
16E		54853				EAST BRANCH HEMLOCK CREEK						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
<b>Q7-10 Flow</b>												
3.400	0.27	0.00	0.27	.0217	0.01028	.414	7.68	18.54	0.09	0.932	20.37	6.97
<b>Q1-10 Flow</b>												
3.400	0.17	0.00	0.17	.0217	0.01028	NA	NA	NA	0.07	1.169	20.56	6.95
<b>Q30-10 Flow</b>												
3.400	0.37	0.00	0.37	.0217	0.01028	NA	NA	NA	0.11	0.793	20.28	6.98

**WQM 7.0 Wasteload Allocations**

**SWP Basin**      **Stream Code**                      **Stream Name**  
 16E                      54853                                      EAST BRANCH HEMLOCK CREEK

**NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
3.400	perennial reach	16.64	16.68	16.64	16.68	0	0

**NH3-N Chronic Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
3.400	perennial reach	1.87	8.34	1.87	8.34	0	0

**Dissolved Oxygen Allocations**

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
3.40	perennial reach	3.33	3.33	8.34	8.34	6.24	6.24	0	0

Attachment 2

**WQM 7.0 D.O.Simulation** (Dry Reach)

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
16E	54853	EAST BRANCH HEMLOCK CREEK		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
4.600	0.014	25.000	6.700	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
0.822	0.383	2.145	0.069	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
25.00	1.500	25.00	1.029	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
4.000	23.930	Owens	2	
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>			
1.068	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.107	20.44	22.40	1.46
	0.214	16.71	20.07	2.14
	0.320	13.66	17.98	2.93
	0.427	11.17	16.11	3.64
	0.534	9.13	14.44	4.24
	0.641	7.46	12.94	4.76
	0.747	6.10	11.59	5.21
	0.854	4.99	10.39	5.60
	0.961	4.08	9.31	5.94
	1.068	3.33	8.34	6.24 (Input into perennial reach model)



### WQM 7.0 Modeling Specifications

Parameters	D.O.	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	Simulation	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	2		

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
16E	54853	EAST BRANCH HEMLOCK CREEK	4.600	1559.00	0.01	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.000	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Dry Reach	PA0263834a	0.0140	0.0000	0.0000	0.000	25.00	6.70

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	0.00	0.00	1.50
Dissolved Oxygen	4.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
16E	54853	EAST BRANCH HEMLOCK CREEK	3.400	1521.00	0.02	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.000	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
perennial reach	PA0263834	0.0140	0.0000	0.0000	0.000	25.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
16E		54853				EAST BRANCH HEMLOCK CREEK						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
<b>Q7-10 Flow</b>												
4.600	0.00	0.00	0.00	NA	0.00600	.383	.82	2.14	0.07	1.068	25.00	6.70
<b>Q1-10 Flow</b>												
4.600	0.00	0.00	0.00	NA	0.00600	NA	NA	NA	0.00	0.000	0.00	0.00
<b>Q30-10 Flow</b>												
4.600	0.00	0.00	0.00	NA	0.00600	NA	NA	NA	0.00	0.000	0.00	0.00

Attachment 3

<b>TRC EVALUATION</b>				
Input appropriate values in A3:A9 and D3:D9				
0.2706	= Q stream (cfs) (first point of use)	0.5	= CV Daily	
0.014	= Q discharge (MGD)	0.5	= CV Hourly	
30	= no. samples	0.499	= AFC_Partial Mix Factor	
0.3	= Chlorine Demand of Stream	1	= CFC_Partial Mix Factor	
0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)	
0.5	= BAT/BPJ Value	720	= CFC_Criteria Compliance Time (min)	
0	= % Factor of Safety (FOS)	0	= Decay Coefficient (K)	
Source	Reference	AFC Calculations		Reference
TRC	1.3.2.iii	WLA_afc = 2.008		1.3.2.iii
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c
PENTOXSD TRG	5.1b	LTA_afc = 0.748		5.1d
				WLA_cfc = 3.897
				LTAMULT_cfc = 0.581
				LTA_cfc = 2.265
Source	Effluent Limit Calculations			
PENTOXSD TRG	5.1f	AML_MULT = 1.231		
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500		BAT/BPJ
		INST MAX LIMIT (mg/l) = 1.635		
WLA_afc	$(.019/e^{-k \cdot AFC\_tc}) + [(AFC\_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC\_tc}) \dots + Xd + (AFC\_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$			
LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$			
LTA_afc	wla_afc * LTAMULT_afc			
WLA_cfc	$(.011/e^{-k \cdot CFC\_tc}) + [(CFC\_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC\_tc}) \dots + Xd + (CFC\_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$			
LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no\_samples + 1)) - 2.326 \cdot LN(cvd^2 / no\_samples + 1)^{0.5})$			
LTA_cfc	wla_cfc * LTAMULT_cfc			
AML_MULT	$EXP(2.326 \cdot LN((cvd^2 / no\_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no\_samples + 1))$			
AVG MON LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)			
INST MAX LIMIT	1.5 * ((av_mon_limit / AML_MULT) / LTAMULT_afc)			