

Application Type Renewal
Facility Type Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0263893
APS ID 1071963
Authorization ID 1411362

Applicant and Facility Information

| | | | |
|---------------------------|---|------------------|---|
| Applicant Name | <u>Hawthorn Redbank Redbank Municipal Authority</u> | Facility Name | <u>Hawthorn Redbank Redbank Municipal Authority WWTP</u> |
| Applicant Address | <u>PO Box 241 Hawthorn, PA 16230-0241</u> | Facility Address | <u>3110 Brookville Street Fairmount City, PA 16224</u> |
| Applicant Contact | <u>Brenda Miller, Township Secretary (hrrma2298@gmail.com)</u> | Facility Contact | <u>Spurgeon Shilling, Operator (spurgeonshilling@icloud.com)</u> |
| Applicant Phone | <u>-</u> | Facility Phone | <u>(814) 229-3955</u> |
| Client ID | <u>43381</u> | Site ID | <u>750265</u> |
| Ch 94 Load Status | <u>Not Overloaded</u> | Municipality | <u>Redbank Township</u> |
| Connection Status | <u>No Limitations</u> | County | <u>Clarion</u> |
| Date Application Received | <u>September 23, 2022</u> | EPA Waived? | <u>Yes</u> |
| Date Application Accepted | <u>September 26, 2022</u> | If No, Reason | <u>-</u> |
| Purpose of Application | <u>Renewal of an NPDES Permit for an existing discharge of treated sanitary wastewater from a municipal sewer system.</u> | | |

Summary of Review

Act 14 - Proof of Notification was submitted and received.

A Part II Water Quality Management permit is not required at this time.

The applicant should be able to meet the limits of this permit, which will protect the uses of the receiving stream.

I. OTHER REQUIREMENTS:

- A. Stormwater into sewers
- B. Right of way
- C. Solids handling
- D. Effluent Chlorine Optimization and Minimization

SPECIAL CONDITIONS:

- II. Solids Management

There are 25 open violations in effects associated with the subject Client ID (43381) as of 7/12/2023 (see Attachment 2). [8/7/2023 CWY](#)

| Approve | Return | Deny | Signatures | Date |
|---------|--------|------|---|-----------|
| X | | | Stephen A. McCauley Stephen A. McCauley, E.I.T. / Environmental Engineering Specialist | 7/12/2023 |
| X | | | Chad W. Yurisc Chad W. Yurisc, P.E. / Environmental Engineer Manager | 8/7/2023 |

Discharge, Receiving Waters and Water Supply Information

| | | | |
|--|--|------------------------------|---------------------------|
| Outfall No. | <u>001</u> | Design Flow (MGD) | <u>0.2</u> |
| Latitude | <u>41° 00' 42.70"</u> | Longitude | <u>-79° 17' 58.90"</u> |
| Quad Name | <u>-</u> | Quad Code | <u>-</u> |
| Wastewater Description: <u>Sewage Effluent</u> | | | |
| Receiving Waters | <u>Redbank Creek (TSF)</u> | Stream Code | <u>48064</u> |
| NHD Com ID | <u>123862912</u> | RMI | <u>26.0</u> |
| Drainage Area | <u>482.2</u> | Yield (cfs/mi ²) | <u>0.12</u> |
| Q ₇₋₁₀ Flow (cfs) | <u>57.9</u> | Q ₇₋₁₀ Basis | <u>calculated</u> |
| Elevation (ft) | <u>1027</u> | Slope (ft/ft) | <u>0.0006</u> |
| Watershed No. | <u>17-C</u> | Chapter 93 Class. | <u>TSF</u> |
| Existing Use | <u>-</u> | Existing Use Qualifier | <u>-</u> |
| Exceptions to Use | <u>-</u> | Exceptions to Criteria | <u>-</u> |
| Assessment Status | <u>Impaired*</u> | | |
| Cause(s) of Impairment | <u>Metals, Nutrients, Siltation</u> | | |
| Source(s) of Impairment | <u>Abandoned Mine Drainage, Abandoned Mine Drainage, Other</u> | | |
| TMDL Status | <u>Final</u> | Name | <u>Redbank Creek TMDL</u> |
| Background/Ambient Data | | Data Source | |
| pH (SU) | <u>-</u> | | <u>-</u> |
| Temperature (°F) | <u>-</u> | | <u>-</u> |
| Hardness (mg/L) | <u>-</u> | | <u>-</u> |
| Other: | <u>-</u> | | <u>-</u> |
| Nearest Downstream Public Water Supply Intake | <u>Redbank Valley Municipal Authority</u> | | |
| PWS Waters | <u>Redbank Creek</u> | Flow at Intake (cfs) | <u>30.6</u> |
| PWS RMI | <u>28.6</u> | Distance from Outfall (mi) | <u>2.0</u> |

* Due to the receiving stream being impaired by metals from abandoned mine drainage, monitoring for Aluminum, Iron, and Manganese was previously added to ensure this discharge is not contributing to the impairment, and will be retained.

Sludge use and disposal description and location(s): Sludge is transported to the Punxsutawney Borough STP, where it is disposed of at an approved landfill.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Narrative: This Fact Sheet details the determination of draft NPDES permit limits for an existing discharge of 0.2 MGD of treated sewage from an existing Publicly Owned Treatment Works (POTW) in Redbank Township, Clarion County.

Treatment permitted under Water Quality Management Permit No. 1612406 consists of: A mechanical bar screen with a backup manually-cleaned bar screen, a washer/compactor, a splitter box, two ABJ-ICEAS (Austin Bio Jet - Intermittent Cycle Extended Aeration System) SBR units, UV disinfection, post aeration, and an aerated 6,250 gallon sludge holding tank.

1. Streamflow:

The yieldrate for the receiving stream at the outfall was calculated using the nearest USGS gage station.

Redbank Creek @ St. Charles gage:

Drainage Area: 528 sq. mi. (from StreamStats)
Q₇₋₁₀: 62.6 cfs (from StreamStats)
Yieldrate: 0.12 cfs (calculated)

Redbank Creek at Outfall 001:

Yieldrate: 0.12 cfs (calculated above)
Drainage Area: 482.2 sq. mi. (from StreamStats)
% of stream allocated: 100% Basis: no nearby discharges
Q₇₋₁₀: 57.9 cfs (calculated)

2. Wasteflow:

Maximum discharge: 0.2 MGD = 0.3 cfs

Runoff flow period: 24 hours Basis: Runoff flow for a Municipal STP

There is more than 3 parts stream flow (Q₇₋₁₀) to 1 part effluent (design flow). Per the SOP, the standards in DEP guidance (391-2000-014) will not be applied.

Flow will be required to be monitored as authorized under Chapter 92a.61, and as recommended in the SOP.

3. Parameters:

The following parameters were evaluated: pH, Total Suspended Solids, Fecal Coliform, Phosphorus, NH₃-N, CBOD₅, Dissolved Oxygen, and Disinfection.

a. pH

Between 6.0 and 9.0 at all times

Basis: Application of Chapter 93.7 technology-based limits.

The measurement frequency was previously set to 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001), and will be retained.

b. Total Suspended Solids

Limits are 30.0 mg/l as a monthly average and 60.0 as an instantaneous maximum.

Basis: Application of Chapter 92a.47 technology-based limits

c. Fecal Coliform

05/01 - 09/30: 200/100ml (monthly average geometric mean)
1,000/100ml (instantaneous maximum)

10/01 - 04/30: 2,000/100ml (monthly average geometric mean)
10,000/100ml (instantaneous maximum)

Basis: Application of Chapter 92a.47 technology-based limits

d. E. Coli

Monitoring was added for E. Coli at a frequency of 1/quarter.

Basis: Application of Chapter 92a.61 as recommended by the SOP for flows greater than 0.05 MGD but less than 1.0 MGD.

e. Total Phosphorus

Chapter 96.5 does not apply. However, the previous monitoring for Total Phosphorus will be retained in accordance with the SOP, based on Chapter 92a.61.

f. Total Nitrogen

The previous monitoring for Total Nitrogen will be retained in accordance with the SOP, based on Chapter 92a.61.

g. Ammonia-Nitrogen (NH₃-N)

Median discharge pH to be used: 6.9 Standard Units (S.U.)

Basis: Average pH value from DMR summary

Discharge temperature: 25°C (default value used for modeling purposes)

Median stream pH to be used: 7.0 Standard Units (S.U.)

Basis: Default value used for modeling purposes

Stream Temperature: 25°C (default value used for TSF modeling purposes)

Background NH₃-N concentration: N/A mg/l

Basis: No background data available for NH₃-N.

Calculated NH₃-N Summer limits: 25.0 mg/l (monthly average)
50.0 mg/l (instantaneous maximum)

Calculated NH₃-N Winter limits: 25.0 mg/l (monthly average)
50.0 mg/l (instantaneous maximum)

Result: WQ modeling resulted in the NH₃-N summer limits above (see Attachment 1), which are the same as the previous permit and will be retained. The winter limits are calculated as three times the summer limits, but since the technology-based limits are more protective, they will be used. Per the SOP, monitoring will be required in lieu of limits, as was done in the previous permit.

h. CBOD₅

Median discharge pH to be used: 6.9 Standard Units (S.U.)

Basis: Average pH value from DMR summary

Discharge temperature: 25°C (default value used for modeling purposes)

Median stream pH to be used: 7.0 Standard Units (S.U.)

Basis: Default value used for modeling purposes

Stream Temperature: 25°C (default value used for TSF modeling purposes)

Background CBOD₅ concentration: 2.0 mg/l

Basis: Default value

Calculated CBOD₅ limits: 25.0 mg/l (monthly average)

50.0 mg/l (instantaneous maximum)

Result: WQ modeling resulted in the above CBOD₅ limits (see Attachment 1), which are the same as the previous permit and will be retained.

i. Influent Total Suspended Solids and BOD₅

Monitoring for these two parameters will be retained as recommended in the SOP for POTWs, as authorized under Chapter 92a.61.

j. Dissolved Oxygen (DO)

The Dissolved Oxygen minimum of 4.0 mg/l will be retained with this renewal. The technology-based minimum is recommended by the WQ Model (see Attachment 1) and the SOP based on Chapter 93.7, under the authority of Chapter 92a.61.

The measurement frequency was previously set to 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001), and will be retained.

k. Disinfection

Ultraviolet (UV) light monitoring

TRC limits: _____ mg/l (monthly average)

_____ mg/l (instantaneous maximum)

Basis: The previous UV Intensity ($\mu\text{w}/\text{cm}^2$) reporting will be retained with this renewal.

The measurement frequency was previously set to 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001), and will be retained.

4. Reasonable Potential Analysis for Receiving Stream:

A Reasonable Potential Analysis was not performed in accordance with State practices using the Department's Toxics Management Spreadsheet since no sampling other than sewage-related parameters was performed for this facility with the renewal application.

5. Reasonable Potential for Downstream Public Water Supply (PWS):

The Department's Toxics Management Spreadsheet does not calculate limits for parameters that are based on PWS criteria (TDS, Chloride, Bromide, and Sulfate). However, since no sample data was provided, mass-balance calculations were not performed.

Nearest Downstream potable water supply (PWS): Redbank Valley Municipal Authority

Distance downstream from the point of discharge: 2.0 miles (approximate)

Result: No limits or monitoring is necessary as there is significant dilution available.

6. Flow Information:

100% of the wastewater flow comes from the Hawthorn Borough. All the sewers in the system are separate sewers.

7. Anti-Backsliding:

Since all the permit limits in this renewal are the same or more restrictive than the previous NPDES Permit, anti-backsliding is not applicable.

8. Attachment Details:

Attachment 1 - WQ Modeling Printouts

Attachment 2 - WMS Open Violations by Client

(The Attachments above can be found at the end of this document)

Compliance History

DMR Data for Outfall 001 (from June 1, 2022 to May 31, 2023)

| Parameter | MAY-23 | APR-23 | MAR-23 | FEB-23 | JAN-23 | DEC-22 | NOV-22 | OCT-22 | SEP-22 | AUG-22 | JUL-22 | JUN-22 |
|--|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| Flow (MGD) Average Monthly | 0.102 | 0.113 | 0.124 | 0.109 | 0.134 | 0.119 | 0.107 | 0.096 | 0.095 | 0.087 | 0.093 | 0.108 |
| Flow (MGD) Weekly Average | 0.112 | 0.122 | 0.125 | 0.112 | 0.143 | 0.127 | 0.128 | 0.103 | 0.101 | 0.088 | 0.101 | 0.128 |
| pH (S.U.) Instantaneous Minimum | 6.7 | 6.6 | 6.6 | 6.6 | 6.6 | 6.7 | 6.7 | 6.8 | 6.9 | 6.9 | 6.8 | 6.8 |
| pH (S.U.) Instantaneous Maximum | 7.0 | 7.0 | 6.9 | 6.9 | 7.0 | 7.0 | 7.1 | 7.1 | 7.1 | 7.1 | 7.2 | 7.2 |
| DO (mg/L) Instantaneous Minimum | 5.02 | 7.19 | 6.34 | 7.43 | 5.16 | 7.21 | 7.24 | 7.36 | 6.25 | 5.16 | 5.32 | 6.05 |
| CBOD5 (lbs/day) Average Monthly | 2.7 | 2.8 | 2.5 | 1.8 | 2.1 | 1.8 | 1.6 | 1.6 | 1.5 | 1.4 | 1.4 | 1.9 |
| CBOD5 (lbs/day) Weekly Average | 3.6 | 2.8 | 3.1 | 1.9 | 2.4 | 1.9 | 1.6 | 1.6 | 1.6 | 1.5 | 1.5 | 2.2 |
| CBOD5 (mg/L) Average Monthly | 2.9 | 3.0 | 2.7 | 2.0 | 2.0 | 2.0 | 2.0 | 2.0 | 2.0 | 2.0 | 2.0 | 2.0 |
| CBOD5 (mg/L) Weekly Average | 3.6 | 3.1 | 3.5 | 2.0 | 2.0 | 2.0 | 2.0 | 2.0 | 2.0 | 2.0 | 2.0 | 2.0 |
| BOD5 (lbs/day) Raw Sewage Influent Average Monthly | 110 | 110 | 131 | 165 | 208 | 87 | 283 | 147 | 173 | 90 | 130 | 100 |
| BOD5 (mg/L) Raw Sewage Influent Average Monthly | 121.3 | 120 | 144 | 182 | 192 | 96.2 | 356 | 188.7 | 228 | 129 | 188 | 101 |
| TSS (lbs/day) Average Monthly | 4.6 | 5.4 | 5.0 | 4.5 | 5.2 | 4.5 | 5.1 | 6.8 | 6.6 | 3.5 | 3.5 | 4.8 |
| TSS (lbs/day) Raw Sewage Influent Average Monthly | 77 | 81 | 135 | 152 | 188 | 108 | 265 | 90 | 173 | 84 | 146 | 106 |
| TSS (lbs/day) Weekly Average | 5.0 | 6.2 | 5.3 | 4.7 | 6.1 | 4.8 | 6.4 | 8.2 | 9.5 | 3.7 | 3.6 | 5.4 |
| TSS (mg/L) Average Monthly | 5.0 | 6.0 | 5.5 | 5.0 | 5.0 | 5.0 | 6.5 | 8.5 | 8.5 | 5.0 | 5.0 | 5.0 |
| TSS (mg/L) Raw Sewage Influent Average Monthly | 85 | 88 | 149 | 167 | 172 | 119 | 334 | 113 | 230 | 120 | 210 | 108 |
| TSS (mg/L) Weekly Average | 5.0 | 7.0 | 6.0 | 5.0 | 5.0 | 5.0 | 8.0 | 10.0 | 12.0 | 5.0 | 5.0 | 5.0 |

**NPDES Permit Fact Sheet
Hawthorn Redbank Redbank Municipal Authority WWTP**

NPDES Permit No. PA0263893

| | | | | | | | | | | | | |
|---|-------|--------|--------|--------|-------|---------|------|--------|--------|------|-------|--------|
| Fecal Coliform (No./100 ml) Geometric Mean | < 10 | < 10 | < 10 | < 10 | < 10 | < 10 | < 10 | < 10.0 | < 10 | 38 | 10 | 155 |
| Fecal Coliform (No./100 ml) Instantaneous Maximum | < 10 | < 10 | < 10 | < 10 | < 10 | < 10 | < 10 | < 10.0 | < 10 | 144 | 10 | 1099 |
| UV Intensity ($\mu\text{w}/\text{cm}^2$) Average Monthly | 8.9 | 12.9 | 12.5 | 8.8 | 7.4 | 7.0 | 6.8 | 11.2 | 10.6 | 9.8 | 13.2 | 12.4 |
| UV Intensity ($\mu\text{w}/\text{cm}^2$) Instantaneous Maximum | 14 | 14.0 | 14.0 | 14 | 12.9 | 13.1 | 13 | 14.0 | 14.0 | 14 | 14.0 | 14 |
| Total Nitrogen (lbs/day) Average Monthly | 2.0 | 3.0 | 10.0 | 5.0 | 6.0 | 5.0 | 3.0 | 1.0 | 2.0 | 3.0 | 3.0 | 4.0 |
| Total Nitrogen (mg/L) Average Monthly | 1.79 | 3.1 | 10.46 | 5.09 | 4.94 | 5.82 | 4.13 | 1.87 | 2.06 | 4.27 | 4.87 | 4.3 |
| Ammonia (lbs/day) Average Monthly | < 0.2 | < 0.20 | < 0.2 | < 0.20 | < 0.1 | < 0.6 | 0.6 | 0.6 | 0.08 | 0.07 | 0.3 | 0.2 |
| Ammonia (mg/L) Average Monthly | < 0.2 | < 0.20 | < 0.2 | < 0.20 | < 0.1 | < 0.657 | 0.8 | 0.8 | 0.1 | 0.1 | 0.459 | 0.221 |
| Total Phosphorus (lbs/day) Average Monthly | 3.0 | 2.0 | 3.0 | 2.0 | 4.0 | 3.0 | 2.0 | 2.0 | 3.0 | 5.0 | 4.0 | 3.0 |
| Total Phosphorus (mg/L) Average Monthly | 3.43 | 2.16 | 3.21 | 2.65 | 3.89 | 2.84 | 2.68 | 2.64 | 4.31 | 6.61 | 5.1 | 3.61 |
| Total Aluminum (lbs/day) Average Quarterly | | | < 0.09 | | | < 0.10 | | | < 0.10 | | | < 0.10 |
| Total Aluminum (mg/L) Average Quarterly | | | < 0.1 | | | < 0.10 | | | < 0.10 | | | < 0.10 |
| Total Iron (lbs/day) Average Quarterly | | | < 0.09 | | | < 0.10 | | | < 0.10 | | | 0.10 |
| Total Iron (mg/L) Average Quarterly | | | < 0.1 | | | < 0.10 | | | < 0.10 | | | 0.10 |
| Total Manganese (lbs/day) Average Quarterly | | | 0.1 | | | < 0.05 | | | < 0.05 | | | < 0.05 |
| Total Manganese (mg/L) Average Quarterly | | | 0.16 | | | < 0.05 | | | < 0.05 | | | < 0.05 |

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|---|-------------------------------------|----------------|-----------------------|------------------|----------------|------------------|--|----------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Weekly Average | Minimum | Average Monthly | Weekly Average | Instant. Maximum | | |
| Flow (MGD) | Report | Report | XXX | XXX | XXX | XXX | Continuous | Measured |
| pH (S.U.) | XXX | XXX | 6.0 Inst Min | XXX | XXX | 9.0 | 1/day | Grab |
| DO | XXX | XXX | 4.0 Inst Min | XXX | XXX | XXX | 1/day | Grab |
| CBOD5 | 41.7 | 66.7 | XXX | 25.0 | 40.0 | 50 | 2/month | 24-Hr Composite |
| BOD5 Raw Sewage Influent | Report | XXX | XXX | Report | XXX | XXX | 2/month | 8 Grabs/24 Hours |
| TSS | 50.0 | 75.0 | XXX | 30.0 | 45.0 | 60 | 2/month | 24-Hr Composite |
| TSS Raw Sewage Influent | Report | XXX | XXX | Report | XXX | XXX | 2/month | 8 Grabs/24 Hours |
| Fecal Coliform (No./100 ml) Oct 1 - Apr 30 | XXX | XXX | XXX | 2000 Geo Mean | XXX | 10000 | 2/month | Grab |
| Fecal Coliform (No./100 ml) May 1 - Sep 30 | XXX | XXX | XXX | 200 Geo Mean | XXX | 1000 | 2/month | Grab |
| E. Coli (No./100 ml) | XXX | XXX | XXX | XXX | XXX | Report | 1/quarter | Grab |
| UV Intensity (µw/cm ²) | XXX | XXX | XXX | Report | XXX | Report | 1/day | Measured |
| Total Nitrogen | Report | XXX | XXX | Report | XXX | XXX | 2/month | 24-Hr Composite |
| Ammonia-Nitrogen | Report | XXX | XXX | Report | XXX | XXX | 2/month | 24-Hr Composite |
| Total Phosphorus | Report | XXX | XXX | Report | XXX | XXX | 2/month | 24-Hr Composite |

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date)

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|-----------------|-------------------------------------|-------------------|-----------------------|---------------------|-------------------|---------------------|--|----------------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Weekly Average | Minimum | Average Monthly | Weekly Average | Instant. Maximum | | |
| Total Aluminum | Report Avg Qrtly | XXX | XXX | Report Avg Qrtly | XXX | XXX | 1/quarter | 24-Hr Composite |
| Total Iron | Report Avg Qrtly | XXX | XXX | Report Avg Qrtly | XXX | XXX | 1/quarter | 24-Hr Composite |
| Total Manganese | Report Avg Qrtly | XXX | XXX | Report Avg Qrtly | XXX | XXX | 1/quarter | 24-Hr Composite |

Compliance Sampling Location: at Outfall 001, after Ultraviolet (UV) light disinfection.

Flow is monitor only based on Chapter 92a.61. The limits for pH and Dissolved Oxygen are technology-based on Chapter 93.7. The limits for CBOD₅, Total Suspended Solids, and Fecal Coliforms are technology-based on Chapter 92a.47. Monitoring for UV Intensity, Total Nitrogen, Total Phosphorus, Ammonia-Nitrogen, influent BOD₅ and influent Total Suspended Solids, and Aluminum, Iron, and Manganese is based on Chapter 92a.61.

Attachment 1

WQM 7.0 Effluent Limits

| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> | | | | | |
|------------------|--------------------|--------------------|-----------------|------------------|--------------------------------|----------------------------|----------------------------|
| 17C | 48064 | REDBANK CREEK | | | | | |
| RMI | Name | Permit Number | Disc Flow (mgd) | Parameter | Effl. Limit 30-day Ave. (mg/L) | Effl. Limit Maximum (mg/L) | Effl. Limit Minimum (mg/L) |
| 26.000 | Redbank | PA0263893 | 0.200 | CBOD5 | 25 | | |
| | | | | NH3-N | 25 | 50 | |
| | | | | Dissolved Oxygen | | | 4 |

WQM 7.0 D.O.Simulation

| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> | | |
|---------------------------------|-----------------------------------|----------------------------------|---------------------|-----------------------------|
| 17C | 48064 | REDBANK CREEK | | |
| <u>RMI</u> | <u>Total Discharge Flow (mgd)</u> | <u>Analysis Temperature (°C)</u> | | <u>Analysis pH</u> |
| 26.000 | 0.200 | 25.000 | | 6.999 |
| <u>Reach Width (ft)</u> | <u>Reach Depth (ft)</u> | <u>Reach WDRatio</u> | | <u>Reach Velocity (fps)</u> |
| 111.480 | 1.002 | 111.264 | | 0.521 |
| <u>Reach CBOD5 (mg/L)</u> | <u>Reach Kc (1/days)</u> | <u>Reach NH3-N (mg/L)</u> | | <u>Reach Kn (1/days)</u> |
| 2.12 | 0.082 | 0.13 | | 1.029 |
| <u>Reach DO (mg/L)</u> | <u>Reach Kr (1/days)</u> | <u>Kr Equation</u> | | <u>Reach DO Goal (mg/L)</u> |
| 7.521 | 12.353 | Tsivoglou | | 5 |
| <u>Reach Travel Time (days)</u> | Subreach Results | | | |
| 0.153 | <u>TravTime (days)</u> | <u>CBOD5 (mg/L)</u> | <u>NH3-N (mg/L)</u> | <u>D.O. (mg/L)</u> |
| | 0.015 | 2.12 | 0.13 | 7.54 |
| | 0.031 | 2.12 | 0.13 | 7.54 |
| | 0.046 | 2.11 | 0.13 | 7.54 |
| | 0.061 | 2.11 | 0.12 | 7.54 |
| | 0.076 | 2.11 | 0.12 | 7.54 |
| | 0.092 | 2.10 | 0.12 | 7.54 |
| | 0.107 | 2.10 | 0.12 | 7.54 |
| | 0.122 | 2.10 | 0.12 | 7.54 |
| | 0.137 | 2.09 | 0.12 | 7.54 |
| | 0.153 | 2.09 | 0.11 | 7.54 |

WQM 7.0 Modeling Specifications

| | | | |
|--------------------|--------|-------------------------------------|-------------------------------------|
| Parameters | Both | Use Inputted Q1-10 and Q30-10 Flows | <input checked="" type="checkbox"/> |
| WLA Method | EMPR | Use Inputted W/D Ratio | <input type="checkbox"/> |
| Q1-10/Q7-10 Ratio | 0.64 | Use Inputted Reach Travel Times | <input type="checkbox"/> |
| Q30-10/Q7-10 Ratio | 1.36 | Temperature Adjust Kr | <input checked="" type="checkbox"/> |
| D.O. Saturation | 90.00% | Use Balanced Technology | <input checked="" type="checkbox"/> |
| D.O. Goal | 5 | | |

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|-----------|-------------|---------------|--------|----------------|-----------------------|---------------|----------------------|-------------------------------------|
| 17C | 48064 | REDBANK CREEK | 26.000 | 1080.00 | 482.20 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY | Trib Flow | Stream Flow | Rch Trav Time | Rch Velocity | WD Ratio | Rch Width | Rch Depth | Tributary | | Stream | |
|--------------|--------|-----------|-------------|---------------|--------------|----------|-----------|-----------|-----------|------|-----------|------|
| | (cfsm) | (cfs) | (cfs) | (days) | (fps) | | (ft) | (ft) | Temp (°C) | pH | Temp (°C) | pH |
| Q7-10 | 0.120 | 0.00 | 0.00 | 0.000 | 0.000 | 0.0 | 0.00 | 0.00 | 25.00 | 7.00 | 0.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |

Discharge Data

| Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
|---------|---------------|--------------------------|---------------------------|------------------------|----------------|----------------|---------|
| Redbank | PA0263893 | 0.2000 | 0.0000 | 0.0000 | 0.000 | 25.00 | 6.90 |

Parameter Data

| Parameter Name | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) |
|------------------|------------------|------------------|--------------------|--------------------|
| CBOD5 | 25.00 | 2.00 | 0.00 | 1.50 |
| Dissolved Oxygen | 4.00 | 7.54 | 0.00 | 0.00 |
| NH3-N | 25.00 | 0.00 | 0.00 | 0.70 |

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|-----------|-------------|---------------|--------|----------------|-----------------------|---------------|----------------------|-------------------------------------|
| 17C | 48064 | REDBANK CREEK | 24.700 | 1049.00 | 502.20 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY | Trib Flow | Stream Flow | Rch Trav Time | Rch Velocity | WD Ratio | Rch Width | Rch Depth | Tributary | | Stream | |
|--------------|--------|-----------|-------------|---------------|--------------|----------|-----------|-----------|-----------|------|-----------|------|
| | (cfsm) | (cfs) | (cfs) | (days) | (fps) | | (ft) | (ft) | Temp (°C) | pH | Temp (°C) | pH |
| Q7-10 | 0.120 | 0.00 | 0.00 | 0.000 | 0.000 | 0.0 | 0.00 | 0.00 | 25.00 | 7.00 | 0.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |

Discharge Data

| Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
|------|---------------|--------------------------|---------------------------|------------------------|----------------|----------------|---------|
| | | 0.0000 | 0.0000 | 0.0000 | 0.000 | 25.00 | 7.00 |

Parameter Data

| Parameter Name | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) |
|------------------|------------------|------------------|--------------------|--------------------|
| CBOD5 | 25.00 | 2.00 | 0.00 | 1.50 |
| Dissolved Oxygen | 3.00 | 8.24 | 0.00 | 0.00 |
| NH3-N | 25.00 | 0.00 | 0.00 | 0.70 |

WQM 7.0 Hydrodynamic Outputs

| <u>SWP Basin</u> | | <u>Stream Code</u> | | | | <u>Stream Name</u> | | | | | | |
|--------------------|----------------------|--------------------|--------------------------|-----------------------------|------------------------|--------------------|---------------|-----------|-------------------|---------------------------|-----------------------|-------------|
| 17C | | 48064 | | | | REDBANK CREEK | | | | | | |
| RMI | Stream Flow (cfs) | PWS With (cfs) | Net Stream Flow (cfs) | Disc Analysis Flow (cfs) | Reach Slope (ft/ft) | Depth (ft) | Width (ft) | W/D Ratio | Velocity (fps) | Reach Trav Time (days) | Analysis Temp (°C) | Analysis pH |
| Q7-10 Flow | | | | | | | | | | | | |
| 26.000 | 57.86 | 0.00 | 57.86 | .3094 | 0.00452 | 1.002 | 111.48 | 111.26 | 0.52 | 0.153 | 25.00 | 7.00 |
| Q1-10 Flow | | | | | | | | | | | | |
| 26.000 | 37.03 | 0.00 | 37.03 | .3094 | 0.00452 | NA | NA | NA | 0.41 | 0.196 | 25.00 | 7.00 |
| Q30-10 Flow | | | | | | | | | | | | |
| 26.000 | 78.70 | 0.00 | 78.70 | .3094 | 0.00452 | NA | NA | NA | 0.62 | 0.129 | 25.00 | 7.00 |

WQM 7.0 Wasteload Allocations

SWP Basin **Stream Code** **Stream Name**
 17C 48064 REDBANK CREEK

NH3-N Acute Allocations

| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|--------|----------------|---------------------------|---------------------|---------------------------|---------------------|----------------|-------------------|
| 26.000 | Redbank | 11.08 | 50 | 11.08 | 50 | 0 | 0 |

NH3-N Chronic Allocations

| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|--------|----------------|---------------------------|---------------------|---------------------------|---------------------|----------------|-------------------|
| 26.000 | Redbank | 1.37 | 25 | 1.37 | 25 | 0 | 0 |

Dissolved Oxygen Allocations

| RMI | Discharge Name | <u>CBOD5</u> | | <u>NH3-N</u> | | <u>Dissolved Oxygen</u> | | Critical Reach | Percent Reduction |
|-------|----------------|-----------------|-----------------|-----------------|-----------------|-------------------------|-----------------|----------------|-------------------|
| | | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | | |
| 26.00 | Redbank | 25 | 25 | 25 | 25 | 4 | 4 | 0 | 0 |

Attachment 2



WATER MANAGEMENT SYSTEM
OPEN VIOLATIONS BY CLIENT

Client ID: 43381
Client: All

Open Violations: 25

| | CLIENT ID | CLIENT | PF ID | FACILITY | PF KIND | PF STATUS | NSP PROGRAM | PROGRAM SPECIFIC ID |
|----|-----------|------------------------------------|--------|--|------------------------------|-----------|---------------------|---------------------|
| 1 | 43381 | HAWTHORN REDBANK REDBANK MUNI AUTH | 477743 | HAWTHORN REDBANK REDBANK MA | Community | Active | Safe Drinking Water | 6160026 |
| 2 | 43381 | HAWTHORN REDBANK REDBANK MUNI AUTH | 744133 | HAWTHORN REDBANK REDBANK MUN AUTH WWTP | Sewage Publicly Owned (Muni) | Active | WPC NPDES | PA0263893 |
| 3 | 43381 | HAWTHORN REDBANK REDBANK MUNI AUTH | 744133 | HAWTHORN REDBANK REDBANK MUN AUTH WWTP | Sewage Publicly Owned (Muni) | Active | WPC NPDES | PA0263893 |
| 4 | 43381 | HAWTHORN REDBANK REDBANK MUNI AUTH | 744133 | HAWTHORN REDBANK REDBANK MUN AUTH WWTP | Sewage Publicly Owned (Muni) | Active | WPC NPDES | PA0263893 |
| 5 | 43381 | HAWTHORN REDBANK REDBANK MUNI AUTH | 744133 | HAWTHORN REDBANK REDBANK MUN AUTH WWTP | Sewage Publicly Owned (Muni) | Active | WPC NPDES | PA0263893 |
| 6 | 43381 | HAWTHORN REDBANK REDBANK MUNI AUTH | 744133 | HAWTHORN REDBANK REDBANK MUN AUTH WWTP | Sewage Publicly Owned (Muni) | Active | WPC NPDES | PA0263893 |
| 7 | 43381 | HAWTHORN REDBANK REDBANK MUNI AUTH | 744133 | HAWTHORN REDBANK REDBANK MUN AUTH WWTP | Sewage Publicly Owned (Muni) | Active | WPC NPDES | PA0263893 |
| 8 | 43381 | HAWTHORN REDBANK REDBANK MUNI AUTH | 744133 | HAWTHORN REDBANK REDBANK MUN AUTH WWTP | Sewage Publicly Owned (Muni) | Active | WPC NPDES | PA0263893 |
| 9 | 43381 | HAWTHORN REDBANK REDBANK MUNI AUTH | 744133 | HAWTHORN REDBANK REDBANK MUN AUTH WWTP | Sewage Publicly Owned (Muni) | Active | WPC NPDES | PA0263893 |
| 10 | 43381 | HAWTHORN REDBANK REDBANK MUNI AUTH | 744133 | HAWTHORN REDBANK REDBANK MUN AUTH WWTP | Sewage Publicly Owned (Muni) | Active | WPC NPDES | PA0263893 |
| 11 | 43381 | HAWTHORN REDBANK REDBANK MUNI AUTH | 744133 | HAWTHORN REDBANK REDBANK MUN AUTH WWTP | Sewage Publicly Owned (Muni) | Active | WPC NPDES | PA0263893 |
| 12 | 43381 | HAWTHORN REDBANK REDBANK MUNI AUTH | 744133 | HAWTHORN REDBANK REDBANK MUN AUTH WWTP | Sewage Publicly Owned (Muni) | Active | WPC NPDES | PA0263893 |
| 13 | 43381 | HAWTHORN REDBANK REDBANK MUNI AUTH | 744133 | HAWTHORN REDBANK REDBANK MUN AUTH WWTP | Sewage Publicly Owned (Muni) | Active | WPC NPDES | PA0263893 |
| 14 | 43381 | HAWTHORN REDBANK REDBANK MUNI AUTH | 744133 | HAWTHORN REDBANK REDBANK MUN AUTH WWTP | Sewage Publicly Owned (Muni) | Active | WPC NPDES | PA0263893 |
| 15 | 43381 | HAWTHORN REDBANK REDBANK MUNI AUTH | 744133 | HAWTHORN REDBANK REDBANK MUN AUTH WWTP | Sewage Publicly Owned (Muni) | Active | WPC NPDES | PA0263893 |
| 16 | 43381 | HAWTHORN REDBANK REDBANK MUNI AUTH | 744133 | HAWTHORN REDBANK REDBANK MUN AUTH WWTP | Sewage Publicly Owned (Muni) | Active | WPC NPDES | PA0263893 |
| 17 | 43381 | HAWTHORN REDBANK REDBANK MUNI AUTH | 744133 | HAWTHORN REDBANK REDBANK MUN AUTH WWTP | Sewage Publicly Owned (Muni) | Active | WPC NPDES | PA0263893 |
| 18 | 43381 | HAWTHORN REDBANK REDBANK MUNI AUTH | 744133 | HAWTHORN REDBANK REDBANK MUN AUTH WWTP | Sewage Publicly Owned (Muni) | Active | WPC NPDES | PA0263893 |
| 19 | 43381 | HAWTHORN REDBANK REDBANK MUNI AUTH | 744133 | HAWTHORN REDBANK REDBANK MUN AUTH WWTP | Sewage Publicly Owned (Muni) | Active | WPC NPDES | PA0263893 |
| 20 | 43381 | HAWTHORN REDBANK REDBANK MUNI AUTH | 744133 | HAWTHORN REDBANK REDBANK MUN AUTH WWTP | Sewage Publicly Owned (Muni) | Active | WPC NPDES | PA0263893 |
| 21 | 43381 | HAWTHORN REDBANK REDBANK MUNI AUTH | 744133 | HAWTHORN REDBANK REDBANK MUN AUTH WWTP | Sewage Publicly Owned (Muni) | Active | WPC NPDES | PA0263893 |
| 22 | 43381 | HAWTHORN REDBANK REDBANK MUNI AUTH | 744133 | HAWTHORN REDBANK REDBANK MUN AUTH WWTP | Sewage Publicly Owned (Muni) | Active | WPC NPDES | PA0263893 |
| 23 | 43381 | HAWTHORN REDBANK REDBANK MUNI AUTH | 744133 | HAWTHORN REDBANK REDBANK MUN AUTH WWTP | Sewage Publicly Owned (Muni) | Active | WPC NPDES | PA0263893 |
| 24 | 43381 | HAWTHORN REDBANK REDBANK MUNI AUTH | 744133 | HAWTHORN REDBANK REDBANK MUN AUTH WWTP | Sewage Publicly Owned (Muni) | Active | WPC NPDES | PA0263893 |
| 25 | 43381 | HAWTHORN REDBANK REDBANK MUNI AUTH | 477743 | HAWTHORN REDBANK REDBANK MA | Community | Active | Safe Drinking Water | SM2263861 |

| | INSP ID | VIOLATION ID | INSPECTION CATEGORY | VIOLATION DATE | VIOLATION CODE | VIOLATION | PF INSPECTOR | NSP REGION |
|----|---------|--------------|---------------------|----------------|----------------|--|---------------------|------------|
| 1 | 3396171 | 962531 | PF | 07/22/2022 | C3F | FAILURE TO TEST ALARM AND SHUTDOWN CAPABILITIES OR RESPOND TO ALARM AND SHUTDOWN EQUIPMENT FAILURES | MUMFORD, MIRANDA | NWRO |
| 2 | 3218650 | 923041 | PF | 06/10/2021 | 92A.61(C) | NPDES - Failure to monitor pollutants as required by the NPDES permit | STONESIFER, CLINTON | NWRO |
| 3 | 3218650 | 923042 | PF | 06/10/2021 | 92A.41(A)10B | NPDES - Failure to utilize approved analytical methods | STONESIFER, CLINTON | NWRO |
| 4 | 3218650 | 923043 | PF | 06/10/2021 | 92A.41(A)10B | NPDES - Failure to utilize approved analytical methods | STONESIFER, CLINTON | NWRO |
| 5 | 3218650 | 923044 | PF | 06/10/2021 | 92A.41(A)10B | NPDES - Failure to utilize approved analytical methods | STONESIFER, CLINTON | NWRO |
| 6 | 3218650 | 923045 | PF | 06/10/2021 | 252.4(A) | NPDES - Failure to utilize an accredited environmental laboratory for testing or analysis of environmental samples | STONESIFER, CLINTON | NWRO |
| 7 | 3218650 | 923046 | PF | 06/10/2021 | 92A.41(A)10B | NPDES - Failure to utilize approved analytical methods | STONESIFER, CLINTON | NWRO |
| 8 | 3218650 | 923047 | PF | 06/10/2021 | 92A.41(A)10B | NPDES - Failure to utilize approved analytical methods | STONESIFER, CLINTON | NWRO |
| 9 | 3218650 | 923048 | PF | 06/10/2021 | 92A.41(A)10B | NPDES - Failure to utilize approved analytical methods | STONESIFER, CLINTON | NWRO |
| 10 | 3218650 | 923049 | PF | 06/10/2021 | 92A.41(A)10B | NPDES - Failure to utilize approved analytical methods | STONESIFER, CLINTON | NWRO |
| 11 | 3218650 | 923050 | PF | 06/10/2021 | 92A.41(A)8 | NPDES - Failure to provide information or records required by the permit or otherwise needed to determine compliance | STONESIFER, CLINTON | NWRO |
| 12 | 3218650 | 923051 | PF | 06/10/2021 | 92A.61(F)1 | NPDES - Failure to properly document monitoring activities and results | STONESIFER, CLINTON | NWRO |
| 13 | 3218650 | 923052 | PF | 06/10/2021 | 92A.61(F)1 | NPDES - Failure to properly document monitoring activities and results | STONESIFER, CLINTON | NWRO |
| 14 | 3218650 | 923053 | PF | 06/10/2021 | 92A.61(F)1 | NPDES - Failure to properly document monitoring activities and results | STONESIFER, CLINTON | NWRO |
| 15 | 3218650 | 923054 | PF | 06/10/2021 | 92A.41(A)12B | NPDES - Failure to submit monitoring report(s) or properly complete monitoring reports | STONESIFER, CLINTON | NWRO |
| 16 | 3218650 | 923055 | PF | 06/10/2021 | 92A.41(A)5 | NPDES - Failure to properly operate and maintain all facilities which are installed or used by the permittee to achieve compliance | STONESIFER, CLINTON | NWRO |
| 17 | 3218650 | 923056 | PF | 06/10/2021 | 92A.41(A)5 | NPDES - Failure to properly operate and maintain all facilities which are installed or used by the permittee to achieve compliance | STONESIFER, CLINTON | NWRO |
| 18 | 3218650 | 923057 | PF | 06/10/2021 | 92A.41(A)12B | NPDES - Failure to submit monitoring report(s) or properly complete monitoring reports | STONESIFER, CLINTON | NWRO |
| 19 | 3218650 | 923058 | PF | 06/10/2021 | 92A.41(A)12B | NPDES - Failure to submit monitoring report(s) or properly complete monitoring reports | STONESIFER, CLINTON | NWRO |
| 20 | 3218650 | 923059 | PF | 06/10/2021 | CSL611 | CSL - Failure to comply with terms and conditions of a WQM permit | STONESIFER, CLINTON | NWRO |
| 21 | 3218650 | 923060 | PF | 06/10/2021 | CSL611 | CSL - Failure to comply with terms and conditions of a WQM permit | STONESIFER, CLINTON | NWRO |
| 22 | 3218650 | 923061 | PF | 06/10/2021 | CSL611 | CSL - Failure to comply with terms and conditions of a WQM permit | STONESIFER, CLINTON | NWRO |
| 23 | 3218650 | 923062 | PF | 06/10/2021 | 302.1201 | Operator Certification - Operator failed to comply with the Act or Chapter 302 regulations | STONESIFER, CLINTON | NWRO |
| 24 | 3218650 | 923063 | PF | 06/10/2021 | 302.1201 | Operator Certification - Operator failed to comply with the Act or Chapter 302 regulations | STONESIFER, CLINTON | NWRO |
| 25 | 3559851 | 996134 | PF | 05/25/2023 | 46 | DISINFECTION/DISINFECTION BYPRODUCTS PRECURSOR REMOVAL VIOLATION | MUMFORD, MIRANDA | NWRO |