

Application Type Renewal
Wastewater Type Sewage
Facility Type SRSTP

**NPDES PERMIT FACT SHEET
INDIVIDUAL SFTF/SRSTP**

Application No. PA0263974
APS ID 1086365
Authorization ID 1435934

Applicant, Facility and Project Information

Applicant Name	<u>Mariah Clark</u>	Facility Name	<u>Mariah Clark SRSTP</u>
Applicant Address	<u>138 Saint Joe Road</u> <u>Butler, PA 16002-0050</u>	Facility Address	<u>138 Saint Joe Road</u> <u>Butler, PA 16002-0050</u>
Applicant Contact	<u>Mariah Clark</u>	Facility Contact	<u></u>
Applicant Phone	<u></u>	Facility Phone	<u></u>
Applicant E Mail	<u>mariahclark5299@gmail.com</u>	Facility E Mail	<u></u>
Client ID	<u>376695</u>	Site ID	<u>734515</u>
Municipality	<u>Oakland Township</u>	County	<u>Butler</u>
SIC Code	<u>8800</u>	SIC Code	<u>4952</u>
SIC Description	<u>Private Households</u>	SIC Description	<u>Trans. & Utilities - Sewerage Systems</u>
Date Application Received	<u>April 3, 2023</u>	WQM Required	<u>Transfer pending</u>
Date Application Accepted	<u>April 24. 2-23</u>	WQM App. No.	<u>1012401 T-2</u>
Project Description	<u>NPDES permit renewal and transfer for SRSTP</u>		

Summary of Review

No open violations listed. [5/2/2023 CWY](#)

This is a late renewal with NPDES and WQM permit transfers.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		<i>William H. Mentzer</i> William H. Mentzer, P.E. Environmental Engineering Specialist	April 24, 2023
X		Chad W. Yurisc Chad W. Yurisc, P.E. Environmental Engineer Manager	5/2/2023

Discharge and Stream Data – 2 - Receiving Waters and PWS

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.0004</u>
Latitude DP	<u>40° 54' 16.00</u>	Longitude DP	<u>-79° 48' 27.00"</u>
Latitude NHD	<u>40° 54' 16.93"</u>	Longitude NHD	<u>-79° 48' 28.31"</u>
Quad Name	<u>East Butler</u>	Quad Code	<u>1107</u>
Wastewater Description: <u>Treated single residence domestic wastes</u>			
Receiving Waters	<u>Unnamed Tributary of Bonnie Brook</u>	Stream Code	<u>35175</u>
NHD Com ID	<u>126217892</u>	RMI	<u>0.3400</u>
Drainage Area	<u>0.04</u>	Yield (cfs/mi ²)	<u>0</u>
Q ₇₋₁₀ Flow (cfs)	<u>0</u>	Q ₇₋₁₀ Basis	<u>Intermittent stream</u>
Elevation (ft)	<u>1260.00</u>	Slope (ft/ft)	<u>0.01263</u>
Watershed No.	<u>20-C</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u>statewide</u>	Existing Use Qualifier	<u>none</u>
Exceptions to Use	<u>none</u>	Exceptions to Criteria	<u>none</u>
Comments	<u>130-feet to intermittent stream</u>		
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	_____		
Source(s) of Impairment	_____		
TMDL Status	_____	Name	_____
Background/Ambient Data	Data Source		
pH (SU)	_____	_____	
Temperature (°F)	_____	_____	
Hardness (mg/L)	_____	_____	
Other:	_____	_____	
Nearest Downstream Public Water Supply Intake	<u>PA Am</u>		
PWS Waters	<u>Connoquenessing Creek</u>	Flow at Intake (cfs)	<u>NA</u>
PWS RMI	<u>0.1</u>	Distance from Outfall (mi)	<u>55.37</u>

Changes Since Last Permit Issuance: Public water intake at Zelienople is no longer in use.

Other Comments: With the small-flow advanced treatment requirements no downstream user impacts are expected.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Annual Average	Maximum	Instant. Maximum		
Flow (GPD)	Report Annl Avg	XXX	XXX	XXX	XXX	XXX	1/year	Estimate
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	Upon Request	Grab
BOD5	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
TSS	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
Fecal Coliform (No./100 ml)	XXX	XXX	XXX	200	XXX	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001 after disinfection