

Application Type Renewal  
Wastewater Type Sewage  
Facility Type SRSTP

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SFTF/SRSTP**

Application No. PA0264075  
APS ID 1023967  
Authorization ID 1328255

**Applicant, Facility and Project Information**

Applicant Name	<u>Harry Snyder</u>	Facility Name	<u>Harry Snyder SRSTP</u>
Applicant Address	<u>6686 Pleasant Drive</u> <u>Warren, PA 16365-7440</u>	Facility Address	<u>6686 Pleasant Drive</u> <u>Warren, PA 16365-7440</u>
Applicant Contact	<u>Harry Snyder</u>	Facility Contact	<u></u>
Applicant Phone	<u>814-726-1340</u>	Facility Phone	<u></u>
Applicant E-Mail	<u></u>	Facility E-Mail	<u></u>
Client ID	<u>321385</u>	Site ID	<u>809155</u>
Municipality	<u>Pleasant Township</u>	County	<u>Warren</u>
SIC Code	<u>8800</u>	SIC Code	<u>4952</u>
SIC Description	<u>Private Households</u>	SIC Description	<u>Trans. &amp; Utilities - Sewerage Systems</u>
Application Received	<u>August 28, 2020</u>	WQM Required	<u>The existing permit should be adequate</u>
Application Accepted	<u>September 24, 2020</u>	WQM App. No.	<u>6215407</u>
Project Description	<u>NPDES discharge permit renewal</u>		

**Summary of Review**

No violations are listed in WMS.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		<i>William H. Mentzer</i> William H. Mentzer, P.E. Environmental Engineering Specialist	March 10, 2021
X		Justin C. Dickey Justin C. Dickey, P.E. Environmental Engineer Manager	March 15, 2021

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.0004</u>
Latitude NHD	<u>41° 47' 24.33"</u>	Longitude NHD	<u>-79° 14' 31.11"</u>
Latitude DP	<u>41° 47' 7.55"</u>	Longitude DP	<u>-79° 14' 17.03"</u>
Quad Name	<u>Warren</u>	Quad Code	<u>0412</u>
Wastewater:	<u>Treated single residence domestic wastes</u>		
Receiving Waters	<u>Un-named tributary of Hedgehog Run</u>	Stream Code	<u>unknown</u>
NHD Com ID	<u>100467221</u>	RMI	<u>0.37</u>
Drainage Area	<u>0.01</u>	Yield (cfs/mi <sup>2</sup> )	<u>0</u>
Q <sub>7-10</sub> Flow (cfs)	<u>0</u>	Q <sub>7-10</sub> Basis	<u>Dry drainage swale</u>
Elevation (ft)	<u>1698.90</u>	Slope (ft/ft)	<u>0.02104</u>
Watershed No.	<u>16F</u>	Chapter 93 Class.	<u>HQ - CWF</u>
Existing Use	<u>Statewide</u>	Existing Use Qualifier	<u>None</u>
Exceptions to Use	<u>None</u>	Exceptions to Criteria	<u>None</u>
Comments	<u>NHD location is 1.67 miles downstream at Hedgehog Run RMI 1.19 and first point-of-use. The downstream drainage is 0.68-square miles.</u>		
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	_____		
Source(s) of Impairment	_____		
TMDL Status	_____	Name	_____
Background/Ambient Data		Data Source	
pH (SU)	_____		_____
Temperature (°F)	_____		_____
Hardness (mg/L)	_____		_____
Other:	_____		_____
Nearest Downstream Public Water Supply Intake	<u>Emlenton Water Company (Aqua Pa)</u>		
PWS Waters	<u>Allegheny River</u>	Flow at Intake (cfs)	<u>1289.37</u>
PWS RMI	<u>90.57</u>	Distance from Outfall (mi)	<u>88.33</u>

Changes Since Last Permit Issuance: none

Other Comments: The HQ stream classification require water supply evaluation at the discharge.

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001 , Continued from Permit Effective Date through Permit Expiration Date**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Annual Average	Maximum	Instant. Maximum		
Flow (GPD)	Report Annl Avg	XXX	XXX	XXX	XXX	XXX	1/year	Estimate
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/month	Grab
TRC	XXX	XXX	XXX	Report	XXX	XXX	1/month	Grab
BOD5	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
TSS	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
Fecal Coliform (No./100 ml)	XXX	XXX	XXX	200	XXX	1000	1/year	Grab

Compliance Sampling Location: Outfall 001 after disinfection