

Application Type Renewal
Wastewater Type Sewage
Facility Type SRSTP

**NPDES PERMIT FACT SHEET
INDIVIDUAL SFTF/SRSTP**

Application No. PA0264237
APS ID 1054500
Authorization ID 1381173

Applicant, Facility and Project Information

Applicant Name	<u>Andre & Julie Turbide</u>	Facility Name	<u>Andre & Julie Turbide SRSTP</u>
Applicant Address	<u>2721 Route 957</u> <u>Russell, PA 16345</u>	Facility Address	<u>2721 Route 957</u> <u>Russell, PA 16345</u>
Applicant Contact	<u>Andre & Julie Turbide</u>	Facility Contact	<u>Andre & Julie Turbide</u>
Applicant Phone		Facility Phone	
Client ID	<u>328246</u>	Site ID	<u>809227</u>
SIC Code	<u>8800</u>	Municipality	<u>Farmington Township</u>
SIC Description	<u>Private Households</u>	County	<u>Warren</u>
Date Application Received	<u>January 10, 2022</u>	WQM Required	<u>No</u>
Date Application Accepted	<u>January 11, 2022</u>	WQM App. No.	<u>-</u>
Project Description	<u>Renewal of an NPDES Permit for a Single Residence Sewage Treatment Plant.</u>		

Summary of Review

Act 14 - Proof of Notification was submitted and received.

The applicant should be able to meet the limits of this permit, which will protect the uses of the receiving stream.

I. OTHER REQUIREMENTS:

- | | |
|--|---------------------------------|
| A. AMRs | F. Stormwater into sewers |
| B. DMRs | G. Right of way |
| C. Depth of Septage and Scum Measurement | H. Solids handling |
| D. Septic Tank Pumping | I. Public Sewerage Availability |
| E. Effluent Chlorine Optimization and Minimization | |

SPECIAL CONDITIONS: Ultraviolet (UV) Disinfection

Permitted treatment consists of: A 1,000 gallon dual compartment septic tank with an effluent filter, an Ecoflo Model 450 coco filter, and ultraviolet (UV) light disinfection.

There are no open violations in effects for Client ID 328246 as of 2/1/2023.

Approve	Deny	Signatures	Date
X		Stephen A. McCauley Stephen A. McCauley, E.I.T. / Environmental Engineering Specialist	2/1/2023
X		Chad W. Yurisc Chad W. Yurisc, P.E. / Environmental Engineer Manager	2/21/2023

Discharge, Receiving Waters and Water Supply Information

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.0004</u>
Latitude	<u>41° 57' 40.6"</u>	Longitude	<u>-79° 11' 3.7"</u>
Quad Name	<u>-</u>	Quad Code	<u>-</u>

Wastewater Description: Sewage Effluent

Receiving Waters	<u>Johnny Run (CWF)</u>	Stream Code	<u>56381</u>
NHD Com ID	<u>129446829</u>	RMI	<u>1.57</u>
Drainage Area	<u>-</u>	Yield (cfs/mi ²)	<u>-</u>
Q ₇₋₁₀ Flow (cfs)	<u>-</u>	Q ₇₋₁₀ Basis	<u>-</u>
Elevation (ft)	<u>-</u>	Slope (ft/ft)	<u>-</u>
Watershed No.	<u>16-B</u>	Chapter 93 Class.	<u>CWF</u>
Existing Use	<u>-</u>	Existing Use Qualifier	<u>-</u>
Exceptions to Use	<u>None</u>	Exceptions to Criteria	<u>None</u>

Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u>-</u>		
Source(s) of Impairment	<u>-</u>		
TMDL Status	<u>-</u>	Name	<u>-</u>

Background/Ambient Data	Data Source
pH (SU)	<u>-</u>
Temperature (°F)	<u>-</u>
Hardness (mg/L)	<u>-</u>
Other:	<u>-</u>

Nearest Downstream Public Water Supply Intake	<u>-</u>		
PWS Waters	<u>-</u>	Flow at Intake (cfs)	<u>-</u>
PWS RMI	<u>-</u>	Distance from Outfall (mi)	<u>-</u>

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

This SFTF was designed where applicable in accordance with the SFTF Manual, but it does not qualify for the PAG-04 General Permit due to the use of an Ecoflo Model 450 filter.

No modeling was performed since this is an application for an NPDES Permit for a septic tank / peat filter system, which have been shown to be capable of meeting BOD₅ and TSS limits below the inputs of the WQ model.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Annual Average	Maximum	Instant. Maximum		
Flow (GPD)	Report Annl Avg	XXX	XXX	XXX	XXX	XXX	1/year	Estimate
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	Upon Request	Grab
BOD5	XXX	XXX	XXX	10.0	XXX	20	1/year	Grab
TSS	XXX	XXX	XXX	10.0	XXX	20	1/year	Grab
Fecal Coliform (No./100 ml)	XXX	XXX	XXX	200	XXX	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001, after ultraviolet (UV) light disinfection.

Flow is monitor only based on Chapter 92a.61. The limits for pH are technology-based on Chapter 93.7. The limits for BOD5, Total Suspended Solids, and Fecal Coliform are technology-based on Chapter 92a.47.