

Application Type Renewal
Wastewater Type Sewage
Facility Type SRSTP

**NPDES PERMIT FACT SHEET
INDIVIDUAL SFTF/SRSTP**

Application No. PA0264881
APS ID 1074496
Authorization ID 1415534

Applicant, Facility and Project Information

Applicant Name	<u>Timothy Hajec</u>	Facility Name	<u>Timothy Hajec SRSTP</u>
Applicant Address	<u>650 Whitney Run Road</u> <u>Corry, PA 16407-2908</u>	Facility Address	<u>650 Whitney Run Road</u> <u>Corry, PA 16407-2908</u>
Applicant Contact	<u>Timothy Hajec</u>	Facility Contact	<u></u>
Applicant Phone	<u>(814) 664-9768</u>	Facility Phone	<u></u>
Applicant E MAl	<u>NA</u>	Facility E Mail	<u>NA</u>
Client ID	<u>332276</u>	Site ID	<u>819047</u>
Municipality	<u>Spring Creek Township</u>	County	<u>Warren</u>
SIC Code	<u>8800</u>	SIC Code	<u>4952</u>
SIC Description	<u>Private Households</u>	SIC Description	<u>Trans. & Utilities - Sewerage Systems</u>
Date Application Received	<u>October 24, 2022</u>	WQM Required	<u>Present permit is adequate</u>
Date Application Accepted	<u>November 7, 2022</u>	WQM App. No.	<u></u>
Project Description	<u>NPDES discharge permit renewal</u>		



Summary of Review

No open violations. Cited on August 1, 2022 for an unpermitted discharge with compliance as of October 24, 2022.

General permit excluded by HQ stream designation

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
		<i>William H. Mentzer</i> William H. Mentzer, P.E. Environmental Engineering Specialist	January 29, 2024
		Vacant Environmental Engineer Manager	Okay to Draft JCD 1/30/2024

Discharge and Stream Data – 2 - Receiving Waters and PWS

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.0004</u>
Latitude	<u>41° 50' 38.75"</u>	Longitude	<u>-79° 35' 28.43"</u>
Quad Name	<u>Spring Creek</u>	Quad Code	<u>0403</u>
Wastewater Description: <u>Treated single residence domestic wastes</u>			
Receiving Waters	<u>Whitney Run</u>	Stream Code	<u>56128</u>
NHD Com ID	<u>112377329</u>	RMI	<u>1.68</u>
Drainage Area	<u>5.96</u>	Yield (cfs/mi ²)	<u>0.11</u>
Q ₇₋₁₀ Flow (cfs)	<u>0.63</u>	Q ₇₋₁₀ Basis	<u>Brokenstraw Creek</u>
Elevation (ft)	<u>1516.34</u>	Slope (ft/ft)	<u>0.00856</u>
Watershed No.	<u>16-B</u>	Chapter 93 Class.	<u>HQ-CWF</u>
Existing Use	<u>statewide</u>	Existing Use Qualifier	<u>none</u>
Exceptions to Use	<u>none</u>	Exceptions to Criteria	<u>none</u>
Comments	<u>DP and NHD are identical. Node RMI 0.8</u>		
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	_____		
Source(s) of Impairment	_____		
TMDL Status	_____	Name	_____
Background/Ambient Data	_____	Data Source	_____
pH (SU)	_____		_____
Temperature (°F)	_____		_____
Hardness (mg/L)	_____		_____
Other:	_____		_____
Nearest Downstream Public Water Supply Intake	<u>Aqua Am Emlenton</u>		
PWS Waters	<u>Allegheny River</u>	Flow at Intake (cfs)	<u>NA</u>
PWS RMI	<u>90/57</u>	Distance from Outfall (mi)	<u>129</u>

Changes Since Last Permit Issuance: none

Other Comments: HQ stream classification requires water supply evaluation at the discharge.

This is an existing and previously approved discharge to a High-Quality watershed. No expansion or changes to effluent quantity or quality are proposed. Therefore, no additional anti-degradation review should be required. JCD

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Annual Average	Maximum	Instant. Maximum		
Flow (GPD)	Report Annl Avg	XXX	XXX	XXX	XXX	XXX	1/year	Estimate
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/month	Grab
BOD5	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
TSS	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
Fecal Coliform (No./100 ml)	XXX	XXX	XXX	200	XXX	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001 after disinfection