



Application Type  
Facility Type  
Major / Minor

Renewal  
Industrial  
Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL INDUSTRIAL WASTE (IW)  
AND IW STORMWATER**

Application No. **PA0265560**  
APS ID **1093675**  
Authorization ID **1448833**

**Applicant and Facility Information**

Applicant Name	<u>Aqua Pennsylvania Inc.</u>	Facility Name	<u>Mount Jewett WTP</u>
Applicant Address	<u>762 W Lancaster Avenue</u>	Facility Address	<u>11385 State Route 6</u>
	<u>Bryn Mawr, PA 19010-3489</u>		<u>Mt Jewett, PA 16740</u>
Applicant Contact	<u>Todd Duerr</u>	Facility Contact	<u>Mike Starr</u>
Applicant Phone	<u>(610) 645-1122</u>	Facility Phone	<u>(610) 645-1122</u>
Client ID	<u>309251</u>	Site ID	<u>240790</u>
SIC Code	<u>4941</u>	Municipality	<u>Hamlin Township</u>
SIC Description	<u>Trans. &amp; Utilities - Water Supply</u>	County	<u>McKean</u>
Date Application Received	<u>June 29, 2023</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted		If No, Reason	
Purpose of Application	<u>NPDES Renewal.</u>		

**Summary of Review**

The Mount Jewett WTP is a potable public water treatment plant (WTP). The source water is from a combination of six wells and one spring. Well water is treated with potassium permanganate, and is then filtered through iron and manganese green sand filters. The filters are generally backwashed once a day, 5 days a week, generating approximately 6,000 gpd of spent filter backwash. The backwash drains by gravity to a 9,000 gallon settling basin that overflows a weir to a 9,000 gallon overflow basin. The wastewater stream also includes a continuous flow of instrument sample water that drains through the same drain as the spent filter backwash. The flow of the sample water is approximately 400 gpd. The overflow basin drains by gravity to Kane Creek through the outfall pipe. The settling basin and overflow basin are periodically pumped down and accumulated solids are trucked for further treatment off-site.

Changes to the permit: A Total Cadmium limit, and Total Copper, Total Silver, and Total Mercury monitoring have been added to the permit. The Total Cadmium limit and Total Copper and Total Silver monitoring may be removed if additional effluent sampling is provided at the Target Quantitation Limits provided in the NPDES application instructions.

There are no open violations for this Applicant.

**Public Participation**

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Benjamin R. Lockwood Benjamin R. Lockwood / Environmental Engineering Specialist	April 6, 2025
X		Adam Olesnanik Adam Olesnanik, P.E. / Environmental Engineer Manager	April 9, 2025

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	.0064
Latitude	41° 43' 16"	Longitude	78° 36' 38"
Quad Name		Quad Code	
Wastewater Description:	Treated filter backwash and instrument sample water		
Receiving Waters	Kane Creek (CWF)	Stream Code	57802
NHD Com ID	112377085	RMI	1.81
Drainage Area	0.82 mi <sup>2</sup>	Yield (cfs/mi <sup>2</sup> )	
Q <sub>7-10</sub> Flow (cfs)	0.0493	Q <sub>7-10</sub> Basis	USGS PA StreamStats
Elevation (ft)	2177	Slope (ft/ft)	
Watershed No.	16-C	Chapter 93 Class.	CWF
Existing Use	N/A	Existing Use Qualifier	N/A
Exceptions to Use	N/A	Exceptions to Criteria	N/A
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment	N/A		
Source(s) of Impairment	N/A		
TMDL Status	N/A	Name	N/A
Nearest Downstream Public Water Supply Intake		PA/NY State Line	
PWS Waters	Allegheny River	Flow at Intake (cfs)	
PWS RMI		Distance from Outfall (mi)	32

Changes Since Last Permit Issuance: None

<b>Compliance History</b>	
<b>Summary of DMRs:</b>	There were no effluent violations reported in the last year of eDMR data.
<b>Summary of Inspections:</b>	2/22/2024: An inspection was conducted. It was noted that the discharge from the treatment plant was carrying out pieces of D-chlor tablets. The Applicant is investigating this issue, and why the effluent trough is holding water.

Other Comments: None

Compliance History

DMR Data for Outfall 001 (from March 1, 2024 to February 28, 2025)

Parameter	FEB-25	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24	APR-24	MAR-24
Flow (MGD) Average Monthly	0.00055 0.00121	0.00055 3	0.0005 703	0.00588 6	0.00636 357	0.00526 1	0.00522 17	0.00244 7	0.00434 7	0.00466 31	0.00051 77	0.00649
Flow (MGD) Daily Maximum	0.01873	0.00636 1	0.0067	0.00698 978	0.00878 36	0.00707 569	0.01277 832	0.00367 18	0.00472	0.00512 4	0.00053 42	0.01284 3
pH (S.U.) Instantaneous Minimum	7.78	7.48	7.7	7.8	7.8	7.7	7.7	8.0	8.1	7.9	8.0	7.84
pH (S.U.) Instantaneous Maximum	7.88	7.87	7.8	7.8	7.8	7.8	8.0	8.0	8.1	8.1	8.0	7.91
TRC (mg/L) Average Monthly	0.11	0.12	0.12	0.2	0.2	0.17	0.03	< 0.01	0.03	< 0.02	< 0.02	0.03
TRC (mg/L) Instantaneous Maximum	0.15	0.10	0.12	0.2	0.2	0.26	0.04	0.01	0.03	0.03	0.02	0.04
TSS (mg/L) Average Monthly	2.8	2.3	< 1.6	2.5	2.0	10.0	8.3	2.3	2.4	2.6	3.2	< 0.9
TSS (mg/L) Instantaneous Maximum	3.0	3.0	3.0	3.0	3.0	18.0	13.0	4.4	2.4	3.6	4.4	1.6
Total Aluminum (mg/L) Average Monthly	0.02	0.03	0.03	0.02	0.03	0.02	0.05	0.02	0.01	0.01	< 0.01	0.01
Total Aluminum (mg/L) Instant. Maximum	0.02	0.03	0.04	0.02	0.03	0.03	0.05	0.02	0.01	0.01	0.01	0.01
Total Iron (mg/L) Average Monthly	0.16	0.23	0.31	0.47	0.27	0.52	0.29	0.37	0.12	0.52	0.42	0.34
Total Iron (mg/L) Instantaneous Maximum	0.39	0.26	0.45	0.52	0.35	0.74	0.41	0.61	0.15	0.88	0.65	0.39
Total Manganese (mg/L) Average Monthly	0.24	0.3	0.32	0.49	0.52	0.69	0.31	0.33	0.12	0.26	0.28	0.39
Total Manganese (mg/L) Instant. Maximum	0.39	0.43	0.41	0.66	0.68	0.89	0.45	0.58	0.12	0.41	0.4	0.41

**Development of Effluent Limitations**

Outfall No. 001  
Latitude 41° 43' 16"

Design Flow (MGD) .0064  
Longitude 78° 36' 38"

Wastewater Description: Treated filter backwash and instrument sample water

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Parameter	Limit (mg/l)	SBC	Federal Regulation	State Regulation
Total Suspended Solids	30	Average Monthly		362-2183-001
Total Suspended Solids	60	Daily Maximum		362-2183-001
Aluminum	4.0	Average Monthly		362-2183-001
Aluminum	8.0	Daily Maximum		362-2183-001
Manganese	1.0	Average Monthly		362-2183-001
Manganese	2.0	Daily Maximum		362-2183-001
Total Iron	2.0	Average Monthly		362-2183-001
Total Iron	4.0	Daily Maximum		362-2183-001
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
Total Residual Chlorine	1.0	Daily Maximum		362-2183-001
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)

Comments: The DEP Guidance "Technology-based Control Requirements for Water Treatment Plant Wastes" (362-2183-001) provides these limits that are based on Best Practical Control Technology (BPT). The Mount Jewett WTP is not subject to Federal Effluent Limitation Guidelines (ELGs) as the SIC code is not listed under 40 CFR parts 405 through 471.

**Toxics**

Effluent sample results for toxic pollutants reported on the renewal application were entered into DEP's Toxics Management Spreadsheet Version 1.3 to develop appropriate permit requirements for toxic pollutants of concern. The Toxics Management Spreadsheet combines the functions of PENTOXSD and DEP's Toxics Screening Analysis. The TMS spreadsheet recommended a limit for Total Cadmium, and monitoring for Total Aluminum, Total Copper, Total Iron, Total Mercury, and Total Silver. The NPDES permit already contains monitoring requirements for Total Aluminum and Total Iron.

This data was analyzed based on the guidelines found in DEP's Water Quality Toxics Management Strategy (Document No. 361-0100-003) and DEP's SOP No. BPNPSM-PMT-033. Spreadsheet results are attached to this fact sheet. The Toxics Management Spreadsheet uses the following logic:

- Establish average monthly and IMAX limits in the draft permit where the maximum reported concentration exceeds 50% of the WQBEL.
- For non-conservative pollutants, establish monitoring requirements where the maximum reported concentration is between 25% - 50% of the WQBEL.
- For conservative pollutants, establish monitoring requirements where the maximum reported concentration is between 10%-50% of the WQBEL.

A Total Cadmium limit will be placed in the draft permit with an average monthly limit of 0.0017 mg/l, daily maximum limit of 0.0026 mg/l, and an instantaneous maximum limit of 0.0042 mg/l. A monitoring requirement will be added to the permit for Total Copper, Total Silver, and Total Mercury. The sampling reported in the application for Total Cadmium, Total Copper, and Total Silver were all non-detect results. The Applicant will be allowed to re-sample these parameters at the Target Quantitation Limits (Target QLs) provided in the NPDES application instructions. Any resampling completed by the Applicant may result in modification or removal of the proposed Total Cadmium limitation and Total Copper and Total Silver monitoring requirements.

**Total Dissolved Solids**

DEP's SOP No. BPNPSM-PMT-032 recommends monitoring for TDS when the discharge concentrations exceed 1,000 mg/l. Outfall 001 sampling results did not exceed 1,000 mg/l for TDS, so TDS monitoring is not included in the permit.

**Additional Considerations**

Monitoring for PFAS parameters – PFOA, PFOS, PFBS, and HFPO-DA will not be required at this time because the facility does not currently have treatment to remove PFAS. The current permit TRC limits are more stringent than the BPT limits listed above.

**Anti-Backsliding**

Pursuant to 40 CFR § 122.44(l)(1), all proposed permit requirements addressed in this fact sheet are at least as stringent as the requirements implemented in the existing NPDES permit.

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	2/month	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	2/month	Grab
TRC	XXX	XXX	XXX	0.3	XXX	0.6	2/month	Grab
TSS	XXX	XXX	XXX	30.0	XXX	60.0	2/month	Grab
Total Aluminum	XXX	XXX	XXX	2.0	XXX	4.0	2/month	Grab
Total Iron	XXX	XXX	XXX	2.0	XXX	4.0	2/month	Grab
Total Manganese	XXX	XXX	XXX	1.0	XXX	2.0	2/month	Grab
Total Cadmium	XXX	XXX	XXX	0.0017	0.0026	0.0042	2/month	Grab
Total Mercury	XXX	XXX	XXX	XXX	Report	XXX	2/month	Grab
Total Copper	XXX	XXX	XXX	XXX	Report	XXX	2/month	Grab
Total Silver	XXX	XXX	XXX	XXX	Report	XXX	2/month	Grab

Compliance Sampling Location: Outfall 001

Other Comments: None


## Aqua Pennsylvania Inc. PA0265560 Outfall 001

**Region ID:** PA

**Workspace ID:** PA20250405010657311000

**Clicked Point (Latitude, Longitude):** 41.72106, -78.61048

**Time:** 2025-04-04 21:07:22 -0400



 [Collapse All](#)

### ➤ Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	0.82	square miles
ELEV	Mean Basin Elevation	2177	feet
PRECIP	Mean Annual Precipitation	45	inches

## ➤ Low-Flow Statistics

### Low-Flow Statistics Parameters [Low Flow Region 3]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	0.82	square miles	2.33	1720
ELEV	Mean Basin Elevation	2177	feet	898	2700
PRECIP	Mean Annual Precipitation	45	inches	38.7	47.9

### Low-Flow Statistics Disclaimers [Low Flow Region 3]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

### Low-Flow Statistics Flow Report [Low Flow Region 3]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.118	ft^3/s
30 Day 2 Year Low Flow	0.173	ft^3/s
7 Day 10 Year Low Flow	0.0493	ft^3/s
30 Day 10 Year Low Flow	0.0675	ft^3/s
90 Day 10 Year Low Flow	0.101	ft^3/s

#### *Low-Flow Statistics Citations*

**Stuckey, M.H.,2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)**

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government


## Aqua Pennsylvania Inc. PA0265560 RMI = 0.73

**Region ID:** PA

**Workspace ID:** PA20250405011232561000

**Clicked Point (Latitude, Longitude):** 41.71258, -78.59675

**Time:** 2025-04-04 21:12:54 -0400



 [Collapse All](#)

### ➤ Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	1.68	square miles
ELEV	Mean Basin Elevation	2126	feet
PRECIP	Mean Annual Precipitation	45	inches

## ➤ Low-Flow Statistics

### Low-Flow Statistics Parameters [Low Flow Region 3]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	1.68	square miles	2.33	1720
ELEV	Mean Basin Elevation	2126	feet	898	2700
PRECIP	Mean Annual Precipitation	45	inches	38.7	47.9

### Low-Flow Statistics Disclaimers [Low Flow Region 3]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

### Low-Flow Statistics Flow Report [Low Flow Region 3]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.241	ft^3/s
30 Day 2 Year Low Flow	0.35	ft^3/s
7 Day 10 Year Low Flow	0.104	ft^3/s
30 Day 10 Year Low Flow	0.142	ft^3/s
90 Day 10 Year Low Flow	0.209	ft^3/s

#### *Low-Flow Statistics Citations*

**Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)**

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government

TRC\_CALC

1A	B	C	D	E	F	G
<b>2 TRC EVALUATION</b>						
3 Input appropriate values in B4:B8 and E4:E7						
4	0.0493	= Q stream (cfs)		0.5	= CV Daily	
5	0.0064	= Q discharge (MGD)		0.5	= CV Hourly	
6	30	= no. samples		1	= AFC_Partial Mix Factor	
7	0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor	
8	0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)	
9	0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)	
	0	= % Factor of Safety (FOS)			= Decay Coefficient (K)	
10	Source	Reference	AFC Calculations	Reference	CFC Calculations	
11	TRC	1.3.2.III	WLA_afc = 1.607	1.3.2.III	WLA_cfc = 1.560	
12	PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581	
13	PENTOXSD TRG	5.1b	LTA_afc = 0.599	5.1d	LTA_cfc = 0.907	
14	15 Source Effluent Limit Calculations					
16	PENTOXSD TRG	5.1f	AML MULT = 1.231			
17	PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500		BAT/BPJ	
18			INST MAX LIMIT (mg/l) = 1.635			
<p>WLA_afc      <math>(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))... + Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)</math></p> <p>LTAMULT_afc      <math>EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)</math></p> <p>LTA_afc      <math>wla_afc*LTAMULT_afc</math></p> <p>WLA_cfc      <math>(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))... + Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)</math></p> <p>LTAMULT_cfc      <math>EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)</math></p> <p>LTA_cfc      <math>wla_cfc*LTAMULT_cfc</math></p> <p>AML MULT      <math>EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))</math></p> <p>AVG MON LIMIT      <math>MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)</math></p> <p>INST MAX LIMIT      <math>1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)</math></p>						



## Discharge Information

Instructions **Discharge** Stream

Facility: **Mount Jewett WTP** NPDES Permit No.: **PA0265560** Outfall No.: **001**

Evaluation Type: **Major Sewage / Industrial Waste** Wastewater Description: **Treated filter backwash**

Discharge Characteristics						
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)			Complete Mix Times (min)
			AFC	CFC	THH	
0.0064	138	8.1				

			0 if left blank		0.5 if left blank		0 if left blank		1 if left blank		
			Trib Conc	Stream Conc	Daily CV	Hourly CV	Strea m CV	Fate Coeff	FOS	Criteri a Mod	Chem Transl
<b>Group 1</b>	Total Dissolved Solids (PWS)	mg/L	192								
	Chloride (PWS)	mg/L	11.9								
	Bromide	mg/L	< 0.4								
	Sulfate (PWS)	mg/L	19.4								
	Fluoride (PWS)	mg/L	< 2								
<b>Group 2</b>	Total Aluminum	µg/L	960								
	Total Antimony	µg/L	< 1								
	Total Arsenic	µg/L	3.8								
	Total Barium	µg/L	283								
	Total Beryllium	µg/L	< 2.5								
	Total Boron	µg/L	599								
	Total Cadmium	µg/L	< 2.5								
	Total Chromium (III)	µg/L	< 5								
	Hexavalent Chromium	µg/L	< 0.25								
	Total Cobalt	µg/L	< 2								
	Total Copper	µg/L	< 12.5								
	Free Cyanide	µg/L									
	Total Cyanide	µg/L	< 10								
	Dissolved Iron	µg/L									
	Total Iron	µg/L	1700								
	Total Lead	µg/L	< 0.5								
	Total Manganese	µg/L	1.2								
	Total Mercury	µg/L	0.14								
	Total Nickel	µg/L	< 2.5								
	Total Phenols (Phenolics) (PWS)	µg/L	< 5								
	Total Selenium	µg/L	< 2.5								
	Total Silver	µg/L	< 2.5								
	Total Thallium	µg/L	< 0.5								
	Total Zinc	µg/L	< 12.5								
	Total Molybdenum	µg/L									
	Acrolein	µg/L	<								
	Acrylamide	µg/L	<								
	Acrylonitrile	µg/L	<								
	Benzene	µg/L	<								
	Bromoform	µg/L	<								







## Stream / Surface Water Information

Instructions    Discharge    Stream

Mount Jewett WTP, NPDES Permit No. PA0265560, Outfall 001

Toxics Management Spreadsheet  
Version 1.4, May 2023

Receiving Surface Water Name: **Kane Creek**

No. Reaches to Model: 1

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi <sup>2</sup> )*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	057802	1.81	2177	0.82			Yes
End of Reach 1	057802	0.73	2126	1.68			Yes

Q<sub>7-10</sub>

Location	RMI	LFY (cfs/mi <sup>2</sup> )*	Flow (cfs)	W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary	Stream	Analysis
			Stream	Tributary					Hardness	pH*	Hardness
Point of Discharge	1.81	0.1	0.0493						100	7	
End of Reach 1	0.73	0.1	0.104						100	7	

16

Q<sub>h</sub>

Location	RMI	LFY (cfs/mi <sup>2</sup> )*	Flow (cfs)	W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary	Stream	Analysis
			Stream	Tributary					Hardness	pH	Hardness
Point of Discharge	1.81										
End of Reach 1	0.73										



## Model Results

<input type="button" value="Instructions"/>	<input checked="" type="button" value="Results"/>	<input type="button" value="RETURN TO INPUTS"/>	<input type="button" value="SAVE AS PDF"/>	<input type="button" value="PRINT"/>
---	---	---	--	--------------------------------------

Mount Jewett WTP, NPDES Permit No. PA0265560, Outfall 001

**Hydrodynamics**

**Wasteload Allocations**

**AFC** CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

Pollutants	Stream Conc (mg/L)	Stream CV	trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0	0	0	N/A	N/A	
Chloride (PWS)	0	0	0	0	N/A	N/A	
Sulfate (PWS)	0	0	0	0	N/A	N/A	
Fluoride (PWS)	0	0	0	0	N/A	N/A	
Total Aluminum	0	0	0	0	750	750	4,485
Total Antimony	0	0	0	0	1,100	1,100	6,577
Total Arsenic	0	0	0	0	340	340	2,033
Total Barium	0	0	0	0	21,000	21,000	125,567
Total Boron	0	0	0	0	8,100	8,100	48,433
Total Cadmium	0	0	0	0	2,138	2,27	13.6
Total Chromium (III)	0	0	0	0	599.253	1,896	11,339
Hexavalent Chromium	0	0	0	0	16	16.3	97.4
Total Cobalt	0	0	0	0	95	95.0	568
Total Copper	0	0	0	0	14,242	14.8	88.7
Total Iron	0	0	0	0	N/A	N/A	
Total Lead	0	0	0	0	69.058	88.3	528
Total Manganese	0	0	0	0	N/A	N/A	
Total Mercury	0	0	0	0	1,400	1.65	9.85
Total Nickel	0	0	0	0	493.290	494.	2,955
Total Phenols (Phenolics) (PWS)	0	0	0	0	N/A	N/A	
Total Selenium	0	0	0	0	N/A	N/A	Chem Translator of 0.922 applied
Total Silver	0	0	0	0	3,576	4.21	25.2
Total Thallium	0	0	0	0	65	65.0	389
Total Zinc	0	0	0	0	123,460	126	755
							Chem Translator of 0.978 applied

**CFC** CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQA Obj (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0	0	0	N/A	N/A	N/A
Chloride (PWS)	0	0	0	0	N/A	N/A	N/A
Sulfate (PWS)	0	0	0	0	N/A	N/A	N/A
Fluoride (PWS)	0	0	0	0	N/A	N/A	N/A
Total Aluminum	0	0	0	0	N/A	N/A	N/A
Total Antimony	0	0	0	0	220	220	1,315
Total Arsenic	0	0	0	0	150	150	897
Total Barium	0	0	0	0	4,100	4,100	24,516
Total Boron	0	0	0	0	1,600	1,600	9,567
Total Cadmium	0	0	0	0	0.257	0.28	1.69
Total Chromium (III)	0	0	0	0	77.950	90.6	542
Hexavalent Chromium	0	0	0	0	10	10.4	62.2
Total Cobalt	0	0	0	0	19	19.0	114
Total Copper	0	0	0	0	9,440	9,83	58.8
Total Iron	0	0	0	0	1,500	1,500	8,969
Total Lead	0	0	0	0	2,691	3,44	20.6
Total Manganese	0	0	0	0	N/A	N/A	N/A
Total Mercury	0	0	0	0	0.770	0.91	5.42
Total Nickel	0	0	0	0	54.789	55.0	329
Total Phenols (Phenolics) (PWS)	0	0	0	0	N/A	N/A	N/A
Total Selenium	0	0	0	0	4,600	4,99	29.8
Total Silver	0	0	0	0	N/A	N/A	N/A
Total Thallium	0	0	0	0	13	13.0	77.7
Total Zinc	0	0	0	0	124,470	126	755

**THH** CCT (min):  PMF:  Analysis Hardness (mg/L):  Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQA Obj (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0	0	0	500,000	500,000	N/A
Chloride (PWS)	0	0	0	0	250,000	250,000	N/A
Sulfate (PWS)	0	0	0	0	250,000	250,000	N/A
Fluoride (PWS)	0	0	0	0	2,000	2,000	N/A
Total Aluminum	0	0	0	0	N/A	N/A	N/A
Total Antimony	0	0	0	0	5.6	5.6	33.5
Total Arsenic	0	0	0	0	10	10.0	59.8
Total Barium	0	0	0	0	2,400	2,400	14,351
Total Boron	0	0	0	0	3,100	3,100	18,536
Total Cadmium	0	0	0	0	N/A	N/A	N/A
Total Chromium (III)	0	0	0	0	N/A	N/A	N/A
Hexavalent Chromium	0	0	0	0	N/A	N/A	N/A
Total Cobalt	0	0	0	0	N/A	N/A	N/A

Total Copper	0	0	0	0	0	N/A	N/A	N/A
Total Iron	0	0	0	0	0	N/A	N/A	N/A
Total Lead	0	0	0	0	0	N/A	N/A	N/A
Total Manganese	0	0	0	0	0	1,000	1,000	5,979
Total Mercury	0	0	0	0	0	0.050	0.05	0.3
Total Nickel	0	0	0	0	0	610	610	3,647
Total Phenols (Phenolics) (PWS)	0	0	0	0	0	5	5.0	N/A
Total Selenium	0	0	0	0	0	N/A	N/A	N/A
Total Silver	0	0	0	0	0	N/A	N/A	N/A
Total Thallium	0	0	0	0	0	0.24	0.24	1.44
Total Zinc	0	0	0	0	0	N/A	N/A	N/A

Pollutants	CCT (min): <input checked="" type="checkbox"/> 0.270				PMF: <input type="checkbox"/> 1				Analysis Hardness (mg/l): <input type="checkbox"/> N/A				Analysis pH: <input type="checkbox"/> N/A							
	Stream Conc (µmol/L)	Stream CV	Stream Conc (µg/L)	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments											
Total Dissolved Solids (PWS)	0	0	0	0	0	N/A	N/A	N/A	N/A											
Chloride (PWS)	0	0	0	0	0	N/A	N/A	N/A	N/A											
Sulfate (PWS)	0	0	0	0	0	N/A	N/A	N/A	N/A											
Fluoride (PWS)	0	0	0	0	0	N/A	N/A	N/A	N/A											
Total Aluminum	0	0	0	0	0	N/A	N/A	N/A	N/A											
Total Antimony	0	0	0	0	0	N/A	N/A	N/A	N/A											
Total Arsenic	0	0	0	0	0	N/A	N/A	N/A	N/A											
Total Barium	0	0	0	0	0	N/A	N/A	N/A	N/A											
Total Boron	0	0	0	0	0	N/A	N/A	N/A	N/A											
Total Cadmium	0	0	0	0	0	N/A	N/A	N/A	N/A											
Total Chromium (III)	0	0	0	0	0	N/A	N/A	N/A	N/A											
Hexavalent Chromium	0	0	0	0	0	N/A	N/A	N/A	N/A											
Total Cobalt	0	0	0	0	0	N/A	N/A	N/A	N/A											
Total Copper	0	0	0	0	0	N/A	N/A	N/A	N/A											
Total Iron	0	0	0	0	0	N/A	N/A	N/A	N/A											
Total Lead	0	0	0	0	0	N/A	N/A	N/A	N/A											
Total Manganese	0	0	0	0	0	N/A	N/A	N/A	N/A											
Total Mercury	0	0	0	0	0	N/A	N/A	N/A	N/A											
Total Nickel	0	0	0	0	0	N/A	N/A	N/A	N/A											
Total Phenols (Phenolics) (PWS)	0	0	0	0	0	N/A	N/A	N/A	N/A											
Total Selenium	0	0	0	0	0	N/A	N/A	N/A	N/A											
Total Silver	0	0	0	0	0	N/A	N/A	N/A	N/A											
Total Thallium	0	0	0	0	0	N/A	N/A	N/A	N/A											
Total Zinc	0	0	0	0	0	N/A	N/A	N/A	N/A											

Recommended WQBELs & Monitoring Requirements

No. Samples/Month: 4

Pollutants	Concentration Limits						Governing WQBEL Basis	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units			
Total Aluminum	Report	Report	Report	Report	Report	µg/L	2,874	AFC	Discharge Conc > 10% WQBEL (no RP)
Total Cadmium	0.00009	0.0001	1.69	2.64	4.23	µg/L	1.69	CFC	Discharge Conc ≥ 50% WQBEL (RP)
Total Copper	Report	Report	Report	Report	Report	µg/L	56.9	AFC	Discharge Conc > 10% WQBEL (no RP)
Total Iron	Report	Report	Report	Report	Report	µg/L	8,969	CFC	Discharge Conc > 10% WQBEL (no RP)
Total Mercury	Report	Report	Report	Report	Report	µg/L	0.3	THH	Discharge Conc > 10% WQBEL (no RP)
Total Silver	Report	Report	Report	Report	Report	µg/L	16.1	AFC	Discharge Conc > 10% WQBEL (no RP)

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g.,  $\leq$  Target QL).

Pollutants	Governing WQBEL	Units	Comments
Total Dissolved Solids (PWS)	N/A	N/A	PWS Not Applicable
Chloride (PWS)	N/A	N/A	PWS Not Applicable
Bromide	N/A	N/A	No WQS
Sulfate (PWS)	N/A	N/A	PWS Not Applicable
Fluoride (PWS)	N/A	N/A	PWS Not Applicable
Total Antimony	N/A	N/A	Discharge Conc < TQL
Total Arsenic	59.8	µg/L	Discharge Conc ≤ 10% WQBEL
Total Barium	14,351	µg/L	Discharge Conc ≤ 10% WQBEL
Total Beryllium	N/A	N/A	No WQS
Total Boron	9,567	µg/L	Discharge Conc ≤ 10% WQBEL
Total Chromium (III)	542	µg/L	Discharge Conc ≤ 10% WQBEL
Hexavalent Chromium	62.2	µg/L	Discharge Conc < TQL
Total Cobalt	114	µg/L	Discharge Conc ≤ 10% WQBEL
Total Cyanide	N/A	N/A	No WQS
Total Lead	20.6	µg/L	Discharge Conc < TQL
Total Manganese	5,979	µg/L	Discharge Conc ≤ 10% WQBEL
Total Nickel	329	µg/L	Discharge Conc < TQL
Total Phenols (Phenolics) (PWS)			Discharge Conc < TQL
Total Selenium	29.8	µg/L	Discharge Conc < TQL
Total Thallium	1.44	µg/L	Discharge Conc < TQL
Total Zinc	484	µg/L	Discharge Conc ≤ 10% WQBEL